



## Allies for Efficiency: *Daimler Trucks North America*

October 13, 2016



# New Buildings Events

## Allies for Efficiency Training Series (AFE)

- Trainings on high-performance design and construction
- Takes place 3 times per year in Portland + regional events
- Registration priority for New Buildings Program Allies

## AFE 2.0

- Advanced training series for designers and architects
- Takes place 2 – 3 times per year
- Content is focused on specific techniques or technologies

## Building Energy Simulation Forum (BESF)

- Advance energy modeling presentations
- Takes place every other month


# Upcoming Allies for Efficiency Trainings

**December 7: Allies for Efficiency 2.0**

*High Performance Design in Oregon*

Portland, OR


Presenting two regional case studies, energy efficiency and design at Cowhorn Vineyard and Unitarian Universalist Fellowship of Central Oregon



# Upcoming Building Energy Simulation Forum Trainings

BESF takes place the third Wednesday of every other month at the Ecotrust Building at noon.

- **October 19:** “Understanding Building Infrastructure and Energy Efficiency Through the Department of Energy’s Asset Score Tool”
- **December 14:** \*Date Changed\*  
NREL – Open Studio Presentation



# Training & Education Webpage

energytrust.org/commercial/training-and-events/

The screenshot shows the Energy Trust of Oregon website. At the top left is the logo with a sun icon. A search bar is in the top right. A navigation menu includes Home, About, News, Blog, Events, Library, Find a Contractor, Contact, and FAQ. Below this is a category bar with RESIDENTIAL, COMMERCIAL (highlighted), INDUSTRY + AG, PUBLIC + NONPROFIT, and RENEWABLE ENERGY. The main content area has a breadcrumb trail: Home : Commercial : Commercial Training and Events. The title is 'Commercial Training and Events' with a subtitle: 'Education opportunities for building operators, development and design professionals'. There are three text blocks: 1) 'Energy Trust offers or supports a variety of training and resources for customers and trade allies.' 2) 'We provide a cash incentive for Building Operator Certification—a training and certification program offered by Northwest Water & Energy Education Institute.' 3) 'We also offer continuing education. The Allies for Efficiency and Building Energy Simulation Forum training series feature real-world examples and case studies presented by experts from the fields of architecture, engineering, construction and development, as well as specialists in a variety of building types and market sectors. Attendees may be eligible for continuing education units, CEUs.' A photo of a presentation with a pie chart is shown. A 'Questions? Contact Us' button is at the bottom. On the left is a sidebar with menu items like 'Equipment Upgrades and Remodels', 'Strategic Energy Management', 'New Construction and Major Renovations', 'Multifamily Properties', 'Renewable Energy', 'Success Stories', 'Find a Form', 'Find a Contractor', 'Training and Events', 'Past Presentations and Resources', and 'Newsletter'. On the right is a 'SHARE THIS +' section with social media icons for Email, Facebook, Twitter, and More... (247), plus an 'AddThis' button. Below that is a 'REASONS TO LOVE ZERO' section with the text 'It's more than construction. It's about bringing a building to life.' and a 'Read more »' link. At the bottom right is a 'PUTTING EFFICIENCY ON THE MAP' section with a map of Oregon and a red star.

Energy Trust of Oregon

Home About News Blog Events Library Find a Contractor Contact FAQ

RESIDENTIAL COMMERCIAL INDUSTRY + AG PUBLIC + NONPROFIT RENEWABLE ENERGY

Home : Commercial : Commercial Training and Events

## Commercial Training and Events

Education opportunities for building operators, development and design professionals

Energy Trust offers or supports a variety of training and resources for customers and trade allies.

We provide a cash incentive for Building Operator Certification—a training and certification program offered by Northwest Water & Energy Education Institute.

We also offer continuing education. The Allies for Efficiency and Building Energy Simulation Forum training series feature real-world examples and case studies presented by experts from the fields of architecture, engineering, construction and development, as well as specialists in a variety of building types and market sectors. Attendees may be eligible for continuing education units, CEUs.

Questions? Contact Us

SHARE THIS +

- Email
- Facebook
- Twitter
- More... (247)

AddThis

REASONS TO LOVE ZERO

It's more than construction. It's about bringing a building to life.

Read more »

PUTTING EFFICIENCY ON THE MAP

# Net Zero Fellowship

- Up to two fellowship grants, not to exceed a combined total of \$50,000, to support net-zero energy research over 12 to 18 months
- Funding for new research to advance design best practices, technologies and policies, and the overall net-zero community in Oregon
- Application deadline January 9, 2017
- Learn more at [energytrust.org/zero](http://energytrust.org/zero)



# Questions?

Have questions about upcoming training and education opportunities or about becoming an Energy Trust New Buildings Ally?

Contact [Amanda.Davidowitz@clearresult.com](mailto:Amanda.Davidowitz@clearresult.com)






# Allies for Efficiency: Daimler Trucks North America

Presentation 2:30-4:00 p.m.

- Matthew Markstaller, Real Estate Manager, Daimler Trucks North America
- Michael Great, Managing Principal, Connie Hotovec, Associate, and Jeff Wilder, Senior Associate - Ankrom Moisan Architects
- Mitchell Dec, Associate Principal, Glumac

Building Tour 4:00 – 5:00 p.m.



# Allies for Efficiency: Daimler Trucks North America



## Learning Objectives:

- Understand how the collaborative process with the design team and building owner led to effective decision-making strategies and a successful project.
- Learn how early energy analysis impacted the orientation, site placement and occupant health of the building.
- Learn how the design team created synergies between building systems to meet the RFP requirements. The course will cover how parametric analysis of envelope systems, HVAC energy consumption, thermal comfort, indoor air quality, and onsite renewable energy were utilized together.
- See how the design team and owners evaluated the building's performance during the post-occupancy measurement and verification period.
- Learn important tips for designing around dedicated outside air systems with radiant comfort systems in the occupied space.



# Thank You

Amanda Davidowitz  
Market Outreach Specialist  
[Amanda.Davidowitz@clearesult.com](mailto:Amanda.Davidowitz@clearesult.com)



# DAIMLER

---

## Daimler Trucks North America – Corp HQ



Mercedes-Benz



October 13, 2016

# DAIMLER

## A Subsidiary of Daimler AG



Trucks



Vans



Passenger cars



Daimler Trucks

DAIMLER




#1 Heavy and Medium Duty  
Truck Manufacturer in  
NAFTA

Energy efficiency is at the core of our business, we offer the most fuel efficient truck on the road

## Freightliner Cascadia Evolution




2015 YTD Market Share, US Class 8  
*in percent*



Today's Freightliner Cascadia is 17.2% more fuel efficient than in 2010, largely due to an integrated powertrain

**Fuel Consumption – Portland to Pendelton route**  
*average miles per gallon*





DAIMLER

---


Daimler Trucks North America  
We bring the materials to your buildings...efficiently!



It only makes sense that our  
buildings are efficient and  
sustainable too

LEED Platinum exemplifies our commitment to waste-free, resource-optimized and CO<sub>2</sub>-neutral production

**Only 6% of LEED certified buildings have achieved Platinum**



## Project Achievements

- Will be in the top 1% in energy efficient office buildings nationwide
- 96% of materials during demolition kept out of landfill
- 13% of entire building energy use will be powered from onsite renewable energy

## Project Aspirations

- Deliver an environmentally friendly and efficient building that aligns with DTNA's market position as the technology and fuel efficiency leader.
- Achieve LEED Platinum Certification.
- Send a strong and positive message to the public about DTNA's presence in Portland and serves as a vehicle to attract and retain top talent.
- Deliver an aesthetically exceptional and state-of-the-art building that contains workspaces and amenities that encourage and enhance employee/management productivity, collaboration and job satisfaction.

## Going green is a good investment

### Efficient Technologies Used:

- Highly efficient HVAC with dedicated outside air system
- Alternative energy such as solar hot water and solar panels
- Low water use fixtures
- LED lighting and daylight controls
- Radiant slab floor
- Green roof to reduce heat generation and manage storm water
- Green building and finish materials




---

Impact: \$200,000 per year in savings relative to a new building under today's code, and substantial savings relative to existing headquarter building

Features and attributes that contribute to employees' health, satisfaction and productivity:

- Ample natural light and access to outdoor spaces
- Smart HVAC systems to heat and cool discrete spaces (not a one size fits all approach)
- Low VOC emitting paint, carpet and furniture
- A multitude of different types of spaces where employees can work (“your workspace is no longer just your desk”)
- Cubicle areas in small “pods” or “communities” - limited to 16-18 people
- Comfortable and ergonomic furniture, including sit to stand desks
- Intelligent outdoor air delivery
- Fitness room & interior bike storage









# DAIMLER TRUCKS NORTH AMERICA

ALLIES FOR EFFICIENCY PRESENTATION



**GLUMAC** engineers for a sustainable future™



Ankrom Moisan






N. CHANNEL AVE.

CORP 1

SEE SHEET L3:  
MAIN ENTRY

SEE SHEET L4:  
PARKING STRUCTURE


WILLAMETTE RIVER





SEE SHEET L5:  
RIVERFRONT EAST

SEE SHEET L7:  
GREENWAY ELEMENTS

SEE SHEET L6:  
RIVERFRONT EAST



WILLAMETTE RIVER




VIEW  
CORRIDORS

OFFSET CORE

TYPICAL TOWER  
FLOORPLAN

# Modeled vs. Actual Office Building Performance



# ASHRAE 90.1 Baseline System Definition

**TABLE G3.1.1A Baseline HVAC System Types**

| Building Type  | Fossil Fuel, Fossil/Electric Hybrid, and Purchased Heat | Electric and Other                   |
|--|---|--------------------------------------|
| Residential  | System 1—PTAC   | System 2—PTHP                        |
| Nonresidential and 3 Floors or Less and <25,000 ft <sup>2</sup>  | System 3—PSZ-AC   | System 4—PSZ-HP                      |
| Nonresidential and 4 or 5 Floors and <25,000 ft <sup>2</sup> or 5 Floors or Less and 25,000 ft <sup>2</sup> to 150,000 ft <sup>2</sup> | System 5—Packaged VAV with Reheat                       | System 6—Packaged VAV with PFP Boxes |
| Nonresidential and More than 5 Floors or >150,000 ft <sup>2</sup>  | System 7—VAV with Reheat                                | System 8—VAV with PFP Boxes          |

**Notes:**

Residential building types include dormitory, hotel, motel, and multifamily. Residential space types include guest rooms, living quarters, private living space, and sleeping quarters. Other building and space types are considered nonresidential.

Where no heating system is to be provided or no heating energy source is specified, use the “Electric and Other” heating source classification.

Where attributes make a building eligible for more than one *baseline* system type, use the predominant condition to determine the system type for the entire building.

For laboratory spaces with a minimum of 5000 cfm of exhaust, use system type 5 or 7 and reduce the exhaust and makeup air volume to 50% of design values during unoccupied periods.


For all-electric buildings, the heating shall be electric resistance.

# ASHRAE 90.1 Baseline System Definition

**TABLE G3.1.1B Baseline System Descriptions**

| System No.                     | System Type                       | Fan Control     | Cooling Type     | Heating Type                 |
|--------------------------------|-----------------------------------|-----------------|------------------|------------------------------|
| 1. PTAC                        | Packaged terminal air conditioner | Constant volume | Direct expansion | Hot-water fossil fuel boiler |
| 2. PTHP                        | Packaged terminal heat pump       | Constant volume | Direct expansion | Electric heat pump           |
| 3. PSZ-AC                      | Packaged rooftop air conditioner  | Constant volume | Direct expansion | Fossil fuel furnace          |
| 4. PSZ-HP                      | Packaged rooftop heat pump        | Constant volume | Direct expansion | Electric heat pump           |
| 5. Packaged VAV with Reheat    | Packaged rooftop VAV with reheat  | VAV             | Direct expansion | Hot-water fossil fuel boiler |
| 6. Packaged VAV with PFP Boxes | Packaged rooftop VAV with reheat  | VAV             | Direct expansion | Electric resistance          |
| 7. VAV with Reheat             | Packaged rooftop VAV with reheat  | VAV             | Chilled water    | Hot-water fossil fuel boiler |
| 8. VAV with PFP Boxes          | VAV with reheat                   | VAV             | Chilled water    | Electric resistance          |

# Energy Use Comparisons






# Energy Efficiency Measures – Decision Making

| EEM #   | Individual Energy Efficiency Measure  | Location          | See Note # | Additional Electricity Savings <sup>6</sup> (kWh/yr) | Additional Natural Gas Savings <sup>6</sup> (therms/yr) | Additional Energy Cost Savings | Additional Energy Cost Percent Savings <sup>7</sup> |
|---|---|-------------------|------------|--|---|--------------------------------|---|
| <b>Energy Efficiency Measures for Consideration</b> |   |                   |            |  |   |                                |   |
| 1A  | Increase wall insulation to achieve an overall U-value of 0.048. Construction would utilize 2.5" of XPS exterior of steel studs and R-13 batt insulation within the steel stud.   | Exterior Wall     |            | 13,967   | 3,785   | \$5,490                        | 1.6%  |
| 1B  | Increase wall insulation to achieve an overall U-value of 0.040. Construction would utilize 2.5" of polystyrene exterior of steel studs and R-13 batt insulation within the steel stud.                                     | Exterior Wall     |            | 16,761   | 5,442   | \$7,578                        | 2.2%  |
| 1C  | Increase wall insulation to achieve an overall U-value of 0.029. Construction would utilize 1" of Dow Corning Vacuum Insulated Panel (VIP) insulation within curtainwall assembly.  | Exterior Wall     |            | 19,582   | 7,267   | \$9,854                        | 2.8%  |
| 2A  | Increase roof insulation to R-30 continuous insulation over roof deck.  | Roof              |            | 8,062  | 1,947   | \$2,908                        | 0.8%  |
| 2B  | Increase roof insulation to R-40 continuous insulation over roof deck.  | Roof              |            | 9,678  | 2,337   | \$3,490                        | 1.0%  |
| 2C  | Increase roof insulation to R-50 continuous insulation over roof deck.  | Roof              |            | 11,103   | 2,597   | \$3,911                        | 1.1%  |
| 3A  | Reduce window U-value from 0.45 to 0.38 using fully thermal breaks in double pane curtain wall system and intercept spacer. Consider products such as EFCO 5500X curtainwall assembly.                                      | Windows           |            | 20,532   | 3,266   | \$5,543                        | 1.6%  |
| 3B  | Reduce window U-value from 0.45 to 0.32 using advanced stick built curtainwall system with elimination of all thermal bridging in aluminum frame. Consider products such as Schuco curtainwall assembly.                    | Windows           |            | 37,131   | 6,065   | \$10,199                       | 2.9%  |
| 3C  | Reduce window U-value from 0.45 to 0.22 using either a fiberglass frame or using triple pane glass within a high performance aluminum frame like the EFCO 5500X, or equivalent, curtainwall system.                         | Windows           |            | 59,716   | 10,731  | \$17,477                       | 5.0%  |
| 4A  | Reduce SHGC from 0.39 (PPG Solarban 60 equivalent) to 0.27 (PPG Solarban 70XL equivalent).  | Windows           |            | 73,996   | -1,662  | \$5,201                        | 1.5%  |
| 4B  | Reduce SHGC from 0.39 (PPG Solarban 60 equivalent) to 0.23 (PPG Solarban R100 equivalent).  | Windows           |            | 98,661   | -2,216  | \$6,935                        | 2.0%  |
| 5A  | Reduce overhead lighting power density to 0.7 W/SF average for offices.   | Lighting          |            | 220,447  | -4,115  | \$16,416                       | 4.7%  |
| 5B  | Reduce overhead lighting power density to 0.5 W/SF average for offices.   | Lighting          |            | 335,421  | -6,738  | \$24,453                       | 7.0%  |
| 6   | Implement daylight dimming controls for the first 20 for all perimeter spaces.  | Lighting          |            | 123,531  | -512  | \$11,172                       | 3.2%  |
| 7   | Utilize vacancy sensors for all office areas - manual on, automatic off controls.   | Lighting          |            | 39,936   | -341  | \$3,419                        | 1.0%  |
| 8   | Work station plug load reduction - set monitors to 50% brightness and install occupancy controlled plug strip to shut off non-critical plug loads when employees are away from their desk.                                  | Plug Loads        |            | 102,211  | -1,744  | \$7,792                        | 2.2%  |
| 9   | Refrigeration/Freezer Energy Use Reduction - use drybulb reset on condenser temperature, use VFDs on compressors/condensers/air units, and reject waste heat to a heat exchanger for kitchen domestic hot water preheating. | Kitchen           |            | 180,000  | 2,782   | \$20,160                       | 5.8%  |
| 10A   | Advanced VAV with DOAS.   | Office HVAC       |            | 346,347  | 18,763  | \$53,542                       | 15.3%   |
| 10B   | DOAS with Chilled Sails or Radiant Panels. DOAS served through overhead air distribution.   | Office HVAC       |            | 787,135  | 29,896  | \$107,663                      | 30.7%   |
| 10C   | DOAS with Chilled Sails or Radiant Panels. DOAS served through underfloor air distribution.   | Office HVAC       |            | 908,736  | 34,368  | \$124,135                      | 35.4%   |
| 11  | Condensing Boilers  | Central Plant     |            |  | 8,962   | \$9,858                        | 2.8%  |
| 12  | Premium Efficiency Chiller, targeting average efficiency around 0.4-0.45 kW/ton.  | Central Plant     |            | 86,452   |   | \$8,213                        | 2.3%  |
| 13  | Cooling tower with VFDs and reduced approach.   | Central Plant     |            | 23,212   |   | \$2,205                        | 0.6%  |
| 14A   | 170-kW PV Array (target 10% for EAc2)   | Onsite Renewables |            | 178,500  |   | \$16,958                       | 4.8%  |
| 14B   | 340-kW PV Array (target 20% for EAc2)   | Onsite Renewables |            | 357,000  |   | \$33,915                       | 9.7%  |
| 15  | 400-kW Fuel Cell from ClearEdge Power   | Onsite Generation |            | 3,153,600  | -33,985   | \$262,209                      | 74.8%   |
| 16  | Ground source heat pump loop to connect central plant heating and cooling.  | Central Plant     |            | -79,000  | 12,000  | \$5,695                        | 1.6%  |
| 17  | Solar Hot Water - 40 panel array  | Onsite Renewables |            |  | 6,500   | \$7,150                        | 2.0%  |
| 18  | Sewer Heat Recovery   | Central Plant     |            |  | 2,894   | \$3,183                        | 0.9%  |
| 19  | Condensing Domestic Hot Water Heaters   | DHW               |            |  | 1,960   | \$2,156                        | 0.6%  |
| 20  | Low Flow Plumbing Fixtures (0.5 gpm lav sinks, 1.5 gpm showers for bike commuters)  | DHW               |            |  | 2,492   | \$2,741                        | 0.8%  |
| <b>Interactive combinations in the design</b>       |   |                   |            |  |   |                                |   |
| A   | EEMs 1A, 2A, 3A, 4A, 5B, 6, 7, 8, 9, 10A, 11, 12, 13  | -                 |            | 1,150,617  | 28,016  | \$140,126                      | 40.0%   |
| B   | Package A but replace 10A with 10B  | -                 |            | 1,525,287  | 37,479  | \$186,129                      | 53.1%   |
| C   | Package A but replace 10A with 10C  | -                 |            | 1,628,648  | 41,280  | \$200,130                      | 57.1%   |
| D   | Package B + 14A   | -                 |            | 1,703,787  | 37,479  | \$203,087                      | 57.9%   |
| E   | Package B + 14B   | -                 |            | 1,882,287  | 37,479  | \$220,044                      | 62.8%   |


# Glazing to Desk Height

- 30" above floor
- at all work areas
- maintains views
- more insulation helps with energy code compliance



# Glazing to Floor


- at all conference rooms/collaborative areas and private offices



# Sunshading - Studies

## Considerations


- River Glare
- Views
- Solar heat gain pertaining to heating/cooling system
- Thermal comfort (employees seated near windows)
- Cost
- Aesthetic (how does it fit the Daimler story)
- Window cleaning
- Birds/Maintenance





# Sunshading - Recommended

## Considerations

- River Glare
- Views
- Solar heat gain pertaining to heating/cooling system
- Thermal comfort (employees seated near windows)
- Cost
- Aesthetic (how does it fit the Daimler story)
- Window cleaning
- Birds/Maintenance




Horizontal Sunshade at window head



Exterior Screen

# PV Sizing for 10% Onsite Renewable



# LEED Point Contribution By System

| End Use                            | Historical Portland Office Building (mix of VAV, Multizone, and Double Duct) | LEED Version 3 Baseline Building | Vestas Building (Modeled Data w/out PV) | Vestas Building (Actual Metered Data w/out PV) | Advanced VAV with DOAS (Shut Off Dampers) | Advanced VAV with DOAS (FPBs at perimeter) | DOAS with Radiant/Beams/Sails |
|------------------------------------|--|----------------------------------|---|--|---|--|-------------------------------|
| Space Heating                      | 37.7   | 30.2                             | 5.8                                     | 11.1   | 22.6                                      | 17.0                                       | 4.7                           |
| Space Cooling                      | 5.3  | 4.2                              | 4.6                                     | 3.0  | 3.2                                       | 2.7  | 3.6                           |
| Fans & Pumps                       | 6.7  | 6.4                              | 3.5                                     | 3.4  | 5.6                                       | 6.6  | 2.3                           |
| Lighting                           | 16   | 11.2                             | 8.8                                     | 4.4  | 4.4                                       | 4.4  | 4.4                           |
| Plug Loads                         | 16.4   | 7.0                              | 7.0                                     | 6.0  | 6.0                                       | 6.0  | 6.0                           |
| DHW                                | 1.8  | 1.8                              | 1.1                                     | 1.5  | 1.1                                       | 1.1  | 1.1                           |
| Total w/out PV                     | 83.9   | 60.7                             | 30.7                                    | 29.4   | 42.9                                      | 37.7                                       | 22.1                          |
| Annual Operating Cost, per sq. ft. | \$ 1.76  | \$ 1.17                          | \$ 0.69                                 | \$ 0.61  | \$ 0.79                                   | \$ 0.74                                    | \$ 0.53                       |
| LEED, EAc1 Percent Savings         | n/a  | n/a                              | 41%                                     | 48%  | 32%                                       | 37%  | 55%                           |

## 10% PV Offset Contribution - Assuming 265,000 SF Building

|   |  |  |              |            |              |              |            |
|---|--|--|--------------|------------|--------------|--------------|------------|
| Site Annual Energy Cost                 |  |  | \$ 182,623   | \$ 162,559 | \$ 209,350   | \$ 196,100   | \$ 140,450 |
| Annual Electricity Offset Required, kWh |  |  | 202,915      | 180,621    | 232,611      | 217,889      | 156,056    |
| PV Size Required, kW                    |  |  | 193          | 172        | 222          | 208          | 149        |
| PV Area Required, sq. ft.               |  |  | 12,883       | 11,468     | 14,769       | 13,834       | 9,908      |
| Site Area Required, sq. ft.             |  |  | 25,767       | 22,936     | 29,538       | 27,668       | 19,817     |
| Estimated Cost of PV Array              |  |  | \$ 1,014,574 | \$ 903,103 | \$ 1,329,206 | \$ 1,245,079 | \$ 780,278 |

EAc1: 19 points

HVAC accounts for 14 points

EAc1: 11 points

HVAC accounts for 8 points

EAc1: 13 points


HVAC accounts for 10 points

EAc1: 19 points

HVAC accounts for 15 points

# Design Challenges & Lessons Learned


**Daimler Chilled Water Systems: Option 1**



**CHW - CORP 1**  
800 Tons  
1,200 SF  
**Cooling Towers On Roof**


**CHW - NOVA**  
700 Tons  
1,000 SF  
**Cooling Towers On Roof**

# Design Challenges & Lessons Learned





# Design Challenges & Lessons Learned



# LESSONS LEARNED

- MANAGING OCCUPANT  
EXPECTATIONS

- SYSTEM  
COMPLEXITY

QUESTIONS?