

Appendix B-2

Hydraulic Calculations for Sewage Treatment Plant

Appendix.B.2 HYDRAULIC CALCULATION OF SEWAGE TREATMENT PLANT

Basic Design Conditions

- (1) Name of STP ASTANA STP
- (2) Sewage collection Separate sewer system
- (3) Design sewage flow

		Proposed Design Flow	
		m ³ /d	m ³ /s
Daily Average Flow	Q1	114,000	1.319
Design Daily Flow	Q2	136,000	1.574
Maximum Flow	Q3	200,000	2.315

- (4) Incoming pipe

Pipe diameter	φ 1400mm
Slope	
Invert level	
Water level	Daily average
	Hourly maximum
Full flow	



- (5) Effluent discharge



Discharge point/river	Taldy Kol Reservoir
Maximum high water level (HHWL)	+346.700m
Design high water level (HWL)	+346.700m
Design river bed level	
Present river bed level	
Pump Pit Water Level	+338.900m
	(Existing)


- (6) Design ground level of STP

+345.0 ~ +351.3 m

LIST OF FORMULA

Name of formula	Formula	Application
(1) Manning (Formula -1)	$V = \frac{1}{n} R^{2/3} I^{1/2}$ <p>V: Velocity (m/sec) n: Roughness coefficient i: Grade R: Mean Depth (m)</p>	RC pipe
(2) Darcy Weisbach (Formula -2)	$h_f = f \frac{L}{D} \frac{V^2}{2g}$ <p>f : Friction loss coefficient $\left[0.2 + \frac{1}{2000 D} \right]$ L : Length (m) D : Diameter (m)</p>	DCIP or Mortar Lined Pipe
(3) Francis (Formula -3)	$L = \frac{Q}{1.8h^{3/2}}$: Perfect overflow $L = \frac{Q}{1.84(h_1 + 1.4h_2)\sqrt{h_1}}$: Imperfect overflow <p>L: Weir width (m) Q : Flow (m³/sec) h, h₁, h₂ : Overflow depth (m)</p>  <p>Perfect overflow</p>	Broad-Crested weir
(4) Thomson (Formula -4)	$Q = 1.42 h^{5/2}$ <p>h: Overflow depth</p> 	Right angle Triangular weir


Name of formula	Formula	Application			
(5) Thomson	$Q = 1.84 bh^{3/2}$  <p style="text-align: right;">b : Weir width (m) h : Overflow height (m)</p>	Rectangular weir			
(6) Bilmont	$Q = Q_1 \left\{ 1 - \left(\frac{h_2}{h_1} \right)^n \right\}^{0.385}$ <p>Q₁: Flow when free overflow depth is h₁ (m³/sec) h₁: Upstream depth above weir top (m) h₂: Down stream depth above weir top (m) n : Coefficient by shape of weir (Broad-Crested Weir, Rectangular Weir, Triangular Weir)</p> <table style="margin-left: auto; margin-right: auto;"> <tr> <td style="padding: 0 20px;">1.50</td> <td style="padding: 0 20px;">1.45</td> <td style="padding: 0 20px;">2.50</td> </tr> </table> 	1.50	1.45	2.50	Submerged sharp-edged weir
1.50	1.45	2.50			
(7) Thomas-Kamp (Formula -5)	$h_0 = \sqrt{3} hc \ell$: Freefall at downstream $h_0 = \sqrt{\frac{2hc \ell^3}{h \ell} + h \ell^2}$: Submerged at downstream h ₀ : Depth at upstream (m) hcℓ : Critical depth (m) hℓ : Depth at downstream (m) $hc \ell = \sqrt[3]{\frac{\alpha Q^2}{gB^2}}$ α : Coefficient (=1) Q; Total flow at down stream (m ³ /sec) B: Trough width (m) Note: Trough bottom is level	Outlet trough in sedimentation tank			

Name of formula	Formula	Application																																										
(10) King	<p>Shrinkage</p> $h_{sc} = f_{sc} \frac{V_1^2}{2g}$ <p>h_{sc}: Shrinkage loss (m) f_{sc}: Coefficient</p>  <table border="1" data-bbox="405 714 986 891"> <tbody> <tr> <td>D₂/D₁</td> <td>0</td> <td>0,1</td> <td>0,2</td> <td>0,3</td> <td>0,4</td> <td>0,5</td> </tr> <tr> <td>A₂/A₁</td> <td>0</td> <td>0,01</td> <td>0,04</td> <td>0,09</td> <td>0,16</td> <td>0,25</td> </tr> <tr> <td>f_{sc}</td> <td>0,5</td> <td>0,5</td> <td>0,49</td> <td>0,49</td> <td>0,46</td> <td>0,43</td> </tr> <tr> <td>D₂/D₁</td> <td>0,6</td> <td>0,7</td> <td>0,8</td> <td>0,9</td> <td>1,0</td> <td></td> </tr> <tr> <td>A₂/A₁</td> <td>0,36</td> <td>0,49</td> <td>0,64</td> <td>0,81</td> <td>1,0</td> <td></td> </tr> <tr> <td>f_{sc}</td> <td>0,38</td> <td>0,29</td> <td>0,18</td> <td>0,07</td> <td>0</td> <td></td> </tr> </tbody> </table>	D ₂ /D ₁	0	0,1	0,2	0,3	0,4	0,5	A ₂ /A ₁	0	0,01	0,04	0,09	0,16	0,25	f _{sc}	0,5	0,5	0,49	0,49	0,46	0,43	D ₂ /D ₁	0,6	0,7	0,8	0,9	1,0		A ₂ /A ₁	0,36	0,49	0,64	0,81	1,0		f _{sc}	0,38	0,29	0,18	0,07	0		
D ₂ /D ₁	0	0,1	0,2	0,3	0,4	0,5																																						
A ₂ /A ₁	0	0,01	0,04	0,09	0,16	0,25																																						
f _{sc}	0,5	0,5	0,49	0,49	0,46	0,43																																						
D ₂ /D ₁	0,6	0,7	0,8	0,9	1,0																																							
A ₂ /A ₁	0,36	0,49	0,64	0,81	1,0																																							
f _{sc}	0,38	0,29	0,18	0,07	0																																							
(11) Weisbach	<p>Shape loss</p> $h = f \frac{V^2}{2g}$ <p>f : Coefficient (= 1)</p> <table border="1" data-bbox="325 1189 1007 1491"> <thead> <tr> <th></th> <th></th> <th><u>f Value</u></th> </tr> </thead> <tbody> <tr> <td>(1) Outlet</td> <td></td> <td>1.0</td> </tr> <tr> <td>(2) Retraction</td> <td>(90°)</td> <td>1.0</td> </tr> <tr> <td></td> <td>(180°)</td> <td>1.0</td> </tr> <tr> <td>(3) Bend</td> <td>(45°)</td> <td>0.13 (CIP 900)</td> </tr> <tr> <td></td> <td>(90°)</td> <td>0.20 (CIP 900)</td> </tr> <tr> <td>(4) Orifice</td> <td></td> <td>3.0</td> </tr> <tr> <td>(5) Inlet</td> <td></td> <td>0.5</td> </tr> </tbody> </table>			<u>f Value</u>	(1) Outlet		1.0	(2) Retraction	(90°)	1.0		(180°)	1.0	(3) Bend	(45°)	0.13 (CIP 900)		(90°)	0.20 (CIP 900)	(4) Orifice		3.0	(5) Inlet		0.5																			
		<u>f Value</u>																																										
(1) Outlet		1.0																																										
(2) Retraction	(90°)	1.0																																										
	(180°)	1.0																																										
(3) Bend	(45°)	0.13 (CIP 900)																																										
	(90°)	0.20 (CIP 900)																																										
(4) Orifice		3.0																																										
(5) Inlet		0.5																																										

Summary Table for Hydraulic Calculation						
Sheet No.	Facility	Upstream water level (m)			Bottom level of facility (m)	Formula
		Daily ave. H(DA)	Daily max. H(DM)	Hourly max. H(HM)		
01	Effluent Discharge Pipe (6/6) ϕ 1500 (Existing)	339.070	339.140	339.420		Formula – 1.3 (Manning's formula/Circular pipe)
02	Effluent Discharge Pipe (5/6) ϕ 1500 (Existing)	339.110	339.190	339.520		Formula – 1.3 (Manning's formula/Circular pipe)
03	Effluent Discharge Pipe (4/6) ϕ 1500 (Existing)	339.120	339.210	339.550		Formula – 1.3 (Manning's formula/Circular pipe)
04	Effluent Discharge Pipe (3/6) ϕ 1500 (Existing)	339.130	339.220	339.570		Formula – 1.3 (Manning's formula/Circular pipe)
05	Effluent Discharge Pipe (2/6) ϕ 1200	339.140	339.230	339.590		Formula – 1.3 (Manning's formula/Circular pipe)
06	Effluent Discharge Pipe (1/6) ϕ 800 (Existing)	339.150	339.240	339.610		Formula – 1.3 (Manning's formula/Circular pipe)
07	Secondary Sedimentation Tank Outlet trough 600W	344.870	344.890	344.940	344.700	Formula – 5 (Thomas-Camp's formula)
08	Secondary Sedimentation Tank Weir (V-notch)	345.300	345.300	345.310	345.260	Formula – 4 (Thomson/Right-angle rectangular weir)
09	Secondary Sedimentation Tank Inlet Pipe ϕ 1200 (Existing)	345.310	345.310	345.320		Formula – 2.1 (Darcy-Weisbach's formula)
10	Distribution Tank (for SST) Gate 900W	345.360	345.360	345.400		Formula – 6.1 (Orifice/Rectangular opening)
11	Aeration Tank \square (Outlet Pit) ϕ 1800 (Existing)	345.390	345.390	345.450		Formula – 2.1 (Darcy-Weisbach's formula)
12	Aeration Tank Outlet weir 4800W	346.690	346.700	346.730	346.500	Formula – 3 (Francis's formula/Full width weir)
13	Aeration Tank Inlet Channel	346.730	346.750	346.800	342.900	Formula – 1.1 (Manning's formula/Rectangular open channel)
14	Primary Sedimentation Tank Outlet pipe (3/3) ϕ 1500	346.770	346.800	346.900		Formula – 2.1 (Darcy-Weisbach's formula)
15	Primary Sedimentation Tank Outlet pipe (2/3) ϕ 1200	346.780	346.820	346.930		Formula – 2.1 (Darcy-Weisbach's formula)
16	Primary Sedimentation Tank Outlet pipe (1/3) ϕ 800	346.800	346.840	346.980		Formula – 2.1 (Darcy-Weisbach's formula)
17	Primary Sedimentation Tank Outlet trough 600W	346.920	346.950	347.050	346.700	Formula – 5 (Thomas-Camp's formula)
18	Primary Sedimentation Tank Weir (V-notch)	347.400	347.400	347.410	347.350	Formula – 4 (Thomson/Right-angle rectangular weir)
19	Primary Sedimentation Tank Inlet pipe (2/2) ϕ 500 (Existing)	347.540	347.600	347.840		Formula – 2.1 (Darcy-Weisbach's formula)
20	Distribution Tank (for PST) Gate 600W	347.570	347.640	347.920		Formula – 6.1 (Orifice/Rectangular opening)
21	Primary Sedimentation Tank Inlet pipe (1/2) ϕ 1200	347.680	347.790	348.240		Formula – 2.1 (Darcy-Weisbach's formula)
22	Grit Chamber Distribution Weir 3400W	348.600	348.630	348.700	348.370	Formula – 3 (Francis's formula/Full width weir)
23	Grit Chamber Weir 3440W	348.670	348.700	348.800	348.200	Formula – 3 (Francis's formula/Full width weir)
24	Grit Chamber Inlet channel 1700W	348.760	348.790	348.900	347.750	Formula – 1.1 (Manning's formula/Rectangular open channel)
25	Grit Chamber Gate 1000 W	348.770	348.800	348.910		Formula – 1.1 (Manning's formula/Rectangular open channel)


Formula - 1.3 (Manning's formula/Circular pipe)

NO.1

Facility	Effluent Discharge Pipe (6/6)					φ1500 (Existing)	Remarks
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3			
Flow (m ³ /s)	Q	1.319	1.574	2.315			
Number of units	N	1	1	1			
Unit flow (m ³ /s)	q	1.319	1.574	2.315			
Dimensions							
Roughness coef.	n	0.014					
Pipe diameter	d	1.500	m (Existing)				
Cross-section area	AW	1.767	m ²				
Hydraulic radius	R	0.375	m				
Pipe length	L	100.000	m				
Downstream water level (m)	Ho	338.900	338.900	338.900			
Flow velocity (m/s)	V	0.746	0.891	1.310			V = q / A W
Velocity head (m)	$\frac{V^2}{2g}$	0.028	0.040	0.088			
Hydraulic gradient (‰)	I	0.404	0.575	1.244			
Friction loss (m)	h _f	0.040	0.058	0.124			h _f = I × L
Inlet loss (m)	h _i	0.043	0.061	0.131			f = 0.50 n = 3
Outlet loss (m)	h _o	0.085	0.121	0.263			f = 1.00 n = 3
Bend loss (m)	h _b						f = n =
Other losses(m)	h _e						f = n =
Total (m)	Σ h	0.168	0.240	0.518			
Head loss (m)	h	0.170	0.240	0.520			Round up to cm
Upstream water level (m)	H	339.070	339.140	339.420			H = H ₀ + h


Formula - 1.3 (Manning's formula/Circular pipe)

NO.2

Facility	Effluent Discharge Pipe (5/6)					φ1500 (Existing)	Remarks	
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3				
Flow (m ³ /s)	Q	1.319	1.574	2.315				
Number of units	N	1.5	1.5	1.5			8/12 tanks	
Unit flow (m ³ /s)	q	0.879	1.049	1.543				
Dimensions								
Roughness coef.	n	0.014						
Pipe diameter	d	1.500	m (Existing)					
Cross-section area	AW	1.767	m ²					
Hydraulic radius	R	0.375	m					
Pipe length	L	65.000	m					
Downstream water level (m)	H _o	339.070	339.140	339.420				
Flow velocity (m/s)	V	0.497	0.594	0.873			V = q / A W	
Velocity head (m)	$\frac{V^2}{2g}$	0.013	0.018	0.039				
Hydraulic gradient (‰)	I	0.179	0.255	0.553				
Friction loss (m)	h _f	0.012	0.017	0.036			h _f = I × L	
Inlet loss (m)	h _i	0.006	0.009	0.019			f = 0.50 n = 1	
Outlet loss (m)	h _o	0.013	0.018	0.039			f = 1.00 n = 1	
Bend loss (m)	h _b						f = n =	
Other losses(m)	h _e						f = n =	
Total (m)	Σ h	0.031	0.044	0.094				
Head loss (m)	h	0.040	0.050	0.100			Round up to cm	
Upstream water level (m)	H	339.110	339.190	339.520			H = H ₀ + h	


Formula - 1.3 (Manning's formula/Circular pipe)

NO.3

Facility	Effluent Discharge Pipe (4/6)					φ1500 (Existing)	Remarks	
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3				
Flow (m ³ /s)	Q	1.319	1.574	2.315				
Number of units	N	3	3	3			4/12 tanks	
Unit flow (m ³ /s)	q	0.440	0.525	0.772				
Dimensions								
Roughness coef.	n	0.014						
Pipe diameter	d	1.500	m (Existing)					
Cross-section area	AW	1.767	m ²					
Hydraulic radius	R	0.375	m					
Pipe length	L	65.000	m					
Downstream water level (m)	H _o	339.110	339.190	339.520				
Flow velocity (m/s)	V	0.249	0.297	0.437			V = q / A W	
Velocity head (m)	$\frac{V^2}{2g}$	0.003	0.005	0.010				
Hydraulic gradient (‰)	I	0.045	0.064	0.138				
Friction loss (m)	h _f	0.003	0.004	0.009			h _f = I × L	
Inlet loss (m)	h _i	0.002	0.002	0.005			f = 0.50 n = 1	
Outlet loss (m)	h _o	0.003	0.005	0.010			f = 1.00 n = 1	
Bend loss (m)	h _b						f = n =	
Other losses(m)	h _e						f = n =	
Total (m)	Σ h	0.008	0.011	0.024				
Head loss (m)	h	0.010	0.020	0.030			Round up to cm	
Upstream water level (m)	H	339.120	339.210	339.550			H = H ₀ + h	


Formula - 1.3 (Manning's formula/Circular pipe)

NO.4

Facility	Effluent Discharge Pipe (3/6)					φ1500 (Existing)	Remarks	
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3				
Flow (m ³ /s)	Q	1.319	1.574	2.315				
Number of units	N	3	3	3			4/12 tanks	
Unit flow (m ³ /s)	q	0.440	0.525	0.772				
Dimensions								
Roughness coef.	n	0.014						
Pipe diameter	d	1.500	m (Existing)					
Cross-section area	AW	1.767	m ²					
Hydraulic radius	R	0.375	m					
Pipe length	L	10.000	m					
Downstream water level (m)	H _o	339.120	339.210	339.550				
Flow velocity (m/s)	V	0.249	0.297	0.437			V = q / A W	
Velocity head (m)	$\frac{V^2}{2g}$	0.003	0.005	0.010				
Hydraulic gradient (‰)	I	0.045	0.064	0.138				
Friction loss (m)	h _f	0.000	0.001	0.001			h _f = I × L	
Inlet loss (m)	h _i	0.002	0.002	0.005			f = 0.50 n = 1	
Outlet loss (m)	h _o	0.003	0.005	0.010			f = 1.00 n = 1	
Bend loss (m)	h _b						f = n =	
Other losses(m)	h _e						f = n =	
Total (m)	Σ h	0.005	0.008	0.016				
Head loss (m)	h	0.010	0.010	0.020			Round up to cm	
Upstream water level (m)	H	339.130	339.220	339.570			H = H ₀ + h	


Formula - 1.3 (Manning's formula/Circular pipe)

NO.5

Facility	Effluent Discharge Pipe (2/6) $\phi 1200$					Remarks
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3		
Flow (m ³ /s)	Q	1.319	1.574	2.315		
Number of units	N	6	6	6		2/12 tanks
Unit flow (m ³ /s)	q	0.220	0.262	0.386		
Dimensions						
Roughness coef.	n	0.014				
Pipe diameter	d	1.200	m (Existing)			
Cross-section area	AW	1.131	m ²			
Hydraulic radius	R	0.300	m			
Pipe length	L	25.000	m			
						
Downstream water level (m)	H _o	339.130	339.220	339.570		
Flow velocity (m/s)	V	0.195	0.232	0.341		$V = q / A W$
Velocity head (m)	$\frac{V^2}{2g}$	0.002	0.003	0.006		
Hydraulic gradient (‰)	I	0.037	0.052	0.114		
Friction loss (m)	h_f	0.001	0.001	0.003		$h_f = I \times L$
Inlet loss (m)	h_i	0.001	0.001	0.003		f = 0.50 n = 1
Outlet loss (m)	h_o	0.002	0.003	0.006		f = 1.00 n = 1
Bend loss (m)	h_b					f = n =
Other losses(m)	h_e					f = n =
Total (m)	Σh	0.004	0.005	0.012		
Head loss (m)	h	0.010	0.010	0.020		Round up to cm
Upstream water level (m)	H	339.140	339.230	339.590		$H = H_0 + h$

Formula - 1.3 (Manning's formula/Circular pipe)

NO.6

Facility	Effluent Discharge Pipe (1/6)				φ800 (Existing)	
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3		Remarks
Flow (m ³ /s)	Q	1.319	1.574	2.315		
Number of units	N	12	12	12		1/12 tanks
Unit flow (m ³ /s)	q	0.110	0.131	0.193		
Dimensions						
Roughness coef.	n	0.014				
Pipe diameter	d	0.800	m (Existing)			
Cross-section area	AW	0.503	m ²			
Hydraulic radius	R	0.200	m			
Pipe length	L	15.000	m			
Downstream water level (m)	Ho	339.140	339.230	339.590		
Flow velocity (m/s)	V	0.219	0.261	0.384		V = q / A W
Velocity head (m)	$\frac{V^2}{2g}$	0.002	0.003	0.008		
Hydraulic gradient (‰)	I	0.080	0.114	0.247		
Friction loss (m)	h _f	0.001	0.002	0.004		h _f = I × L
Inlet loss (m)	h _i	0.001	0.002	0.004		f = 0.50 n = 1
Outlet loss (m)	h _o	0.002	0.003	0.008		f = 1.00 n = 1
Bend loss (m)	h _b					f = n =
Other losses(m)	h _e					f = n =
Total (m)	Σ h	0.004	0.007	0.016		
Head loss (m)	h	0.010	0.010	0.020		Round up to cm
Upstream water level (m)	H	339.150	339.240	339.610		H = H ₀ + h


Formula - 5 (Thomas-Camp's formula)

NO.7

Facility	Secondary Sedimentation Tank				Outlet trough 600W	Remarks
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3		
Flow (m ³ /s)	Q	1.319	1.574	2.315		
Number of units	N	24	24	24		12 Tanks x 2 Troughs
Unit flow (m ³ /s)	q	0.055	0.066	0.096		
Dimensions						
Trough width	B	0.60	m			
Trough length	L	42.00	m (28 - 0.60 x 2) x 3.14 / 2			
Trough slope	i	0.00	‰			
Trough bottom level	H _b	+344.700	m (Existing trough level)			
Downstream water level (m)	H ₀	339.150	339.240	339.610		
Trough bottom level (m)	H _b	344.700	344.700	344.700		
Water depth at end of trough	h ₁					
Critical depth (m)	h _{cl}	0.095	0.107	0.138		
Water depth at start of trough	h ₀	0.165	0.186	0.239		
Friction loss (m)	h _f	0.165	0.186	0.239		i × L + h _o
Total (m)	Σ h	0.165	0.186	0.239		
Head loss (m)	h	0.170	0.190	0.240		Round up to cm
Upstream water level (m)	H	344.870	344.890	344.940		H=H ₀ +h


Formula - 4 (Thomson/Right-angle rectangular weir)

NO.8

Facility	Secondary Sedimentation Tank				Weir (V-notch)		
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3		Remarks	
Flow (m ³ /s)	Q	1.319	1.574	2.315			
Number of units	N	4039	4039	4039		N = (28 - 0.6 x 2) x 3.14 x 12 tanks x 4 unit/m = 4039	
Unit flow (m ³ /s)	q	×10 ⁻⁴ 3.266	×10 ⁻⁴ 3.897	×10 ⁻⁴ 5.732			
Dimensions Notch level	H _b	+345.260 m					
Downstream water level (m)	H ₀	344.870	344.890	344.940			
Notch level (m)	H _b	345.260	345.260	345.260			
Overflow depth (m)	h	0.035	0.038	0.044		$h = (q / 1.42)^{2/5}$	
Total (m)	Σ h	0.035	0.038	0.044			
Head loss (m)	h	0.040	0.040	0.050		Round up to cm	
Upstream water level (m)	H	345.300	345.300	345.310		H = H ₀ + h	


Formula - 2.1 (Darcy-Weisbach's formula)

NO.9

Facility	Secondary Sedimentation Tank				Inlet Pipe	φ1200 (Existing)
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3	Remarks	
Flow (m ³ /s)	Q	2.893	3.148	3.889	Q1' = Q1 + Q2 x 1 Q2' = Q2 + Q2 x 1 Q3' = Q3 + Q2 x 1	
Number of units	N	12	12	12		
Unit flow (m ³ /s)	q	0.241	0.262	0.324		
Dimensions						
Pipe diameter	d	1.200 m (Existing)				
Cross-section area	AW	1.131 m ²				
Pipe length	L	20.00 m				
Friction loss coef	f	0.031				
Downstream water level (m)	H _o	345.300	345.300	345.310		
Flow velocity (m/s)	V	0.213	0.232	0.286	V = q / AW	
Velocity head (m)	$\frac{V^2}{2g}$	0.002	0.003	0.004		
Straight pipe loss (m)	h _{fl}	0.001	0.001	0.002		
Inlet loss (m)	h _i	0.001	0.001	0.002	f = 0.50 n = 1	
Outlet loss (m)	h _o	0.002	0.003	0.004	f = 1.00 n = 1	
Bend loss (m)	h _b	0.001	0.001	0.002	f = 0.20 n = 2	
Other losses	h _e				f = n =	
Total (m)	Σ h	0.005	0.006	0.010		
Head loss (m)	h	0.010	0.010	0.010	Round up to cm	
Upstream water level (m)	H	345.310	345.310	345.320	H = H _o + h	


Formula - 6.1 (Orifice/Rectangular opening)

NO.10

Facility	Distribution Tank (for SST)				Gate 900W	Remarks
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3		
Flow (m ³ /s)	Q	2.893	3.148	3.889		Q1' = Q1 + Q2 x 1 Q2' = Q2 + Q2 x 1 Q3' = Q3 + Q2 x 1
Number of openings		12	12	12		
Unit flow (m ³ /s)	q	0.241	0.262	0.324		
Dimensions (for opening)						
Width	B	0.900 m				
Height	H	0.500 m				
Cross-section area	Aw	0.450 m ²				
Downstream water level (m)	H ₀	345.310	345.310	345.320		
Flow velocity (m/s)	V	0.536	0.583	0.720		V = q / Aw
Velocity head (m)	$\frac{V^2}{2g}$	0.015	0.017	0.026		
Head loss (m)	h _f	0.041	0.048	0.074		h _f = 3.0 x n x V ² / 2 g
Total	Σ h	0.041	0.048	0.074		
Head loss	h	0.050	0.050	0.080		Round up to cm
Upstream water level (m)	H	345.360	345.360	345.400		H = H ₀ + h

Formula - 2.1 (Darcy-Weisbach's formula)

NO.11

Facility	Aeration Tank (Outlet Pit)					φ1800 (Existing)	Remarks
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3			
Flow (m ³ /s)	Q	2.893	3.148	3.889			Q1' = Q1 + Q2 x 1 Q2' = Q2 + Q2 x 1 Q3' = Q3 + Q2 x 1
Number of units	N	3	3	3			
Unit flow (m ³ /s)	q	0.964	1.049	1.296			
Dimensions							
Pipe diameter	d	1.800	m (Existing)				
Cross-section area	AW	2.545	m ²				
Pipe length	L	90.00	m				
Friction loss coef	f	0.030					
Downstream water level (m)	H _o	345.360	345.360	345.400			
Flow velocity (m/s)	V	0.379	0.412	0.509			V = q / AW
Velocity head (m)	$\frac{V^2}{2g}$	0.007	0.009	0.013			
Straight pipe loss (m)	h _{fl}	0.011	0.013	0.020			
Inlet loss (m)	h _i	0.004	0.004	0.007			f = 0.50 n = 1
Outlet loss (m)	h _o	0.007	0.009	0.013			f = 1.00 n = 1
Bend loss (m)	h _b	0.003	0.003	0.005			f = 0.20 n = 2
Other losses	h _e						f = n =
Total (m)	Σ h	0.025	0.029	0.045			
Head loss (m)	h	0.030	0.030	0.050			Round up to cm
Upstream water level (m)	H	345.390	345.390	345.450			H = H _o + h


Formula - 3 (Francis's formula/Full width weir)

NO.12

Facility	Aeration Tank				Outlet weir 4800W	
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3		Remarks
Flow (m ³ /s)	Q	2.893	3.148	3.889		Q1' = Q1 + Q2 x 1 Q2' = Q2 + Q2 x 1 Q3' = Q3 + Q2 x 1
Number of units	N	4	4	4		
Unit flow (m ³ /s)	q	0.723	0.787	0.972		
Dimensions						
Weir width Weir height	B H _b					
Downstream water level (m)	H ₀	345.390	345.390	345.450		
Weir height (m)	H _b	346.500	346.500	346.500		
Downstream depth above weir	h ₂					h ₂ = H ₀ - H _b
Upstream depth (m)	h ₁	0.189	0.200	0.230		
Total (m)	Σ h	0.189	0.200	0.230		
Head loss (m)	h	0.190	0.200	0.230		Round up to cm
Upstream water level (m)	H	346.690	346.700	346.730		H = H ₀ + h


Formula - 1.1 (Manning's formula/Rectangular open channel)

NO.13

Facility	Aeration Tank				Inlet Channel	
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3		Remarks
Flow (m ³ /s)	Q	1.319	1.574	2.315		
Number of units	N	1	1	1		
Unit flow (m ³ /s)	q	1.319	1.574	2.315		
Dimensions						
Roughness coef.	n	0.014				
Channel width	B	1.500	m (Existing)			
Channel length	L	200.00	m			
Haunch height	a	0.00	m			
Haunch width	b	0.00	m			
Bottom level	H _b	342.900	m			
						
Downstream water level (m)	H ₀	346.690	346.700	346.730		
Channel bottom level (m)	H _b	342.900	342.900	342.900		
Effective depth (m)	h	3.790	3.800	3.830		$h = H_0 - H_b$
Cross-section area (m ²)	AW	5.685	5.700	5.745		$WA=B \times h - (a \times b)$
Hydraulic radius (m)	R	0.626	0.626	0.627		$R = \frac{AW}{(2h + B - 2(a + b) + 2\sqrt{(a^2 + b^2)})}$
Hydraulic radius (m)	R ^{4/3}	0.536	0.536	0.537		
Flow velocity (m/s)	V	0.232	0.276	0.403		$V = \frac{q}{AW}$
Velocity head (m)	$\frac{V^2}{2g}$	0.003	0.004	0.008		
Hydraulic gradient (%)	I	0.020	0.028	0.059		$I = (n \cdot V / R^{2/3})^2$
Friction loss (m)	h _f	0.004	0.006	0.012		$h_f = I \times L$
Head loss (m) (Out)	h _{se}	0.001	0.002	0.004		f = 0.5 n = 1
Head loss (m) (Contraction)	h _{sc}					f = n =
Bend loss (m)	h _b	0.005	0.008	0.017		f = 1 n = 2
Other losses (m)	h _e	0.030	0.030	0.030		f = n =
Total (m)	h	0.040	0.046	0.063		
Head loss (m)	h	0.040	0.050	0.070		Round up to cm
Upstream water level (m)	H	346.730	346.750	346.800		


Formula - 2.1 (Darcy-Weisbach's formula)

NO.14

Facility	Primary Sedimentation Tank				Outlet pipe (3/3) φ1500	
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3		Remarks
Flow (m ³ /s)	Q	1.319	1.574	2.315		
Number of units	N	2	2	2		
Unit flow (m ³ /s)	q	0.660	0.787	1.158		
Dimensions						
Pipe diameter	d	1.500	m			
Cross-section area	AW	1.767	m ²			
Pipe length	L	70.00	m			
Friction loss coef	f	0.030				
Downstream water level (m)	H _o	346.730	346.750	346.800		
Flow velocity (m/s)	V	0.373	0.445	0.655		V=q / AW
Velocity head (m)	$\frac{V^2}{2g}$	0.007	0.010	0.022		
Straight pipe loss (m)	h _{fL}	0.010	0.014	0.031		
Inlet loss (m)	h _i	0.007	0.010	0.022		f = 0.50 n = 2
Outlet loss (m)	h _o	0.014	0.020	0.044		f = 1.00 n = 2
Bend loss (m)	h _b					f = n =
Other losses	h _e					f = n =
Total (m)	Σ h	0.031	0.044	0.097		
Head loss (m)	h	0.040	0.050	0.100		Round up to cm
Upstream water level (m)	H	346.770	346.800	346.900		H=H _o +h


Formula - 2.1 (Darcy-Weisbach's formula)

NO.15

Facility	Primary Sedimentation Tank				Outlet pipe (2/3) φ1200	
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3	Remarks	
Flow (m ³ /s)	Q	1.319	1.574	2.315		
Number of units	N	4	4	4	2/8 tanks	
Unit flow (m ³ /s)	q	0.330	0.394	0.579		
Dimensions						
Pipe diameter	d					1.200 m
Cross-section area	AW					1.131 m ²
Pipe length	L					20.00 m
Friction loss coef	f					0.031
Downstream water level (m)	H _o	346.770	346.800	346.900		
Flow velocity (m/s)	V	0.292	0.348	0.512	V=q / AW	
Velocity head (m)	$\frac{V^2}{2g}$	0.004	0.006	0.013		
Straight pipe loss (m)	h _{fl}	0.002	0.003	0.007		
Inlet loss (m)	h _i	0.002	0.003	0.007	f = 0.50 n = 1	
Outlet loss (m)	h _o	0.004	0.006	0.013	f = 1.00 n = 1	
Bend loss (m)	h _b				f = n =	
Other losses	h _e				f = n =	
Total (m)	Σ h	0.008	0.012	0.027		
Head loss (m)	h	0.010	0.020	0.030	Round up to cm	
Upstream water level (m)	H	346.780	346.820	346.930	H=H _o +h	

Formula - 2.1 (Darcy-Weisbach's formula)

NO.16

Facility	Primary Sedimentation Tank				Outlet pipe (1/3) φ800	
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3	Remarks	
Flow (m ³ /s)	Q	1.319	1.574	2.315		
Number of units	N	8	8	8	1/8 tanks	
Unit flow (m ³ /s)	q	0.165	0.197	0.289		
Dimensions						
Pipe diameter	d					0.800 m
Cross-section area	AW					0.503 m ²
Pipe length	L					25.00 m
Friction loss coef	f					0.031
Downstream water level (m)	H _o	346.780	346.820	346.930		
Flow velocity (m/s)	V	0.328	0.392	0.575	V=q / AW	
Velocity head (m)	$\frac{V^2}{2g}$	0.005	0.008	0.017		
Straight pipe loss (m)	h _{f1}	0.005	0.008	0.016		
Inlet loss (m)	h _i	0.003	0.004	0.008	f = 0.50 n = 1	
Outlet loss (m)	h _o	0.005	0.008	0.017	f = 1.00 n = 1	
Bend loss (m)	h _b				f = n =	
Other losses	h _e				f = n =	
Total (m)	Σ h	0.013	0.020	0.041		
Head loss (m)	h	0.020	0.020	0.050	Round up to cm	
Upstream water level (m)	H	346.800	346.840	346.980	H=H _o +h	


Formula - 5 (Thomas-Camp's formula)

NO.17

Facility	Primary Sedimentation Tank				Outlet trough 600W	
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3		Remarks
Flow (m ³ /s)	Q	1.319	1.574	2.315		
Number of units	N	16	16	16		8 Tanks x 2 Troughs
Unit flow (m ³ /s)	q	0.082	0.098	0.145		
Dimensions						
Trough width	B	0.60	m			
Trough length	L	40.00	m	(28 - 0.6) x 3.14 / 2		
Trough slope	i	0.00	‰			
Trough bottom level	H _b	+346.700	m	(Existing trough level)		
Downstream water level (m)	H ₀	346.800	346.840	346.980		
Trough bottom level (m)	H _b	346.700	346.700	346.700		
Water depth at end of trough	h ₁	0.100	0.140	0.280		
Critical depth (m)	h _{cl}	0.124	0.140	0.181		
Water depth at start of trough	h ₀	0.219	0.242	0.348		
Friction loss (m)	h _f	0.219	0.242	0.348		i × L + h ₀
Total (m)	Σ h	0.219	0.242	0.348		
Head loss (m)	h	0.220	0.250	0.350		Round up to cm
Upstream water level (m)	H	346.920	346.950	347.050		H=H ₀ +h


Formula - 4 (Thomson/Right-angle rectangular weir)

NO.18

Facility	Primary Sedimentation Tank				Weir (V-notch)		
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3		Remarks	
Flow (m ³ /s)	Q	1.319	1.574	2.315			
Number of units	N	2692	2692	2692		N = (28 - 0.6 x 2) x 3.14 x 8 tanks x 4 unit/m = 2692	
Unit flow (m ³ /s)	q	×10 ⁻⁴ 4.900	×10 ⁻⁴ 5.847	×10 ⁻⁴ 8.600			
Dimensions Notch level	H _b	+347.350 m (Existing Level)					
Downstream water level (m)	H ₀	346.920	346.950	347.050			
Notch level (m)	H _b	347.350	347.350	347.350			
Overflow depth (m)	h	0.041	0.044	0.052		$h = (q / 1.42)^{2/5}$	
Total (m)	Σ h	0.041	0.044	0.052			
Head loss (m)	h	0.050	0.050	0.060		Round up to cm	
Upstream water level (m)	H	347.400	347.400	347.410		H = H ₀ + h	


Formula - 2.1 (Darcy-Weisbach's formula)

NO.19

Facility	Primary Sedimentation Tank					Inlet pipe (2/2) φ500 (Existing)
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3		Remarks
Flow (m ³ /s)	Q	1.319	1.574	2.315		
Number of units	N	8	8	8		1/8 tanks
Unit flow (m ³ /s)	q	0.165	0.197	0.289		
Dimensions						
Pipe diameter	d	0.500	m (Existing)			
Cross-section area	AW	0.196	m ²			
Pipe length	L	28.00	m			
Friction loss coef	f	0.031				
Downstream water level (m)	H _o	347.400	347.400	347.410		
Flow velocity (m/s)	V	0.840	1.003	1.472		V=q / AW
Velocity head (m)	$\frac{V^2}{2g}$	0.036	0.051	0.111		
Straight pipe loss (m)	h _{f1}	0.063	0.089	0.192		
Inlet loss (m)	h _i	0.018	0.026	0.055		f = 0.50 n = 1
Outlet loss (m)	h _o	0.036	0.051	0.111		f = 1.00 n = 1
Bend loss (m)	h _b	0.022	0.031	0.066		f = 0.20 n = 3
Other losses	h _e					f = n =
Total (m)	Σ h	0.139	0.197	0.424		
Head loss (m)	h	0.140	0.200	0.430		Round up to cm
Upstream water level (m)	H	347.540	347.600	347.840		H=H _o +h


Formula - 6.1 (Orifice/Rectangular opening)

NO.20

Facility	Distribution Tank (for PST)				Gate 600W	Remarks
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3		
Flow (m ³ /s)	Q	1.319	1.574	2.315		
Number of openings		8	8	8		
Unit flow (m ³ /s)	q	0.165	0.197	0.289		
Dimensions (for opening)						
Width	B					0.600 m
Height	H					0.650 m
Cross-section area	Aw	0.390 m ²				
Downstream water level (m)	H ₀	347.540	347.600	347.840		
Flow velocity (m/s)	V	0.423	0.504	0.742		V = q / Aw
Velocity head (m)	$\frac{V^2}{2g}$	0.009	0.013	0.028		
Head loss (m)	h _f	0.025	0.036	0.078		h _f = 3.0 × n × V ² / 2 g
Total	Σ h	0.025	0.036	0.078		
Head loss	h	0.030	0.040	0.080		Round up to cm
Upstream water level (m)	H	347.570	347.640	347.920		H = H ₀ + h


Formula - 2.1 (Darcy-Weisbach's formula)

NO.21

Facility	Primary Sedimentation Tank				Inlet pipe (1/2) φ1200	
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3	Remarks	
Flow (m ³ /s)	Q	1.319	1.574	2.315		
Number of units	N	2	2	2	4/8 tanks	
Unit flow (m ³ /s)	q	0.660	0.787	1.158		
Dimensions						
Pipe diameter	d	1.200	m (New)			
Cross-section area	AW	1.131	m ²			
Pipe length	L	145.00	m			
Friction loss coef	f	0.031				
Downstream water level (m)	H _o	347.570	347.640	347.920		
Flow velocity (m/s)	V	0.584	0.696	1.024	V=q / AW	
Velocity head (m)	$\frac{V^2}{2g}$	0.017	0.025	0.053		
Straight pipe loss (m)	h _{fl}	0.065	0.093	0.200		
Inlet loss (m)	h _i	0.009	0.012	0.027	f = 0.50 n = 1	
Outlet loss (m)	h _o	0.017	0.025	0.053	f = 1.00 n = 1	
Bend loss (m)	h _b	0.010	0.015	0.032	f = 0.20 n = 3	
Other losses	h _e				f = n =	
Total (m)	Σ h	0.101	0.145	0.312		
Head loss (m)	h	0.110	0.150	0.320	Round up to cm	
Upstream water level (m)	H	347.680	347.790	348.240	H=H _o +h	

Formula - 3 (Francis's formula/Full width weir)

NO.22

Facility	Grit Chamber				Distribution Weir 3400W	
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3		Remarks
Flow (m ³ /s)	Q	1.319	1.574	2.315		
Number of units	N	2	2	2		
Unit flow (m ³ /s)	q	0.660	0.787	1.158		
Dimensions						
Weir width	B	3.40 m				
Weir height	H _b	+348.370 m				
						
Downstream water level (m)	H ₀	347.680	347.790	348.240		
Weir height (m)	H _b	348.370	348.370	348.370		
Downstream depth above weir	h ₂					h ₂ =H ₀ -H _b
Upstream depth (m)	h ₁	0.223	0.251	0.325		
Total (m)	Σ h	0.223	0.251	0.325		
Head loss (m)	h	0.230	0.260	0.330		Round up to cm
Upstream water level (m)	H	348.600	348.630	348.700		H=H ₀ +h


Formula - 3 (Francis's formula/Full width weir)

NO.23

Facility	Grit Chamber				Weir 3440W	
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3		Remarks
Flow (m ³ /s)	Q	1.319	1.574	2.315		
Number of units	N	2	2	2		
Unit flow (m ³ /s)	q	0.660	0.787	1.158		
Dimensions						
Weir width	B					
Weir height	H _b	+348.200 m				
Downstream water level (m)	H ₀	348.600	348.630	348.700		
Weir height (m)	H _b	348.200	348.200	348.200		
Downstream depth above weir	h ₂	0.400	0.430	0.500		h ₂ =H ₀ -H _b
Upstream depth (m)	h ₁	0.031	0.038	0.061		
Total (m)	Σ h	0.031	0.038	0.061		
Head loss (m)	h	0.070	0.070	0.100		Round up to cm
Upstream water level (m)	H	348.670	348.700	348.800		H=H ₀ +h

Formula - 1.1 (Manning's formula/Rectangular open channel)

NO.24

Facility	Grit Chamber				Inlet channel 1700W	
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3		Remarks
Flow (m ³ /s)	Q	1.319	1.574	2.315		
Number of units	N	2	2	2		
Unit flow (m ³ /s)	q	0.660	0.787	1.158		
Dimensions						
Roughness coef.	n	0.013				
Channel width	B	1.700 m				
Channel length	L	6.00 m				
Haunch height	a	0.00 m				
Haunch width	b	0.00 m				
Bottom level	H _b	347.750 m				
						
Downstream water level (m)	H ₀	348.670	348.700	348.800		
Channel bottom level (m)	H _b	347.750	347.750	347.750		
Effective depth (m)	h	0.920	0.950	1.050		$h = H_0 - H_b$
Cross-section area (m ²)	AW	1.564	1.615	1.785		$WA=B \times h - (a \times b)$
Hydraulic radius (m)	R	0.442	0.449	0.470		$R = \frac{AW}{(2h + B - 2(a + b) + 2\sqrt{(a^2 + b^2)})}$
Hydraulic radius (m)	R ^{4/3}	0.336	0.343	0.365		
Flow velocity (m/s)	V	0.422	0.487	0.649		$V = \frac{q}{AW}$
Velocity head (m)	$\frac{V^2}{2g}$	0.009	0.012	0.021		
Hydraulic gradient (%)	I	0.089	0.117	0.195		$I = (n \cdot V / R^{2/3})^2$
Friction loss (m)	h _f	0.001	0.001	0.001		$h_f = I \times L$
Head loss (m) (Out)	h _{se}	0.005	0.006	0.011		f = 0.5 n = 1
Head loss (m) (Contraction)	h _{sc}					f = n =
Bend loss (m)	h _b					f = n =
Other losses (m)	h _e	0.080	0.080	0.080		f = n =
Total (m)	h	0.086	0.087	0.092		
Head loss (m)	h	0.090	0.090	0.100		Round up to cm
Upstream water level (m)	H	348.760	348.790	348.900		

Formula - 1.1 (Manning's formula/Rectangular open channel)

NO.25

Facility	Grit Chamber				Gate 1000 W		
Item	Sign	Daily Flow Q1	Design Flow Q2	Maxi. Flow Q3		Remarks	
Flow (m ³ /s)	Q	1.319	1.574	2.315			
Number of units	N	4	4	4			
Unit flow (m ³ /s)	q	0.330	0.394	0.579			
Dimensions							
Roughness coef.	n						0.014
Channel width	B						1.200 m
Channel length	L						0.50 m
Haunch height	a						0.00 m
Haunch width	b						0.00 m
Bottom level	H _b						346.950 m
Downstream water level (m)	H ₀	348.760	348.790	348.900			
Channel bottom level (m)	H _b	346.950	346.950	346.950			
Effective depth (m)	h	1.810	1.840	1.950		$h = H_0 - H_b$	
Cross-section area (m ²)	AW	2.172	2.208	2.340		$WA=B \times h - (a \times b)$	
Hydraulic radius (m)	R	0.451	0.452	0.459		$R = \frac{AW}{(2h + B - 2(a + b) + 2\sqrt{(a^2 + b^2)})}$	
Hydraulic radius (m)	R ^{4/3}	0.345	0.347	0.354			
Flow velocity (m/s)	V	0.152	0.178	0.247		$V = \frac{q}{AW}$	
Velocity head (m)	$\frac{V^2}{2g}$	0.001	0.002	0.003			
Hydraulic gradient (%)	I	0.013	0.018	0.034		$I = (n \cdot V / R^{2/3})^2$	
Friction loss (m)	h _f	0.000	0.000	0.000		$h_f = I \times L$	
Head loss (m) (Gate)	h _{se}	0.002	0.002	0.005		f = 1.5 n = 1	
Head loss (m) (Contraction)	h _{sc}					f = n =	
Bend loss (m)	h _b					f = n =	
Other losses (m)	h _e					f = n =	
Total (m)	h	0.002	0.002	0.005			
Head loss (m)	h	0.010	0.010	0.010		Round up to cm	
Upstream water level (m)	H	348.770	348.800	348.910			