

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

Background Report Reference

AP-42 Section Number: 10.6.1

Background Report Section: 4

Reference Number: 88

**Title: Air Emission Test Results, June
1994 Louisiana Pacific Canada
LTD, Dawson Creek, B C**

**N. R. McCall & Associates
Environmental Consultants, Ltd.**

August 1994

4-88)



LOUISIANA PACIFIC CANADA LTD.

MILE 3, ALASKA HIGHWAY

DAWSON CREEK, B.C.

JUNE 20-22, 1994

FILE NUMBER M94-055

MCA 44 694

**N.R.M^cCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.**

N.R.M^cCALL & ASSOCIATES ENVIRONMENTAL CONSULTANTS LTD.

1015 GLEN FOREST WAY, RR 1, VICTORIA, B.C. V9B 5T7 PHONE & FAX: (604) 478-0902

August 15, 1994

Louisiana Pacific Canada Ltd.
P.O. Box 2338, Mile 3, Alaska Highway
Dawson Creek, B.C.
V1G 4P2

Attention: Mr. Bill Nylund

Dear Bill:

Reference: Air Emission Test Results - June 1994

Please find enclosed four copies of the test results from the test program completed June 1994. The lab analysis for the MDI isocyanates is expected shortly and will be sent at a later date.

1. TEST METHODS

The following test methods were used exclusively in the test program:

Formaldehyde - E.P.A Method 0011

Phenols - E.P.A. Method 0010

MDI 2,4 Toluene Disocyanate - Proposed Method developed by EPA Research Triangle Park, N.C.

Particulate & Condensable Organics - EPA Modified Method 5 Train (State of Oregon developed the method).

Total Particulate - M.O.E. Reference Method 5

2. TEST LOCATIONS & TEST REQUIREMENTS

Core Wood Wafer Dryer

Condensable Organics
Formaldehyde
Hydrogen Cyanide

Blender Area Baghouse

MDI Isocyanates
Phenols
Formaldehyde

Press Vent

Formaldehyde
MDI Isocyanates

Konus Kessel


Total Particulate

3. TEST RESULTS

The results are summarized in the following tables, and if you have any questions concerning the test results, please contact us at your convenience.

Yours truly,

N.R. MCCALL & ASSOCIATES LTD.



Neil McCall

Louisiana Pacific Canada Ltd.
Dawson Creek B.C.

1. CORE WOOD WAFER DRYER

Summary of Test Results -Condensible Organics

	Test 1	Test 2	Average
Gas Temperature (°C.)	61	60	61
Gas Moisture %	24.2	22.0	23.1
Gas Velocity (m/sec)	19.7	19.3	19.5
Dry Gas Flow Rate Std. Conditions (m ³ /sec)	18.0	18.1	18.1
Concentration (mg/m ³)			
Total Particulate inc. Condensibles	91.3	82.3	86.8
Front	30.69	20.13	25.41
Back (Condensibles)	60.62	62.17	61.40
Total Mass Emission Rate (kg/hr)	5.91	5.37	5.64
Method Blank - 0.0005 gm			

Louisiana Pacific Canada Ltd.
Dawson Creek B.C.

1. CORE WOOD WAFER DRYER cont,d

Summary of Test Results -Formaldehyde

	Test 1	Test 2	Average
Gas Temperature (°C.)	62	61	62
Gas Moisture %	22.5	24.8	23.7
Gas Velocity (m/sec)	19.3	19.4	19.4
Dry Gas Flow Rate Std. Conditions (m ³ /sec)	18.0	17.6	17.8
Concentration (mg/m ³)	0.67	1.2	0.94
Total Mass Emission Rate (kg/hr)	0.04	0.08	0.06
Minimum detectable limit 0.03ug			
Trip Blank 26ug			

Louisiana Pacific Canada Ltd.
Dawson Creek B.C.

1. CORE WOOD WAFER DRYER cont,d

Summary of Test Results -Hydrogen Cyanide

	Test 1	Test 2	Average
Gas Temperature (°C.)	59	61	60
Gas Moisture %	21.1	25.3	23.2
Gas Velocity (m/sec)	19.6	19.7	19.7
Dry Gas Flow Rate Std. Conditions (m ³ /sec)	18.8	17.7	18.3
Concentration (mg/m ³)	0.079	0.073	0.076
Total Mass Emission Rate (kg/hr)	0.005	0.005	0.005
Minimum detectable limit 0.001 mg/l			
Method Blank <0.001 mg/l			

Louisiana Pacific Canada Ltd.
Dawson Creek B.C.

2. BLENDER AREA BAGHOUSE

Summary of Test Results -Phenols

	Test 1	Test 2	Average
Gas Temperature (°C.)	28	30	29
Gas Moisture %	1.2	0.9	1.0
Gas Velocity (m/sec)	22.0	22.5	22.2
Dry Gas Flow Rate Std. Conditions (m ³ /sec)	9.9	10.1	10.0
Concentration (mg/m ³)	6.93	5.2	6.07
Total Mass Emission Rate (kg/hr)	0.25	0.19	0.22
Method Blank 0.0 ug			
Field Blank 0.36 ug			

Louisiana Pacific Canada Ltd.
Dawson Creek B.C.

2. BLENDER AREA BAGHOUSE cont,d

Summary of Test Results -Formaldehyde

	Test 1	Test 2	Average
Gas Temperature (°C.)	34	34	34
Gas Moisture %	1.2	2.3	1.8
Gas Velocity (m/sec)	22.1	22.2	22.2
Dry Gas Flow Rate Std. Conditions (m ³ /sec)	9.9	9.7	9.8
Concentration (mg/m ³)	0.7	1.08	0.89
Total Mass Emission Rate (kg/hr)	0.02	0.04	0.03
Minimum detectable limits 0.03 ug			
Trip Blank 26 ug			

Louisiana Pacific Canada Ltd.
Dawson Creek B.C.

4. KONUS KESSEL BURNER

Summary of Test Results -Total Particulate

	Test 1	Test 2	Average
Gas Temperature (°C.)	202	205	203
Gas Moisture %	8.8	9.2	9.0
Gas Velocity (m/sec)	10.0	9.6	9.8
Dry Gas Flow Rate Std. Conditions (m ³ /sec)	12.1	11.5	11.8
Total Particulate Concentration			
Actual Dry Basis (mg/m ³)	92.7	102.8	97.7
Corr. to 12% CO ₂ (mg/m ³)	278.2	308.3	293.2
Total Mass Emission Rate (kg/hr)	4.0	4.3	4.2

Louisiana Pacific Canada Ltd.
Dawson Creek B.C.

3. PRESS VENT

Summary of Test Results -Formaldehyde

	Test 1	Test 2	Average
Gas Temperature (°C.)	43	44	44
Gas Moisture %	0.0	0.0	0.0
Gas Velocity (m/sec)	12.9	12.9	12.9
Dry Gas Flow Rate Std. Conditions (m ³ /sec)	23.8	23.7	23.8
Concentration (mg/m ³)	0.54	1.61	1.08
Total Mass Emission Rate (kg/hr)	0.05	0.14	0.10
Minimum detectable limits 0.03 ug			
Trip Blank 26 ug			

Test Data- CORE WOOD WAFER DRYER

N.R. McCall & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC CANADA LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

E.F.B. DRYER - CONDENSIBLES

Average of Air Emission Tests 1 TO 2

DATE: JUNE 20 1994

FIELD MEASUREMENT DATA :

Gas Temperature	140.7 deg F	60.4 deg C
Moisture Content (by volume)	23.1 %	23.1 %
Average Stack Gas Velocity	63.8 ft/sec	19.5 m/sec
Total Actual Gas Flow Rate	60,903 ACFM	--
Gas Flow Rate Reference Conditions	49,986 SCFM	23.6 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0378 gr/SCF	86.46 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0921 gr/SCF	210.80 mg/cubic meter
Wet Basis, Actual	0.0591 lb/1000lb	0.0591 kg/1000kg
Wet Basis at 50 excess air	0.0906 lb/1000lb	0.0906 kg/1000kg

PARTICULATE FROM FRONT HALF OF TRAIN

Dry Basis, Actual	3.6 lbs/hr	1.7 kg/hr
Wet Basis, Actual	0.0173 lb/1000lb	0.0173 kg/1000kg
Wet Basis at 50 excess air	0.0284 lb/1000lb	0.0284 kg/1000kg

Neil McCall
ENVIRONMENTAL CONSULTANTS LTD.
N.R. McCall & ASSOCIATES

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC CANADA LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

E.F.B. DRYER - CONDENSIBLES

Summary of Air Emission Tests of JUNE 20 1994

TEST 1 :

Gas Temperature	141.0 deg F	60.6 deg C
Moisture Content (by volume)	24.2 %	24.2 %
Average Stack Gas Velocity	64.5 ft/sec	19.7 m/sec
Total Actual Gas Flow Rate	61,533 ACFM	--
Gas Flow Rate Reference Conditions	50,469 SCFM	23.8 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0397 gr/SCF	90.93 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.1589 gr/SCF	363.72 mg/cubic meter
Wet Basis, Actual	0.0630 lb/1000lb	0.0630 kg/1000kg
Wet Basis at 50 excess air	0.1363 lb/1000lb	0.1363 kg/1000kg

PARTICULATE FROM FRONT HALF OF TRAIN

Dry Basis, Actual	4.4 lbs/hr	2.0 kg/hr
Wet Basis, Actual	0.0212 lb/1000lb	0.0212 kg/1000kg
Wet Basis at 50 excess air	0.0458 lb/1000lb	0.0458 kg/1000kg

TEST 2 :

Gas Temperature	140.3 deg F	60.1 deg C
Moisture Content (by volume)	22.0 %	22.0 %
Average Stack Gas Velocity	63.2 ft/sec	19.3 m/sec
Total Actual Gas Flow Rate	60,273 ACFM	--
Gas Flow Rate Reference Conditions	49,502 SCFM	23.4 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0358 gr/SCF	81.99 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0253 gr/SCF	57.88 mg/cubic meter
Wet Basis, Actual	0.0551 lb/1000lb	0.0551 kg/1000kg
Wet Basis at 50 excess air	0.0449 lb/1000lb	0.0449 kg/1000kg

PARTICULATE FROM FRONT HALF OF TRAIN

Dry Basis, Actual	2.9 lbs/hr	1.3 kg/hr
Wet Basis, Actual	0.0135 lb/1000lb	0.0135 kg/1000kg
Wet Basis at 50 excess air	0.0110 lb/1000lb	0.0110 kg/1000kg

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

GAS FLOW AND PARTICULATE MONITORING TEST 1

JOB NUMBER : M94-055
CLIENT : LOUISIANA PACIFIC CANADA LTD.
PLANT LOCATION : DAWSON CREEK B.C.
Process : E.F.S. DRYER - CONDENSIBLES
Plant Licence Number : N/A

Monitoring Personnel : M. JOHNS / D. LAWRENCE
Test Procedure : WMB. STD. TEST PROCEDURE USING
A LEAK SIEGLER PM-100

Date of Test : JUNE 20 1994
Test Start Time : 12:40 P.M.
Test Stop Time : 1:46 P.M.
On-line Sampling Time : 60 minutes

TEST RESULTS :

Gas Temperature	141 deg F	61 deg C
Moisture Content	24.2 %	24.2 %
Average Stack Gas Velocity	64.5 ft/sec	19.7 m/sec
Total Actual Gas Flow Rate	61,533 ACFM	--
Gas Flow Rate Reference Conditions	50,469 SCFM	23.8 cubic meter/sec
Particulate concentration - Dry Basis Corrected to 12% CO2	0.1589 gr/SCF	363.72 mg/cubic meter
Particulate Emission Rate	4.4 lbs/hr	2.0 kg/hr

N.E. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC CANADA LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

TEST DATA - TEST 1

AS	Cross Section Area of Duct/Stack	15.90 square feet
PB	Barometric Pressure	27.80 inches Hg
PS	Pressure in Duct or Stack	27.83 inches Hg
VM	Dry Gas Meter Volume	30.60 cubic feet
WC	Weight of Condensate Collected	180.0 grams
WSS	Weight of Moisture in Silica Gel	8.0 grams
WF	Weight of Filter Particulate	0.0236 grams
WFL	Weight of Cyclone Particulate	0.0001 grams
WW	Weight of Washings	0.0005 grams
WTI	Weight of impinger catch	0.0478 grams
NT	Total Number of Sample Points	20
CP	Type-S Pitot Tube Coefficient	0.8674
DN	Diameter of Nozzle Tip	0.1820 inches

GAS ANALYSIS (VOLUME %, DRY BASIS)

	Measured
CO	0.00010
CO2	3.00000
O2	17.00000
N2	80.00000
H2O	

GAS ANALYSIS (VOLUME % WET BASIS)

	Measured
CO	0.000076
CO2	2.274910
O2	12.891160
N2	60.664270
H2O	24.16966

PERCENT OF EXCESS AIR IN FLUE GAS

412.615

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

SAMPLING TEST DATA - TEST 1

SAMPLE POINT	VELOCITY	ORIFICE	DRY GAS METER		STACK GAS	GAS SAMPLE
	HEAD (in H ₂ O)	PRESSURE (in H ₂ O)	TEMP IN (deg F)	TEMP OUT (deg F)	TEMP (deg F)	VOLUME (cubic feet)
A-10	0.860	0.660	70	70	145	508.53
A-9	0.870	0.750	86	72	141	506.92
A-8	0.900	0.770	92	72	141	508.33
A-7	0.920	0.800	98	74	141	509.86
A-6	0.950	0.820	102	76	140	511.35
A-5	1.050	0.920	104	76	141	512.88
A-4	0.950	0.840	106	78	142	514.49
A-3	0.900	0.800	108	78	141	516.05
A-2	0.900	0.800	108	80	142	517.57
A-1	0.900	0.800	110	80	140	519.07
B-10	0.900	0.770	88	78	144	520.55
B-9	0.950	0.840	106	82	143	522.05
B-8	1.000	0.880	12	84	141	523.61
B-7	0.970	0.860	114	84	141	525.20
B-6	1.000	0.890	14	86	141	526.79
B-5	1.000	0.900	116	86	140	528.39
B-4	0.920	0.830	117	87	140	529.98
B-3	0.900	0.810	118	88	140	531.54
B-2	0.900	0.810	118	88	139	533.10
B-1	0.880	0.790	120	90	138	534.62
						536.13

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

Data for TEST 1 :

DELTA P:	0.9629	ACFM:	51533.36
DELTA H:	0.8175	SCFM:	50469.33
TMAVG:	547.9000	PE:	27.80
TS AVG:	501.0500	VM:	30.60
MC:	1.015	VM(CORR):	31.04
MD:	29.1600	PM:	27.8602
MS:	26.4627	PCON:	0.0397
VMSTD:	27.9582	CORR:	0.1589
RWD:	0.2417	ERAT:	13.0351
USAVG:	64.5004		
FHC(I)	0.3361		

INDIVIDUAL ISOKINETICS

VELOCITY OF INDIVIDUAL SAMPLE POINTS (m/sec) TEST 1

1.	1.087	11.	1.079	1.	18.322	11.	19.417
2.	1.073	12.	1.070	2.	19.043	12.	19.933
3.	1.064	13.	1.157	3.	19.369	13.	20.417
4.	1.051	14.	1.067	4.	19.583	14.	20.108
5.	1.056	15.	1.160	5.	19.883	15.	20.417
6.	1.056	16.	1.047	6.	20.921	16.	20.400
7.	1.073	17.	1.069	7.	19.916	17.	19.567
8.	1.071	18.	1.079	8.	19.369	18.	19.353
9.	1.056	19.	1.050	9.	19.385	19.	19.337
10.	1.038	20.	1.050	10.	19.353	20.	19.105

Overall Isokinetic for TEST 1 : 1.072

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

GAS FLOW AND PARTICULATE MONITORING TEST 2

JOB NUMBER : M94-055
CLIENT : LOUISIANA PACIFIC CANADA LTD.
PLANT LOCATION : DAWSON CREEK B.C.
Process : E.F.B. DRYER - CONDENSIBLES
Plant Licence Number : N/A

Monitoring Personnel : M. JOHNS / D. LAWRENCE
Test Procedure : WMB. STD. TEST PROCEDURE USING
A LEAR SIEGLER PM-100

Date of Test : JUNE 20 1994
Test Start Time : 2:20 P.M.
Test Stop Time : 3:30 P.M.
On-line Sampling Time : 60 minutes

TEST RESULTS :

Gas Temperature	140 deg F	60 deg C
Moisture Content	22.0 %	22.0 %
Average Stack Gas Velocity	63.2 ft/sec	19.3 m/sec
Total Actual Gas Flow Rate	60,273 ACFM	--
Gas Flow Rate Reference Conditions	49,502 SCFM	23.4 cubic meter/sec
Particulate concentration - Dry Basis Corrected to 12% CO2	0.0253 gr/SCF	57.88 mg/cubic meter
Particulate Emission Rate	2.9 lbs/hr	1.3 kg/hr

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC CANADA LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

TEST DATA - TEST 2

AS	Cross Section Area of Duct/Stack	15.90 square feet
PS	Barometric Pressure	27.80 inches Hg
PS	Pressure in Duct or Stack	27.83 inches Hg
VM	Dry Gas Meter Volume	31.16 cubic feet
WE	Weight of Condensate Collected	158.0 grams
WSG	Weight of Moisture in Silica Gel	8.0 grams
WF	Weight of Filter Particulate	0.0153 grams
WFL	Weight of Cyclone Particulate	0.0001 grams
WW	Weight of Washings	0.0004 grams
WTI	Weight of impinger catch	0.0488 grams
NT	Total Number of Sample Points	20
CP	Type-S Pitot Tube Coefficient	0.8674
DN	Diameter of Nozzle Tip	0.1820 inches

GAS ANALYSIS (VOLUME %, DRY BASIS)

	Measured
CO	0.00010
CO2	17.00000
O2	3.00000
N2	80.00000
H2O	

GAS ANALYSIS (VOLUME % WET BASIS)

	Measured
CO	0.000078
CO2	13.251890
O2	2.338569
N2	62.361840
H2O	22.04770

PERCENT OF EXCESS AIR IN FLUE GAS

16.556

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

SAMPLING TEST DATA - TEST 2

SAMPLE POINT	VELOCITY HEAD (in H2O)	ORIFICE PRESSURE (in H2O)	DRY GAS METER TEMP IN TEMP OUT (deg F) (deg F)		STACK GAS TEMP (deg F)	GAS SAMPLE VOLUME (cubic feet)
B-10	0.950	0.830	90	86	141	536.29
B-9	0.950	0.850	106	88	139	537.85
B-8	0.950	0.650	110	90	137	539.41
B-7	1.000	0.900	114	88	138	540.98
B-6	1.000	0.900	116	88	140	542.58
B-5	0.970	0.870	116	88	141	544.17
B-4	0.970	0.870	116	88	139	545.75
B-3	0.950	0.860	118	88	138	547.32
B-2	0.900	0.810	118	88	135	548.89
B-1	0.900	0.820	118	88	134	550.44
A-10	0.850	0.740	98	86	144	551.98
A-9	0.900	0.790	112	86	144	553.44
A-8	1.000	0.890	116	88	144	554.92
A-7	1.050	0.940	118	88	145	556.52
A-6	0.900	0.800	118	88	143	558.17
A-5	0.930	0.830	118	88	143	559.70
A-4	0.950	0.850	118	88	141	561.28
A-3	1.000	0.900	118	88	140	562.85
A-2	0.900	0.900	118	88	140	564.45
A-1	0.850	0.760	118	88	139	566.00
						567.45

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

Data for TEST 2 :

DELTA P:	0.9710	ACEM:	60273.26
DELTA H:	0.8480	SCPM:	49501.69
TMAVG:	560.7500	PB:	27.80
TS AVG:	600.2500	VM:	31.16
MC:	1.015	VM(CORR):	31.61
MD:	30.8400	PM:	27.8624
MS:	28.0091	PCON:	0.0258
VMSTD:	27.6197	CORR:	0.0253
BWG:	0.2205	ERAT:	11.9508
USAUG:	63.1795		
EHC(I)	0.2446		

INDIVIDUAL ISOKINETICS

VELOCITY OF INDIVIDUAL SAMPLE POINTS (m/sec) TEST 2

1.	1.080	11.	1.064	1.	19.342	11.	18.342
2.	1.061	12.	1.035	2.	19.310	12.	18.874
3.	1.060	13.	1.056	3.	19.278	13.	19.894
4.	1.053	14.	1.062	4.	19.795	14.	20.403
5.	1.046	15.	1.061	5.	19.828	15.	18.858
6.	1.056	16.	1.078	6.	19.545	16.	19.170
7.	1.048	17.	1.058	7.	19.512	17.	19.342
8.	1.056	18.	1.051	8.	19.294	18.	19.828
9.	1.068	19.	1.073	9.	18.732	19.	18.811
10.	1.060	20.	1.031	10.	18.717	20.	18.266

Overall Isokinetic for TEST 2 : 1.058

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

E.F.B. DRYER HYDROGEN CYANIDE

Average of Air Emission Tests 1 TO 2

DATE: JUNE 20 1994

FIELD MEASUREMENT DATA :

Gas Temperature	140 deg F	60 deg C
Moisture Content (by volume)	23.2 %	23.2 %
Average Stack Gas Velocity	64.4 ft/sec	19.6 m/sec
Total Actual Gas Flow Rate	61,485 ACFM	--
Standard Gas Flow Rate Reference Conditions		
	39,702 SCFM	18.3 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0000 gr/SCF	0.00 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter

Neil McCall
ENVIRONMENTAL CONSULTANTS LTD.
N.R. McCALL & ASSOCIATES

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

E.F.B. DRYER HYDROGEN CYANIDE

Summary of Air Emission Tests of JUNE 20 1994

TEST 1 :

Gas Temperature	138 deg F	59 deg C
Moisture Content (by volume)	21.1 %	21.1 %
Average Stack Gas Velocity	64.4 ft/sec	19.6 m/sec
Total Actual Gas Flow Rate	61,390 ACFM	--
Standard Gas Flow Rate Reference Conditions	39,827 SCFM	18.2 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0000 gr/SCF	0.00 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter

TEST 2 :

Gas Temperature	141 deg F	61 deg C
Moisture Content (by volume)	25.3 %	25.3 %
Average Stack Gas Velocity	64.5 ft/sec	19.7 m/sec
Total Actual Gas Flow Rate	61,580 ACFM	--
Standard Gas Flow Rate Reference Conditions	37,577 SCFM	17.7 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0000 gr/SCF	0.00 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

GAS FLOW AND PARTICULATE MONITORING TEST 1

Job Number : M94-055
Client : LOUISIANA PACIFIC LTD.
Plant Location : DAWSON CREEK B.C.
Process : E.F.B. DRYER HYDROGEN CYANIDE
Pollution Control Permit : N/A

Monitoring Personnel : M. JOHNS / D. LAWRENCE
Test Procedure : WMB. STD. TEST PROCEDURE USING
A LEAR SIEGLER PM-100

Date of Test : JUNE 20 1994
Test Start Time : 4:00 P.M.
Test Stop Time : 5:08 P.M.
On-line Sampling Time : 60 minutes

TEST RESULTS :

Gas Temperature	138 deg F	59 deg C
Moisture Content	21.1 %	21.1 %
Average Stack Gas Velocity	64.4 ft/sec	19.6 m/sec
Total Actual Gas Flow Rate	61,390 ACFM	--
Standard Gas Flow Rate Reference Conditions	39,827 SCFM	18.8 cubic meter/sec
Particulate concentration - Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter
Particulate Emission Rate	0.0 lbs/hr	0.0 kg/hr

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

TEST DATA - TEST 1

AS	Cross Section Area of Duct/Stack	15.90 square feet
PB	Barometric Pressure	27.80 inches Hg
PS	Pressure in Duct or Stack	27.85 inches Hg
VM	Dry Gas Meter Volume	31.03 cubic feet
WE	Weight of Condensate Collected	157.0 grams
WSG	Weight of Moisture in Silica Gel	0.0 grams
WF	Weight of Filter Particulate	0.0000 grams
WEL	Weight of Cyclone Particulate	0.0000 grams
WW	Weight of Washings	0.0000 grams
NT	Total Number of Sample Points	20
CP	Type-S Pitot Tube Coefficient	0.8674
DN	Diameter of Nozzle Tip	0.1820 inches

GAS ANALYSIS (VOLUME %, DRY BASIS)

	Measured	Assumed
CO		
CO2	3.0	
O2	17.0	
N2		80.0

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

SAMPLING TEST DATA - TEST 1

SAMPLE POINT	VELOCITY HEAD (in H2O)	ORIFICE PRESSURE (in H2O)	DRY GAS METER TEMP IN TEMP OUT (deg F) (deg F)		STACK GAS TEMP (deg F)	GAS SAMPLE VOLUME (cubic feet)
A-10	0.900	0.770	84	78	141	567.60
A-9	0.950	0.820	102	80	139	569.09
A-8	0.950	0.840	108	80	139	570.61
A-7	0.950	0.850	110	80	137	572.13
A-6	0.970	0.870	112	81	136	573.71
A-5	1.000	0.900	114	81	135	575.29
A-4	0.950	0.850	114	81	137	576.89
A-3.	0.950	0.850	114	81	137	578.47
A-2	1.000	0.890	114	81	137	580.03
A-1	1.000	0.890	114	81	138	581.62
B-10	0.900	0.790	98	80	141	583.24
B-9	0.920	0.820	112	82	138	584.76
B-8	0.930	0.830	114	82	138	586.28
B-7	0.950	0.850	116	83	139	587.83
B-6	0.900	0.810	116	83	138	589.40
B-5	0.900	0.810	116	83	137	590.93
B-4	0.900	0.810	116	83	138	592.45
B-3	0.920	0.820	116	83	136	593.96
B-2	0.930	0.840	116	83	136	595.51
B-1	0.950	0.850	116	83	137	597.08
						598.63

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

Date for TEST 1 :

DELTA P:	0.9699	ACFM:	61290.09
DELTA H:	0.8380	SCFM:	39827.18
TMAVG:	556.2750	PB:	27.80
TS AVG:	397.7000	VM:	31.03
AC:	1.015	VM(CORR):	31.48
MD:	29.1600	PM:	27.8617
MS:	26.8050	PCON:	0.0000
VMSID:	27.8244	CORR:	0.0000
BWD:	0.2110	ERAT:	0.0000
USAVG:	64.3502		

INDIVIDUAL ISOKINETICS - TEST 1

1.	1.037	11.	1.043
2.	1.010	12.	1.014
3.	1.004	13.	1.027
4.	1.040	14.	1.027
5.	1.026	15.	1.028
6.	1.021	16.	1.020
7.	1.036	17.	1.014
8.	1.023	18.	1.028
9.	1.016	19.	1.036
10.	1.036	20.	1.012

Overall Isokinetic for TEST 1 : 1.025

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

GAS FLOW AND PARTICULATE MONITORING TEST 2

Job Number : M94-055
Client : LOUISIANA PACIFIC LTD.
Plant Location : DAWSON CREEK B.C.
Process : E.F.B. DRYER HYDROGEN CYANIDE
Pollution Control Permit : N/A

Monitoring Personnel : M. JOHNS / D. LAWRENCE
Test Procedure : WME. STD. TEST PROCEDURE USING
A LEAR SIEGLER PM-100

Date of Test : JUNE 20 1994
Test Start Time : 5:22 P.M.
Test Stop Time : 6:15 P.M.
On-line Sampling Time : 48 minutes

TEST RESULTS :

Gas Temperature	141 deg F	61 deg C
Moisture Content	25.3 %	25.3 %
Average Stack Gas Velocity	64.5 ft/sec	19.7 m/sec
Total Actual Gas Flow Rate	61,580 ACFM	--
Standard Gas Flow Rate Reference Conditions	37,577 SCFM	17.7 cubic meter/sec
Particulate concentration - Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter
Particulate Emission Rate	0.0 lbs/hr	0.0 kg/hr

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

TEST DATA - TEST 2

AS	Cross Section Area of Duct/Stack	15.90 square feet
PB	Barometric Pressure	27.80 inches Hg
PS	Pressure in Duct or Stack	27.85 inches Hg
Vm	Dry Gas Meter Volume	24.29 cubic feet
WE	Weight of Condensate Collected	156.0 grams
WSG	Weight of Moisture in Silica Gel	0.0 grams
WF	Weight of Filter Particulate	0.0000 grams
WFL	Weight of Cyclone Particulate	0.0000 grams
WW	Weight of Washings	0.0000 grams
NT	Total Number of Sample Points	16
CP	Type-S Pitot Tube Coefficient	0.8674
DN	Diameter of Nozzle Tip	0.1820 inches

GAS ANALYSIS (VOLUME %, DRY BASIS)

	Measured	Assumed
CO		
CO2	3.0	
O2	17.0	
N2		80.0

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

SAMPLING TEST DATA - TEST 2

SAMPLE POINT	VELOCITY	ORIFICE	DRY GAS METER		STACK GAS	GAS SAMPLE
	HEAD (in H2O)	PRESSURE (in H2O)	TEMP IN (deg F)	TEMP OUT (deg F)	TEMP (deg F)	VOLUME (cubic feet)
E-10	0.950	0.820	86	78	140	598.85
E-9	0.920	0.810	104	80	140	600.37
E-8	0.950	0.840	108	81	141	601.88
E-7	0.950	0.850	112	81	139	603.42
E-6	0.950	0.850	114	81	139	604.98
E-5	0.920	0.820	114	81	141	606.54
E-4	0.900	0.800	115	81	142	608.07
E-3	0.900	0.800	115	81	141	609.56
E-2	0.920	0.820	116	82	142	611.05
E-1	0.950	0.850	116	82	144	612.56
A-10	0.950	0.830	92	84	143	614.08
A-9	0.930	0.820	112	82	142	615.67
A-8	0.900	0.800	116	82	142	617.20
A-7	0.900	0.800	116	82	141	618.71
A-6	0.900	0.800	118	83	142	620.20
A-5	0.900	0.800	118	83	142	621.68
						623.14

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

Data for TEST 2 :

DELTA P:	0.9614	ACEM:	61580.15
DELTA M:	0.8194	SCEM:	37576.95
TMAVG:	556.1350	PB:	27.80
TS AVG:	601.3125	VM:	24.29
MC:	1.015	VM(CORR):	24.64
MD:	29.1600	PM:	27.2603
MS:	26.3320	PCON:	0.0000
VMSTD:	21.7855	CORR:	0.0000
BWD:	0.2534	ERAT:	0.0000
USAvg:	64.5494		

INDIVIDUAL ISOKINETICS - TEST 2

1.	1.076	9.	1.055
2.	1.067	10.	1.047
3.	1.067	11.	1.116
4.	1.075	12.	1.067
5.	1.073	13.	1.067
6.	1.071	14.	1.052
7.	1.054	15.	1.043
8.	1.054	16.	1.029

Overall Isokinetic for TEST 2 : 1.063

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

E.F.B. DRYER FORMALDEHYDE

Average of Air Emission Tests 1 TO 2

DATE: JUNE 21 1994

FIELD MEASUREMENT DATA :

Gas Temperature	143 deg F	62 deg C
Moisture Content (by volume)	23.7 %	23.7 %
Average Stack Gas Velocity	63.5 ft/sec	19.4 m/sec
Total Actual Gas Flow Rate	60,565 ACFM	--
Standard Gas Flow Rate Reference Conditions		
	37,695 SCFM	17.8 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0000 gr/SCF	0.00 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter

Neil McCall
ENVIRONMENTAL CONSULTANTS LTD.
N.R. McCALL & ASSOCIATES

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

E.F.B. DRYER FORMALDEHYDE

Summary of Air Emission Tests of JUNE 21 1994

TEST 1 :

Gas Temperature	143 deg F	62 deg C
Moisture Content (by volume)	22.5 %	22.5 %
Average Stack Gas Velocity	63.4 ft/sec	19.3 m/sec
Total Actual Gas Flow Rate	60,510 ACFM	--
Standard Gas Flow Rate Reference Conditions	36,194 SCFM	18.0 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0000 gr/SCF	0.00 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter

TEST 2 :

Gas Temperature	142 deg F	61 deg C
Moisture Content (by volume)	24.8 %	24.8 %
Average Stack Gas Velocity	63.5 ft/sec	19.4 m/sec
Total Actual Gas Flow Rate	60,620 ACFM	--
Standard Gas Flow Rate Reference Conditions	37,196 SCFM	17.6 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0000 gr/SCF	0.00 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

GAS FLOW AND PARTICULATE MONITORING TEST 1

Job Number : M94-055
Client : LOUISIANA PACIFIC LTD.
Plant Location : LAWSON CREEK B.C.
Process : E.F.B. DRYER FORMALDEHYDE
Pollution Control Permit : N/A

Monitoring Personnel : M. JOHNS / D. LAWRENCE
Test Procedure : WMB. STD. TEST PROCEDURE USING
A LEAR SIEGLER PM-100

Date of Test : JUNE 21 1994
Test Start Time : 9:16 A.M.
Test Stop Time : 10:22 A.M.
On-line Sampling Time : 60 minutes

TEST RESULTS :

Gas Temperature	143 deg F	62 deg C
Moisture Content	22.5 %	22.5 %
Average Stack Gas Velocity	63.4 ft/sec	19.3 m/sec
Total Actual Gas Flow Rate	60,510 ACFM	--
Standard Gas Flow Rate Reference Conditions		
	38,194 SCFM	18.0 cubic meter/sec
Particulate concentration - Dry Basis Corrected to 12% CO2	0.0000 gr/SCE	0.00 mg/cubic meter
Particulate Emission Rate	0.0 lbs/hr	0.0 kg/hr

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

TEST DATA - TEST 1

AS	Cross Section Area of Duct/Stack	15.90 square feet
PE	Barometric Pressure	27.80 inches Hg
PS	Pressure in Duct or Stack	27.85 inches Hg
VM	Dry Gas Meter Volume	29.84 cubic feet
WE	Weight of Condensate Collected	162.0 grams
WBG	Weight of Moisture in Silica Gel	0.0 grams
WF	Weight of Filter Particulate	0.0000 grams
WFL	Weight of Cyclone Particulate	0.0000 grams
WW	Weight of Washings	0.0000 grams
NT	Total Number of Sample Points	20
CP	Type-S Pitot Tube Coefficient	0.8648
DN	Diameter of Nozzle Tip	0.1820 inches

GAS ANALYSIS (VOLUME %, DRY BASIS)

	Measured	Assumed
CO		
CO2	3.0	
O2	17.0	
N2		80.0

W.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

SAMPLING TEST DATA - TEST 1

SAMPLE POINT	VELOCITY	ORIFICE	DRY GAS METER		STACK GAS	GAS SAMPLE
	HEAD (in H ₂ O)	PRESSURE (in H ₂ O)	TEMP IN (deg F)	TEMP OUT (deg F)	TEMP (deg F)	VOLUME (cubic feet)
A-10	0.900	0.810	104	104	142	623.28
A-9	0.850	0.750	104	90	146	624.69
A-8	0.850	0.750	106	88	145	626.12
A-7	0.900	0.790	108	86	145	627.55
A-6	0.950	0.840	112	86	144	629.03
A-5	0.950	0.840	114	86	145	630.55
A-4	0.950	0.840	116	86	144	632.09
A-3.	0.900	0.810	118	88	143	633.63
A-2	0.950	0.850	120	88	143	635.13
A-1	0.900	0.810	120	88	142	636.65
B-10	0.850	0.760	112	90	143	638.15
B-9	0.850	0.760	120	90	144	639.59
B-8	0.900	0.810	122	90	143	641.02
B-7	0.900	0.810	123	90	144	642.49
B-6	0.950	0.850	123	90	146	643.99
B-5	0.950	0.850	124	90	143	645.53
B-4	0.970	0.870	124	90	142	647.05
B-3	0.900	0.810	124	90	142	648.62
B-2	0.900	0.810	124	90	141	650.13
B-1	0.850	0.770	124	90	139	651.64
						653.12

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

Data for TEST 1 :

DELTA P:	0.9516	ACFM:	60510.23
DELTA H:	0.8095	SCFM:	38193.77
TMAVG:	563.3000	PE:	27.80
TS AVG:	603.3000	VM:	29.84
MC:	1.015	VM(CORR):	30.27
MD:	29.1600	PM:	27.8596
MS:	26.6470	PCON:	0.0000
VMSTD:	26.4216	CORR:	0.0000
BWD:	0.2252	ERAT:	0.0000
USAUG:	63.4279		

INDIVIDUAL ISOKINETICS - TEST 1

1.	0.960	11.	1.015
2.	1.017	12.	1.001
3.	1.017	13.	0.998
4.	1.023	14.	1.018
5.	1.018	15.	1.019
6.	1.030	16.	1.003
7.	1.028	17.	1.024
8.	1.024	18.	1.022
9.	1.008	19.	1.022
10.	1.021	20.	1.028

Overall Isokinetic for TEST 1 : 1.015

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

GAS FLOW AND PARTICULATE MONITORING TEST 2

Job Number : M94-055
Client : LOUISIANA PACIFIC LTD.
Plant Location : DAWSON CREEK B.C.
Process : E.F.B. DRYER FORMALDEHYDE
Pollution Control Permit : N/A

Monitoring Personnel : M. JOHNS / B. LAWRENCE
Test Procedure : WMB. STD. TEST PROCEDURE USING
A LEAR SIEGLER PM-100

Date of Test : JUNE 21 1994
Test Start Time : 11:13 A.M.
Test Stop Time : 12:20 P.M.
On-line Sampling Time : 60 minutes

TEST RESULTS :

Gas Temperature	142 deg F	61 deg C
Moisture Content	24.8 %	24.8 %
Average Stack Gas Velocity	63.5 ft/sec	19.4 m/sec
Total Actual Gas Flow Rate	60,620 ACFM	--
Standard Gas Flow Rate Reference Conditions		
	37,196 SCFM	17.6 cubic meter/sec
Particulate concentration - Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter
Particulate Emission Rate	0.0 lbs/hr	0.0 kg/hr

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

TEST DATA - TEST 2

AS	Cross Section Area of Duct/Stack	15.90 square feet
FB	Barometric Pressure	27.80 inches Hg
PS	Pressure in Duct or Stack	27.85 inches Hg
VM	Dry Gas Meter Volume	30.25 cubic feet
WE	Weight of Condensate Collected	186.0 grams
WSG	Weight of Moisture in Silica Gel	0.0 grams
WF	Weight of Filter Particulate	0.0000 grams
WEL	Weight of Cyclone Particulate	0.0000 grams
WW	Weight of Washings	0.0000 grams
NT	Total Number of Sample Points	20
CP	Type-S Pitot Tube Coefficient	0.8648
DN	Diameter of Nozzle Tip	0.1820 inches

GAS ANALYSIS (VOLUME %, DRY BASIS)

	Measured	Assumed
CO		
CO2	3.0	
O2	17.0	
N2		80.0

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

SAMPLING TEST DATA - TEST 2

SAMPLE POINT	VELOCITY	ORIFICE	DRY GAS METER		STACK GAS	GAS SAMPLE
	HEAD (in H ₂ O)	PRESSURE (in H ₂ O)	TEMP IN (deg F)	TEMP OUT (deg F)	TEMP (deg F)	VOLUME (cubic feet)
B-10	0.850	0.750	100	94	145	653.24
B-9	0.850	0.750	106	90	144	654.69
B-8	0.900	0.800	114	90	143	656.13
B-7	0.920	0.820	118	90	143	657.63
B-6	0.920	0.820	120	90	146	659.16
B-5	0.950	0.850	120	90	146	660.70
B-4	0.950	0.850	120	90	145	662.30
B-3	0.900	0.810	120	90	145	663.86
B-2	0.900	0.810	120	90	144	665.39
B-1	0.850	0.760	120	90	143	666.92
A-10	0.850	0.760	106	92	142	668.39
A-9	0.850	0.760	116	90	142	669.88
A-8	0.850	0.760	120	90	142	671.33
A-7	0.900	0.810	122	90	139	672.78
A-6	0.900	0.810	122	90	140	674.29
A-5	0.900	0.810	122	90	141	675.79
A-4	0.950	0.850	122	90	141	677.30
A-3	0.950	0.860	123	90	140	678.83
A-2	0.950	0.860	123	90	138	680.38
A-1	0.950	0.860	123	91	139	681.93
						683.49

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

Data for TEST 2 :

DELTA P:	0.9495	ACFM:	60620.20
DELTA H:	0.8080	SCFM:	37196.31
TMAVG:	564.1000	PB:	27.80
TS AVG:	602.4000	VM:	30.25
MC:	1.015	VM(CORR):	30.69
MD:	29.1600	PM:	27.8595
MS:	26.3933	PCGN:	0.0000
VMSTD:	26.7465	CORR:	0.0000
BWD:	0.2479	ERAT:	0.0000
USAVG:	63.5432		

INDIVIDUAL ISOKINETICS - TEST 2

1.	1.057	11.	1.080
2.	1.047	12.	1.043
3.	1.051	13.	1.039
4.	1.057	14.	1.048
5.	1.065	15.	1.041
6.	1.089	16.	1.049
7.	1.061	17.	1.035
8.	1.069	18.	1.047
9.	1.068	19.	1.045
10.	1.055	20.	1.052

Overall Isokinetic for TEST 2 : 1.055

Test Data-

BLENDER - BAGHOUSE

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

BAGHOUSE - H&I

Average of Air Emission Tests 1 TO 3

DATE: JUNE 20 1994

FIELD MEASUREMENT DATA :

Gas Temperature	82 deg F	28 deg C
Moisture Content (by volume)	0.0 %	0.0 %
Average Stack Gas Velocity	67.6 ft/sec	20.6 m/sec
Total Actual Gas Flow Rate	23,355 ACFM	--
Standard Gas Flow Rate Reference Conditions	19,989 SCFM	9.4 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0000 gr/SCF	0.00 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter

Neil McCall
ENVIRONMENTAL CONSULTANTS LTD.
N.R. McCALL & ASSOCIATES

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

BAGHOUSE - MDI

Summary of Air Emission Tests of JUNE 20 1994

TEST 1 :

Gas Temperature	82 deg F	28 deg C
Moisture Content (by volume)	0.0 %	0.0 %
Average Stack Gas Velocity	65.2 ft/sec	19.9 m/sec
Total Actual Gas Flow Rate	22,530 ACFM	--
Standard Gas Flow Rate Reference Conditions	19.297 SCFM	9.1 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0000 gr/SCF	0.00 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter

TEST 2 :

Gas Temperature	82 deg F	28 deg C
Moisture Content (by volume)	0.0 %	0.0 %
Average Stack Gas Velocity	70.0 ft/sec	21.3 m/sec
Total Actual Gas Flow Rate	24,180 ACFM	--
Standard Gas Flow Rate Reference Conditions	20,681 SCFM	9.8 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0000 gr/SCF	0.00 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

GAS FLOW AND PARTICULATE MONITORING TEST 1

Job Number : MS4-055
Client : LOUISIANA PACIFIC LTD.
Plant Location : DAWSON CREEK P.D.
Process : SAGHOUSE - MDI
Pollution Control Permit : N/A

Monitoring Personnel : N. McCALL/C. YEE
Test Procedure : WMB. STD. TEST PROCEDURE USING
A LEAR SIEGLER PM-100

Date of Test : JUNE 20 1994
Test Start Time : 1:45 P.M.
Test Stop Time : 2:55 P.M.
On-line Sampling Time : 64 minutes

TEST RESULTS :

Gas Temperature	82 deg F	28 deg C
Moisture Content	0.0 %	0.0 %
Average Stack Gas Velocity	65.2 ft/sec	19.9 m/sec
Total Actual Gas Flow Rate	22,530 ACFM	--
Standard Gas Flow Rate Reference Conditions	19,297 SCFM	9.1 cubic meter/sec
Particulate concentration - Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter
Particulate Emission Rate	0.0 lbs/hr	0.0 kg/hr

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

TEST DATA - TEST 1

AS	Cross Section Area of Duct/Stack	51.75 square feet
PB	Barometric Pressure	27.80 inches Hg
PS	Pressure in Duct or Stack	26.30 inches Hg
VM	Dry Gas Meter Volume	36.75 cubic feet
WE	Weight of Condensate Collected	0.0 grams
WSG	Weight of Moisture in Silica Gel	0.0 grams
WF	Weight of Filter Particulate	0.0000 grams
WFL	Weight of Cyclone Particulate	0.0000 grams
WW	Weight of Washings	0.0000 grams
NT	Total Number of Sample Points	16
CP	Type-S Pitot Tube Coefficient	0.8662
DN	Diameter of Nozzle Tip	0.1850 inches

GAS ANALYSIS (VOLUME %, DRY BASIS)

	Measured	Assumed
CO		
CO2	0.0	
O2	21.0	
N2		79.0

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

SAMPLING TEST DATA - TEST 1

SAMPLE POINT	VELOCITY	ORIFICE	DRY GAS METER		STACK GAS	GAS SAMPLE
	HEAD (in H ₂ O)	PRESSURE (in H ₂ O)	TEMP IN (deg F)	TEMP OUT (deg F)	TEMP (deg F)	VOLUME (cubic feet)
A-8	0.800	1.000	73	74	79	163.61
A-7	0.850	1.170	81	74	71	165.92
A-6	0.900	1.260	83	75	71	168.30
A-5	0.750	1.060	85	76	78	170.78
A-4	1.100	1.300	89	76	90	173.13
A-3	1.200	1.000	90	80	88	175.65
A-2	1.200	1.000	94	81	90	177.97
A-1	1.200	1.000	97	82	90	180.22
B-8	1.100	1.000	88	84	74	182.51
B-7	1.400	1.000	97	86	69	184.77
B-6	1.400	1.000	101	87	68	186.98
B-5	0.900	1.000	103	88	82	189.20
B-4	1.200	1.000	104	89	87	191.43
B-3	1.200	1.000	105	90	91	193.67
B-2	1.200	1.000	105	92	91	195.92
B-1	1.100	1.000	106	92	91	198.17
						200.36

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

Data for TEST 1 :

DELTA P:	1.0416	ACFM:	22530.00
DELTA H:	1.0494	SCFM:	19297.01
TMAVG:	548.5000	PB:	27.80
TS AVG:	541.8750	VM:	36.75
MC:	1.012	VM(CORR):	37.17
MD:	28.8400	PM:	27.8772
MS:	26.8400	PCON:	0.0000
UMSID:	33.3403	CORR:	0.0000
PWG:	0.0000	ERAT:	0.0000
USAUG:	65.1910		

INDIVIDUAL ISOKINETICS - TEST 1

1.	0.996	9.	0.812
2.	0.986	10.	0.693
3.	0.996	11.	0.693
4.	1.037	12.	0.877
5.	0.925	13.	0.765
6.	0.810	14.	0.770
7.	0.783	15.	0.768
8.	0.794	16.	0.781

Overall Isokinetic for TEST 1 : 0.833

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

GAS FLOW AND PARTICULATE MONITORING TEST 2

Job Number : M94-055
Client : LOUISIANA PACIFIC LTD.
Plant Location : DAWSON CREEK P.C.
Process : BAGHOUSE - MDI
Pollution Control Permit : N/A

Monitoring Personnel : N. McCALL/C. YEE
Test Procedure : WMB. STD. TEST PROCEDURE USING
A LEAR SIEGLER FM-100

Date of Test : JUNE 20 1994
Test Start Time : 4:20 P.M.
Test Stop Time : 5:30 P.M.
On-line Sampling Time : 64 minutes

TEST RESULTS :

Gas Temperature	83 deg F	28 deg C
Moisture Content	0.0 %	0.0 %
Average Stack Gas Velocity	70.0 ft/sec	21.3 m/sec
Total Actual Gas Flow Rate	24,180 ACFM	--
Standard Gas Flow Rate Reference Conditions	20.681 SCFM	9.8 cubic meter/sec
Particulate concentration - Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter
Particulate Emission Rate	0.0 lbs/hr	0.0 kg/hr

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK S.C.
DAWSON CREEK S.C.

TEST DATA - TEST 2

AS	Cross Section Area of Duct/Stack	5.75 square feet
PR	Barometric Pressure	27.80 inches Hg
PS	Pressure in Duct or Stack	26.30 inches Hg
VM	Dry Gas Meter Volume	34.61 cubic feet
WE	Weight of Condensate Collected	0.0 grams
WSG	Weight of Moisture in Silica Gel	0.0 grams
WF	Weight of Filter Particulate	0.0000 grams
WFL	Weight of Cyclone Particulate	0.0000 grams
WW	Weight of Washings	0.0000 grams
NT	Total Number of Sample Points	16
CP	Type-S Pitot Tube Coefficient	0.8667
DN	Diameter of Nozzle Tip	0.1850 inches

GAS ANALYSIS (VOLUME %, DRY BASIS)

	Measured	Assumed
CO		
CO2	0.0	
O2	21.0	
N2		79.0

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

SAMPLING TEST DATA - TEST 2

SAMPLE POINT	VELOCITY	ORIFICE PRESSURE (in H ₂ O)	DRY GAS METER		STACK GAS TEMP (deg F)	GAS SAMPLE VOLUME (cubic feet)
	HEAD (in H ₂ O)		TEMP IN (deg F)	TEMP OUT (deg F)		
A-8	1.200	1.000	82	76	68	200.71
A-7	1.200	1.000	83	76	66	202.71
A-6	1.200	1.000	86	78	69	204.91
A-5	1.200	1.000	90	79	85	207.10
A-4	1.300	1.000	93	80	86	209.25
A-3	1.300	1.000	95	82	91	211.42
A-2	1.250	1.000	97	83	91	213.56
A-1	1.300	1.000	99	85	90	215.75
B-8	1.200	1.000	88	85	89	217.92
B-7	1.200	1.000	98	87	68	220.10
B-6	1.200	1.000	103	88	70	222.30
B-5	1.200	1.000	104	89	82	224.44
B-4	1.300	1.000	105	90	92	226.63
B-3	1.300	1.000	106	91	91	228.82
B-2	1.300	1.000	106	92	92	230.99
B-1	1.300	1.000	106	92	92	233.17
						235.32

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

Data for TEST 2 :

DELTA P:	1.1164	ACFM:	24179.80
DELTA H:	1.0000	SCFM:	20681.45
TMAVG:	550.4375	PS:	27.80
TS AVG:	542.6250	VM:	34.61
MC:	1.012	VM(CORR):	35.01
MB:	28.8400	PM:	27.8736
MS:	28.8400	PCOM:	0.0000
UMSTD:	31.2842	CURR:	0.0000
PWD:	0.0000	ERAT:	0.0000
USAUG:	69.9647		

INDIVIDUAL ISOKINETICS - TEST 2

1.	0.692	9.	0.759
2.	0.760	10.	0.743
3.	0.755	11.	0.720
4.	0.749	12.	0.744
5.	0.724	13.	0.720
6.	0.715	14.	0.713
7.	0.744	15.	0.715
8.	0.719	16.	0.705

Overall Isokinetic for TEST 2 : 0.729

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

SAGHOUSE - PHENOLS

Average of Air Emission Tests 1 TO 2

DATE: JUNE 21 1994

FIELD MEASUREMENT DATA :

Gas Temperature	84 deg F	29 deg C
Moisture Content (by volume)	1.0 %	1.0 %
Average Stack Gas Velocity	73.9 ft/sec	22.2 m/sec
Total Actual Gas Flow Rate	25,184 ACFM	--
Standard Gas Flow Rate Reference Conditions		
	21,261 SCFM	10.0 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0000 gr/SCF	0.00 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter

Neil McCall
ENVIRONMENTAL CONSULTANTS LTD.
N.R. McCALL & ASSOCIATES

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

SAGHOUSE - PHENOLS

Summary of Air Emission Tests of JUNE 21 1994

TEST 1 :

Gas Temperature	83 deg F	28 deg C
Moisture Content (by volume)	1.3 %	1.2 %
Average Stack Gas Velocity	72.1 ft/sec	22.0 m/sec
Total Actual Gas Flow Rate	24,908 ACFM	--
Standard Gas Flow Rate Reference Conditions	21,050 SCFM	9.9 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0000 gr/SCE	0.00 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0000 gr/SCE	0.00 mg/cubic meter

TEST 2 :

Gas Temperature	85 deg F	30 deg C
Moisture Content (by volume)	0.9 %	0.9 %
Average Stack Gas Velocity	73.7 ft/sec	22.5 m/sec
Total Actual Gas Flow Rate	25,460 ACFM	--
Standard Gas Flow Rate Reference Conditions	21,473 SCFM	10.1 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0000 gr/SCE	0.00 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0000 gr/SCE	0.00 mg/cubic meter

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

GAS FLOW AND PARTICULATE MONITORING TEST 1

Job Number : M94-055
Client : LOUISIANA PACIFIC LTD.
Plant Location : DAWSON CREEK S.C.
Process : BAGHOUSE - PHENOLS
Pollution Control Permit : N/A

Monitoring Personnel : N. McCALL/C. YEE
Test Procedure : WMB. STD. TEST PROCEDURE USING
A LEAR SIEGLER PM-100

Date of Test : JUNE 21 1994
Test Start Time : 10:10 A.M.
Test Stop Time : 11:24 A.M.
On-line Sampling Time : 64 minutes

TEST RESULTS :

Gas Temperature	83 deg F	29 deg C
Moisture Content	1.2 %	1.2 %
Average Stack Gas Velocity	72.1 ft/sec	22.0 m/sec
Total Actual Gas Flow Rate	24,908 ACFM	--
Standard Gas Flow Rate Reference Conditions	21,050 SCFM	9.9 cubic meter/sec
Particulate concentration - Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter
Particulate Emission Rate	0.0 lbs/hr	0.0 kg/hr

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK S.C.
DAWSON CREEK B.C.

TEST DATA - TEST 1

AS	Cross Section Area of Duct/Stack	5.76 square feet
PS	Barometric Pressure	27.80 inches Hg
PG	Pressure in Duct or Stack	26.20 inches Hg
VM	Dry Gas Meter Volume	22.01 cubic feet
WE	Weight of Condensate Collected	3.0 grams
WGG	Weight of Moisture in Silica Gel	0.0 grams
WF	Weight of Filter Particulate	0.0000 grams
WFL	Weight of Cyclone Particulate	0.0000 grams
WW	Weight of Washings	0.0000 grams
NT	Total Number of Sample Points	16
CP	Type-S Pitot Tube Coefficient	0.8667
DN	Diameter of Nozzle Tip	0.1250 inches

GAS ANALYSIS (VOLUME %, DRY BASIS)

	Measured	Assumed
CO		
CO2	0.0	
O2	21.0	
N2		79.0

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

SAMPLING TEST DATA - TEST 1

SAMPLE POINT	VELOCITY	ORIFICE	DRY GAS METER		STACK GAS	GAS SAMPLE
	HEAD (in H ₂ O)	PRESSURE (in H ₂ O)	TEMP IN (deg F)	TEMP OUT (deg F)	TEMP (deg F)	VOLUME (cubic feet)
A-8	1.200	0.350	77	74	64	235.93
A-7	1.200	0.350	80	74	64	237.22
A-6	1.200	0.350	84	76	64	238.56
A-5	1.200	0.350	88	76	64	239.82
A-4	1.200	0.370	91	78	60	241.11
A-3	1.200	0.370	89	82	97	242.42
A-2	1.300	0.370	93	82	98	243.62
A-1	1.300	0.370	95	83	91	245.04
B-8	1.300	0.370	86	83	71	246.41
B-7	1.300	0.370	99	86	66	247.80
B-6	1.400	0.400	96	88	84	249.17
B-5	1.400	0.400	100	89	87	250.52
B-4	1.400	0.410	102	89	90	252.02
B-3	1.500	0.440	102	90	93	253.46
B-2	1.500	0.440	102	91	92	254.98
B-1	1.500	0.440	102	91	89	256.49
						258.00

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

Data for TEST 1 :

DELTA P:	1.1473	ACFM:	24908.35
DELTA H:	0.3844	SCFM:	21049.61
THAVG:	548.0625	PS:	27.80
TS AVG:	542.7500	VM:	22.01
MC:	1.012	VM(CORR):	22.26
MD:	28.2400	PM:	27.8283
MS:	28.7128	PCOR:	0.0000
VMSTD:	19.9487	CORR:	0.0000
BWG:	0.0117	ERAT:	0.0000
USAVG:	72.0728		

INDIVIDUAL ISOKINETICS - TEST 1

1.	0.948	9.	1.013
2.	1.024	10.	0.980
3.	0.958	11.	0.947
4.	0.995	12.	1.050
5.	1.012	13.	1.009
6.	0.931	14.	1.031
7.	1.055	15.	1.023
8.	1.009	16.	1.020

Overall Isokinetic for TEST 1 : 1.001

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

GAS FLOW AND PARTICULATE MONITORING TEST 2

Job Number : M94-055
Client : LOUISIANA PACIFIC LTD.
Plant Location : DAWSON CREEK B.C.
Process : BARNHOUSE - PHENOLS
Pollution Control Permit : N/A

Monitoring Personnel : M. McCALL/C. YEE
Test Procedure : WMS. STD. TEST PROCEDURE USING
A LEAR SIEGLER PM-100

Date of Test : JUNE 21 1994
Test Start Time : 12:59 P.M.
Test Stop Time : 2:07 P.M.
On-line Sampling Time : 64 minutes

TEST RESULTS :

Gas Temperature	95 deg F	30 deg C
Moisture Content	0.9 %	0.9 %
Average Stack Gas Velocity	73.7 ft/sec	22.5 m/sec
Total Actual Gas Flow Rate	25,460 ACFM	--
Standard Gas Flow Rate Reference Conditions		
	21,473 SCFM	10.1 cubic meter/sec
Particulate concentration - Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter
Particulate Emission Rate	0.0 lbs/hr	0.0 kg/hr

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

TEST DATA - TEST 2

AS	Cross Section Area of Duct/Stack	5.76	square feet
PB	Barometric Pressure	27.80	inches Hg
PS	Pressure in Duct or Stack	26.30	inches Hg
VM	Dry Gas Meter Volume	22.76	cubic feet
WE	Weight of Condensate Collected	4.0	grams
WSG	Weight of Moisture in Silica Gel	0.0	grams
WF	Weight of Filter Particulate	0.0000	grams
WEL	Weight of Cyclone Particulate	0.0000	grams
WW	Weight of Washings	0.0000	grams
NT	Total Number of Sample Points	16	
CP	Type-S Pitot Tube Coefficient	0.8667	
DN	Diameter of Nozzle Tip	0.1250	inches

GAS ANALYSIS (VOLUME %, DRY BASIS)

	Measured	Assumed
CO		
CO2	0.0	
O2	21.0	
N2		79.0

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

SAMPLING TEST DATA - TEST 2

SAMPLE POINT	VELOCITY	ORIFICE	DRY GAS METER		STACK GAS	GAS SAMPLE
	HEAD (in H ₂ O)	PRESSURE (in H ₂ O)	TEMP IN (deg F)	TEMP OUT (deg F)	TEMP (deg F)	VOLUME (cubic feet)
A-8	1.300	0.370	75	75	75	258.18
A-7	1.300	0.370	78	74	77	259.56
A-6	1.300	0.430	83	74	75	260.95
A-5	1.300	0.320	86	75	88	262.45
A-4	1.400	0.400	89	76	93	253.87
A-3	1.400	0.400	92	78	93	265.30
A-2	1.400	0.400	94	79	94	266.75
A-1	1.400	0.400	96	81	93	268.18
B-8	1.400	0.400	87	82	72	269.58
B-7	1.400	0.400	97	84	72	270.97
B-6	1.500	0.430	98	85	73	272.39
B-5	1.200	0.340	97	85	86	273.91
B-4	1.350	0.380	97	86	93	275.26
B-3	1.400	0.400	96	87	94	276.65
B-2	1.350	0.380	98	87	94	278.08
B-1	1.350	0.380	98	87	93	279.53
						280.94

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

Data for TEST 2 :

DELTA P:	1.1709	ACFM:	25460.44
DELTA H:	0.3875	SCFM:	21472.82
TMAVG:	546.1250	PS:	27.80
TS AVG:	545.3125	VM:	22.76
MC:	1.012	VM(CORR):	23.02
MD:	28.3400	PM:	27.3265
MS:	28.7417	PCGN:	0.0000
VMSTD:	20.7019	CORR:	0.0000
BWD:	0.0091	ERAT:	0.0000
USAVG:	73.6702		

INDIVIDUAL ISOKINETICS - TEST 2

1.	1.026	9.	0.975
2.	1.033	10.	0.986
3.	1.031	11.	1.018
4.	1.057	12.	1.024
5.	1.027	13.	1.000
6.	1.036	14.	1.011
7.	1.020	15.	1.042
8.	0.994	16.	1.012

Overall Isokinetic for TEST 2 : 1.018

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
CHETWYND B.C.
CHETWYND B.C.

BAGHOUSE - FORMALDEHYDE

Average of Air Emission Tests 1 TO 3

DATE: JUNE 21 1994

FIELD MEASUREMENT DATA :

Gas Temperature	93 deg F	34 deg C
Moisture Content (by volume)	1.2 %	1.2 %
Average Stack Gas Velocity	72.6 ft/sec	22.1 m/sec
Total Actual Gas Flow Rate	25,091 ACFM	--
Standard Gas Flow Rate Reference Conditions	20,820 SCFM	9.8 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0000 gr/SCF	0.00 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter

Neil McCall
ENVIRONMENTAL CONSULTANTS LTD.
N.R. McCALL & ASSOCIATES

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
CHETWYND B.C.
CHETWYND B.C.

BAGHOUSE - FORMALDEHYDE

Summary of Air Emission Tests of JUNE 21 1994

TEST 1 :

Gas Temperature	92 deg F	34 deg C
Moisture Content (by volume)	0.0 %	0.0 %
Average Stack Gas Velocity	72.4 ft/sec	22.1 m/sec
Total Actual Gas Flow Rate	25,015 ACFM	--
Standard Gas Flow Rate Reference Conditions	21,026 SCFM	9.9 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0000 gr/SCF	0.00 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter

TEST 2 :

Gas Temperature	94 deg F	34 deg C
Moisture Content (by volume)	2.3 %	2.3 %
Average Stack Gas Velocity	72.8 ft/sec	22.2 m/sec
Total Actual Gas Flow Rate	25,166 ACFM	--
Standard Gas Flow Rate Reference Conditions	20,614 SCFM	9.7 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0000 gr/SCF	0.00 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter

W.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

GAS FLOW AND PARTICULATE MONITORING TEST 1

Job Number : M94-055
Client : LOUISIANA PACIFIC LTD.
Plant Location : CHETWYND S.C.
Process : BAGHOUSE - FORMALDEHYDE
Pollution Control Permit : N/A

Monitoring Personnel : N. McCALL C. YEE
Test Procedure : WME. STD. TEST PROCEDURE USING
 A LEAK SIEGLER FM-100

Date of Test : JUNE 21 1994
Test Start Time : 2:55 P.M.
Test Stop Time : 4:06 P.M.
On-line Sampling Time : 64 minutes

TEST RESULTS :

Gas Temperature	92 deg F	34 deg C
Moisture Content	0.0 %	0.0 %
Average Stack Gas Velocity	72.4 ft/sec	22.1 m/sec
Total Actual Gas Flow Rate	25,015 ACFM	--
Standard Gas Flow Rate Reference Conditions		
	21,026 SCFM	9.9 cubic meter/sec
Particulate concentration - Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter
Particulate Emission Rate	0.0 lbs/hr	0.0 kg/hr

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
CHETWYND B.C.
CHETWYND B.C.

TEST DATA - TEST 1

AS	Cross Section Area of Duct/Stack	5.76 square feet
PE	Barometric Pressure	27.82 inches Hg
PS	Pressure in Duct or Stack	26.31 inches Hg
VM	Dry Gas Meter Volume	22.32 cubic feet
WE	Weight of Condensate Collected	0.0 grams
WSS	Weight of Moisture in Silica Gel	0.0 grams
WF	Weight of Filter Particulate	0.0000 grams
WFL	Weight of Cyclone Particulate	0.0000 grams
WW	Weight of Washings	0.0000 grams
NT	Total Number of Sample Points	16
CF	Type-S Pitot Tube Coefficient	0.8667
DN	Diameter of Nozzle Tip	0.1250 inches

GAS ANALYSIS (VOLUME %, DRY BASIS)

	Measured	Assumed
CO		
CO2	0.0	
O2	21.0	
N2		79.0

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

SAMPLING TEST DATA - TEST 1

SAMPLE POINT	VELOCITY	ORIFICE PRESSURE (in H ₂ O)	DRY GAS METER		STACK GAS TEMP (deg F)	GAS SAMPLE VOLUME (cubic feet)
	HEAD (in H ₂ O)		TEMP IN (deg F)	TEMP OUT (deg F)		
A-8	1.300	0.370	75	75	80	381.11
A-7	1.300	0.370	80	75	80	382.54
A-6	1.500	0.430	85	75	79	383.96
A-5	1.300	0.370	88	75	91	385.51
A-4	1.400	0.400	86	77	101	386.94
A-3	1.300	0.370	82	78	102	388.44
A-2	1.300	0.370	94	79	101	389.83
A-1	1.300	0.370	96	81	113	391.25
B-8	1.300	0.370	88	81	79	392.71
B-7	1.300	0.370	98	83	76	394.09
B-6	1.300	0.370	100	84	81	395.51
B-5	1.100	0.350	102	85	90	396.91
B-4	1.350	0.390	102	86	101	398.27
B-3	1.350	0.380	102	87	101	399.73
B-2	1.300	0.370	102	87	102	401.15
B-1	1.300	0.370	102	88	101	402.54
						403.93

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

Data for TEST 1 :

DELTA P:	1.1452	ACFM:	25015.19
DELTA H:	0.3762	SCFM:	21026.30
THAVG:	547.1250	FB:	27.82
TS AVG:	532.3750	VM:	22.82
MC:	1.012	VM(CORR):	23.05
MD:	28.8400	PM:	27.8477
ME:	28.8400	PCDN:	0.0000
VMSTD:	20.7328	CORR:	0.0000
BWD:	0.0000	ERAT:	0.0000
USAVG:	72.3819		

INDIVIDUAL ISOKINETICS - TEST 1

1.	1.060	9.	1.005
2.	1.063	10.	1.020
3.	1.046	11.	1.007
4.	1.058	12.	1.059
5.	1.079	13.	1.046
6.	1.032	14.	1.016
7.	1.051	15.	1.015
8.	1.088	16.	1.013

Overall Isokinetic for TEST 1 : 1.041

W.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

GAS FLOW AND PARTICULATE MONITORING TEST 2

Job Number : M94-055
Client : LOUISIANA PACIFIC LTD.
Plant Location : CHETWYND S.C.
Process : BAGHOUSE - FORMALDEHYDE
Pollution Control Permit : N/A

Monitoring Personnel : N. McCALL C. YEE
Test Procedure : WNE. STD. TEST PROCEDURE USING
 A LEAR SIEGLER PM-100

Date of Test : JUNE 21 1994
Test Start Time : 4:45 P.M.
Test Stop Time : 5:55 P.M.
On-line Sampling Time : 64 minutes

TEST RESULTS :

Gas Temperature	94 deg F	34 deg C
Moisture Content	2.3 %	2.3 %
Average Stack Gas Velocity	72.8 ft/sec	22.2 m/sec
Total Actual Gas Flow Rate	25,166 ACFM	--
Standard Gas Flow Rate Reference Conditions		
	20,614 SCFM	9.7 cubic meter/sec
Particulate concentration - Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter
Particulate Emission Rate	0.0 lbs/hr	0.0 kg/hr

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
CHETWYND S.C.
CHETWYND B.C.

TEST DATA - TEST 2

AS	Cross Section Area of Duct/Stack	5.76 square feet
PB	Barometric Pressure	27.82 inches Hg
PS	Pressure in Duct or Stack	26.31 inches Hg
VM	Dry Gas Meter Volume	22.06 cubic feet
WE	Weight of Condensate Collected	10.0 grams
WSG	Weight of Moisture in Silica Gel	0.0 grams
WF	Weight of Filter Particulate	0.0000 grams
WPL	Weight of Cyclone Particulate	0.0000 grams
WW	Weight of Washings	0.0000 grams
NT	Total Number of Sample Points	16
CP	Type-S Pitot Tube Coefficient	0.8667
DN	Diameter of Nozzle Tip	0.1250 inches

GAS ANALYSIS (VOLUME %, DRY BASIS)

	Measured	Assumed
CO		
CO2	0.0	
O2	21.0	
N2		79.0

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

SAMPLING TEST DATA - TEST 2

SAMPLE POINT	VELOCITY	ORIFICE	DRY GAS METER		STACK GAS	GAS SAMPLE
	HEAD (in H2O)	PRESSURE (in H2O)	TEMP IN (deg F)	TEMP OUT (deg F)	TEMP (deg F)	VOLUME (cubic feet)
A-8	1.300	0.360	77	77	85	304.13
A-7	1.300	0.360	82	76	86	305.55
A-6	1.300	0.360	86	77	82	308.98
A-5	1.300	0.360	89	77	91	308.40
A-4	1.350	0.380	91	79	100	309.78
A-3	1.300	0.370	93	79	101	311.17
A-2	1.300	0.370	95	80	103	312.55
A-1	1.300	0.370	97	81	101	313.93
B-8	1.300	0.370	87	82	81	315.30
B-7	1.300	0.370	99	84	80	316.67
B-6	1.300	0.370	101	85	81	318.02
B-5	1.300	0.370	102	86	101	319.39
B-4	1.300	0.370	103	86	101	320.74
B-3	1.350	0.380	104	88	102	322.11
B-2	1.350	0.380	105	90	101	323.50
B-1	1.350	0.380	107	91	102	324.83
						326.19

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

Data for TEST 2 :

DELTA P:	1.1456	ACFM:	25166.05
DELTA H:	0.3790	SCFM:	20614.04
TMAVG:	549.6875	PS:	27.82
TS AVG:	553.6875	VM:	22.06
MC:	1.012	VM(CORR):	22.31
MD:	28.9400	PM:	27.8472
MS:	23.5389	PCON:	0.0000
VMSTD:	19.9849	CORR:	0.0000
RWG:	0.0232	ERAT:	0.0000
USAVG:	72.8184		

INDIVIDUAL ISCKINETICS - TEST 2

1.	1.074	9.	1.018
2.	1.079	10.	0.990
3.	1.063	11.	1.003
4.	1.039	12.	1.004
5.	1.032	13.	1.016
6.	1.042	14.	1.012
7.	1.041	15.	0.964
8.	1.028	16.	0.985

Overall Isckinetic for TEST 2 : 1.024

Test Data-

PRESS VENT

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

PRESS VENT - FORMALDEHYDE

Average of Air Emission Tests 1 TO 2

DATE: JUNE 21 1994

FIELD MEASUREMENT DATA :

Gas Temperature	110 deg F	44 deg C
Moisture Content (by volume)	0.0 %	0.0 %
Average Stack Gas Velocity	42.4 ft/sec	12.9 m/sec
Total Actual Gas Flow Rate	58,464 ACFM	--
Standard Gas Flow Rate Reference Conditions		
	50.367 SCFM	23.8 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0000 gr/SCF	0.00 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter

Neil McCall
ENVIRONMENTAL CONSULTANTS LTD.
N.R. McCALL & ASSOCIATES

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

PRESS VENT - FORMALDEHYDE

Summary of Air Emission Tests of JUNE 21 1994

TEST 1 :

Gas Temperature	110 deg F	43 deg C
Moisture Content (by volume)	0.0 %	0.0 %
Average Stack Gas Velocity	42.4 ft/sec	12.9 m/sec
Total Actual Gas Flow Rate	58,466 ACFM	--
Standard Gas Flow Rate Reference Conditions	50,407 SCFM	23.8 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0000 gr/SCF	0.00 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter

TEST 2 :

Gas Temperature	111 deg F	44 deg C
Moisture Content (by volume)	0.0 %	0.0 %
Average Stack Gas Velocity	42.4 ft/sec	12.9 m/sec
Total Actual Gas Flow Rate	58,461 ACFM	--
Standard Gas flow Rate Reference Conditions	50,327 SCFM	23.7 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0000 gr/SCF	0.00 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

GAS FLOW AND PARTICULATE MONITORING TEST 1

Job Number : M94-055
Client : LOUISIANA PACIFIC LTD.
Plant Location : DAWSON CREEK R.C.
Process : PRESS VENT - FORMALDEHYDE
Pollution Control Permit : N/A

Monitoring Personnel : M. JOHNS / D. LAWRENCE
Test Procedure : WMB. STD. TEST PROCEDURE USING
A LEAR SIEGLER PM-100

Date of Test : JUNE 21 1994
Test Start Time : 3:25 P.M.
Test Stop Time : 4:39 P.M.
On-line Sampling Time : 60 minutes

TEST RESULTS :

Gas Temperature	110 deg F	43 deg C
Moisture Content	0.0 %	0.0 %
Average Stack Gas Velocity	42.4 ft/sec	12.9 m/sec
Total Actual Gas Flow Rate	58,466 ACFM	--
Standard Gas Flow Rate Reference Conditions	50,407 SCFM	23.8 cubic meter/sec
Particulate concentration - Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter
Particulate Emission Rate	0.0 lbs/hr	0.0 kg/hr

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

TEST DATA - TEST 1

AS	Cross Section Area of Duct/Stack	22.96 square feet
PB	Barometric Pressure	27.82 inches Hg
PS	Pressure in Duct or Stack	27.85 inches Hg
VM	Dry Gas Meter Volume	27.02 cubic feet
WE	Weight of Condensate Collected	0.0 grams
WSG	Weight of Moisture in Silica Gel	0.0 grams
WF	Weight of Filter Particulate	0.0000 grams
WFL	Weight of Cyclone Particulate	0.0000 grams
WW	Weight of Washings	0.0000 grams
NT	Total Number of Sample Points	20
CP	Type-S Pitot Tube Coefficient	0.8638
DN	Diameter of Nozzle Tip	0.1820 inches

GAS ANALYSIS (VOLUME %, DRY BASIS)

	Measured	Assumed
CO		
CO2	0.0	
O2	21.0	
N2		79.0

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

SAMPLING TEST DATA - TEST 1

SAMPLE POINT	VELOCITY	ORIFICE	DRY GAS METER		STACK GAS	GAS SAMPLE
	HEAD (in H ₂ O)	PRESSURE (in H ₂ O)	TEMP IN (deg F)	TEMP OUT (deg F)	TEMP (deg F)	VOLUME (cubic feet)
A-5	0.480	0.620	88	84	107	683.72
A-4	0.500	0.650	100	82	110	685.05
A-3	0.500	0.650	104	82	111	686.43
A-2	0.450	0.580	108	82	112	687.80
A-1	0.350	0.460	112	84	109	689.10
B-5	0.620	0.820	102	88	107	690.25
B-4	0.620	0.830	114	88	108	691.82
B-3	0.630	0.840	116	88	118	693.38
B-2	0.580	0.760	118	88	122	694.93
B-1	0.500	0.670	120	88	109	696.42
C-5	0.630	0.830	104	90	109	697.84
C-4	0.400	0.530	118	92	108	699.39
C-3	0.400	0.540	122	92	105	700.74
C-2	0.400	0.540	122	92	106	702.07
C-1	0.300	0.410	124	93	106	703.36
D-5	0.400	0.530	112	92	106	704.48
D-4	0.400	0.530	120	92	111	705.73
D-3	0.350	0.460	122	92	115	706.98
D-2	0.450	0.600	124	92	115	708.13
D-1	0.450	0.610	124	92	107	709.42
						710.74

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

Data for TEST 1 :

DELTA P:	0.6822	ACFM:	58466.22
DELTA H:	0.6230	SCFM:	50406.85
TMAVG:	561.1750	PB:	27.82
TS AVG:	570.0500	VM:	27.02
MC:	1.015	VM(CORR):	27.41
MD:	28.8400	PM:	27.9658
MS:	28.8400	PCON:	0.0000
VMSTD:	24.0207	CORR:	0.0000
BWD:	0.0000	ERAT:	0.0000
USAVG:	42.4405		

INDIVIDUAL ISOKINETICS - TEST 1

1.	1.003	11.	1.003
2.	1.013	12.	1.079
3.	1.003	13.	1.056
4.	1.001	14.	1.025
5.	0.995	15.	1.025
6.	1.026	16.	1.002
7.	1.009	17.	1.000
8.	1.002	18.	0.985
9.	1.005	19.	0.973
10.	1.018	20.	0.988

Overall Isokinetic for TEST 1 : 1.010

H.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

GAS FLOW AND PARTICULATE MONITORING TEST 2

Job Number : M94-055
Client : LOUISIANA PACIFIC LTD.
Plant Location : DAWSON CREEK P.C.
Process : PRESS VENT - FORMALDEHYDE
Pollution Control Permit : N/A

Monitoring Personnel : M. JOHNS / D. LAWRENCE
Test Procedure : WMB. STD. TEST PROCEDURE USING
A LEAR SIEGLER PM-100

Date of Test : JUNE 21 1994
Test Start Time : 5:14 P.M.
Test Stop Time : 6:30 P.M.
On-line Sampling Time : 60 minutes

TEST RESULTS :

Gas Temperature	111 deg F	44 deg C
Moisture Content	0.0 %	0.0 %
Average Stack Gas Velocity	42.4 ft/sec	12.9 m/sec
Total Actual Gas Flow Rate	58,461 ACFM	--
Standard Gas Flow Rate Reference Conditions	50,327 SCFM	23.7 cubic meter/sec
Particulate concentration - Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter
Particulate Emission Rate	0.0 lbs/hr	0.0 kg/hr

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

TEST DATA - TEST 2

AS	Cross Section Area of Duct/Stack	22.96 square feet
PB	Barometric Pressure	27.82 inches Hg
PS	Pressure in Duct or Stack	27.95 inches Hg
VM	Dry Gas Meter Volume	27.13 cubic feet
WE	Weight of Condensate Collected	0.0 grams
WSG	Weight of Moisture in Silica Gel	0.0 grams
WF	Weight of Filter Particulate	0.0000 grams
WEL	Weight of Cyclone Particulate	0.0000 grams
WW	Weight of Washings	0.0000 grams
NT	Total Number of Sample Points	20
CP	Type-S Pitot Tube Coefficient	0.8638
DN	Diameter of Nozzle Tip	0.1820 inches

GAS ANALYSIS (VOLUME %, DRY BASIS)

	Measured	Assumed
CO		
CO2	0.0	
O2	21.0	
N2		79.0

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

SAMPLING TEST DATA - TEST 3

SAMPLE POINT	VELOCITY	ORIFICE	DRY GAS METER		STACK GAS	GAS SAMPLE
	HEAD (in H ₂ O)	PRESSURE (in H ₂ O)	TEMP IN (deg F)	TEMP OUT (deg F)	TEMP (deg F)	VOLUME (cubic feet)
D-5	0.400	0.820	90	88	118	710.99
D-4	0.400	0.530	106	88	118	712.23
D-3	0.420	0.570	112	88	108	713.49
D-2	0.450	0.610	114	88	109	714.74
D-1	0.450	0.610	118	88	104	716.06
C-5	0.500	0.670	104	88	106	717.39
C-4	0.500	0.670	112	90	112	718.80
C-3	0.400	0.530	118	90	112	720.20
C-2	0.400	0.540	120	90	115	721.45
C-1	0.300	0.410	122	90	107	722.69
B-5	0.620	0.820	106	88	115	723.75
B-4	0.620	0.820	118	90	120	725.30
B-3	0.580	0.790	120	90	111	726.85
B-2	0.580	0.790	121	90	109	728.39
B-1	0.400	0.550	122	92	107	729.88
A-5	0.550	0.730	106	88	118	731.19
A-4	0.400	0.540	110	90	109	732.66
A-3	0.500	0.680	120	90	107	733.96
A-2	0.500	0.680	122	90	107	735.37
A-1	0.400	0.540	122	90	106	736.79
						738.12

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

Data for TEST 2 :

DELTA P:	0.6816	ACFM:	58461.21
DELTA H:	0.6300	SCFM:	50327.49
TMAVG:	561.6750	PH:	27.82
TS AVG:	570.9000	VM:	27.13
MC:	1.015	VM(CORR):	27.52
MD:	38.8400	PM:	27.8664
MS:	38.8400	PCON:	0.0000
VMSTB:	24.0974	CORR:	0.0000
BWD:	0.0000	ERAT:	0.0000
USAvg:	42.4370		

INDIVIDUAL ISOKINETICS - TEST 2

1.	1.030	11.	1.016
2.	1.030	12.	1.008
3.	0.983	13.	1.025
4.	1.003	14.	0.989
5.	1.002	15.	1.042
6.	1.022	16.	1.025
7.	1.012	17.	1.049
8.	1.004	18.	1.007
9.	0.997	19.	1.012
10.	0.975	20.	1.059

Overall Isokinetic for TEST 2 : 1.014

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK S.D.
DAWSON CREEK S.D.

PRESS VENT - M01

Average of Air Emission Tests 1 TO 2

DATE: JUNE 22 1994

FIELD MEASUREMENT DATA :

Gas Temperature	117 deg F	47 deg C
Moisture Content (by volume)	2.5 %	2.5 %
Average Stack Gas Velocity	40.7 ft/sec	12.4 m/sec
Total Actual Gas Flow Rate	56,130 ACFM	--
Standard Gas Flow Rate Reference Conditions		
	46,341 SCFM	31.9 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0000 gr/SCF	0.00 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter

Neil McCall
ENVIRONMENTAL CONSULTANTS LTD.
N.R. McCALL & ASSOCIATES

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK P.C.
DAWSON CREEK B.C.

PROCESS VENT - HBI

Summary of Air Emission Tests of JUNE 22 1994

TEST 1 :

Gas Temperature	115 deg F	46 deg C
Moisture Content (by volume)	3.6 %	3.6 %
Average Stack Gas Velocity	40.9 ft/sec	12.5 m/sec
Total Actual Gas Flow Rate	56,393 ACFM	--
Standard Gas Flow Rate Reference Conditions	46,220 SCFM	21.8 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0000 gr/SCF	0.00 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter

TEST 2 :

Gas Temperature	119 deg F	49 deg C
Moisture Content (by volume)	1.5 %	1.5 %
Average Stack Gas Velocity	40.6 ft/sec	12.4 m/sec
Total Actual Gas Flow Rate	55,868 ACFM	--
Standard Gas Flow Rate Reference Conditions	46,452 SCFM	21.9 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0000 gr/SCF	0.00 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

GAS FLOW AND PARTICULATE MONITORING TEST 1

Job Number : M94-055
Client : LOUISIANA PACIFIC LTD.
Plant Location : DAWSON CREEK P.D.
Process : PRESS VENT - MBI
Pollution Control Permit : N/A

Monitoring Personnel : N. McCALL/C. YEE
Test Procedure : WMB. STD. TEST PROCEDURE USING
A LEAR SIEBLER PM-100

Date of Test : JUNE 22 1994
Test Start Time : 10:57 A.M.
Test Stop Time : 12:11 P.M.
On-line Sampling Time : 60 minutes

TEST RESULTS :

Gas Temperature	115 deg F	46 deg C
Moisture Content	3.6 %	3.6 %
Average Stack Gas Velocity	40.9 ft/sec	12.5 m/sec
Total Actual Gas Flow Rate	56,393 ACFM	--
Standard Gas Flow Rate Reference Conditions	46,230 SCFM	21.9 cubic meter/sec
Particulate concentration - Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter
Particulate Emission Rate	0.0 lbs/hr	0.0 kg/hr

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK S.C.
DAWSON CREEK S.C.

TEST DATA - TEST 1

AS	Cross Section Area of Duct/Stack	32.96 square feet
PB	Barometric Pressure	27.75 inches Hg
PS	Pressure in Duct or Stack	27.71 inches Hg
VM	Dry Gas Meter Volume	35.99 cubic feet
WE	Weight of Condensate Collected	25.0 grams
WBG	Weight of Moisture in Silica Gel	0.0 grams
WF	Weight of Filter Particulate	0.0000 grams
WEL	Weight of Cyclone Particulate	0.0000 grams
WW	Weight of Washings	0.0000 grams
NT	Total Number of Sample Points	20
CP	Type-S Pitot Tube Coefficient	0.8536
DN	Diameter of Nozzle Tip	0.2180 inches

GAS ANALYSIS (VOLUME %, DRY BASIS)

	Measured	Assumed
CO		
CO2	0.0	
O2	21.0	
N2		79.0

H.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

SAMPLING TEST DATA - TEST 1

SAMPLE POINT	VELOCITY	ORIFICE	DRY GAS METER		STACK GAS	GAS SAMPLE
	HEAD (in H ₂ O)	PRESSURE (in H ₂ O)	TEMP IN (deg F)	TEMP OUT (deg F)	TEMP (deg F)	VOLUME (cubic feet)
A-5	0.150	0.320	87	85	122	326.56
A-4	0.500	1.280	91	88	125	327.64
A-3	0.500	1.260	94	88	119	329.42
A-2	0.500	1.290	96	90	110	331.40
A-1	0.350	0.900	101	88	112	333.32
B-5	0.350	0.900	95	90	113	335.03
B-4	0.600	1.550	102	90	126	336.68
B-3	0.550	1.400	103	91	110	338.78
B-2	0.550	1.400	105	92	112	340.85
B-1	0.350	0.920	106	92	112	342.91
C-5	0.500	1.300	101	94	112	344.53
C-4	0.500	1.300	105	94	114	346.54
C-3	0.500	1.300	107	94	112	348.47
C-2	0.450	1.180	108	95	114	350.42
C-1	0.350	0.920	109	95	115	352.39
D-5	0.150	0.390	100	96	119	353.96
D-4	0.500	1.290	109	96	120	355.06
D-3	0.500	1.290	109	96	110	356.98
D-2	0.500	1.290	110	97	113	358.93
D-1	0.500	1.290	110	97	112	360.91
						362.55

N.R. McCall & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

Data for TEST 1 :

DELTA P:	0.8570	ACFM:	55892.58
DELTA H:	1.1418	SCFM:	46230.05
TMAVG:	557.2750	PS:	27.75
TS AVG:	575.2500	VM:	35.59
MC:	1.012	VM(CORR):	36.40
MD:	29.8400	PM:	27.8340
MS:	28.4540	PCON:	0.0000
VMSTD:	22.0363	CORR:	0.0000
BWD:	0.0256	ERAT:	0.0000
USAVG:	40.9254		

INDIVIDUAL ISOKINETICS - TEST 1

1.	1.079	11.	1.030
2.	0.999	12.	1.016
3.	1.025	13.	1.022
4.	1.025	14.	1.034
5.	1.076	15.	1.046
6.	1.050	16.	1.062
7.	1.027	17.	1.011
8.	1.040	18.	1.018
9.	1.034	19.	1.034
10.	1.035	20.	0.856

Overall Isokinetic for TEST 1 : 1.025

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

GAS FLOW AND PARTICULATE MONITORING TEST 2

Job Number : M94-055
Client : LOUISIANA PACIFIC LTD.
Plant Location : DAWSON CREEK B.C.
Process : PRESS VENT - MUI
Pollution Control Permit : N/A

Monitoring Personnel : N. McCALL/C. YEE
Test Procedure : WMB. STD. TEST PROCEDURE USING
A LEAR SIEGLER PM-100

Date of Test : JUNE 22 1994
Test Start Time : 12:47 P.M.
Test Stop Time : 2:13 P.M.
On-line Sampling Time : 60 minutes

TEST RESULTS :

Gas Temperature	119 deg F	49 deg C
Moisture Content	1.5 %	1.5 %
Average Stack Gas Velocity	40.6 ft/sec	12.4 m/sec
Total Actual Gas Flow Rate	55,868 ACFM	--
Standard Gas Flow Rate Reference Conditions	46,452 SCFM	21.9 cubic meter/sec
Particulate concentration - Dry Basis Corrected to 12% CO2	0.0000 gr/SCF	0.00 mg/cubic meter
Particulate Emission Rate	0.0 lbs/hr	0.0 kg/hr

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK S.C.
DAWSON CREEK S.C.

TEST DATA - TEST 2

AS	Cross Section Area of Duct/Stack	22.96	square feet
PR	Barometric Pressure	27.75	inches Hg
PS	Pressure in Duct or Stack	27.71	inches Hg
VM	Dry Gas Meter Volume	35.38	cubic feet
WC	Weight of Condensate Collected	10.0	grams
WSE	Weight of Moisture in Silica Gel	0.0	grams
WF	Weight of Filter Particulate	0.0000	grams
WFL	Weight of Cyclone Particulate	0.0000	grams
WW	Weight of Washings	0.0000	grams
NT	Total Number of Sample Points	20	
CP	Type-G Pitot Tube Coefficient	0.8536	
DN	Diameter of Nozzle Tip	0.2130	inches

GAS ANALYSIS (VOLUME %, DRY BASIS)

	Measured	Assumed
CO		
CO2	0.0	
O2	21.0	
N2		79.0

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

SAMPLING TEST DATA - TEST 2

SAMPLE POINT	VELOCITY	ORIFICE	DRY GAS METER		STACK GAS	GAS SAMPLE
	HEAD (in H ₂ O)	PRESSURE (in H ₂ O)	TEMP IN (deg F)	TEMP OUT (deg F)	TEMP (deg F)	VOLUME (cubic feet)
D-5	0.100	0.350	92	91	129	362.73
D-4	0.500	1.260	96	91	135	362.63
D-3	0.500	1.260	96	91	110	365.48
D-2	0.500	1.300	100	91	118	367.40
D-1	0.500	1.290	101	92	112	369.35
C-5	0.500	1.260	94	92	120	371.29
C-4	0.500	1.260	98	92	116	373.20
C-3	0.500	1.260	101	92	116	375.15
C-2	0.450	1.170	102	92	122	377.06
C-1	0.300	0.770	104	94	115	379.98
B-5	0.500	1.260	99	94	123	380.45
B-4	0.450	1.130	103	94	119	382.40
B-3	0.500	1.260	106	95	112	384.25
B-2	0.500	1.260	107	95	113	386.15
B-1	0.350	0.980	102	96	112	388.05
A-5	0.100	0.250	98	97	128	389.67
A-4	0.470	1.200	107	97	132	390.55
A-3	0.450	1.150	108	97	114	392.29
A-2	0.600	1.530	109	97	136	394.10
A-1	0.500	1.230	109	97	105	396.15
						398.11

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

Date for TEST 2 :

DELTA P:	0.6511	ACEM:	55267.83
DELTA H:	1.1140	SCPM:	46452.20
TMAVG:	557.9500	PS:	27.75
TE AVG:	579.4000	VM:	35.38
MC:	1.012	VM(CORR):	25.79
MD:	28.8400	PM:	27.8320
MS:	29.6794	PCON:	0.0000
UMSTD:	31.5025	SORR:	0.0000
BWD:	0.0148	ERAT:	0.0000
USAVG:	40.5545		

INDIVIDUAL ISOKINETICS - TEST 2

1.	1.067	11.	1.022
2.	0.985	12.	1.015
3.	0.999	13.	0.980
4.	1.020	14.	0.980
5.	1.008	15.	0.995
6.	1.005	16.	1.031
7.	1.019	17.	0.939
8.	0.995	18.	0.982
9.	1.030	19.	0.981
10.	1.016	20.	1.000

Overall Isokinetic for TEST 2 :- 1.001

Test Data- KONUS KESSEL

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

KONNUS KESSEL BURNER

Average of Air Emission Tests 1 TO 2

DATE: JUNE 22 1994

FIELD MEASUREMENT DATA :

Gas Temperature	398 deg F	203 deg C
Moisture Content (by volume)	9.0 %	9.0 %
Average Stack Gas Velocity	32.1 ft/sec	9.8 m/sec
Total Actual Gas Flow Rate	47,934 ACFM	--
Standard Gas Flow Rate Reference Conditions	24,947 SCFM	11.8 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0427 gr/SCF	97.74 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.1281 gr/SCF	293.22 mg/cubic meter

Neil McCall
ENVIRONMENTAL CONSULTANTS LTD.
N.R. McCALL & ASSOCIATES

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

KONNUS KESSEL BURNER

Summary of Air Emission Tests of JUNE 22 1994

TEST 1 :

Gas Temperature	396 deg F	202 deg C
Moisture Content (by volume)	8.8 %	8.8 %
Average Stack Gas Velocity	32.8 ft/sec	10.0 m/sec
Total Actual Gas Flow Rate	48,892 ACFM	--
Standard Gas Flow Rate Reference Conditions	25,581 SCFM	12.1 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0405 gr/SCF	92.73 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.1216 gr/SCF	278.18 mg/cubic meter

TEST 2 :

Gas Temperature	401 deg F	205 deg C
Moisture Content (by volume)	9.2 %	9.2 %
Average Stack Gas Velocity	31.5 ft/sec	9.6 m/sec
Total Actual Gas Flow Rate	46,976 ACFM	--
Standard Gas Flow Rate Reference Conditions	24,313 SCFM	11.5 cubic meter/sec

Total Particulate Concentration :

Dry Basis, Actual	0.0449 gr/SCF	102.76 mg/cubic meter
Dry Basis Corrected to 12% CO2	0.1347 gr/SCF	308.27 mg/cubic meter

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

GAS FLOW AND PARTICULATE MONITORING TEST 1

Job Number : M94-055
Client : LOUISIANA PACIFIC LTD.
Plant Location : DAWSON CREEK B.C.
Process : KONNUS KESSEL BURNER
Pollution Control Permit : N/A

Monitoring Personnel : M. JOHNS / D. LAWRENCE
Test Procedure : WMB. STD. TEST PROCEDURE USING
A LEAR SIEGLER PM-100

Date of Test : JUNE 22 1994
Test Start Time : 8:52 A.M.
Test Stop Time : 10:12 A.M.
On-line Sampling Time : 72 minutes

TEST RESULTS :

Gas Temperature	396 deg F	202 deg C
Moisture Content	8.8 %	8.8 %
Average Stack Gas Velocity	32.8 ft/sec	10.0 m/sec
Total Actual Gas Flow Rate	48,892 ACFM	--
Standard Gas Flow Rate Reference Conditions	25,581 SCFM	12.1 cubic meter/sec
Particulate concentration - Dry Basis Corrected to 12% CO2	0.1216 gr/SCF	278.18 mg/cubic meter
Particulate Emission Rate	8.9 lbs/hr	4.0 kg/hr

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

TEST DATA - TEST 1

AS	Cross Section Area of Duct/Stack	24.85 square feet
PB	Barometric Pressure	27.80 inches Hg
PS	Pressure in Duct or Stack	27.81 inches Hg
VM	Dry Gas Meter Volume	31.37 cubic feet
WE	Weight of Condensate Collected	50.0 grams
WSG	Weight of Moisture in Silica Gel	6.2 grams
WF	Weight of Filter Particulate	0.0459 grams
WFL	Weight of Cyclone Particulate	0.0045 grams
WW	Weight of Washings	0.0222 grams
NT	Total Number of Sample Points	36
CP	Type-S Pitot Tube Coefficient	0.8599
DN	Diameter of Nozzle Tip	0.2650 inches

GAS ANALYSIS (VOLUME %, DRY BASIS)

	Measured	Assumed
CO		
CO2	4.0	
O2	17.0	
N2		79.0

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

SAMPLING TEST DATA - TEST 1

SAMPLE POINT	VELOCITY HEAD (in H2O)	ORIFICE PRESSURE (in H2O)	DRY GAS METER TEMP IN TEMP OUT (deg F) (deg F)		STACK GAS TEMP (deg F)	GAS SAMPLE VOLUME (cubic feet)
A-18	0.200	0.640	90	88	394	738.24
A-17	0.210	0.670	96	86	390	739.14
A-16	0.220	0.710	104	86	391	740.06
A-15	0.210	0.680	108	86	392	741.00
A-14	0.160	0.520	111	86	392	741.92
A-13	0.200	0.650	112	86	393	742.74
A-12	0.190	0.620	114	86	396	743.62
A-11	0.210	0.680	116	87	396	744.52
A-10	0.250	0.810	118	88	396	745.46
A-9	0.180	0.590	120	88	396	746.45
A-8	0.270	0.880	120	88	397	747.34
A-7	0.150	0.490	122	88	398	748.36
A-6	0.180	0.580	122	90	399	749.19
A-5	0.160	0.520	122	90	397	750.04
A-4	0.120	0.400	122	90	389	750.86
A-3	0.150	0.490	122	90	395	751.55
A-2	0.180	0.590	123	90	394	752.32
A-1	0.190	0.620	123	90	395	753.17
B-18	0.180	0.590	108	90	394	754.04
B-17	0.170	0.560	118	92	394	754.92
B-16	0.180	0.590	122	92	393	755.77
B-15	0.180	0.590	124	93	390	756.64
B-14	0.180	0.590	124	93	395	757.51
B-13	0.190	0.630	126	94	396	758.38
B-12	0.190	0.630	126	94	398	759.30
B-11	0.170	0.560	126	94	397	760.20
B-10	0.170	0.560	128	94	399	761.05
B-9	0.170	0.560	128	94	401	761.90
B-8	0.180	0.590	128	95	400	762.74
B-7	0.180	0.590	128	95	400	763.62
B-6	0.190	0.620	128	95	399	764.50
B-5	0.190	0.630	130	96	398	765.38
B-4	0.170	0.560	130	96	398	766.26
B-3	0.160	0.530	130	96	396	767.11
B-2	0.170	0.560	130	96	396	767.92
B-1	0.180	0.600	130	96	396	768.75
						769.61

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

Data for TEST 1 :

DELTA P:	0.4281	ACFM:	48892.00
DELTA H:	0.6022	SCFM:	25580.58
TMAVG:	565.6528	PB:	27.80
TS AVG:	855.5556	VM:	31.37
MC:	1.015	VM(CORR):	31.82
MD:	29.3200	PM:	27.8443
MS:	28.3251	PCON:	0.0405
VMSTD:	27.6456	CORR:	0.1216
BWO:	0.0879	ERAT:	8.8846
USA VG:	32.7914		

INDIVIDUAL ISOKINETICS - TEST 1

1.	0.991	19.	1.003
2.	0.983	20.	0.987
3.	0.975	21.	0.977
4.	0.974	22.	0.973
5.	0.991	23.	0.976
6.	0.951	24.	1.003
7.	0.998	25.	0.982
8.	0.989	26.	0.980
9.	0.953	27.	0.979
10.	1.007	28.	0.969
11.	0.943	29.	0.985
12.	1.028	30.	0.985
13.	0.960	31.	0.958
14.	0.981	32.	0.955
15.	0.948	33.	0.975
16.	0.950	34.	0.957
17.	0.956	35.	0.951
18.	0.953	36.	0.958

Overall Isokinetic for TEST 1 : 0.974

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

GAS FLOW AND PARTICULATE MONITORING TEST 2

Job Number : M94-055
Client : LOUISIANA PACIFIC LTD.
Plant Location : DAWSON CREEK B.C.
Process : KONNUS KESSEL BURNER
Pollution Control Permit : N/A

Monitoring Personnel : M. JOHNS / D. LAWRENCE
Test Procedure : WMB. STD. TEST PROCEDURE USING
 A LEAR SIEGLER PM-100

Date of Test : JUNE 22 1994
Test Start Time : 10:23 A.M
Test Stop Time : 11:38 A.M
On-line Sampling Time : 72 minutes

TEST RESULTS :

Gas Temperature	401 deg F	205 deg C
Moisture Content	9.2 %	9.2 %
Average Stack Gas Velocity	31.5 ft/sec	9.6 m/sec
Total Actual Gas Flow Rate	46,976 ACFM	--
Standard Gas Flow Rate Reference Conditions	24,313 SCFM	11.5 cubic meter/sec
Particulate concentration - Dry Basis Corrected to 12% CO2	0.1347 gr/SCF	308.27 mg/cubic meter
Particulate Emission Rate	9.4 lbs/hr	4.2 kg/hr

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

LOUISIANA PACIFIC LTD.
DAWSON CREEK B.C.
DAWSON CREEK B.C.

TEST DATA - TEST 2

AS	Cross Section Area of Duct/Stack	24.85 square feet
PB	Barometric Pressure	27.80 inches Hg
PS	Pressure in Duct or Stack	27.81 inches Hg
VM	Dry Gas Meter Volume	30.34 cubic feet
WE	Weight of Condensate Collected	50.0 grams
WSG	Weight of Moisture in Silica Gel	6.4 grams
WF	Weight of Filter Particulate	0.0497 grams
WFL	Weight of Cyclone Particulate	0.0024 grams
WW	Weight of Washings	0.0245 grams
NT	Total Number of Sample Points	36
CP	Type-S Pitot Tube Coefficient	0.8599
DN	Diameter of Nozzle Tip	0.2650 inches

GAS ANALYSIS (VOLUME %, DRY BASIS)

	Measured	Assumed
CO		
CO2	4.0	
O2	17.0	
N2		79.0

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

SAMPLING TEST DATA - TEST 2

SAMPLE POINT	VELOCITY HEAD (in H2O)	ORIFICE PRESSURE (in H2O)	DRY GAS METER TEMP IN TEMP OUT (deg F) (deg F)		STACK GAS TEMP (deg F)	GAS SAMPLE VOLUME (cubic feet)
B-18	0.170	0.550	98	94	392	769.80
B-17	0.170	0.560	118	98	398	770.63
B-16	0.170	0.560	124	99	401	771.47
B-15	0.180	0.590	126	99	402	772.31
B-14	0.190	0.630	128	100	401	773.18
B-13	0.180	0.590	130	100	402	774.07
B-12	0.170	0.560	130	100	403	774.93
B-11	0.170	0.560	130	100	404	775.77
B-10	0.160	0.530	130	100	404	776.61
B-9	0.180	0.590	130	100	406	777.43
B-8	0.180	0.590	130	100	406	778.29
B-7	0.170	0.560	130	100	406	779.15
B-6	0.180	0.590	130	100	403	780.00
B-5	0.190	0.620	132	100	403	780.87
B-4	0.190	0.620	132	100	402	781.76
B-3	0.180	0.600	132	100	399	782.65
B-2	0.160	0.530	132	100	398	783.53
B-1	0.180	0.600	132	100	398	784.35
A-18	0.170	0.550	112	94	400	785.22
A-17	0.170	0.560	126	100	399	786.09
A-16	0.150	0.490	130	100	400	786.95
A-15	0.160	0.530	130	100	398	787.77
A-14	0.150	0.490	132	100	401	788.62
A-13	0.170	0.560	132	100	401	789.42
A-12	0.160	0.530	132	100	402	790.30
A-11	0.160	0.530	132	100	403	791.15
A-10	0.170	0.560	132	100	403	792.00
A-9	0.150	0.490	132	100	404	792.87
A-8	0.160	0.530	132	100	403	793.67
A-7	0.170	0.530	134	100	398	794.47
A-6	0.150	0.490	134	101	403	795.29
A-5	0.170	0.560	134	101	401	796.07
A-4	0.170	0.560	134	101	399	796.90
A-3	0.150	0.500	134	101	397	797.74
A-2	0.150	0.500	134	101	395	798.56
A-1	0.150	0.500	135	102	394	799.36
						800.14

N.R. McCALL & ASSOCIATES
ENVIRONMENTAL CONSULTANTS LTD.

Data for TEST 2 :

DELTA P:	0.4097	ACFM:	46976.17
DELTA H:	0.5525	SCFM:	24312.83
TMAVG:	574.5278	PB:	27.80
TS AVG:	860.8056	VM:	30.34
MC:	1.015	VM(CORR):	30.78
MD:	29.3200	PM:	27.8407
MS:	28.2763	PCON:	0.0449
VMSTD:	26.3215	CORR:	0.1347
BWO:	0.0922	ERAT:	9.3578
USAVG:	31.5065		

INDIVIDUAL ISOKINETICS - TEST 2

1.	0.982	19.	1.021
2.	0.976	20.	0.991
3.	0.972	21.	1.003
4.	0.977	22.	1.005
5.	0.970	23.	0.977
6.	0.961	24.	1.010
7.	0.967	25.	1.006
8.	0.967	26.	1.007
9.	0.973	27.	1.000
10.	0.964	28.	0.979
11.	0.964	29.	0.947
12.	0.980	30.	0.938
13.	0.973	31.	0.951
14.	0.967	32.	0.950
15.	0.967	33.	0.960
16.	0.980	34.	0.997
17.	0.968	35.	0.971
18.	0.969	36.	0.945

Overall Isokinetic for TEST 2 : 0.976

Appendix

CALIBRATION CERTIFICATE
DRY GAS METER

DATE: MARCH 22, 1994

CONSOLE MANUF.: LEAR SIEGLER PM-100

CONSOLE I.D.: 170

PARAMETER SUMMARY	RUN #1	RUN #2	RUN #3
Ta = Ambient (WTM) Temperature (oF.)	57.0	56.5	57.0
P=Pres. Differential at WTM ("Hg)	0.0640	0.1140	0.1663
Pb= Atmospheric Pressure ("Hg)	29.75	29.75	29.75
Pv= Vapour Pressure Water at Temp. Ta ("Hg)	0.4683	0.4600	0.4683
H=Pres. Differential at Orifice	1.0	2.0	3.0
Ti= Dry Test Meter Inlet Temp. (oF.)	98.0	90.4	109.0
To= Dry Test Meter Outlet Temp. (oF.)	63.6	60.0	66.0
Ri= Initial Dry Test volume (ft3)	596.65	591.13	602.18
Rf= Final Dry Test Volume (ft3)	601.70	596.16	607.28
Vi= Initial Wet Test Volume (ft3)	0.0	0.0	0.0
Vf= Final Wet Test Volume (ft3)	5.000	5.000	5.000
Pw= $P_b - (H/13.59)$ "Hg	29.6860	29.6360	29.5837
Pd= $P_b + (H/13.59)$ "Hg	29.8236	29.8972	29.9708
Tw= $T_a + 460$ (oR.)	517.0	516.5	517.0
Td= $[(T_i + T_o)/2] + 460$ (oR.)	540.8	535.2	547.5
Bw= P_v/P_b ("Hg)	0.0157	0.0155	0.0157
WET TEST METER FACTOR (WTMF)	0.9998	0.9998	0.9998
(Calculated Y Value)(WTMF)	1.0145	1.0050	1.0085
Y (MEAN)(WTMF) =	1.0093		

N.R. MCCALL & ASSOCIATES LTD.

ORIFICE METER CALIBRATION

DATE: MARCH 22, 1994

CONSOLE I.D. 170

	RUN 1	RUN 2	RUN 3
MD = mol. wt. dry air	28.967	28.967	28.967
Pb = bar. pressure "Hg	29.76	29.76	29.76
Y = gas meter factor	1.0145	1.0145	1.005
Delta H =	0.5	1	1.5
Ri = int. gas meter vol.	607.5	609.5	612.2
Rf = final gas meter vol.	609.32	612.13	615.45
min. samp	5	5	5
$Q_m = Y(R_f - R_i) / \sqrt{T} \text{ (FT}^3/\text{MIN)}$	0.369278	0.533627	0.65325
	68.5	68	68
	528.5	528	528
Tm = meter out temp. (oR.)	29.79679	29.83358	29.87038
Pm = Pb + ^H	0.553313	0.78165	0.956732
$\text{SQRT}(T_m / P_m * H / M_d)$	0.667394	0.682693	0.682793
Ko = orifice const.			

Ko MEAN = 0.677627

$Ko * 4 * 144 = 390.3129$

N.R. McCALL & ASSOCIATES LTD.

ORIFICE METER CALIBRATION

DATE: MARCH 22, 1994

CONSOLE I.D. 170

	RUN 4	RUN 5	RUN 6
MD = mol. wt. dry air	28.967	28.967	28.967
Pb = bar. pressure "Hg	29.76	29.76	29.76
Y = gas meter factor	1.005	1.0085	1.0085
Delta H =	2	2.5	3
Ri = int. gas meter vol.	615.6	619.5	623.8
Rf = final gas meter vol.	619.31	623.65	628.38
min. samp	5	5	5
Qm = $Y(Rf - Ri) / \sqrt{T(FT^3/MIN)}$	0.74571	0.837055	0.923786
To = meter out temp. (oF.)	70	71	72
Tm = meter out temp. (oR.)	530	531	532
Pm = Pb + ^H	29.90717	29.94396	29.98075
SQRT(Tm/Pm*H/Md)	1.106149	1.237117	1.355637
Ko = orifice const.	0.67415	0.676617	0.681441

Ko MEAN = 0.677403

Ko*4*144 = 390.1839

N.R. McCALL & ASSOCIATES LTD.

CALIBRATION CERTIFICATE
DRY GAS METER

DATE: MARCH 24, 1994

CONSOLE MANUF.: NAPP MODEL 31

CONSOLE I.D.: C-980

PARAMETER SUMMARY

	RUN #1	RUN #2	RUN #3
Ta = Ambient (WTM) Temperature (oF.)	55.5	56.0	56.0
P=Pres. Differential at WTM ("Hg)	0.0625	0.1140	0.1589
Pb= Atmospheric Pressure ("Hg)	30.04	30.04	30.04
Pv= Vapour Pressure Water at Temp. Ta ("Hg)	0.4436	0.4517	0.4517
H=Pres. Differential at Orifice	1.0	2.0	3.0
Ti= Dry Test Meter Inlet Temp. (oF.)	75.2	74.6	84.8
To= Dry Test Meter Outlet Temp. (oF.)	64.0	65.0	66.6
Ri= Initial Dry Test volume (ft3)	105.05	110.52	115.95
Rf= Final Dry Test Volume (ft3)	110.03	115.46	120.92
Vi= Initial Wet Test Volume (ft3)	0.0	0.0	0.0
Vf= Final Wet Test Volume (ft3)	5.000	5.000	5.000
Pw= Pb - (^P/13.59) "Hg	29.9775	29.9260	29.8811
Pd= Pb + (^H/13.59) "Hg	30.1136	30.1872	30.2608
Tw= Ta +460 (oR.)	515.5	516.0	516.0
Td= [(Ti + To)/2] + 460 (oR.)	529.6	529.8	535.7
Bw= Pv/Pb ("Hg)	0.0148	0.0150	0.0150
WET TEST METER FACTOR (WTMF)	0.9998	0.9998	0.9998
(Calculated Y Value)(WTMF)	1.0115	1.0145	1.0156
Y (MEAN)(WTMF) =	1.0139		

N.R. MCCALL & ASSOCIATES LTD.

ORIFICE METER CALIBRATION

DATE: MARCH 24, 1994

CONSOLE I.D. C-980

	RUN 1	RUN 2	RUN 3
MD= mol. wt. dry air	28.967	28.967	28.967
Pb=bar. pressure "Hg	30.04	30.04	30.04
Y=gas meter factor	1.0115	1.0115	1.0145
Delta H=	0.5	1	1.5
Ri=int. gas meter vol.	121.1	123.1	125.9
Rf=final gas meter vol.	122.98	125.72	129.08
min. samp	5	5	5
Qm=Y(Rf-Ri)/^T(FT3/MIN)	0.380324	0.530026	0.645222
	59.2	60.4	62.6
Tm=meter out temp. (oR.)	519.2	520.4	522.6
Pm=Pb + ^H	30.07679	30.11358	30.15038
SQRT(Tm/Pm*H/Md)	0.545864	0.772388	0.947397
Ko=orifice const.	0.696737	0.686217	0.681047

Ko MEAN = 0.688

Ko*4*144= 396.2882

N.R. McCALL & ASSOCIATES LTD.

ORIFICE METER CALIBRATION

DATE: MARCH 24, 1994

CONSOLE I.D. C-980

	RUN 4	RUN 5	RUN 6
MD = mol. wt. dry air	28.967	28.967	28.967
Pb = bar. pressure "Hg	30.04	30.04	30.04
Y = gas meter factor	1.0145	1.0156	1.0156
Delta H =	2	2.5	3
Ri = int. gas meter vol.	129.2	133	137.2
Rf = final gas meter vol.	132.81	137.01	141.56
min. samp	5	5	5
Qm = $Y(R_f - R_i) / \Delta T (FT^3 / MIN)$	0.732469	0.814511	0.885603
Tm = meter out temp. (oR.)	64.8	67.4	69.4
Pm = $P_b + \Delta H$	524.8	527.4	529.4
SQRT($T_m / P_m \cdot H / M_d$)	30.18717	30.22396	30.26075
Ko = orifice const.	1.095592	1.227192	1.346049
	0.66856	0.663719	0.657928

Ko MEAN = 0.663402

$Ko^4 \cdot 144 = 382.1197$

N.R. McCALL & ASSOCIATES LTD.

N.R. MCCALL & ASSOCIATES LTD.

CALIBRATION CERTIFICATE S - TYPE PITOT TUBE

DATE:	JAN. 24/94	BAROM. PRESSURE ("Hg)	30.05
PITOT I.D.:	147.0	W. TUNNEL TEMP. (oF.)	68.0
NOZZLE I.D.:	0.25		

WIND VELOCITY (ft/sec).	REF. PITOT IN. H2O	S - TYPE PITOT	PITOT FACTOR
10.10	0.02350	0.02847	0.89944
26.00	0.15564	0.20433	0.86401
40.36	0.37501	0.49160	0.86467
60.22	0.83475	1.09040	0.86620
82.54	1.56840	2.05702	0.86446
100.10	2.30675	3.09565	0.85459
		AVERAGE =	0.86890

NOTE: The new pitot tip should be installed so that the serial number engraved is aligned directly into the gas stream.

N.R. MCCALL & ASSOCIATES LTD.

CALIBRATION CERTIFICATE S - TYPE PITOT TUBE

DATE:	JAN. 24/94	BAROM. PRESSURE ("Hg)	30.05
PITOT I.D.:	148.0	W. TUNNEL TEMP. (oF.)	68.0
NOZZLE I.D.:	0.25		

WIND VELOCITY (ft/sec)	REF. PITOT IN. H2O	S - TYPE PITOT	PITOT FACTOR
9.48	0.02068	0.02546	0.89224
25.59	0.15077	0.20029	0.85895
40.61	0.37956	0.49671	0.86542
60.74	0.84939	1.10638	0.86744
80.05	1.47529	1.91537	0.86886
101.37	2.36571	3.06653	0.86955
		AVERAGE =	0.87041

NOTE: The new pitot tip should be installed so that the serial number engraved is aligned directly into the gas stream.

N.R. MCCALL & ASSOCIATES LTD.

CALIBRATION CERTIFICATE S - TYPE PITOT TUBE

DATE:	JAN. 24/94	BAROM. PRESSURE ("Hg)	30.05
PITOT I.D.:	149.0	W. TUNNEL TEMP. (oF.)	68.0
NOZZLE I.D.:	0.25		

WIND VELOCITY (ft/sec)	REF. PITOT IN. H2O	S - TYPE PITOT	PITOT FACTOR
10.05	0.02324	0.02895	0.88700
26.57	0.16253	0.21544	0.85988
39.92	0.36677	0.48176	0.86381
60.17	0.83340	1.09214	0.86482
80.53	1.49287	1.99072	0.85732
102.12	2.40056	3.23481	0.85284
		AVERAGE =	0.86428

NOTE: The new pitot tip should be installed so that the serial number engraved is aligned directly into the gas stream.

CLIENT: K P DANSON
 Test Number: 1 - CONDENSIBLES -
 FROST DRYER - SOURCE # 7
 Barometric Pressure: 27.8
 Sulfur Pressure: 7.53
 Nozzle Diameter: 1.82
 *C Correction Factor: 1.0

Filter No: AA + AA
 First No: 17
 Sites Gas: AA
 Assumed Moisture: 20
 Assumed Meter Temp: 12.40
 Start Time: 12:40
 Stop Time: 1:46

TIME	CO ₂	O ₂	CO	M ₁
1	3	17		50
2	3	17		
3	3	17		
4				

Impinger Volume
 Final: 500
 Initial: 150

Date: JUNE 20/94
 Comments: 171-2145
CP - 86744 AS-15-91
P. 1017 149
CAN SAVE 170
 Tester 1: MIKE/DAN
 Tester 2: _____
 Leakage Rate @ _____ %

SAMPLE POINT	Time					GAS METER TEMP. OUT (°F)	GAS METER TEMP. IN (°F)	GAS METER TEMP. OUT (°F)	STACK GAS TEMP. (°F)
	5	10	15	20	25				
1	1.1810	1.1810	1.1810	1.1810	1.1810	1170	1170	1170	1145
2	1.1871	1.1871	1.1871	1.1871	1.1871	1172	1172	1172	1141
3	1.1910	1.1910	1.1910	1.1910	1.1910	1172	1172	1172	1141
4	1.1912	1.1912	1.1912	1.1912	1.1912	1174	1174	1174	1141
5	1.1915	1.1915	1.1915	1.1915	1.1915	1176	1176	1176	1140
6	1.1915	1.1915	1.1915	1.1915	1.1915	1176	1176	1176	1141
7	1.1915	1.1915	1.1915	1.1915	1.1915	1178	1178	1178	1142
8	1.1910	1.1910	1.1910	1.1910	1.1910	1178	1178	1178	1141
9	1.1910	1.1910	1.1910	1.1910	1.1910	1180	1180	1180	1142
10	1.1910	1.1910	1.1910	1.1910	1.1910	1180	1180	1180	1140
11	1.1910	1.1910	1.1910	1.1910	1.1910	1180	1180	1180	1141
12	1.1915	1.1915	1.1915	1.1915	1.1915	1182	1182	1182	1143
13	1.1910	1.1910	1.1910	1.1910	1.1910	1184	1184	1184	1141
14	1.1917	1.1917	1.1917	1.1917	1.1917	1184	1184	1184	1141
15	1.1919	1.1919	1.1919	1.1919	1.1919	1186	1186	1186	1141
16	1.1910	1.1910	1.1910	1.1910	1.1910	1186	1186	1186	1140
17	1.1912	1.1912	1.1912	1.1912	1.1912	1186	1186	1186	1140
18	1.1910	1.1910	1.1910	1.1910	1.1910	1187	1187	1187	1140
19	1.1910	1.1910	1.1910	1.1910	1.1910	1188	1188	1188	1140
20	1.1918	1.1918	1.1918	1.1918	1.1918	1190	1190	1190	1138

Vm	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUM (HG)	SAMPLE BOX TEMP. (°F)
505.53	3. Min.	0 = 6.1		
508.92		1.35		
508.38		4.4		
509.86		7.9		
511.35		12.2		
512.79		18.5		
514.49		35.5		
516.05		41.8		
517.57		46.1		
519.07		49.6		
520.55		52.6		
522.05				
523.61				
525.20				
526.79				
528.39				
529.98				
531.57				
533.10				
534.62				

27.50

536.13

CLIENT: L.P. DANSON
 Test Number: 2 - CONDENSIBLES
 Process: REF. B. DAVEN SIMMER
 Barometer Pressure: 27.8
 Static Pressure: 27.83
 Nozzle Diameter: 1.82
 Correction Factor: 89

Filter No.: B6 + B6 - 9 initial
 Flux No.: 17
 Species Gas: Air
 Assumed Moisture: 20
 Assumed Meter Temp.: 2:00 PM
 Start Time: 3:30
 Stop Time: 3:30

TIME	CO ₂	O ₂	CO	H ₂
1	3	17		80
2	3	17		
3	3	17		
4				

Impinger Volume	1	2	3
Final	544	+14	
Initial	250	150	

Date: JUNE 20 / 98
 Comments: 27-1015
CP - 8670445 15-90
P. IPT 149
 SAMPLE ID: GANICE 170
 Tester 1: MIKE / BAN
 Tester 2: _____
 Leakage Rate @ YES

SAMPLE POINT	VELOCITY HEAD (M/S)	Time				GAS METER TEMP. OUT (F)	GAS METER TEMP. IN (F)	STACK GAS TEMP. (F)
		5	10	15	20			
1	1.915	1.1813	1.190	1.1816	1.1816	1.141		
2	1.915	1.1815	1.1106	1.1818	1.1818	1.1319		
3	1.915	1.1815	1.1110	1.1910	1.1818	1.1317		
4	1.100	1.1910	1.1114	1.1818	1.1818	1.1318		
5	1.100	1.1910	1.1114	1.1818	1.1818	1.1410		
6	1.917	1.1817	1.1116	1.1818	1.1818	1.1411		
7	1.917	1.1817	1.1116	1.1818	1.1818	1.1319		
8	1.915	1.1816	1.1118	1.1818	1.1818	1.1318		
9	1.910	1.1818	1.1118	1.1818	1.1818	1.1315		
10	1.910	1.1812	1.1118	1.1818	1.1818	1.1314		
11	1.815	1.1710	1.1918	1.1816	1.1816	1.1414		
12	1.910	1.1709	1.1112	1.1816	1.1816	1.1411		
13	1.100	1.1819	1.1116	1.1818	1.1818	1.1414		
14	1.1015	1.1914	1.1118	1.1818	1.1818	1.1415		
15	1.910	1.1812	1.1118	1.1818	1.1818	1.1413		
16	1.1013	1.1813	1.1118	1.1818	1.1818	1.1413		
17	1.1015	1.1815	1.1118	1.1818	1.1818	1.1411		
18	1.1010	1.1910	1.1118	1.1818	1.1818	1.1410		
19	1.1010	1.1910	1.1118	1.1818	1.1818	1.1410		
20	1.1815	1.1716	1.1118	1.1818	1.1818	1.1319		

Vm	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUMING	SAMPLE BOX TEMP. (F)
536.29				
537.95				
539.41				
540.98				
542.58				
544.17				
545.75				
547.32				
548.89				
550.44				
551.98				
553.54				
554.92				
556.52				
558.17				
559.70				
561.28				
562.85				
564.45				
566.00				

667-45

OK Dam for ...
 SOURCE TEST W/DIN
 DATE: JAN 20/94
 COMMENTS: M-0145
 CP 66744 AS/590
 VITRILIX
 CANNISTER
 Tester 1: MIKE/DAM
 Tester 2: [Signature]
 Leakage Rate @ 300: 245

TIME	CO ₂	O ₂	CO	H ₂
1	3	17		
2	3	17		
3	3	17		
4				

Initial	Final
150	451

CLIENT: L-P DAWSON
 Test Number: HYDROGEN CHAMBER
 Process: E-F-B DRYER - SAMPLE # 7
 Barometric Pressure: 27.8
 Subc Pressure: 192
 Nozzle Diameter: 1/8
 Correction Factor: 1.29
 Filler No: CC
 Part No: 17
 Specs Cat: CC
 Assumed Moisture: 20
 Assumed Meier Temp: 4.00
 Start Time: 5:08
 Stop Time: 5:08

VM	GAS SAMPLE VOLUME (ft ³)	SAMPLE TIME	PUMP VACUUM (inHg)	SAMPLE AGE (Temp. (°F))
567.60		3 MIN		
569.09				
570.61				
572.13				
573.71				
575.29				
576.89				
578.47				
580.03				
581.62				
583.24			27.76	
584.76				
586.28				
587.83			55.65	
589.40				
590.93				
592.45				
593.96				
595.51				
597.08				

SAMPLE POINT	VELOCITY HEAD (ft. O ₂)	ORIFICE PRESS (ft. O ₂)	GAS METEN TEMP. IN (°F)	GAS METEN TEMP. OUT (°F)	STACK GAS TEMP. (°F)	Time				
						5	10	15	20	
1	1.910	1.177	1814	1814	1718	1144				
2	1.915	1.182	1810	1810	1810	1739				
3	1.915	1.184	1810	1810	1810	1739				
4	1.915	1.185	1810	1810	1810	1737				
5	1.917	1.187	1811	1811	1811	1736				
6	1.910	1.190	1811	1811	1811	1735				
7	1.915	1.185	1811	1811	1811	1737				
8	1.915	1.185	1811	1811	1811	1737				
9	1.910	1.189	1811	1811	1811	1737				
10	1.910	1.189	1811	1811	1811	1738				
11	1.910	1.179	1818	1818	1818	1741				
12	1.912	1.182	1812	1812	1812	1718				
13	1.913	1.183	1814	1814	1814	1718				
14	1.915	1.185	1816	1816	1816	1719				
15	1.910	1.181	1816	1816	1816	1718				
16	1.910	1.181	1816	1816	1816	1737				
17	1.910	1.181	1816	1816	1816	1738				
18	1.912	1.182	1816	1816	1816	1736				
19	1.913	1.184	1816	1816	1816	1737				
20	1.915	1.185	1816	1816	1816	1738				

Date: JAN 21/92
 COMMENTS: ON 1-045-D
CP 86381 AS-57-S
P/T 1/19 SQUARE
CONV 170
 Tester 1: MIKE/DAN
 Tester 2: _____
 Leakage Rate @ ✓ HG 15

TIME	CO ₂	O ₂	CO	H ₂
1	0	21		79
2				
3				
4				

Impinger Volume	1	2	3
Final	297		
Initial	150	150	

CLIENT: L.P. DANSON Filter No: DD
 Test Number: 1 - FORMALDEHYDE Flux No: M
 Process: PRESS VENT - SUMMERS Sites Get: AB
 Barometric Pressure: 27.22 Assumed Moisture: 2
 Static Pressure: F-5 H₂O Assumed Meter Temp: 32.5 PM
 Nozzle Diameter: 1.80 Start Time: 4:39 PM
 Corrosion Factor: 1.30 Stop Time: _____

SAMPLE POINT	VELOCITY HEAD (M/S)	ORIFICE PRESS (PSI)	GAS METER TEMP. IN (°F)	GAS METER TEMP. OUT (°F)	STACK GAS TEMP. (°F)	TIME	V _m	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUM (HG)	SAMPLE BOX TEMP. (°F)	TEMP. LAST WPT	CORROSION	
													15	30
1	1.481	1.162	181	184	1107	5	683.72	3 MIN						
2	1.510	1.165	1100	1812	1110	10	685.05							
3	1.510	1.165	1104	1817	1111	15	686.43							
4	1.415	1.158	1108	1812	1112	20	687.80				FLANS CYCLING			
5	1.315	1.146	1112	1814	1109	25	689.10				VERY GRATIC			
6	1.612	1.182	1102	186	1107	30	690.25							
7	1.624	1.183	1111	1818	1108	35	691.82							
8	1.631	1.184	1116	189	1118	40	693.38							
9	1.518	1.176	1118	188	1122	45	694.93							
10	1.510	1.167	1120	186	1109	50	696.42							
11	1.631	1.185	1104	190	1109	55	697.84							
12	1.440	1.151	1118	192	1108	60	699.39							
13	1.440	1.154	1122	192	1105	65	700.74							
14	1.440	1.154	1122	192	1106	70	702.07							
15	1.310	1.141	1124	193	1106	75	703.36							
16	1.440	1.153	1112	192	1106	80	704.48							
17	1.440	1.153	1120	192	1111	85	705.73							
18	1.315	1.146	1122	192	1115	90	706.98							
19	1.445	1.162	1124	192	1115	95	708.13							
20	1.445	1.161	1124	192	1107	100	709.42							

SOURCE TEST CODING FURN DATA FOR PARTICULATE

DATE: JAN 21 1971
 COMMENTS: PP 1-DIV 5
CD-86381 AS 57.5-1 SQ
PIT 199
SAMPLE 170
 Tester 1: MIKE JON
 Tester 2: _____

	HE	CO ₂	O ₂	CO	H ₂
1					
2					
3					
4					

Impinger Volume	1	2	3
Final	25.7		
Initial	25.0	15.0	

CLIENT: L.P. DANSON Filter No: DD
 Test Number: 2-FORMALDEHYDE Filter No: 17
 Process: PRESS VEST - SPARK # 15565 G6 BB
 Barometric Pressure: 27.82 Assumed Moisture: 0
 Static Pressure: 1-5" H₂O Assumed Meter Temp: _____
 Nozzle Diameter: 1.62 Start Time: 5:14 PM
 Correction Factor: 1.35 Stop Time: 6:30

Leakage Rate @ _____ THG

VM	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUM (THG)	SAMPLE FOR TEMP. (F)	TEMP. LAST WP
	710-99	3 min			
	712-23				
	713-49				
	714-74				
	716-06				
	717-39				
	718-80				
	720-20				
	721-45				
	722-69				
	723-75				
	725-30				
	726-85				
	728-39				
	729-88				
	731-19				
	732-66				
	733-76				
	735-37				
	736-79	738.12			

SAMPLE POINT	VELOCITY HEAD (PSI)	ORIFICE PRESS (PSI)	Time			GAS METER TEMP. OUT (F)	STACK GAS TEMP. (F)
			15	20	25		
1	1.410	1.1512	1910	1816	1816	11118	
2	1.410	1.1513	11106	1818	1818	11118	
3	1.412	1.1517	11112	1818	1818	11108	
4	1.415	1.1611	11114	1818	1818	11109	
5	1.415	1.1611	11118	1818	1818	11104	
6	1.501	1.1607	11104	1818	1818	11106	
7	1.510	1.1607	11112	1910	1910	11112	
8	1.410	1.1513	11118	1910	1910	11112	
9	1.410	1.1514	11120	1910	1910	11115	
10	1.310	1.1411	11122	1910	1910	11107	
11	1.621	1.1821	11106	1818	1818	11115	
12	1.621	1.1812	11118	1910	1910	11120	
13	1.518	1.1717	11124	1910	1910	11111	
14	1.518	1.1719	11121	1910	1910	11109	
15	1.410	1.1515	11122	1912	1912	11107	
16	1.515	1.1713	11106	1818	1818	11118	
17	1.410	1.1514	11110	1910	1910	11109	
18	1.510	1.1618	11120	1910	1910	11107	
19	1.510	1.1618	11122	1916	1916	11107	
20	1.410	1.1514	11122	1910	1910	11106	

SOURCE TEST CODING JRM Data for Particulate

CLIENT: L.P. DANSON

Test Number: _____

Process: SCANNAS KESSEL

Barometric Pressure: 27.8

Static Pressure: 4.19" H₂O

Nozzle Diameter: 26.5

Filter No.: 14

Flask No.: 14

Sizes Gals: 4

Assumed Moisture: 10

Assumed Meter Temp.: _____

Start Time: 8:52

Stop Time: _____

TIME	CO ₂	O ₂	CO	H ₂
1				
2				
3				
4				

Impinger Volume: 1 2 3

Final: _____

Initial: 250 150

DATE: JAN 22 1964

Comments: M 1.0195

CP 85988 AS 675-11

PLOT 14A

CALIBRATE 170

Tester 1: M. K. DANSON

Tester 2: _____

Leakage Rate @ THG 15

C Correction Factor: 3.7

SAMPLE POINT	5		10		15		20		25		30	
	VELOCITY HEAD (H ₂ O)	ORIFICE PRESS (H ₂ O)	GAS METER TEMP. IN (F)	GAS METER TEMP. OUT (F)	GAS METER TEMP. IN (F)	GAS METER TEMP. OUT (F)	STACK GAS TEMP. (F)	TIME	TIME	TIME	TIME	TIME
1	1.1181	1.1614	11910	11818	131914							
2	1.1171	1.1617	11916	11816	131910							
3	1.1161	1.1611	11014	11816	131911							
4	1.1151	1.1619	11018	11816	131912							
5	1.1141	1.1612	11111	11816	131912							
6	1.1131	1.1615	11112	11816	131913							
7	1.1121	1.1612	11114	11816	131916							
8	1.1111	1.1618	11116	11817	131916							
9	1.1101	1.1617	11119	11818	131916							
10	1.1111	1.1618	11212	11818	131916							
11	1.1111	1.1618	11210	11818	131917							
12	1.1111	1.1619	11212	11818	131918							
13	1.1111	1.1618	11212	11818	131919							
14	1.1111	1.1616	11212	11818	131917							
15	1.1111	1.1617	11212	11818	131917							
16	1.1111	1.1615	11212	11818	131915							
17	1.1111	1.1616	11213	11818	131916							
18	1.1111	1.1619	11213	11818	131915							
19	1.1111	1.1618	11213	11818	131915							
20	1.1111	1.1617	11213	11818	131914							

VM	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUM (THG)	SAMPLE PZL TEMP. (F)	TEMP. (F)
	738.24	2 MN			
	739.14		2.9		
	740.06		5		
	741.00		7.3		
	741.92		9.8		
	742.74		12.6		
	743.62		15.8		
	744.52		19.8		
	745.46		25.6		
	746.45		41.4		
	747.34		47		
	748.36		57.2		
	749.17		58.4		
	750.04		57.2		
	750.86		59.7		
	751.55		62		
	752.32		64		
	753.17		66		
	754.04				
	754.92				

COUPON TEST COUPLING ERROR Data for Particulate Emissions

Client: C.P. Dawson
 Test Number: 1 Unit
 Process: KINDAS RESEET
 Barometric Pressure: 27.8
 Static Pressure: _____
 Nozzle Diameter: _____
 Correction Factor: _____

Filter No.: 14
 Flask No.: 14
 Sides Cut: 14
 Assumed Moisture: _____
 Assumed Meter Temp.: _____
 Start Time: _____
 Stop Time: 10:18

Date: JUNE 24/44
 Comments: _____
 Tester 1: _____
 Tester 2: _____
 Leakage Rate @ 2 m/h

TIME	CO ₂	O ₂	CO	H ₂
1				
2				
3				
4				

Impinger Volume	1	2	3
Final	450		
Initial			

SAMPLE POINT	5		6		7		8		9		10		11		12		13		14		15		16		17		18							
	ΔP	ΔH	ORIFICE PRESS (P ₁ O)	GAS METER TEMP. IN (F)	GAS METER TEMP. OUT (F)	STACK GAS TEMP. (F)	VELOCITY HEAD (M ₁ O)	ORIFICE PRESS (P ₁ O)	GAS METER TEMP. IN (F)	GAS METER TEMP. OUT (F)	STACK GAS TEMP. (F)	VELOCITY HEAD (M ₁ O)	ORIFICE PRESS (P ₁ O)	GAS METER TEMP. IN (F)	GAS METER TEMP. OUT (F)	STACK GAS TEMP. (F)	VELOCITY HEAD (M ₁ O)	ORIFICE PRESS (P ₁ O)	GAS METER TEMP. IN (F)	GAS METER TEMP. OUT (F)	STACK GAS TEMP. (F)	VELOCITY HEAD (M ₁ O)	ORIFICE PRESS (P ₁ O)	GAS METER TEMP. IN (F)	GAS METER TEMP. OUT (F)	STACK GAS TEMP. (F)	VELOCITY HEAD (M ₁ O)	ORIFICE PRESS (P ₁ O)	GAS METER TEMP. IN (F)	GAS METER TEMP. OUT (F)	STACK GAS TEMP. (F)			
1	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113
2	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113
3	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113
4	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113
5	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113
6	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113
7	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113
8	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113
9	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113
10	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113
11	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113
12	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113
13	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113
14	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113
15	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113
16	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113
17	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113
18	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113	1.1181	1.1181	1.1519	1120	1912	13113

Vm	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUM (HG)	SAMPLE BOX TEMP. (F)	TEMP. LAST WP
755-77	756-64	2 min			
757-51	758-38				
759-30	760-20				
761-05	761-90				
762-74	763-62				
764-50	765-38				
766-26	767-11				
767-90	768-75				
769-61					

Customer: L.P. DANIN
 Test Number: 2
 Process: KASSEL
 Barometric Pressure: 30.1
 Static Pressure: 12.4
 Nozzle Diameter: 2.5

Filter No.: 16
 Flash No.: 16
 Sizes Gals: 16
 Assumed Moisture: 1.2
 Assumed Meter Temp: 10.23
 Start Time: 10:23
 Stop Time: 10:23

Date: JUNE 27 1944
 Comments: CP 85988 AS 24-85
2107 144
CONTRACT 170
 Tester 1: MIKLE/DAN
 Tester 2: _____
 Leakage Rate @ _____ 7HG

TIME	CO ₂	O ₂	CO	H ₂
1	4	17		
2				
3				
4				

Impinger Volume	1	2	3
Final			
Initial	710	157	

SAMPLE POINT	VELOCITY HEAD (P ₃₀)	ORIFICE PRESS (P ₁₀)	Time				GAS METER TEMP. OUT (F°)	GAS METER TEMP. IN (F°)	STACK GAS TEMP. (F°)	GAS SAMPLE VOLUME (FT ³)	PUMP VACUUM (HG)	SAMPLE NO. TEMP. (F°)	TEMP. LAST W.P.
			5	10	15	20							
1	1.117	1.155	1.1918	1.1918	1.1914	1.1912	1.1912	1.1912	769.80	2 m			
2	1.117	1.156	1.1118	1.1118	1.1118	1.1118	1.1118	1.1118	770.63				
3	1.117	1.156	1.1114	1.1114	1.1119	1.1111	1.1111	1.1111	771.47				
4	1.115	1.159	1.1126	1.1126	1.1119	1.1112	1.1112	1.1112	772.31				
5	1.114	1.163	1.1128	1.1128	1.1100	1.1100	1.1100	1.1100	773.18				
6	1.113	1.159	1.1130	1.1130	1.1100	1.1100	1.1100	1.1100	774.07				
7	1.112	1.156	1.1130	1.1130	1.1100	1.1100	1.1100	1.1100	774.93				
8	1.111	1.156	1.1130	1.1130	1.1100	1.1100	1.1100	1.1100	775.77				
9	1.110	1.153	1.1130	1.1130	1.1100	1.1100	1.1100	1.1100	776.61				
10	1.111	1.159	1.1130	1.1130	1.1100	1.1100	1.1100	1.1100	777.43				
11	1.118	1.159	1.1130	1.1130	1.1100	1.1100	1.1100	1.1100	776.29				
12	1.117	1.156	1.1130	1.1130	1.1100	1.1100	1.1100	1.1100	779.15				
13	1.116	1.159	1.1130	1.1130	1.1100	1.1100	1.1100	1.1100	780.00				
14	1.115	1.162	1.1132	1.1132	1.1100	1.1100	1.1100	1.1100	780.87				
15	1.114	1.162	1.1132	1.1132	1.1100	1.1100	1.1100	1.1100	781.72				
16	1.113	1.160	1.1132	1.1132	1.1100	1.1100	1.1100	1.1100	782.65				
17	1.112	1.153	1.1132	1.1132	1.1100	1.1100	1.1100	1.1100	783.53				
18	1.111	1.160	1.1132	1.1132	1.1100	1.1100	1.1100	1.1100	784.35				
19	1.111	1.155	1.1110	1.1110	1.1100	1.1100	1.1100	1.1100	785.22				
20	1.111	1.156	1.1122	1.1122	1.1100	1.1100	1.1100	1.1100	786.09				

SOURCE TEST CORRECTING FACTOR DATA FOR PARTICULATE / GASEOUS EMISSIONS P. 40

CLIENT: L.P. DANIN
 Test Number: 2 LAST
 Process: KESLER
 Barometric Pressure: 27.6
 Static Pressure: 0.65
 Nozzle Diameter: 0.65
 "C" Correction Factor: 1

TIME	CO ₂	O ₂	CO	N ₂
1	4	17		
2				
3				
4				

Impinger Volume	1	2	3
Final:	450		
Initial:	250	150	

Date: JAN 22/94
 Comments: _____
 Tester 1: MAKE/DW
 Tester 2: _____
 Leakage Rate @ "HG/15"

SAMPLE POINT	VELOCITY HEAD (H ₂ O)	ORIFICE PRESS (H ₂ O)	GAS METER TEMP. (F°)			STACK GAS TEMP. (F°)
			15 Tm	20 Tmz	25 Ts	
1	0.1151	0.419	11310	11100	1400	
2	0.1161	0.513	1130	11100	13918	
3	0.1151	0.419	1132	1100	1401	
4	0.1171	0.516	1132	11010	1401	
5	0.1161	0.513	1132	11010	1402	
6	0.1161	0.513	1132	1100	1403	
7	0.1171	0.516	1132	1100	1403	
8	0.1151	0.419	1132	1100	1404	
9	0.1161	0.513	1134	1100	1405	
10	0.1171	0.513	1134	1100	1398	
11	0.1151	0.419	1134	1101	1405	
12	0.1171	0.516	1134	1101	1401	
13	0.1171	0.516	1134	1101	1399	
14	0.1151	0.510	1134	1101	1397	
15	0.1151	0.50	1134	1101	1395	
16	0.1151	0.510	1135	1102	1394	
17	0.1151	0.515	1135	1102	1394	
18	0.1151	0.515	1135	1102	1394	
19	0.1151	0.515	1135	1102	1394	
20	0.1151	0.515	1135	1102	1394	

Vm	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUM ("HG)	SAMPLE BOX TEMP. (F°)	TEMP. OF LAST IMP. (F°)
786.95	2 MRS.				
787.77					
788.62					
789.42					
790.30					
791.15					
792.00					
792.87					
793.67					
794.47					
795.29			76.5		
796.07					
796.90					
797.74					
798.56					
799.36					
800.14					

SOURCE TEST CODING . JRM . Data for Particulate / Gaseous Emissions

Page No. _____

CLIENT: L. PACIFIC DAWEN
 Test Number: 1-MD1
 Process: BACHAUSE
 Barometric Pressure: 27.8
 Static Pressure: -20.01140
 Nozzle Diameter: 0.185
 "C" Correction Factor: _____

Date: JUNE 20/94
 Comments: DIAN 325 0561
AS 576 DOWN 20 FT UN 75"
3.4, 6.3, 10.4, 22.0, 26.7, 29.7
CP 8662 MERA 1.015
 Tester 1: PIVY7
 Tester 2: CCN880
 Leakage Rate @ REG IN OIS "HG" TS1
END 013

TIME	CO ₂	O ₂	CO	N ₂
1	0	21		
2	0	21		
3				
4				

Impinger Volume	1	2	3
Final:	212	205	195
Initial:	300	200	200

SAMPLE POINT	5		4		3		2		1		Ts
	ΔP	VELOCITY HEAD (H ₂ O)	ORIFICE PRESS (H ₂ O)	GAS METER TEMP. IN (°F)	GAS METER TEMP. OUT (°F)	STACK GAS TEMP. (°F)	T _{im}	T _{im}	T _s		
1	1.18101	11.18101	11.18101	1718	1714	1719					
2	1.18151	11.18151	11.18151	1811	1711	1711					
3	1.19101	11.19101	11.19101	1813	1715	1711					
4	1.17151	11.17151	11.17151	1815	1716	1718					
5	1.14111	11.14111	11.14111	1819	1716	1710					
6	1.13111	11.13111	11.13111	1910	1810	1818					
7	1.12111	11.12111	11.12111	1914	1811	1910					
8	1.11121	11.11121	11.11121	1917	1812	1910					
9	1.11111	11.11111	11.11111	1818	1814	1714					
10	1.14111	11.14111	11.14111	1917	1816	1619					
11	1.14111	11.14111	11.14111	1101	1817	1618					
12	1.19111	11.19111	11.19111	1103	1818	1812					
13	1.18111	11.18111	11.18111	1104	1818	1817					
14	1.13111	11.13111	11.13111	1105	1910	1911					
15	1.13111	11.13111	11.13111	1105	1912	1911					
16	1.11111	11.11111	11.11111	1106	1912	1911					
17	1.01111	11.01111	11.01111								
18	1.01111	11.01111	11.01111								
19	1.01111	11.01111	11.01111								
20	1.01111	11.01111	11.01111								

Vm	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUM (THG)	SAMPLE BOX TEMP. (F°)	TEMP. OF LAST IMP. (F°)
	163.61	4	PROBE WASH		
	165.92		OF 1ST 1/4" SECTION		
	168.30		COUNTER		
	170.78				
	173.13		NOT ABOUT TO SAMPLE		
	175.65		180.46 (T _{im})		
	177.97		GOING TO SAMPLE		
	180.22		AT 1/4" 1.0		
	182.51		FOR RES		
	184.77		OF 1/4"		
	186.98				
	189.20				
	191.43				
	193.67				
	195.92				
	198.17				
	200.36				

← TULLUENE AFTER 1/4" SWEEP AFTER 1/4" TAP CHANGING. USED UP

SOURCE TEST CODING FORM Data for Particulate / Gaseous Emissions

CLIENT: L PACIFIC DAWSON
 Filter No.: 1
 Test Number: 1 PHENOLS
 Flask No.: 1
 Process: BAGHOUSE
 Silica Gel: 1
 Assumed Moisture: 1
 Barometric Pressure: 27.82
 Assumed Meter Temp.: _____
 Static Pressure: -26.4 "H2O
 Nozzle Diameter: 0.125
 Start Time: 10:10
 Stop Time: 10:44
 "C" Correction Factor: _____

TIME	CO ₂	O ₂	CO	N ₂
1	0	21		
2				
3				
4				

Impinger Volume	1	2	3
Final:	405		
Initial:	400		

Date: JUNE 21/94
 Comments: AS 5.76
CP 8667 MERCK 1.015
 Tester 1: PJT 147
 Tester 2: CON 980
 Leakage Rate @ 0.15 "HG 15
 @ 0.13 "HG 15

SAMPLE POINT	VELOCITY HEAD (H ₂ O)	ORIFICE PRESS (H ₂ O)	Time			GAS METER TEMP. OUT (F°)	GAS METER TEMP. IN (F°)	STACK GAS TEMP. (F°)
			5	10	15			
1	11.02	11.035	11.177	11.174	11.164			
2	11.02	11.035	11.180	11.174	11.164			
3	11.02	11.035	11.187	11.170	11.164			
4	11.02	11.035	11.188	11.170	11.184			
5	11.03	11.037	11.197	11.178	11.190			
6	11.03	11.037	11.189	11.180	11.197			
7	11.03	11.037	11.193	11.182	11.198			
8	11.03	11.037	11.195	11.183	11.191			
9	11.08	11.037	11.186	11.180	11.177			
10	11.03	11.037	11.199	11.186	11.166			
11	11.07	11.040	11.196	11.188	11.184			
12	11.04	11.040	11.190	11.189	11.187			
13	11.04	11.041	11.192	11.189	11.196			
14	11.05	11.044	11.192	11.190	11.193			
15	11.05	11.044	11.192	11.191	11.192			
16	11.05	11.044	11.192	11.191	11.189			
17	11.01	11.011	11.111	11.111	11.111			
18	11.01	11.011	11.111	11.111	11.111			
19	11.01	11.011	11.111	11.111	11.111			
20	11.01	11.011	11.111	11.111	11.111			

Vm	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUM (HG)	SAMPLE BOX TEMP. (F°)	TEMP. OF LAST IMP. (F°)
235.99	4 MIN	8.5V			
237.87					
238.56		GLASS AFFER FILTER			
239.82		+ CONDENSEL + COND			
241.11		KNOCK UP WERE			
248.42		ACC RINSED WITH			
243.62		1:1 METHYLENE CHLORIDE			
245.04		F METHANOL + SAVER			
246.41		SEPARATELY			
247.80					
249.17		IMPINGER CONT WERE			
250.52		ALSO SAVER IN			
251.02		SEPARATE CONT.			
253.46					
254.98					
256.49					
258.00					

SOURCE TEST CODING FORM Data for Particulate / Gaseous Emissions

CLIENT: L PACIFIC
 Test Number: 2 PHEAOL
 Process: BAGHOUSE
 Barometric Pressure: 27.82
 Static Pressure: -20.4" H₂O
 Nozzle Diameter: 0.125
 "C" Correction Factor: _____
 Filter No.: 2
 Flask No.: 2
 Silica Gel: 2
 Assumed Moisture: 1
 Assumed Meter Temp.: _____
 Start Time: 18:55
 Stop Time: 9:07

TIME	CO ₂	O ₂	CO	N ₂
1				
2				
3				
4				

Impinger Volume	1	2	3
Final:			
Initial:			

Date: JUNE 21/94
 Comments: AS 576
CP 8667 MTRD 101F
 Tester 1: _____
 Tester 2: _____
 Leakage Rate @ _____ "HG

SAMPLE POINT	5			10			15			20			25			30			
	AP	VP	ORIFICE PRESS (H ₂ O)	GAS METER TEMP. IN (F°)	GAS METER TEMP. OUT (F°)	STACK GAS TEMP. (F°)	AP	VP	ORIFICE PRESS (H ₂ O)	GAS METER TEMP. IN (F°)	GAS METER TEMP. OUT (F°)	STACK GAS TEMP. (F°)	AP	VP	ORIFICE PRESS (H ₂ O)	GAS METER TEMP. IN (F°)	GAS METER TEMP. OUT (F°)	STACK GAS TEMP. (F°)	
1	AF-181	11.031	11.030	175	175	175	175	175	175	175	175	175	175	175	175	175	175	175	175
2	171	11.031	11.030	178	178	178	178	178	178	178	178	178	178	178	178	178	178	178	178
3	161	11.031	11.030	183	183	183	183	183	183	183	183	183	183	183	183	183	183	183	183
4	151	11.031	11.030	186	186	186	186	186	186	186	186	186	186	186	186	186	186	186	186
5	141	11.031	11.030	189	189	189	189	189	189	189	189	189	189	189	189	189	189	189	189
6	131	11.031	11.030	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192	192
7	121	11.031	11.030	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194	194
8	111	11.031	11.030	196	196	196	196	196	196	196	196	196	196	196	196	196	196	196	196
9	AF-181	11.031	11.030	187	187	187	187	187	187	187	187	187	187	187	187	187	187	187	187
10	171	11.031	11.030	197	197	197	197	197	197	197	197	197	197	197	197	197	197	197	197
11	161	11.031	11.030	198	198	198	198	198	198	198	198	198	198	198	198	198	198	198	198
12	151	11.031	11.030	197	197	197	197	197	197	197	197	197	197	197	197	197	197	197	197
13	141	11.031	11.030	197	197	197	197	197	197	197	197	197	197	197	197	197	197	197	197
14	131	11.031	11.030	196	196	196	196	196	196	196	196	196	196	196	196	196	196	196	196
15	121	11.031	11.030	198	198	198	198	198	198	198	198	198	198	198	198	198	198	198	198
16	111	11.031	11.030	198	198	198	198	198	198	198	198	198	198	198	198	198	198	198	198
17																			
18																			
19																			
20																			

Vm	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUM ("HG)	SAMPLE BOX TEMP. (F°)	TEMP. OF LAST IMP.
258.18	4	8.5			
259.52					
260.95					
262.45					
263.87					
265.30					
266.75					
268.18					
269.58					
270.97					
272.39					
273.91					
275.26					
276.65					
278.08					
279.53					
280.94					

SOURCE TEST CODING . ORM / Data for Particulate / Gaseous Emissions

CLIENT: L PACIFIC DAWSON
Test Number: 1 FORMAL
Process: BAGHOUSE
Filler No.: 2
Flask No.: 2
Silica Gel: _____
Assumed Moisture: 1
Assumed Meter Temp.: _____
Start Time: 2:55
Stop Time: 4:06
Barometric Pressure: 27.82
Static Pressure: -20.4 H2O
Nozzle Diameter: 1.25
"C" Correction Factor: _____

TIME	CO ₂	O ₂	CO	N ₂
1	0	21		
2				
3				
4				

Impinger Volume	1	2	3
Final:	150	150	
Initial:	150	150	

Date: JUNE 21/94
Comments: AS 5.76
CP-8667 MERCEN 1.0115
Tester 1: CON GRU
Tester 2: PLI 147
Leakage Rate @ _____ "HG"

SAMPLE POINT	5		10		15		20		25		30	
	ΔP	VELOCITY HEAD (H ₂ O)	ORIFICE PRESS (H ₂ O)	GAS METER TEMP. IN (F)	GAS METER TEMP. OUT (F)	STACK GAS TEMP. (F)						
1	11.031	11.031	11.037	175	175	181						
2	11.031	11.031	11.037	180	175	181						
3	11.031	11.031	11.043	185	175	179						
4	11.031	11.031	11.034	182	175	191						
5	11.031	11.031	11.037	186	177	1101						
6	11.031	11.031	11.037	190	178	1102						
7	11.031	11.031	11.037	194	179	1101						
8	11.031	11.031	11.037	196	181	1113						
9	11.031	11.031	11.037	188	181	1719						
10	11.031	11.031	11.037	198	183	1716						
11	11.031	11.031	11.037	11010	184	181						
12	11.031	11.031	11.035	11005	185	1910						
13	11.031	11.031	11.038	11012	186	11011						
14	11.031	11.031	11.038	11012	187	11011						
15	11.031	11.031	11.037	11012	187	11012						
16	11.031	11.031	11.037	11012	188	11011						
17	11.031	11.031	11.031	11.031	11.031	11.031						
18	11.031	11.031	11.031	11.031	11.031	11.031						
19	11.031	11.031	11.031	11.031	11.031	11.031						
20	11.031	11.031	11.031	11.031	11.031	11.031						

Vm	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUM (HG)	SAMPLE BOX TEMP. (F)	TEMP. OF LAST IMP. (F)
281.11	L				
282.54					
283.98					
285.51					
286.94					
288.44					
289.83					
291.25					
292.71					
294.09					
295.51					
296.97					
298.27					
299.73					
301.15					
302.54					
303.93					

SOURCE TEST CODING FORM Data for Particulate / Gaseous Emissions

CLIENT: L. PACIFIC
 Filter No.: 2
 Test Number: 2 FERNALDI
 Flask No.: _____
 Process: BAGHOUSE
 Silica Gel: 2
 Assumed Moisture: 1
 Barometric Pressure: 27.82
 Assumed Meter Temp.: _____
 Static Pressure: -20.4
 Assumed Meter Temp.: _____
 Nozzle Diameter: 0.125
 Start Time: 4:45
 "C" Correction Factor: _____
 Stop Time: 5:55

TIME	CO ₂	O ₂	CO	N ₂
1				
2				
3				
4				

Impinger Volume	1	2	3
Final	310		
Initial	200		

Date: JUNE 21/94
 Comments: AS 5.76
CP 8667 METER 1.0115
 Tester 1: _____
 Tester 2: _____
 Leakage Rate @ 010 "HG" _____

SAMPLE POINT	5			10			15			20			25			30			
	ΔP	VELOCITY HEAD (H ₂ O)	ORIFICE PRESS (H ₂ O)	GAS METER TEMP. IN (F°)	GAS METER TEMP. OUT (F°)	STACK GAS TEMP. (F°)	ΔP	VELOCITY HEAD (H ₂ O)	ORIFICE PRESS (H ₂ O)	GAS METER TEMP. IN (F°)	GAS METER TEMP. OUT (F°)	STACK GAS TEMP. (F°)	ΔP	VELOCITY HEAD (H ₂ O)	ORIFICE PRESS (H ₂ O)	GAS METER TEMP. IN (F°)	GAS METER TEMP. OUT (F°)	STACK GAS TEMP. (F°)	
1	A1-181	11.031	1.0316	172	177	185													
2	17	11.031	1.0316	182	176	186													
3	16	11.031	1.0316	186	177	183													
4	15	11.031	1.0316	189	177	191													
5	14	11.031	1.0318	191	178	190													
6	13	11.031	1.0317	193	179	197													
7	12	11.031	1.0317	195	180	193													
8	11	11.031	1.0317	197	181	191													
9	A1-181	11.031	1.0317	187	182	187													
10	17	11.031	1.0317	199	184	180													
11	16	11.031	1.0317	191	185	187													
12	15	11.031	1.0317	192	186	191													
13	14	11.031	1.0317	193	188	191													
14	13	11.031	1.0318	194	188	192													
15	12	11.031	1.0318	196	190	191													
16	11	11.031	1.0318	197	191	192													
17		1.0	1.0	1.0	1.0	1.0													
18		1.0	1.0	1.0	1.0	1.0													
19		1.0	1.0	1.0	1.0	1.0													
20		1.0	1.0	1.0	1.0	1.0													

V _m	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUM ("HG)	SAMPLE BOX TEMP. (F°)	TEMP. OF LAST IMP. (F°)
	304.13	4			
	305.55				
	306.98				
	308.40				
	309.78				
	311.17				
	312.55				
	313.93				
	315.30				
	316.67				
	318.02				
	319.39				
	320.76				
	322.11				
	323.50				
	324.83				
	326.19				

SOURCE TEST CODING - CRM Data for Particulate / Gaseous Emissions

CLIENT: PACIFIC DANSON
 Filter No.: 5
 Test Number: 3 MD1
 Flask No.: 3
 Process: PRESS VENT
 Silica Gel: 3
 Assumed Moisture: 0
 Barometric Pressure: 27.75
 Assumed Meter Temp.: _____
 Static Pressure: -0.6 H₂O
 Start Time: 10:57
 Nozzle Diameter: .185
 Stop Time: 12:11

TIME	CO ₂	O ₂	CO	N ₂
1	0	21		
2				
3				
4				

Impinger Volume	1	2	3
Final:	625		
Initial:	300	200	200

Date: JUNE 22/94
 Comments: AS 2294 575X575
C.P. 85362 MESSER-1-0115
5.75 17.25 28.75 40.25
51.75 0:21
 Tester 1: PJT
 Tester 2: CON 980

Leakage Rate @ _____ °HG

SAMPLE POINT	5		4		3		2		1	
	AP	ΔH	ΔH	ΔH	ΔH	ΔH	ΔH	ΔH	ΔH	ΔH
1	1.1151	11.138	11.187	11.185	11.185	11.185	11.185	11.185	11.185	11.185
2	1.1510	11.128	11.191	11.185	11.185	11.185	11.185	11.185	11.185	11.185
3	1.1510	11.181	11.194	11.185	11.185	11.185	11.185	11.185	11.185	11.185
4	1.1510	11.184	11.196	11.190	11.190	11.190	11.190	11.190	11.190	11.190
5	1.1315	11.195	11.101	11.188	11.188	11.188	11.188	11.188	11.188	11.188
6	1.1315	11.190	11.195	11.190	11.190	11.190	11.190	11.190	11.190	11.190
7	1.1610	11.185	11.162	11.190	11.190	11.190	11.190	11.190	11.190	11.190
8	1.1515	11.140	11.103	11.191	11.191	11.191	11.191	11.191	11.191	11.191
9	1.1515	11.140	11.105	11.192	11.192	11.192	11.192	11.192	11.192	11.192
10	1.1315	11.192	11.106	11.192	11.192	11.192	11.192	11.192	11.192	11.192
11	1.1515	11.130	11.101	11.194	11.194	11.194	11.194	11.194	11.194	11.194
12	1.1510	11.130	11.105	11.194	11.194	11.194	11.194	11.194	11.194	11.194
13	1.1510	11.130	11.107	11.194	11.194	11.194	11.194	11.194	11.194	11.194
14	1.1415	11.118	11.108	11.195	11.195	11.195	11.195	11.195	11.195	11.195
15	1.1315	11.192	11.109	11.195	11.195	11.195	11.195	11.195	11.195	11.195
16	1.1115	11.139	11.100	11.196	11.196	11.196	11.196	11.196	11.196	11.196
17	1.1510	11.129	11.109	11.199	11.199	11.199	11.199	11.199	11.199	11.199
18	1.1510	11.129	11.109	11.199	11.199	11.199	11.199	11.199	11.199	11.199
19	1.1510	11.129	11.110	11.197	11.197	11.197	11.197	11.197	11.197	11.197
20	1.1115	11.111	11.111	11.111	11.111	11.111	11.111	11.111	11.111	11.111

VM	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUM (HG)	SAMPLE BOX TEMP. (F°)	TEMP OF LAST IMP. (F°)
326.56		3			
327.64					
329.48		IMPINGER CONT			
331.40		RIMP RINSING			
333.33		4 CLEAN DEBRIS RINSING			
335.03		AGG IN SALT BUTLE			
336.08		FREN - HALF G			
338.78		GLASSWARE RANSEIN			
340.85		IN ALBI BOX NET			
342.91		SAVED			
344.59					
346.54					
348.47					
350.42					
352.29					
353.96					
355.06					
356.98					
358.93					
360.91		362.55			

SOURCE TEST BUILDING

URM

Data in Publications

Gauss Missiles

P. 10.

CLIENT: L. PACIFIC DALSON
 Filter No.: 3
 Test Number: 4 MD1
 Flask No.: 3
 Process: PRESS VENT
 Silica Gel: 3
 Assumed Moisture: 0
 Barometric Pressure: 27.75
 Assumed Meter Temp.:
 Static Pressure:
 Start Time: 12:4
 Nozzle Diameter: 0.185
 Stop Time: 2:13
 "C" Correction Factor:

TIME	CO ₂	O ₂	CO	N ₂
1	0	21		
2				
3				
4				

Impinger Volume	1	2	3
Final:	610		
Initial:			

Date: JUNE 22/94
 Comments: AS 22.96
CP 85362 METEA 1.0815
 Tester 1:
 Tester 2:
 Leakage Rate @ "HG

SAMPLE POINT	5			4			3			2			1		
	ΔP	VELOCITY HEAD (H ₂ O)	ORIFICE PRESS (H ₂ O)	GAS METER TEMP. IN (F°)	GAS METER TEMP. OUT (F°)	STACK GAS TEMP. (F°)	T _{ms}	T _{ms}	T _{ms}	T _{ms}	T _{ms}	T _{ms}	T _{ms}	T _{ms}	T _{ms}
1	1.151	1.1101	11.1215	1912	1911	11219									
2	1.141	1.1510	11.1216	1916	1911	11315									
3	1.131	1.1510	11.1216	1918	1911	11110									
4	1.121	1.1510	11.1310	11210	1911	11118									
5	1.111	1.1510	11.1219	11211	1912	11113									
6	1.151	1.1510	11.1216	1914	1912	11210									
7	1.141	1.1510	11.1216	1918	1912	11116									
8	1.131	1.1510	11.1216	11101	1912	11116									
9	1.121	1.1415	11.1117	11101	1913	11212									
10	1.111	1.1310	11.1177	11101	1914	11115									
11	1.151	1.1510	11.1216	1919	1914	11213									
12	1.141	1.1415	11.1113	11103	1914	11119									
13	1.131	1.1510	11.1216	11106	1915	11112									
14	1.121	1.1510	11.1216	11107	1915	11113									
15	1.111	1.1315	11.1218	11108	1916	11112									
16	1.151	1.1110	11.1215	1918	1917	11218									
17	1.141	1.1417	11.1210	11107	1917	11312									
18	1.131	1.1415	11.1115	11108	1917	11114									
19	1.121	1.1610	11.1113	11109	1917	11316									
20	1.111	1.1510	11.1218	11109	1917	11015									

V _m	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUM (7HG)	SAMPLE BOX TEMP. (F°)	TEMP. OF LAST IMP. (F°)
362.73	362.73	3M IN			
363.63	363.63				
365.48	365.48				
367.40	367.40				
369.35	369.35				
371.29	371.29				
373.20	373.20				
375.15	375.15				
377.06	377.06				
378.93	378.93				
380.45	380.45				
382.40	382.40				
384.85	384.85				
386.15	386.15				
388.05	388.05				
389.67	389.67				
390.55	390.55				
392.29	392.29				
394.10	394.10				
396.15	396.15				

**CALIBRATION CERTIFICATE
DRY GAS METER**

DATE: MARCH 24, 1994

CONSOLE MANUF.: NAPP MODEL 31

CONSOLE I.D.: C-980

PARAMETER SUMMARY

	RUN #1	RUN #2	RUN #3
Ta = Ambient (WTM) Temperature (oF.)	55.5	56.0	56.0
P=Pres. Differential at WTM ("Hg)	0.0625	0.1140	0.1589
Pb= Atmospheric Pressure ("Hg)	30.04	30.04	30.04
Pv= Vapour Pressure Water at Temp. Ta ("Hg)	0.4436	0.4517	0.4517
H=Pres. Differential at Orifice	1.0	2.0	3.0
Ti= Dry Test Meter Inlet Temp. (oF.)	75.2	74.6	84.8
To= Dry Test Meter Outlet Temp. (oF.)	64.0	65.0	66.6
Ri= Initial Dry Test volume (ft3)	105.05	110.52	115.95
Rf= Final Dry Test Volume (ft3)	110.03	115.46	120.92
Vj= Initial Wet Test Volume (ft3)	0.0	0.0	0.0
Vf= Final Wet Test Volume (ft3)	5.000	5.000	5.000
Pw= Pb - (^P/13.59) "Hg	29.9775	29.9260	29.8811
Pd= Pb + (^H/13.59) "Hg	30.1136	30.1872	30.2608
Tw= Ta +460 (oR.)	515.5	516.0	516.0
Td= [(Ti + To)/2] + 460 (oR.)	529.6	529.8	535.7
Bw= Pv/Pb ("Hg)	0.0148	0.0150	0.0150
WET TEST METER FACTOR (WTMF)	0.9998	0.9998	0.9998
(Calculated Y Value)(WTMF)	1.0115	1.0145	1.0156
Y (MEAN)(WTMF) =	1.0139		

N.R. MCCALL & ASSOCIATES LTD.

ORIFICE METER CALIBRATION

DATE: MARCH 24, 1994

CONSOLE I.D. C-980

	RUN 1	RUN 2	RUN 3
MD= mol. wt. dry air	28.967	28.967	28.967
Pb=bar. pressure "Hg	30.04	30.04	30.04
Y=gas meter factor	1.0115	1.0115	1.0145
Delta H=	0.5	1	1.5
Ri=int. gas meter vol.	121.1	123.1	125.9
Rf=final gas meter vol.	122.98	125.72	129.08
min. samp	5	5	5
Qm=Y(Rf-Ri)/^T(FT3/MIN)	0.380324	0.530026	0.645222
	59.2	60.4	62.6
Tm=meter out temp. (oR.)	519.2	520.4	522.6
Pm=Pb + ^H	30.07679	30.11358	30.15038
SQRT(Tm/Pm*H/Md)	0.545864	0.772388	0.947397
Ko=orifice const.	0.696737	0.686217	0.681047

Ko MEAN = 0.688

Ko*4*144= 396.2882

N.R. McCALL & ASSOCIATES LTD.

ORIFICE METER CALIBRATION

DATE: MARCH 24, 1994

CONSOLE I.D. C-980

	RUN 4	RUN 5	RUN 6
MD= mol. wt. dry air	28.967	28.967	28.967
Pb=bar. pressure "Hg	30.04	30.04	30.04
Y=gas meter factor	1.0145	1.0156	1.0156
Delta H=	2	2.5	3
Ri=int. gas meter vol.	129.2	133	137.2
Rf=final gas meter vol.	132.81	137.01	141.56
min. samp	5	5	5
Qm=Y(Rf-Ri)/^T(FT3/MIN)	0.732469	0.814511	0.885603
	64.8	67.4	69.4
Tm=meter out temp. (oR.)	524.8	527.4	529.4
Pm=Pb + ^H	30.18717	30.22996	30.26075
SQRT(Tm/Pm*H/Md)	1.095592	1.227192	1.346049
Ko=orifice const.	0.66856	0.663719	0.657928

Ko MEAN = 0.663402

Ko*4*144= 382.1197

N.R. McCALL & ASSOCIATES LTD.

N.R. MCCALL & ASSOCIATES LTD.

CALIBRATION CERTIFICATE S - TYPE PITOT TUBE

DATE:	JAN. 24/94	BAROM. PRESSURE ("Hg)	30.05
PITOT I.D.:	147.0	W. TUNNEL TEMP. (oF.)	68.0
NOZZLE I.D.:	0.25		

WIND VELOCITY (ft/sec).	REF. PITOT IN. H2O	S - TYPE PITOT	PITOT FACTOR
10.10	0.02350	0.02847	0.89944
26.00	0.15564	0.20433	0.86401
40.36	0.37501	0.49160	0.86467
60.22	0.83475	1.09040	0.86620
82.54	1.56840	2.05702	0.86446
100.10	2.30675	3.09565	0.85459
		AVERAGE =	0.86890

NOTE: The new pitot tip should be installed so that the serial number engraved is aligned directly into the gas stream.

N.R. MCCALL & ASSOCIATES LTD.

CALIBRATION - S TYPE PITOT TUBE

DATE:	JAN. 25/94	BAROM. PRESSURE ("Hg)	30.20
PITOT I.D.:	118.0	W. TUNNEL TEMP. (oF.)	66.0
NOZZLE I.D.:	0.25		

WIND VELOCITY (ft/sec)	REF. PITOT IN. H2O	S - TYPE PITOT	PITOT FACTOR
9.57	0.02129	0.03090	0.82175
18.60	0.08032	0.11132	0.84092
38.31	0.34089	0.45851	0.85362
57.91	0.77886	1.03783	0.85763
73.09	1.24093	1.62044	0.86630
100.88	2.36350	3.19626	0.85132
		AVERAGE =	0.84859

NOTE: The new pitot tip should be installed so that the serial number engraved is aligned directly into the gas stream.

SOURCE TEST CODING FORM Data for Particulate / Gaseous Emissions

Date: June 20/94
 Comments: DIAM 32.5 O-61
AS 5.76 DWK 20FT 4475'
3.4, 6.3, 10.4, 22.0, 26.7, 29.7
CP 8669 MEREN 1-0115
 Tester 1: P11147
 Tester 2: CCN 886
 Leakage Rate @ REG. IN 015 "HG 15'
 END 013

TIME	CO ₂	O ₂	CO	N ₂
1	0	21		
2	0	21		
3				
4				

Impinger Volume	1	2	3
Final:	212	205	195
Initial:	300	200	200

CLIENT: L. PACIKAL DAWEN
 Filter No.: 7
 Test Number: 1 - MD1
 Process: BAGHOUSE
 Barometric Pressure: 27.8
 Static Pressure: -20.0" H₂O
 Nozzle Diameter: 0.185
 "C" Correction Factor: _____
 Assumed Moisture: 1
 Assumed Meter Temp.: _____
 Start Time: 1:47
 Stop Time: 2:55

Vm	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUM ("HG)	SAMPLE BOX TEMP. (F°)	TEMP. OF LAST IMP. (F°)
163.61	4	PROBE WAS 4 FEET			
165.92		0-15' 1" SEARCH			
168.30		SEARCH			
170.78		← NOT ABLE TO SEARCH			
173.13		180' AS 11'			
175.65		GOING TO SEARCH			
177.97		AT 10'			
180.22		FOR 10'			
182.51		OFF			
184.77					
186.98					
189.20					
191.43					
193.67					
195.92		← TOLUENE SWELL AFTER 11'			
198.17		1" TAP CHANGE			
200.36		USED UP			

SAMPLE POINT	VELOCITY HEAD (H ₂ O)	ORIFICE PRESS (H ₂ O)	T _m			GAS METER TEMP. OUT (F°)	STACK GAS TEMP. (F°)
			5	10	15		
1	1.1810	11.101	11.178	11.174	11.174	11.171	11.171
2	1.1815	11.101	11.181	11.171	11.171	11.171	11.171
3	1.1910	11.101	11.183	11.175	11.175	11.171	11.171
4	1.1715	11.101	11.185	11.176	11.176	11.178	11.178
5	1.1111	11.101	11.189	11.176	11.176	11.180	11.180
6	1.1121	11.101	11.190	11.180	11.180	11.188	11.188
7	1.1121	11.101	11.194	11.181	11.181	11.190	11.190
8	1.1121	11.101	11.197	11.182	11.182	11.190	11.190
9	1.1111	11.101	11.188	11.184	11.184	11.174	11.174
10	1.1141	11.101	11.197	11.186	11.186	11.169	11.169
11	1.1141	11.101	11.101	11.187	11.187	11.168	11.168
12	1.1911	11.101	11.103	11.188	11.188	11.182	11.182
13	1.1121	11.101	11.194	11.188	11.188	11.187	11.187
14	1.1121	11.101	11.105	11.190	11.190	11.191	11.191
15	1.1121	11.101	11.105	11.192	11.192	11.191	11.191
16	1.1111	11.101	11.106	11.192	11.192	11.191	11.191
17	1.1111	11.101	11.111	11.111	11.111	11.111	11.111
18	1.1111	11.101	11.111	11.111	11.111	11.111	11.111
19	1.1111	11.101	11.111	11.111	11.111	11.111	11.111
20	1.1111	11.101	11.111	11.111	11.111	11.111	11.111

SOURCE TEST CODING JRM Data for Particulate / Gaseous Emissions Page No. _____

Date: JUNE 20/94

Comments: AS 5.76

CP 8667 MEER 1.015

Tester 1: PII 147

Tester 2: CCW 980

Leakage Rate @ 015 "HG _____

TIME	CO ₂	O ₂	CO	N ₂
1	0	21		
2				
3				
4				

Impinger Volume	1	2	3
Final:	215	212	203
Initial:	300	300	300

CLIENT: L PACIFIC DAWSON Filter No.: 7

Test Number: 2 MD1 Flask No.: 7

Process: BAGHOUSE Silica Gel: _____

Barometric Pressure: 27.8 Assumed Moisture: 0

Static Pressure: -20.4" H2O Assumed Meter Temp: _____

Nozzle Diameter: 0.185 Start Time: 4:20

"C" Correction Factor: _____ Stop Time: 5:30

SAMPLE POINT	5	ΔP	10'	ORIFICE PRESS (H ₂ O)	15	T _{im}	20	J _{im}	25	T _s	30	STACK GAS TEMP. (F°)	GAS METER TEMP. OUT (F°)	GAS METER TEMP. IN (F°)	GAS METER TEMP. OUT (F°)	V _m	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUM ("HG)	SAMPLE BOX TEMP. (F°)	TEMP. OF LAST IMP. (F°)	
																						1
1	AI-181	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021
2	1171	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021
3	1161	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021
4	1151	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021
5	1141	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021
6	1131	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021
7	1121	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021
8	1111	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021
9	BF 181	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021
10	1171	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021
11	1161	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021
12	1151	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021
13	1141	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021
14	1131	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021
15	1121	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021
16	1111	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021
17	1101	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021
18	1091	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021
19	1081	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021
20	1071	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021	11.021

V _m	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUM ("HG)	SAMPLE BOX TEMP. (F°)	TEMP. OF LAST IMP. (F°)
200.71		4			
202.71					
204.91					
207.10					
209.85					
211.62					
213.56					
215.75					
217.98					
220.10					
222.36					
224.44					
226.63					
228.82					
230.99					
233.17					
235.32					

SOURCE TEST CODING

ORM Data for Particulate

Gaseous Emissions

Page No. _____

CLIENT: L PACIFIC DAWSON
 Filter No.: 1
 Test Number: 1 PHENOLS
 Process: BAGHOUSE
 Barometric Pressure: 27.82
 Static Pressure: -26.4420
 Nozzle Diameter: 0.125
 Assumed Moisture: 1
 Assumed Meter Temp.: _____
 Start Time: 10:10
 Stop Time: 10:44
 "C" Correction Factor: _____

TIME	CO ₂	O ₂	CO	N ₂
1	0	21		
2				
3				
4				

Impinger Volume	1	2	3
Final	405		
Initial	400		

Date: JUNE 21/94
 Comments: AS 876
CP-8667 MGRK 1.015
 Tester 1: PIT 147
 Tester 2: CON 980
 Leakage Rate @ 015 "HG 15
 @ 013 "HG 15

SAMPLE POINT	VELOCITY HEAD (H ₂ O)	ORIFICE PRESS (H ₂ O)	T _m			GAS METER TEMP. OUT (F°)	STACK GAS TEMP. (F°)
			5	20	30		
1	11.12	11.1315	11.1717	11.1714	11.1614		
2	11.12	11.1315	11.1810	11.1714	11.1614		
3	11.12	11.1315	11.1817	11.1714	11.1614		
4	11.12	11.1315	11.1818	11.1714	11.1814		
5	11.13	11.1317	11.1911	11.1718	11.1910		
6	11.13	11.1317	11.1819	11.1812	11.1917		
7	11.13	11.1317	11.1913	11.1812	11.1918		
8	11.13	11.1317	11.1915	11.1813	11.1911		
9	11.13	11.1317	11.1816	11.1813	11.1717		
10	11.14	11.1410	11.1919	11.1813	11.1616		
11	11.14	11.1410	11.1916	11.1818	11.1814		
12	11.14	11.1410	11.1910	11.1819	11.1817		
13	11.14	11.1411	11.1912	11.1819	11.1916		
14	11.15	11.1414	11.1912	11.1910	11.1913		
15	11.15	11.1414	11.1912	11.1911	11.1912		
16	11.15	11.1414	11.1912	11.1911	11.1819		
17	11.15	11.1414	11.1912	11.1911	11.1819		
18	11.15	11.1414	11.1912	11.1911	11.1819		
19	11.15	11.1414	11.1912	11.1911	11.1819		
20	11.15	11.1414	11.1912	11.1911	11.1819		

Vm	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUM ("HG)	SAMPLE BOX TEMP. (F°)	TEMP. OF LAST IMP. (F°)
235.99	4 min	8.58			
237.87					
238.56		GLASS AFFIX FILTER			
239.82		+ COND. WASH + COND			
241.11		KNOCK UP WASH			
242.42		ACC RINSED WITH			
243.62		1:1 METHYLENE CHLORIDE			
245.04		+ METH. WASH + SAVED			
246.41		SEPARATELY			
247.80					
249.17		IMPINGER CONT WASH			
250.52		ALSO SAVED IN			
251.82		SEPARATE CONT.			
253.46					
254.98					
256.49					
258.00					

SOURCE TEST CODING . ORM Data for Particulate / Gaseous Emissions Page No. _____

CLIENT: L PACIFIC
 Filter No.: 2
 Test Number: 2 PHENOLS
 Flask No.: 2
 Process: RAQHOUSE
 Silica Gel: 2
 Assumed Moisture: 1
 Barometric Pressure: 27.82
 Assumed Meter Temp.: _____
 Static Pressure: -80.4 H2O
 Start Time: 18:59
 Nozzle Diameter: 0.135
 Stop Time: 9:07
 "C" Correction Factor: _____

TIME	CO ₂	O ₂	CO	N ₂
1	0	21		
2				
3				
4				

Impinger Volume	1	2	3
Final:			
Initial:			

Date: JUNE 21/94
 Comments: AS 5.76
CP. 8667 MTA 1012
 Tester 1: _____
 Tester 2: _____
 Leakage Rate @ _____ "HG

Ym	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUM ("HG)	SAMPLE BOX TEMP. (F°)	TEMP. OF LAST IMP. (F°)
	258.18	4	8.5		
	259.56				
	260.95				
	262.45				
	263.87				
	265.30				
	266.75				
	268.18				
	269.58				
	270.97				
	272.39				
	273.91				
	275.26				
	276.65				
	278.08				
	279.53				
	280.94				

	5	10	15	20	25	30
	ΔP	ΔH	ΔH	Time	Time	Ts
1	AF-181	11.13	1.1317	11.175	11.175	11.175
2	11.171	1.1317	1.178	11.174	11.174	11.177
3	11.161	1.1315	1.1413	11.175	11.175	11.175
4	11.151	1.1311	1.1312	11.175	11.175	11.178
5	11.141	1.1311	1.1415	11.176	11.176	11.173
6	11.131	1.1311	1.1418	11.178	11.178	11.173
7	11.121	1.1311	1.1415	11.179	11.179	11.174
8	11.111	1.1311	1.1415	11.181	11.181	11.173
9	AF-191	11.141	1.1411	11.187	11.187	11.172
10	11.171	1.1311	1.1412	11.197	11.197	11.172
11	11.161	1.1311	1.1413	11.198	11.198	11.173
12	11.151	1.1311	1.1314	11.197	11.197	11.186
13	11.141	1.1315	1.1318	11.197	11.197	11.193
14	11.131	1.1311	1.1410	11.196	11.196	11.194
15	11.121	1.1315	1.1318	11.198	11.198	11.194
16	11.111	1.1315	1.1318	11.199	11.199	11.193
17	11.101	1.1311	1.1311	11.199	11.199	11.193
18	11.091	1.1311	1.1311	11.199	11.199	11.193
19	11.081	1.1311	1.1311	11.199	11.199	11.193
20	11.071	1.1311	1.1311	11.199	11.199	11.193

SOURCE TEST CODING / Data for Particulate / Gaseous Emissions

Page No. _____

Date: JUNE 21/94
 Comments: AS 5.76
SP 8667 MEXIA 1-0115

Tester 1: CON 980
 Tester 2: P11147
 Leakage Rate @ _____ "HG

TIME	CO ₂	O ₂	CO	N ₂
1	0	21		
2				
3				
4				

Impinger Volume	1	2	3
Final:	150	150	
Initial:	150	150	

CLIENT: L PACIFIC DAWSON
 Filter No.: 2
 Test Number: 1 FORMALD
 Flask No.: 2
 Process: BAGHOUSE
 Silica Gel: _____
 Barometric Pressure: 27.82
 Assumed Moisture: 1
 Static Pressure: -20.4 "H₂O
 Assumed Meter Temp.: _____
 Nozzle Diameter: 1.25
 Start Time: 2:55
 Stop Time: 4:06
 "C" Correction Factor: _____

SAMPLE POINT	5		4		3		2		1		Ts
	ΔP	ΔH	ΔH	Tm	Tm	Tm	Tm	Tm	Tm		
1	11.131	11.137	11.175	11.175	11.175	11.180	11.180	11.180	11.180	11.180	1810
2	11.131	11.137	11.180	11.180	11.180	11.180	11.180	11.180	11.180	11.180	1810
3	11.131	11.143	11.185	11.185	11.185	11.185	11.185	11.185	11.185	11.185	1719
4	11.131	11.137	11.188	11.188	11.188	11.188	11.188	11.188	11.188	11.188	1917
5	11.141	11.140	11.186	11.186	11.186	11.186	11.186	11.186	11.186	11.186	111011
6	11.131	11.137	11.192	11.192	11.192	11.192	11.192	11.192	11.192	11.192	111012
7	11.131	11.137	11.194	11.194	11.194	11.194	11.194	11.194	11.194	11.194	111011
8	11.131	11.137	11.196	11.196	11.196	11.196	11.196	11.196	11.196	11.196	111113
9	11.131	11.137	11.188	11.188	11.188	11.188	11.188	11.188	11.188	11.188	1719
10	11.131	11.137	11.198	11.198	11.198	11.198	11.198	11.198	11.198	11.198	1716
11	11.131	11.137	11.1010	11.1010	11.1010	11.1010	11.1010	11.1010	11.1010	11.1010	1817
12	11.131	11.135	11.1015	11.1015	11.1015	11.1015	11.1015	11.1015	11.1015	11.1015	1910
13	11.131	11.138	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	111011
14	11.131	11.138	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	111012
15	11.131	11.137	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	111012
16	11.131	11.137	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	111011
17	11.131	11.137	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	111011
18	11.131	11.137	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	111011
19	11.131	11.137	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	111011
20	11.131	11.137	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	11.1012	111011

Vm	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUM ("HG)	SAMPLE BOX TEMP. (F°)	TEMP. OF LAST IMP. (F°)
281.11	4				
282.54					
283.98					
285.51					
286.94					
288.44					
289.83					
291.25					
292.71					
294.09					
295.51					
296.91					
298.27					
299.73					
301.15					
302.50					
303.93					

SOURCE TEST CODING FORM Data for Particulate / Gaseous Emissions

Page No. _____

CLIENT: L PACIFIC Filter No.: 2
 Test Number: 2 FURHALD Flask No.: 2
 Process: BAGHOUSE Silica Gel: 2
 Barometric Pressure: 27.82 Assumed Moisture: 1
 Static Pressure: -20.4 Assumed Meter Temp.: _____
 Nozzle Diameter: 0.125 Start Time: 4:45
 "C" Correction Factor: _____ Stop Time: 5:55

TIME	CO ₂	O ₂	CO	N ₂
1				
2				
3				
4				

Impinger Volume	1	2	3
Final:	310		
Initial:	300		

Date: JUN 21/94
 Comments: AS 5.76
CP 8667 METEA 1.0115
 Tester 1: _____
 Tester 2: _____
 Leakage Rate @ 010 "HG" _____

Vm	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUM (HG)	SAMPLE BOX TEMP. (F°)	TEMP. OF LAST IMP. (F°)
	304.13	4			
	305.55				
	306.98				
	308.40				
	309.78				
	311.17				
	312.55				
	313.93				
	315.30				
	316.67				
	318.02				
	319.39				
	320.76				
	322.11				
	323.50				
	324.83				
	326.19				

SAMPLE POINT	5		10		15		20		25		30	
	AP	VP	ORIFICE PRESS (H ₂ O)	GAS METER TEMP. IN (F°)	GAS METER TEMP. OUT (F°)	STACK GAS TEMP. (F°)	TS	TS	TS	TS	TS	TS
1	A1-181	11.031	1.0316	1712	1717	1815						
2	117	11.031	1.0316	1812	176	186						
3	116	11.031	1.0316	1816	1717	1813						
4	115	11.031	1.0316	1819	1717	1911						
5	114	11.0315	1.0318	1911	1718	11010						
6	113	11.031	1.0317	1913	1719	17017						
7	112	11.031	1.0317	1915	1810	11013						
8	111	11.031	1.0317	1917	1811	11011						
9	A1-181	11.031	1.0317	1817	1812	1817						
10	117	11.031	1.0317	1919	1814	1810						
11	116	11.031	1.0317	11011	1815	1811						
12	115	11.031	1.0317	11012	186	11017						
13	114	11.031	1.0318	11013	1818	11011						
14	113	11.0315	1.0318	11014	1818	11012						
15	112	11.0315	1.0318	11016	1910	11011						
16	111	11.0315	1.0318	11017	1911	11012						
17	110	1.0	1.0	11018	11018	11018						
18	109	1.0	1.0	11019	11019	11019						
19	108	1.0	1.0	11020	11020	11020						
20	107	1.0	1.0	11021	11021	11021						

SOURCE TEST CODING - JRM - Data for Particulate / Gaseous Emissions

CLIENT: L. PACIFIC DANSEN
 Filter No.: 5
 Test Number: 3 MD1
 Flask No.: 3
 Silica Gel: 3
 Process: CRACK VENT
 Assumed Moisture: 0
 Barometric Pressure: 27.75
 Assumed Meter Temp.: _____
 Static Pressure: -0.6 H₂O
 Start Time: 10:57
 Nozzle Diameter: 2.18
 Stop Time: 12:11
 "C" Correction Factor: _____

TIME	CO ₂	O ₂	CO	N ₂
1	0	21		
2				
3				
4				

Impinger Volume	1	2	3
Final:	625		
Initial:	300	200	200

Date: JUNE 22/94
 Comments: AS 2294 57.5x57.5
CRACK VENT MERC 1-0115
5.75 1725 2875 4035
5175 0:20

Tester 1: PIT
 Tester 2: CON 980
 Leakage Rate @ _____ "HG

SAMPLE POINT	ΔP	VELOCITY HEAD (H ₂ O)	ORIFICE PRESS (H ₂ O)	Time			STACK GAS TEMP. (F°)
				15	20	25	
1	1.1151	1.1318	1.187	1.185	1.185	1.185	1.1135
2	1.1510	1.1911	1.185	1.185	1.185	1.185	1.1125
3	1.1510	1.1914	1.186	1.186	1.186	1.186	1.1110
4	1.1510	1.1916	1.190	1.190	1.190	1.190	1.1110
5	1.1315	1.1811	1.188	1.188	1.188	1.188	1.1118
6	1.1315	1.1910	1.195	1.195	1.195	1.195	1.1113
7	1.1610	1.1615	1.162	1.162	1.162	1.162	1.1126
8	1.1515	1.1410	1.1013	1.1013	1.1013	1.1013	1.1112
9	1.1515	1.1410	1.1015	1.1015	1.1015	1.1015	1.1110
10	1.1315	1.1912	1.11016	1.11016	1.11016	1.11016	1.1112
11	1.1515	1.1310	1.11017	1.11017	1.11017	1.11017	1.1113
12	1.1515	1.1310	1.1105	1.1105	1.1105	1.1105	1.1112
13	1.1510	1.1310	1.1107	1.1107	1.1107	1.1107	1.1112
14	1.1415	1.1118	1.1108	1.1108	1.1108	1.1108	1.1114
15	1.1315	1.1912	1.11019	1.11019	1.11019	1.11019	1.1112
16	1.1115	1.1319	1.11010	1.11010	1.11010	1.11010	1.1119
17	1.1510	1.11019	1.11019	1.11019	1.11019	1.11019	1.1120
18	1.1510	1.11019	1.11019	1.11019	1.11019	1.11019	1.1110
19	1.1510	1.11019	1.1110	1.1110	1.1110	1.1110	1.1113
20	1.01	1.01	1.01	1.01	1.01	1.01	1.01

Vm	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUM (HG)	SAMPLE BOX TEMP. (F°)	TEMP. OF LAST IMP. (F°)
326.56	327.64	329.48	331.40	333.33	335.03
336.68	338.78	340.85	342.91	344.59	346.54
348.47	350.42	352.29	353.96	355.06	356.98
358.93	360.91	362.55			

66
132

CLIENT: L. PACIFIC DAWSON
 Filter No.: 3
 Test Number: 4 MD1
 Process: PRESS VENT
 Barometric Pressure: 27.75
 Static Pressure: 218
 Nozzle Diameter: 218
 "C" Correction Factor: _____

TIME	CO ₂	O ₂	CO	N ₂
1	0	21		
2				
3				
4				

Date: JUNE 22 1966
 Comments: AS 22.96
CP 85362 MSEA 1.0815
 Tester 1: _____
 Tester 2: _____
 Leakage Rate @ _____ "HG

Impinger Volume	1	2	3
Final:	610		
Initial:			

Vm	GAS SAMPLE VOLUME (FT ³)	SAMPLE TIME	PUMP VACUUM ("HG)	SAMPLE BOX TEMP. (F°)	TEMP. OF LAST IMP. (F°)
	362.73	3 MIN			
	363.63				
	365.48				
	367.40				
	369.35				
	371.29				
	373.20				
	375.15				
	377.06				
	378.93				
	380.85				
	382.70				
	384.65				
	386.55				
	388.45				
	389.67				
	390.55				
	392.29				
	394.10				
	396.15				

SAMPLE POINT	VELOCITY HEAD (H ₂ O)	ORIFICE PRESS (H ₂ O)	GAS METER			STACK GAS TEMP. (F°)
			TEMP. IN (F°)	TEMP. OUT (F°)	Ts	
1	1.1101	11.1215	11.1912	11.1911	11.1219	
2	1.1510	11.1216	11.1916	11.1911	11.1315	
3	1.1510	11.1216	11.1918	11.1911	11.1110	
4	1.1510	11.1310	11.1910	11.1911	11.1118	
5	1.1510	11.1219	11.1911	11.1912	11.1113	
6	1.1510	11.1216	11.1912	11.1912	11.1210	
7	1.1510	11.1216	11.1918	11.1912	11.1116	
8	1.1510	11.1216	11.1911	11.1912	11.1116	
9	1.1415	11.1117	11.1912	11.1913	11.1212	
10	1.1310	11.1717	11.1914	11.1914	11.1115	
11	1.1510	11.1216	11.1919	11.1914	11.1213	
12	1.1415	11.1713	11.1913	11.1914	11.1119	
13	1.1510	11.1216	11.1916	11.1915	11.1112	
14	1.1510	11.1216	11.1917	11.1915	11.1113	
15	1.1315	11.1818	11.1918	11.1916	11.1112	
16	1.1110	11.1215	11.1918	11.1917	11.1218	
17	1.1417	11.1210	11.1917	11.1917	11.1312	
18	1.1415	11.1115	11.1918	11.1917	11.1114	
19	1.1610	11.1513	11.1919	11.1917	11.1316	
20	1.1510	11.1218	11.1919	11.1917	11.1015	