

# Cold-Climate Air-Source Heat Pumps

February 2018

**Ben Schoenbauer, Senior Research Engineer**

Center for Energy and Environment



# Discover + Deploy

the most effective solutions for a healthy, low-carbon economy





# Minnesota Applied Research & Development Fund

- **Purpose to help Minnesota utilities achieve 1.5% energy savings goal by:**
  - *Identifying new technologies or strategies to maximize energy savings;*
  - *Improving effectiveness of energy conservation programs;*
  - *Documenting CO<sub>2</sub> reductions from energy conservation programs.*

[Minnesota Statutes §216B.241, Subd. 1e](#)

- ***Additional Support from:***
  - ***Great River Energy***
  - ***Electric Power Research Institute***




# Agenda

- Cold Climate Air Source Heat Pump
  - Technology Advancement
  - Opportunity
  - Installation and operation
  - Results
  - Conclusions

# • Cold Climate Air-Source Heat Pump?

- An ASHP uses a refrigerant system involving a compressor, condenser, and evaporator to absorb heat at one place and release it at another.
- Delivery of both heating and cooling via forced air distribution
- New generation systems can operate as low as  $-13^{\circ}\text{F}$
- ASHPs have the potential to deliver energy and peak saving as well as reduce reliance on delivered fuels.





# Opportunity

- Winter of 2013/2014 saw delivered fuel shortages in MN
  - Delivered fuel expensive or unavailable
  - Compensation with electric resistance space heaters
- Market:
  - Delivered fuel are the primary space heating fuel for more than 40% of homes in MN, IA, SD, ND (RECS, 2009)
  - Over 25% of Midwest homes rely on fuels other than natural gas for space heating (RECS, 2009)
  - Over 47% of homes in the US rely on fuels other than natural gas for space heating (RECS, 2009)



# Cold Climate Heat Pump Options

- System type
  - Central whole house ducted
    - Flex Fuel
    - All electric
  - Ductless mini-splits
    - Single Zone
    - Multi Zone
  - Short Duct mini-splits
    - Single Zone
    - Multi Zone



# Cold Climate Heat Pump Options

- System type
  - **Central whole house ducted**
    - **Flex Fuel**
    - All electric
  - Ductless mini-splits
    - Single Zone
    - Multi Zone
  - Short Duct mini-splits
    - Single Zone
    - Multi Zone



# • Ducted Whole House Installation





# Cold Climate Heat Pump Options

- System type
  - **Central whole house ducted**
    - Flex Fuel
    - **All electric**
  - Ductless mini-splits
    - Single Zone
    - Multi Zone
  - Short Duct mini-splits
    - Single Zone
    - Multi Zone

# All Electric Heat Pump





# Cold Climate Heat Pump Options

- System type
  - Central whole house ducted
    - Flex Fuel
    - All electric
  - **Ductless mini-splits**
    - **Single Zone**
    - Multi Zone
  - Short Duct mini-splits
    - Single Zone
    - Multi Zone

# Ductless Heat Pumps





# Cold Climate Heat Pump Options

- System type
  - Central whole house ducted
    - Flex Fuel
    - All electric
  - Ductless mini-splits
    - Single Zone
    - Multi Zone
  - **Short Duct mini-splits**
    - Single Zone
    - Multi Zone

# Ducted Mini Splits





# Installation

- Important Issues:
  - Equipment
  - Sizing
  - Operation
  - Integration with back-up systems






# Installation Scenarios


- Home has forced air systems → Ducted Whole House System
- Homes with hydronic → Ductless Mini Split System
- Homes with electric resistance → Ductless Mini Split System
  
- Does the home need cooling?
  
- What fuel sources are available?

# Manufacturer Specified Performance



Pg. 7

# Cold Climate Specification and Product List



## Download Current ccASHP Specification Listing:

[ColdClimateAir-SourceHeatPumpSpecificationListing-Updated 2.24.17.xlsx](#)

[Skip to details on listing products](#)

On behalf of energy efficiency stakeholders across the Northeast and Mid-Atlantic, Northeast Energy Efficiency Partnerships (NEEP) is pleased to be housing the new Cold Climate Air-Source Heat Pump (ccASHP) Specification and a list of those products that meet the specification's requirements. Those requirements include both specific performance levels as well as a series of reporting requirements.

Energy efficiency stakeholders from the Northeast lack confidence that the existing heating performance metric (HSPF) for air-source heat pumps provides the necessary information to adequately characterize heating performance at low temperatures. In addition, the supplemental information that is provided by manufacturers to demonstrate cold temperature performance is not standardized or consistent. The current performance metric (HSPF) does not include low temperature testing points below 17°F, assumes the use of electric resistance elements, and tests in steady-state operation (as opposed to allowing modulation). These deficiencies add up to measurements that do not accurately reflect performance of the latest generation of air-source heat pumps, designed and optimized to provide heat during cold conditions.

In order to address these concerns, a group of interested stakeholders, working together as part of the

## AIR SOURCE HEAT PUMPS

[Cold Climate Air Source Heat Pump](#)

[Subscribe to our Newsletter!](#)

## RELATED BLOG POSTS



Hot strategies for Cold Climate Air-Source Heat Pumps



NEEP's Greatest Heat Pump Hits

# Specify Ratings (NEEP as example)


- Performance ratings
  - Minimum HSPF rating
    - HSPF  $\geq$  10 at 47 °F
- Capacity Ratings
  - Minimum capacity ratings at 47°F (dry bulb)
    - <65k Btu/hour at 47°F
  - Require percentage of capacity at colder outdoor air conditions
    - 100% maximum rated capacity at 0 °F (not required by NEEP)
- Other performance testing or ratings
  - Metrics: Power draw, capacity, COP
  - At additional temperature levels: 47°F, 17°F, 5°F
- Equipment types
  - Variable Capacity
  - ECM indoor fan



# Operation

- Switchover set point:
  - Primary ccASHP meets load at temps greater than switchover
  - Secondary heating system meets load below switchover
- Primary is priority
  - Runs primary system whenever possible
  - Back up as boost or when primary cannot operate
- Dynamic
  - Considers estimates efficiency and energy costs chooses primary/secondary control based on estimated performance
    - Typically based on operating costs
- Controls:
  - Ducted Systems: automated controls to bring up backup
  - Ductless Systems: manual action by homeowner
- Interaction with back-up systems
  - Ducted Systems: Integrated installs with shared controls
  - Ductless Systems: Separate systems

# System Design: Sizing for Ducted Systems



The OAT for the systems to switch to back up:

4 ton ~3 F

3 ton ~10 F

2 ton ~19 F

Percentage of heating load meet by ASHP:


4 ton ~ 86%,

3 ton ~ 77%

2 ton ~ 60%

\*Targeted a maximum change-over temp of 10 F

# Impact of Change-Over Set Point



# Furnace Integration – Keep or Replace?


- Issues:
  - Air handler requires a multi-stage fan to achieve the full capability of the ccASHPs
  - Furnace and heat pump require integrated controls
- Proposed Solutions:
  - New condensing furnace with control integration
  - New 80% AFUE with multi-stage fan with control integration
  - Retrofit existing system (future?)
  - Plenum electric resistance heater
- Several manufacturers are working on solutions to pair new ASHPs with existing furnaces



# • Ductless Heat Pumps



# • Ductless: Install Location






# Other Installation Considerations

- Refrigerant
  - R-410A
  - What's next?
- Integration with other systems
  - Ventilation
  - Energy recovery
- Control options
  - Cost
  - Environment
  - Minimizing back-up use

# Study Overview

- Field Study
  - 8 ccASHP in a variety of MN residences
    - 6 ducted whole house system
      - 4 flex fuel
      - 2 all electric
    - 2 ductless mini-split systems
  - Monitor installed field performance of ASHP & backup
- Incorporate into Conservation Improvement Program (CIP)
- Climate zones 6 & 7



# Instrumentation

Power Measurements:


- 1) Outdoor unit
- 2) Indoor unit
- 3) Indoor fan
- 4) Reversing valve

Temperatures:

- 5) Supply Air
- 6) Return Air
- 7) Mechanical area ambient
- 8) Conditioned space

Additional:

- 9) Back up fuel consumption
- 10) Delivered air flow
- 11) NOAA data






# Site Equipment


| Site Number | ASHP System                                     | ASHP Size       | ASHP Type | Backup              |
|-------------|---|-----------------|-----------|---------------------|
| 1           | Carrier Infinity with Greenspeed [25VNA048A003] | 4 ton           | Ducted    | LP Cond. Furnace    |
| 2           | Bryant Extreme Heat Pump [280ANV048]            | 4 ton           | Ducted    | LP Cond. Furnace    |
| 3           | Carrier Infinity with Greenspeed [25VNA036A003] | 3 ton           | Ducted    | LP 80% Furnace      |
| 4           | Trane XV20i [4TWV0036A]                         | 3 ton           | Ducted    | LP Cond. Furnace    |
| 5           | Mitsubishi Ductless Hyper Heat [MUZ-FH18NAH]    | 1.5 ton         | Ductless  | Electric Resistance |
| 6           | Mitsubishi Ductless Hyper Heat [MSZ-FH12NA]     | 1 ton (2 units) | Ductless  | Electric Resistance |
| 7           | Mitsubishi Hyper Heat System [PVA-A30AA7]       | 3 ton           | Ducted    | Electric Booster    |
| 8           | Mitsubishi Hyper Heat System [PVA-A30AA7]       | 3 ton           | Ducted    | Electric Booster    |

# Modes of System Operation

- Heating system has 3 modes of operation
  - ASHP heating
  - Back up heating
  - Defrost



# ASHP and Furnace Cycle Efficiency, Site 2




- Without propane:
- COPs 1.5 to 3.5

uces  
 .5  
 out at 10




# Defrost Controls

- Temperature near coil
- Lockout time



# Example: Capacity on a 17 °F day




At 18:45  
 OAT = 15 F  
 House load = 15,300 Btu/hr  
 ASHP Output = 16,700 Btu/hr  
 ASHP Sup Temp = 89 F  
 Airflow = 734 CFM

| mode               | Active time (seconds) | % of Day |
|--------------------|-----------------------|----------|
| Heating            | 72248                 | 83.6%    |
| Heating: ASHP only | 65991                 | 66.0%    |
| Heating: LP Only   | 6549                  | 7.6%     |
| Defrost:           | 8708                  | 10.1%    |

# Cold Temperature Performance of ASHPs

- Ducted ASHPs were capable of delivering heat at outdoor temps from 5 to 10 F
- Ductless systems operated below -13 F.
  - Homeowner in WI has removed several ER baseboards

Site 02 - Ducted ccASHP - Capacity






# Energy Use Analysis


- Measure installed performance data
  - ccASHP with backup mode
  - Baseline mode
- Characterize the heating load of the home
- Create equipment performance models
  
- Summarize system performance and energy use at each site

# Energy Use Vs OAT Models – Flex Fuel

Site 2 Ducted ccASHP




# System Performance



Annual COP: All-elect and ductless ~1.9 to 2.1  
Flex Fuel ~1.2 to 1.3

# Annual Energy Use (by Test Site)



Cooling Savings with increased SEER (13.0 to 16.5+)  
 300 to 500 kWh saved per year or ~\$50/year

# Annual Characteristics and Savings

| Site         | Heating balance Point [F] | Heating Design Load [Btu/hr] | Site Energy Reduction | Cost Reduction | Propane reduction | Savings [\$ /yr] |
|--------------|---------------------------|------------------------------|-----------------------|----------------|-------------------|------------------|
| S_1_ducted   | 62.6                      | 35,468                       | <b>37%</b>            | 28%            | 56%               | <b>\$469</b>     |
| S_2_ducted   | 60.9                      | 30,046                       | <b>46%</b>            | 32%            | 73%               | <b>\$497</b>     |
| S_3_ducted   | 66.1                      | 24,923                       | <b>49%</b>            | 40%            | 67%               | <b>\$767</b>     |
| S_4_ducted   | 64.5                      | 22,778                       | <b>40%</b>            | 30%            | 60%               | <b>\$358</b>     |
| S_6_ductless | 70.1                      | 14,200*                      | <b>52%</b>            | 52%            | NA                | <b>\$610</b>     |
| S_8_ductless | 59.1                      | 9,400*                       | <b>54%</b>            | 54%            | NA                | <b>\$349</b>     |
| S_10_elec    | 70                        | 15,150                       | <b>47%</b>            | 47%            | NA                | <b>\$496</b>     |
| S_12_elec    | 68                        | 26,446                       | <b>48%</b>            | 48%            | NA                | <b>\$833</b>     |

*\* Design loads for ductless systems are estimated and intended as metric to gauge magnitude of heating load.*





# Install Costs

- For the 4 ducted flex fuel systems:
  - Our average cost was ~\$14,000\*
- NREL Residential equipment install database:
  - \$6,340 for ducted 3ton ccASHP
  - \$4,000 for a new condensing propane furnace (\$3,000 for an 80%).
  - \$5,540 for a new comparable SEER A/C
- If furnace or A/C needs replacement
  - Incremental cost ~\$3,000 will results in paybacks around 6 years
- Hard to calculate paybacks for ductless systems.
  - Costs have high variance.
  - Systems are often not direct replacements



# Further discussion of costs

- Incremental equipment costs
  - Vs split system A/C
  - Vs other ASHPs
- Incremental labor costs
  - Vs split system A/C
  - Vs other ASHPs
- Risks
  - Impact of pushing to low temperature performance
- Thermostats and other controls

# Summary of Results

- Cold Climate ASHPs:
  - **Energy Reduced:** 37% and 54% of site energy consumption
  - **Cost Reduced:** total heating costs 28% to 54%
  - **Heating Load Served:** on average ducted ccASHP met 84% of the homes heating loads
  - **Propane Reduction:** propane consumption down by 64%
    - Less than 500 gallons per year at each house
  - Percentage of heating load for ductless largely dependent on usage & install location
  - Provided more efficient space heating
    - Ducted ccASHP COP of 1.4 & ductless COP of 2.3.
    - Compared to a COP 1.0 for ER



# Conclusions

- Field monitoring confirmed expected performance of ccASHPs
- Freeze protection and integration with auxiliary heating are important
- Ducted ccASHPs can heat below 5F, ductless below -13F
- Paybacks are attractive when existing heating or cooling system need to be replaced



# Future Needs – Metrics and Programs

- How should ASHPs be evaluated?
  - Site energy
  - Source energy
  - Carbon reductions
  - Efficiency
  - Homeowner cost
- Impacts of improving equipment
- Impacts of the grid
- Stay tuned for future CEE work

# www.mncee.org/heat\_pumps



[About](#) | [Contact](#) | [News](#) | [Blog](#)

Search



[Services](#) ⋮

[Research](#) ⋮

[Resources](#) ⋮

[Policy](#) ⋮

[Find Financing & Incentives](#) ▶

**News Release**  
**Nonprofits**  
**for greater**  
**and impact**

**CEE and Neighborhood Energy Connection Announce Plans to Merge in 2017**

**Keep Reading** ⋮

[Research Overview](#)

[Research Projects](#)

[Participation Opportunities](#)

[Field Notes Newsletters](#)



Practical energy solutions for homes, businesses, and communities



THANK  
*you!*

Ben Schoenbauer:  
bschoenbauer@mncee.org