

# Complete Compressed Air System Audit Case Study - Southwestern Dairy Products Packaging Plant

To earn Professional Development  
Hours (PDH):

1. Log into the CONEXPO –  
CON/AGG App
2. Go to this session in “Schedule”
3. Check In using the Slider in  
Session Detail



INTERNATIONAL FLUID POWER EXPO

**March 7-11, 2017**

Las Vegas, Nevada, USA

---

# Compressed Air System Audit Case Study: Southwestern Dairy Products Packaging Plant

## Complete Compressed Air System Audit

- ✓ Supply and Demand-Side System Analysis
- ✓ Energy Savings
- ✓ Productivity
- ✓ Reliability Issues
- ✓ Future Projects for Continuous Improvement



# Economics Outline – Current Situation

---

This facility currently spends an estimated **\$159,919** annually on energy to operate the compressed air system.

This figure is based on 11.5 cents per kWh, and operating 8,760 hours per year

The following projects will reduce the total cost by an estimated **\$81,877** or 51%

Additional savings estimated at **\$35,380** will be attained with heat recovery in steam use reduction.

Additional identified operating cost reductions:

- |   |                        |
|---|------------------------|
| - oil and filter change reduction       | \$93,120 year          |
| - elimination premature air end failure | <u>+ \$13,000 year</u> |

Total: \$106,170 year

Total Cost Recovery: **\$228,202 year**

Total Budget Cost: **\$220,000**

Simple pay back period: **12 Months**

# Dairy Product Plant - Overview

## Compressed Air System Review: Executive Summary

PROJECT	SAVINGS PROFILE	ENERGY AND OTHER SAVINGS			TOTAL PROJECT COST (\$)
		AVG kW	kWh	SAVINGS (\$)	
<b>AIR COMPRESSOR SUPPLY</b>					
1. Convert the 150-hp and 100-hp air-cooled units to water-cooled; flush system and add new type food grade lubricant to system	Savings taken with Project 2.			\$25,000	
Alternate: convert all four compressors to water cooled, as described for large units.	We recommend converting the primary 150-hp and 100-hp variable speed drive to water-cooled, but leave the 50-hp and 75-hp air-cooled in back up after ventilation problems are corrected.				

# Dairy Product Plant – Overview

PROJECT	SAVINGS PROFILE	ENERGY AND OTHER SAVINGS			TOTAL PROJECT COST (\$)
		AVG kW	kWh	SAVINGS (\$)	
<b>HEAT RECOVERY</b>					
2. Add a new water / glycol cooling system sized for all four compressors with a duplex 7.5-hp pumping station, control valve and a trim cooler to allow pre-heating of process water for heat recovery (6,240 hrs./yr.)	Steam use savings 567,000 1,000 lbs./hour	N/A	N/A	\$35,380/yr. (\$10 hr. / 1,000 lbs. yr.)	\$100,000
3. Reconfigure Compressor Room interconnecting piping; to eliminate “dead head” crossing tees and allow for proper operation of compressors. Install 3,000 gallon receiver.	24 kW	24	211,087	\$24,275	\$50,000
4. Replace current dryers with new oversized glycol based, full cycling refrigerated dryer (2,400 scfm) with mist eliminator	9.8 kW	9.8	85,844	\$9,851	\$31,514
5. Replace (2) electric timer drains with electric or pneumatic actuated no-loss drains	6 cfm	1.14	9,956	\$1,145	\$1,000
6. Implement recommended ventilation modification	This is not an energy savings measure, but will improve air quality and equipment reliability. (Potentially a phase two project to be reevaluated after the other projects have been completed)				TBD

# Dairy Product Plant – Overview

PROJECT	SAVINGS PROFILE	ENERGY AND OTHER SAVINGS			TOTAL PROJECT COST (\$)
		AVG kW	kWh	SAVINGS (\$)	
<b>DEMAND-SIDE SYSTEM</b>					
7. Replace 17 open blows and add auto shut-off as listed.	95 cfm	18.01	157,774	\$18,144	\$1,700
8. Repair 53 identified and tagged leaks	238 cfm	26.35	164,484	\$26,546	\$4,000
9. Replace two air vibrators with electric	14 cfm	2.67	16,686	\$1,558	\$1,000
10. Add electronic stroke optimizer to AODD pump	25 cfm	4.74	41,521	\$4,775	\$2,000
11. Central control monitoring Quote	No projected energy savings for this project. Strictly recommended for operational optimization and risk avoidance.				TBD
TOTAL	567 1,000 lbs./hr. 378 cfm 33.8 kW	86.71 kW	687.352 kWh	\$122,032 per year	\$216,214

## Potential Follow-up Projects:



- Optimization of the Palletizing, Case Erection and Vacuum System
- Optimization of the pulse jet collectors
- Cabinet coolers
- Vacuum generation optimization
- Lower system and compressor discharge pressure in “Dry Ingredients” Room

# Project #1 – Compressor Conversion

Convert the 150-hp and 100-hp air-cooled compressors to water-cooled, closed water/glycol with air-cooled heat exchanger and trim cooler.

Flush and service the Compressor Lubrication System and add new type food grade lubricant to system.

Project cost: \$25K





# Project #2 Closed Cooling – Trim & Heat Recovery

Add a new water / glycol cooling system sized for all four compressors with a duplex 7.5-hp pumping station, control valve and a trim cooler to allow pre-heating of process water for heat recovery (6,240 hours year).


Current heating cost of alternative heat source	\$555K BTU year
Annual hours - equipment operation	6,240 hours/year
Estimated annual heating cost being offset	\$10.00 hour
	1,000 lbs. / year
Estimated cost of steam (1,000 lbs.)	567 lbs. / hours
Estimated annual heating cost being offset	\$35,380
Cost for heat recovery project (equipment and delivery)	\$65,000
Installation	\$35,000

Approximate BTU's Per Unit for Most Common Fuels		
<b>Butane</b>	=	103,000 Btu/gal
<b>Electricity</b>	=	3413 Btu/kWh
<b>Firewood</b>	=	20,960,000 Btu/cord
<b>Gasoline</b>	=	125,000 Btu/gal
<b>Kerosene</b>	=	135,000 Btu/gal
<b>Natural Gas</b>	=	1,000 Btu/cu ft.
<b>#2 Oil</b>	=	138,500 Btu/gal
<b>#6 Oil</b>	=	150,000 Btu/gal
<b>Propane</b>	=	91,500 Btu/gal
<b>Steam</b>	=	970 Btu / hour / lbs. @ 212°F @ 14.7 psig



# Project #2 Closed Cooling – Trim and Heat Recovery

Typical Compressor Closed-Cooling System for  
Cooling Water (Water/Glycol) Heat Recovery System



# Project #2 Highlights

---

Total cost: \$100,000

Energy and operating cost reductions:

- Heat Recovery steam: 567 lbs. / 1,000 lbs./hr. - \$35,380/year
- Oil change and support \$93,120/year operating cost reductions (historical data)
- Eliminate premature air end failure \$13,000/year (historical data)
- Converting air to water will remove much of the heat load of the compressors

## Critical Goals For Performance And Reliability

Compressor operating < 200°F

Entry temperature to dryer < 100°F

# Project #3 – Compressor Room Piping


---

Reconfigure the Compressor Room interconnecting piping; eliminating “dead heads” and “crossing T’s” to allow for proper operation of the compressors.


Piping should be upsized to maintain a 20 fps velocity.

Project energy savings    \$24,275 year


Project cost                    \$50,000 year



# Current Compressed Air System



# Reconfigured Compressed Air System



# Project #4 – Compressed Air Dryers

Replace current dryers with new, oversized glycol based full cycling refrigerated dryers (2,400 scfm) with mist eliminators.

Manufacturer	Gardner Denver	Gardner Denver	Gardner Denver	Replacement Zeks
Model	RVXRD750	RNC500	RSD800	<b>2400 HSM</b>
Unit Type	Non-Cycling	Non-Cycling	Non-Cycling	<b>Heat Sink Cycling</b>
Rated Flow @ 100°F / 100 psig / 100 scfm	750	500	800	<b>2,400</b>
Full Load Heater kW (or Refrigerated kW)	4.2	2.68	4.2	<b>9.9</b>
Total Full Load kW	4.2	2.68	4.2	<b>9.9</b>
% Load w/ Dew Point Demand Control or Cycling Regeneration	100%	100%	100%	<b>15%</b>
Net Electric Demand (kW)	4.2	2.68	4.2	<b>1.3</b>
Total Annual Operating Cost (\$)	\$4,231	\$2,699	\$4,231	<b>\$1,310</b>

Annual electric energy cost of current dryers \$11,161 year

Annual electric energy cost of proposed dryer \$1,310 year


**Annual cost savings with new proposed dryer \$9,851 year**

Equip. cost for proposed dryer \$31,614 (Installation included with Project #2)

Note: If the compressor and new dryer remain air-cooled, a larger multiplex 3,250 scfm unit may be needed.

# Heatsink Cycling Refrigerated Dryer

## How It Works





# Project #5 – Condensate Drains



---

Replace timer drains with electric-or pneumatic-actuated no-loss drains.

Savings: 6 cfm

Project savings: \$1,145 yr.

Project cost: \$1,000



# Project #7 – Open Blows & Auto Shut-offs

---

Replace all identified open blows and add auto shut-offs where applicable.

Total number of applications	17 open blows/units
Compressed HP air currently used	180 scfm (10-11 scfm each)
Compressed HP air used after installation of Venturi nozzles	1 scfm each (17 scfm total)
Value of air reduction	\$111.31 scfm/year (163 scfm)
Total electric energy cost recovery by installing Venturi nozzles	\$18,144 year
Project cost with installation	\$1,700


Note: Add automatic shut-off to area when applicable.



# Project #7- Examples


---

Pictured below are examples of project implementations that resulted in a lower CFM use and delivery of more air to the individual process. Nozzles used have a 25:1 amplification.



Blue dispersion nozzles using about 10-11 scfm

50 scfm to process



Replace with (3) 48002 AiRTX Venturi-driven micro nozzles using 1 cfm each at 40 psi.

75 scfm at process

# Project #8 – Compressed Air Leaks


Repair all identified and tagged compressed air leaks. Implementation of a company-wide leak management program is an effective step to key “best practices” and energy saving solutions.

Total compressed air leaks identified:	53
Total SCFM of leaks	238 scfm
Cost to repair leaks	\$4,000
Recoverable annual energy savings	\$26,546 yr.



# Project #9 – Air Vibrators vs. Electric Vibrators


---



Air Vibrator

Currently uses: 7 cfm at 80 psig

Annual cost = 1.5 kW X \$.05 /kWh X 8,760 hours = **\$657.00 year**



Electric Vibrator

Proposed usage: .25 kW

Annual cost = .25 kW x \$.05 /kWh x 8,760 hours = **\$109.00 year**

Air vibrators are primarily used to keep product or packaging moving and/or separated, e.g. keeping product lids separate prior to sealing. If a plant employs air vibrators that use about 7 cfm each they will require approximately 2.5-hp or more to produce the same as a similar electric vibrator - which might use about 0.25-hp input energy. Air vibrators can almost always be replaced with electric except in foundry sand mold operations.

Total project savings = \$1,558

Total project cost = \$1,000





# Project #10 – AODD Pump Electronic Stroke Control

Add electronic-optimized stroke control, pneumatic-operated or 24v DC to all applicable diaphragm (AODD) pumps.

Total project cost savings: \$4,775

Total project cost: \$ 2,000



# Equipment Reliability Issues

---

Addressing supply-side equipment reliability issues. The following are concerns identified during the compressed air system audit.

- Short compressor oil life
- Compressor airend failure
- Frequently fouled coolers
- Wet compressed air during summer months
- High operating temperatures

**ALL OF THESE ARE RELATED!**





# Project #6 – Ventilation Modification

This project recommendation is not a energy savings measure but it will improve air quality and equipment reliability. This project should be evaluated after all other project recommendations have been implemented. Modifications made as required.




# Project #6 – Ventilation Modification

---

Air quality and equipment reliability issue.

Evaluate and modify after all other projects are implemented.



# Equipment Reliability Issues

---

## Root Cause of Food Grade Lubricant / Coolant Oil Short Life

- Frequently running too hot shortens the oil life
- Air-cooled compressors combined with high ambient temperatures
  - Oil cooler is too hot – varnish exacerbates
  - Thermostatic controls fouls, etc.
  - Aftercooler too hot – dryer pressure dewpoint (PDP) to 75-80°F / Production area is air conditioned at 70°F

# Equipment Reliability Issues


---

## Two-pronged Program

- Convert air-cooled 150-hp and 100-hp variable speed drive compressors from air-cooled to water-cooled, with air-cooled multi-fan, closed coolant cooling system, and trim cooler – set for heat recovery
- Clean, flush and repair all units and refill with “new” HI food grade PAD with enhanced additive package with ESTERS

# Equipment Reliability Issues


Refrigerated  
dryers work  
okay –  
except in hot  
weather



# Troubleshooting

---

## Proper Lubricant / Coolant Selection



# Standard PAO Food Grade

- PAO Without “new” FDA H1 approved enhancement additive packaging including Ester
- Currently lasting **less than 1,000 hours**
- Compressor running hot which increasingly makes the situation works (**>200°F**)
- Hard varnish left in the compressor, coolers, etc. – contributes to high operating temperatures
- Air-cooled units
- Ventilation is an issue
- High ambient temperatures

## Synthetic

<ul style="list-style-type: none"> <li>• Superior Protection synthetic lubricant</li> <li>• Increased machine operating efficiencies</li> <li>• Formulated for excellent condensate oil/water separation</li> </ul>	<ul style="list-style-type: none"> <li>• Exceptional thermal stability</li> <li>• Completely demulsible</li> <li>• Long life at high temperature</li> </ul>	<ul style="list-style-type: none"> <li>• Food grade extended life lubricant</li> <li>• Minimizes maintenance and downtime</li> <li>• Improved lubrication at high and low temperatures</li> </ul>	<ul style="list-style-type: none"> <li>• Long life, polyolester synthetic lubricant</li> <li>• Non-hazardous, BIO-degradable, demulsible</li> <li>• Maximum operating efficiencies realized</li> </ul>
<p>AEON 9000SP is a Superior Protection PAO (polyalphaolefin)/MFSE (multi-functional synthetic ester) blend formulated with proven additive components. The result is superior thermal and oxidative stability.</p> <p>AEON 9000SP is ideal for applications which require extended operating intervals. It is formulated for demulsibility and optimum viscosity over the compressors entire operating temperature range.</p> <p>Lab life and multiple field applications have proven AEON 9000SP to provide superior service life, while minimizing oil carry over and unit maintenanc</p>	<p>AEON 9000TH is a polyalphaolefin (PAO)/MFSE synthetic ester custom blend formulation for proven performance.</p> <p>AEON 9000TH is an extended life lubricant for rotary screw compressors with oil injection operating under harsh service conditions with high compressor temperatures. It is ideal for rotary screw air compressor applications where oil is exposed to high operating temperatures needed to prevent condensation in high humidity applications. This lubricant may not be appropriate in applications with low ambient temperatures.</p>	<p>AEON 6000 Food Grade is a PAO (polyalphaolefin) blend, authorized by the USDA as an H-1 approved lubricant for use in federally inspected meat and poultry plants. It complies with FDA 21CFR 178.3570—lubricants for incidental food contact.</p> <p>AEON 6000 Food Grade is an extended life lubricant formulated to reduce maintenance intervals and extend compressor life.</p>	<p>AEON BIO is a custom blended polyolester (POE), long life synthetic lubricant, readily bio-degradable according to CEC Test L-33-T-82.</p> <p>AEON BIO is especially advantageous in applications where it is exposed to elevated temperatures for extended periods of time. AEON BIO resists forming sludge and varnish even under these extreme conditions.</p> <p>AEON BIO is formulated to be recyclable with standard mineral oil recycling systems and technology. Also, none of the ingredients are found on OSHA's list (29CFR 1910.1200) of hazardous materials.</p>



# Effect of High Operating Temperatures

High discharge air temperatures may shorten the life of the any oil, even some synthetics, as follows:

Discharge air temperature	Probable oil change interval
85° to 96°C (185° - 205°F)	4,000 hours*
> 102°C (>215°F)	3,000 hours*
> 107°C (>225°F)	1,000 hours*
> 113°C (>235°F)	? hours*

\*Confirm by measuring the total acid number (T.A.N.) of the used oil. T.A.N. value of > 2.0 mg KOH/g is indicative that an oil is breaking down or has broken down.

# Troubleshooting


---

## What causes a compressor to run hot?

- Dirty compressor due to varnish build-up
- Air intake near or downwind of diesel or natural gas engine exhaust fumes / gases
- Air intake near another air-cooled compressor's aftercooler exhaust fan / air-cooled dryer
- Limited ventilation in the Compressor Room
- High altitude
- High ambient temperatures
- Stuck thermostat valve
- Dirty coolers

# Troubleshooting


Heat-of-compression removal is affected by varnish build-up



# Troubleshooting

---

Over-extended run of coolant / lubricant



# Troubleshooting

---

## Other Cautions: Potential High Water Content Oil

- The lower the operating temperature, the longer the lubricant will last. But operating at **discharge temperatures too cool** and/or below the operating oil pressure will cause water to accumulate in the lubricant forming emulsions, causing corrosion, wear, and lowering viscosity. This will not only reduce oil life, but will also significantly affect bearing and oil separator life.
- The thermostatic bypass valve may need to be set or changed so as to maintain the proper operating temperature, both low and high, with the proper new water-cooled heat exchanger.



# Troubleshooting: Oil Analysis

## An Effective Oil Analysis Interpretation Program



### Oil Analysis Program

The in-house Summit laboratory, with the R&D support from their international partner Klüber Lubrication, is one of the international leaders in providing their customers high quality data and technical support. The Summit lab continues to grow in the range of lab test performed and they are continually updating diagnostic equipment. Summit guarantees quality oil analysis with strict accordance to ISO 9001:2000 registered procedures. Summit lab analysis assists in preventing the end user from experiencing equipment failure and expensive downtime. Customer support is a primary focus for the Summit laboratory staff. They are dedicated to improving existing products and the research and development of new lubricants for specific applications.

Summit is internationally known for their expertise in manufacturing synthetic lubricants. They support their synthetic products with Free Oil Analysis to confirm the extended life of synthetic lubricants versus petroleum based lubricants. Summit provides their customers with a free testing kit to use in drawing samples for oil analysis and evaluation. Oil analysis will aid in increasing equipment life and oil change intervals.

Through thorough and detailed oil testing Summit lab technicians can help in discovering equipment problems in the early stages to prevent costly down time and repairs. Summit provides the customer with an oil analysis report, data interpretation and recommended actions that should be taken. For new users of Summit synthetic lubricants the Summit lab can help with compatibility issues and recommend to the customer the Summit synthetic product to be used for replacement.

You receive an added value by using Summit lubricants. Summit Industrial Products provides free oil analysis for anyone using their synthetic lubricants. This is a normal charge by most companies of \$10 to \$30 a sample depending on the scope of the test. For a small fee, Summit provides a TAN (Total Acid Number) Test Kit for the evaluation of an in use lubricant for possible replacement. There are two reasons to conduct routine oil analysis: to assess the condition of the used lubricant and to assess the condition of the equipment. The benefits of assessing oil condition include the savings in oil purchasing, lowering the cost for oil disposal and to reduce the downtime and labor cost associated with oil changes and repair. Periodic oil analysis can aid you in effectively controlling equipment wear by noting contaminants to detect active equipment wear. When you sample for lubricant condition you save money with extended oil change intervals, and reduce downtime by increasing equipment reliability.

Summit continues to commit to laboratory expansion and product development. They recognize the value of their laboratory for customer support and product development. For more information about the abilities of the Summit laboratory, call 1.800.749.5823.

- Most important - High Ambient + High Humidity = The worst of both worlds
- Interpret for reliability not necessarily maximum oil life
- When analysis or operation indicates "varnish" starting – partial mix flushes before oil change will often help control

# Troubleshooting: Oil Analysis

---

## Key Variables to Watch:

- pH – contaminated air
- Total Acid Number (T.A.N.) coolant life remaining
- Viscosity
- Contamination – other lubricant
- Wear metals – DR Ferrography



# Troubleshooting: Oil Analysis

---

## Used Oil Condemning Limits

- Viscosity
  - 10% increase
  - 10% decrease
- Viscosity stabilization for gas compressors
- T.A.N: 2 mg KOH/gram above new oil
- H<sub>2</sub>O: Any amount above 0.1% (1,000 ppm) by volume

# Troubleshooting: Oil Analysis Report

---

## Baselines and Report Interpretation



# Oil Analysis Report

Maintenance Recommendations for Lab No. <u>ABC 0113501</u>													Unit No. 1													
													End User:													
????????													Location:													
Baseline													Component: Rotary Screw Air Compressor													
													Make & Model: QSI 200													
													Oil Capacity:													
													Oil Type: Summit Supra Coolant													
ELEMENTAL CONCENTRATIONS IN PARTS PER MILLION (PPM) BY WEIGHT																										
LAB. NO.	Ag	Al	B	Ba	Ca	Cd	Cr	Cu	Fe	Mg	Mn	Mo	Na	Ni	P	Pb	Sb	Si	Sn	Ti	V	Zn	Sample Drawn			
Baseline	0	0	0	253	0	0	0	0	0	0	0	0	0	0	31	0	0	0	0	0	0	0	0			
Actual	0	1	10	186	11	0	1	4	1	1	0	0	46	0	127	0	0	0	1	0	0	135				
SAMPLE INFORMATION													PHYSICAL TEST RESULTS													
LAB. NO.	M/HR UNIT				M/HR OIL				KV100	KV40	TAN	H2O%														
Baseline	N/G				N/G				9.38	55.38	0.11	< 0.1%														
Actual	40896				5635				9.08	59.81	3.48	< 0.1%														
Ag = Silver			Al = Aluminum			B = Boron			KV40 = Kinematic Viscosity @ 40°C																	
Ba = Barium			Ca = Calcium			Cd = Cadmium			KV100 = Kinematic Viscosity @ 100°C																	
Cr = Chromium			Cu = Copper			Fe = Iron			TAN = Total Acid Number mg KOH/1g																	
Mg = Magnesium			Mn = Manganese			Mo = Molybdenum			N/G = Not Given or Provided																	
Na = Sodium			Ni = Nickel			P = Phosphorus																				
Pb = Lead			Sb = Antimony			Si = Silicon																				
Sn = Tin			Ti = Titanium			V = Vanadium																				
Zn = Zinc																										

# Oil Analysis Report

Maintenance Recommendations for Lab No. <u>ABC 0113501</u>												Unit No. 1											
												End User: <span style="background-color: black; color: black;">XXXXXXXXXX</span>											
Barium content has dropped. Viscosity & TAN are high.												Location: Costa Rica											
Boron & Calcium are slightly elevated.												Component: Rotary Screw Air Compressor											
Phosphorus, Sodium & Zinc are high. Possible mixed fluid.												Make & Model: QSI 200											
Recommend changing oil due to high TAN.												Oil Capacity:											
												Oil Type: Summit Supra Coolant											
Possible wear metals																							
<b>ELEMENTAL CONCENTRATIONS IN PARTS PER MILLION (PPM) BY WEIGHT</b>																							
LAB. NO.	Ag	Al	B	Ba	Ca	Cd	Cr	Cu	Fe	Mg	Mn	Mo	Na	Ni	P	Pb	Sb	Si	Sn	Ti	V	Zn	Sample Draw n
Baseline	0	0	0	253	0	0	0	0	0	0	0	0	0	0	31	0	0	0	0	0	0	0	
Actual	0	1	10	186	11	0	1	4	1	1	0	0	46	0	127	0	0	0	1	0	0	135	
<b>SAMPLE INFORMATION</b>											<b>PHYSICAL TEST RESULTS</b>												
LAB. NO.	MI/HR UNIT			MI/HR OIL			KV100	KV40	TAN	H2O%													
Baseline	N/G			N/G			9.38	55.38	0.11	< 0.1%													
Actual	40896			5635			9.08	59.81	3.48	<0.1%													
Ag = Silver		Al = Aluminum		B = Boron		KV40 = Kinematic Viscosity @ 40°C																	
Ba = Barium		Ca = Calcium		Cd = Cadmium						KV100 = Kinematic Viscosity @ 100°C													
Cr = Chromium		Cu = Copper		Fe = Iron						TAN = Total Acid Number mg KOH/1g													
Mg = Magnesium		Mn = Manganese		Mo = Molybdenum						N/G = Not Given or Provided													
Na = Sodium		Ni = Nickel		P = Phosphorus																			
Pb = Lead		Sb = Antimony		Si = Silicon																			
Sn = Tin		Ti = Titanium		V = Vanadium																			
Zn = Zinc																							

# Oil Analysis Report

Maintenance Recommendations for Lab No. _____	Unit No.
??????	End User:
	Location:
Bearing wear, high water and dirt levels.	Component: Rotary Screw Air Compressor
	Make & Model: Atlas Copco GA-75
	Oil Capacity:
	Oil Type: Summit SH-46

### ELEMENTAL CONCENTRATIONS IN PARTS PER MILLION (PPM) BY WEIGHT

LAB. NO.	Ag	Al	B	Ba	Ca	Cd	Cr	Cu	Fe	Mg	Mn	Mo	Na	Ni	P	Pb	Sb	Si	Sn	Ti	V	Zn	Sample Draw n
Baseline	0	0	0	0	0	0	0	0	0	0	0	0	0	0	474	0	0	0	0	0	0	0	
Actual	0	0	0	0	0	0	0	0	45	0	0	0	0	0	462	0	0	15	0	0	0	0	

SAMPLE INFORMATION			PHYSICAL TEST RESULTS			
LAB. NO.	MI/HR UNIT	MI/HR OIL	KV100	KV40	TAN	H2O%
Baseline	N/G	N/G	7.11	43.36	0.17	< 0.1%
Actual		1000	7	40	0.2	3.12%

Ag = Silver	Al = Aluminum	B = Boron	KV40 = Kinematic Viscosity @ 40°C
Ba = Barium	Ca = Calcium	Cd = Cadmium	KV100 = Kinematic Viscosity @ 100°C
Cr = Chromium	Cu = Copper	Fe = Iron	TAN = Total Acid Number mg KOH/1g
Mg = Magnesium	Mn = Manganese	Mo = Molybdenum	N/G = Not Given or Provided
Na = Sodium	Ni = Nickel	P = Phosphorus	
Pb = Lead	Sb = Antimony	Si = Silicon	
Sn = Tin	Ti = Titanium	V = Vanadium	
Zn = Zinc			

# Summary

---

## Compressed Air System Audit Case Study: Southwestern Dairy Products Packaging Plant

### Complete Compressed Air System Audit

- ✓ Supply and Demand-Side System Analysis
- ✓ Energy Savings
- ✓ Productivity
- ✓ Reliability Issues
- ✓ Future Projects for Continuous Improvement



---

# Thank you for the opportunity to present!

Hank van Ormer – Technical Director  
Air Power USA  
[airpowerusainc.com](http://airpowerusainc.com) / (740) 862-4112



# Questions?

To earn Professional Development Hours (PDH):

- Log into the IFPE App
- Go to this session in "Schedule"
- Check in using the Slider in Session Detail

Please complete the session evaluation on the IFPE Mobile App

- Go to Schedule and Select This Session

