

EPA Section 608 Preparatory Manual

9th Edition



esco institute



This manual was developed by The ESCO INSTITUTE
Mount Prospect, IL 60056

ESCO Institute
P.O. Box 521
Mount Prospect, IL 60056

Phone: (800) 726-9696
Website: www.escogroup.org

Fax: (800) 546-3726
E-Mail: customerservice@escogroup.org

COPYRIGHT © 2018 ESCO INSTITUTE
All rights reserved

Printed in the United States of America
ISBN 1-930044-60-7

No part of this manual may be reproduced, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without written permission of the authors. No patent liability is assumed with respect to the use of the information contained herein. While every precaution has been taken in the preparation of this book, the authors and publisher assume no responsibility for errors or omissions. Neither is any liability assumed for damages resulting from the use of the information contained herein.



Disclaimer: Passing the EPA Section 608 Certification Exam is required for handling and purchasing regulated Refrigerants.

The 608 certification is not an indicator of an individual's competency as an installer or service technician and does not replace formal training one should receive prior to taking this examination.

Table of Contents

Introduction	
Overview of the Examination	4
Core	
Stratospheric Ozone Depletion	8
Ozone Depletion Potential	8
What is global warming?	8
Clean Air Act	9
Montreal Protocol	10
The Three 'R's	10
Recovery Devices	11
Sales Restriction	11
Substitute Refrigerants & Oils	11
Recovery Techniques	12
Leak Detection	13
Dehydration	13
Recovery Cylinders	14
Safety	15
Shipping & Transporting	15
Refrigerant Characteristics Table	16
Type I Certification	
Equipment Requirements	17
Leak Repair Requirements	17
Recovery Techniques	17
Safety & Shipping	18
Type II Certification	
Leak Detection	19
Leak Repair Requirements	19
Recovery Techniques	20
Recovery Requirements	20
Refrigeration Notes	21
Safety	22
Type III Certification	
Leak Detection	23
Leak Repair Requirements	23
Recovery Techniques	24
Recharging Techniques	24
Recovery Requirements	25
Refrigeration Notes	25
Safety	25
Saturation Chart	Back Cover

Introduction

This manual is intended to prepare technicians for the Environmental Protection Agency's (EPA) Section 608 Certification examination and contains the information required to successfully complete the exam. This book serves as a guide for reviewing material related to the amendment of Section 608 of the Clean Air Act and is not a formal refrigeration training course. Technicians preparing for this examination should be familiar with the basic vapor-compression refrigeration cycle, as well as common service principles, practices and procedures.

This manual has been developed with the most current information available at the time of publication. Should EPA regulations change after a technician becomes certified, it is the responsibility of the technician to comply with these changes. The EPA also reserves the right to modify the test questions and/or require new certification or recertification based on advancements in technology. The ESCO Institute will update this manual as necessary to reflect current EPA regulations and testing requirements.

Federal Regulations

Section 608 of the Clean Air Act requires that all persons who maintain, service, repair, or dispose of appliances that contain regulated refrigerants, be certified in proper refrigerant handling techniques as required by the EPA's National Recycling and Emission Reduction Program. Regulated refrigerants currently includes: CFC, HCFC, HFC, and HFO refrigerants.



You cannot work under another person's certification.

Before You Begin

In addition to this preparatory manual, practice questions are available to help prepare you for the EPA Section 608 examination. You can access these practice questions free of charge on the ESCO website at www.escogroup.org.

If your examination was administered through an ESCO approved testing location, you will be able to login to the ESCO website to access your examination results, order replacement certification cards, update your information (i.e., address), opt out of the public certification registry, order additional training materials, etc. You may also contact our customer service team, Monday-Friday, 8:00 AM 5:00 PM Central Time at 1-800-726-9696 if you have any questions related to your certification. Please note: if you participate in an examination that was administered in paper format (i.e., Scantron answer sheet), please allow 5-7 business days for your examination to be received at our grading center for processing.

Overview of the Examination

Distributors can only sell regulated refrigerants to a Section 608 certified technician or company which employs a Section 608 certified technician.

There are four (4) categories of technician certification:

Type I. Persons who maintain, service, repair, or dispose of small appliances must be certified as Type I technicians. A small appliance is defined as a pre-assembled unit, hermetically sealed and factory charged with 5 lbs. or less of refrigerant. Examples include equipment such as water coolers, window units, refrigerators, freezers, de-humidifiers, ice machines, and package terminal air conditioning. **Split systems are not included in Type I.**

Type II. Persons who maintain, service, repair, or dispose of medium, high and very high pressure appliances containing more than 5 lbs. of refrigerant or if the installation of such equipment requires refrigerant charging, must be certified as Type II technicians.



High-pressure refrigerants have a pressure between 155 psig & 340 psig at a liquid phase temperature of 104°F and medium pressure refrigerants have a pressure between 30 psig & 155 psig at a liquid phase temperature of 104°F. Type II certification does not include small appliances or motor vehicle air conditioning (MVAC) systems.

Type III. Persons who maintain, service, repair, or dispose of low-pressure appliances (centrifugals and chillers) must be certified as Type III technicians. Low-pressure refrigerants have pressures of 30 psig or lower at a liquid phase temperature of 104°F.

Universal To be certified as Universal, a technician must pass all four sections; Core, Type I, Type II, and Type III.

Test Format

The test contains four sections: the Core, and sections I, II, and III. Each section contains twenty five (25) multiple-choice questions. A technician **MUST** achieve a minimum passing score of 70 percent in each group/section in which they are to be certified. For example, a technician seeking Universal certification must achieve a minimum score of 70 percent, or 18 out of 25 correct, on each section of the test. If a technician fails one or more of the sections, they may retake the failed section(s) without retaking the section(s) in which they earned a passing score. In the meantime, the technician will be certified in the Type for which they received a passing score. There is one exception; a technician **MUST** achieve a passing score on the Core plus any one Type to receive any certification.

The Core contains 25 general knowledge questions relating to stratospheric ozone depletion, rules and regulations of the Clean Air Act, the Montreal Protocol, refrigerant recovery, recycling and reclaiming, recovery devices, substitute refrigerants and oils, recovery techniques, dehydration, recovery cylinders, safety, and shipping. Section I contains 25 sector specific questions pertaining to small appliances. Section II contains 25 sector specific questions pertaining to medium and high-pressure appliances and Section III contains 25 sector specific questions pertaining to low-pressure appliances.

Federal regulation requires that this exam be conducted as a closed book exam by an authorized test administrator (Proctor). The only outside materials allowed during the test are a temperature/pressure chart and a calculator. Phones are **NOT** allowed to be used during the examination and **MUST** be turned off and put away (not on the desktop) during the examination.

Certain personal information is requested on the exam. Technicians should be prepared to provide:

- Picture Identification (Proctors will ask for this to verify your identity—this is required.)
- Social security number (Used for identification purposes only.)
- Home/mailing address
- Date of Birth
- Phone Number
- Email address

All examination participants will be included in an online registry/lookup by name, city and state as well as certification achieved. (No personal information will be included in the public registry.) Technicians will be able to opt out of this registry by logging into the ESCO website at www.escogroup.org or by contacting customer service at 800-726-9696.

Technicians should carefully study the Core and section(s) related to the Type(s) of certification in which they are seeking to achieve a passing score. Free EPA practice exams can be found online at: www.escogroup.org.




Figure 1. Basic Vapor/Compression Refrigeration Cycle

Vapor / Compression Refrigeration Cycle

The compressor is the heart of the vapor-compression refrigeration cycle. Low-pressure, low-temperature superheated refrigerant vapor entering the compressor is compressed, changing it to a high-pressure, high-temperature, superheated vapor. It then moves to the condenser where the heat is removed, de-superheating and condensing it into a liquid. Before it leaves the condenser, the liquid refrigerant is subcooled to a point below the liquid saturation temperature. It then flows to the metering device as a high-pressure, subcooled liquid. As the refrigerant flows through the metering device, the liquid is reduced to a low-pressure causing a small percentage of the liquid to flash to a vapor (flash-gas) lowering the remaining refrigerant to its saturation temperature. The low-pressure, low-temperature refrigerant flows into the evaporator as a low-temperature liquid. As the refrigerant absorbs heat, it evaporates into a low-temperature vapor. During this process the refrigerant vapor is superheated above its saturation temperature and then enters the suction line. From the suction line, refrigerant enters the compressor as a low-pressure, low-temperature superheated vapor to repeat the cycle. The compressor and the metering device are the dividing points between the low-pressure and high-pressure sides of the system.

Accessories shown in the basic diagram are the liquid receiver and a suction accumulator. Use of these components depends on system design and/or the type of metering device used. A system that uses a thermostatic expansion valve (TEV) is usually equipped with a receiver located in the liquid line directly following the condenser. A system that uses a thermostatic expansion valve (TEV), capillary tube, or fixed bore metering device may be equipped with an accumulator located in the suction line, which prevents liquid from entering the compressor.

A system may have service valves, access valves or process stubs to gain access for service. Never front-seat (turn the valve stem clockwise as far as it will go) a service valve when the system is in operation. The valve must be back-seated (turn the valve stem counter-clockwise as far as possible) to close the service or gauge port before removing the service manifold hoses.




Figure 2. Manifold and Hose Set



Figure 3. Digital Manifold and Temperature Kit

Gauge Manifold Set

One of the most important tools for an HVACR technician is the gauge manifold set. The left side, compound gauge (blue) and the right side, high-pressure gauge (red), are attached to the manifold to measure system pressures. Hoses are used to connect the manifold to the refrigeration system's access ports or service valves to gain access to system pressures. The compound gauge measures low-pressure (psig) and vacuum (inches Hg). The high pressure gauge measures high side (discharge) pressure. Depending on the refrigerant, the high-pressure gauge may be rated at 500 or 800 psig. The manifold is also equipped with a center port, (usually a yellow hose), that can be connected to a recovery device, evacuation vacuum pump, or charging device.

An electronic manifold may have combined temperature probes to measure refrigerant line temperatures for calculating system superheat and subcooling.

EPA recommends that hoses be equipped with low loss fittings or valves that manually close or which close automatically to minimize refrigerant loss when hoses are disconnected. The hoses used for service and with recovery equipment must be equipped with low-loss fittings.

A minor release of refrigerant, when connecting or disconnecting hoses for service or recovery is considered to be a de-minimis release.



Caution: The gauge manifold and hoses must be pressure rated to handle the refrigerant being used.

Stratospheric Ozone Depletion

The introduction of Chlorofluorocarbons (CFCs) and Hydrochlorofluorocarbons (HCFCs) have dramatically changed our lifestyles. ASHRAE's safety classifications do not consider a refrigerant's environmental effects. Little did we know that the use and release of these compounds into the atmosphere would have far reaching, long-term effects on our environment. The greatest effect is in the stratosphere, which is far removed from the Earth's surface.

The stratosphere, located between 7 and 30 miles above sea level, is comprised of ozone and other gases. The ozone layer is the Earth's security blanket. An ozone molecule, (O₃), which consists of **3 oxygen atoms**, protects us from harmful ultraviolet radiation from the Sun, and helps maintain stable Earth temperatures.

Stratospheric ozone depletion is a global issue that can lead to problems such as crop loss, skin cancer, increased eye diseases such as cataracts and reduced plankton and other microscopic marine life.

CFCs (chlorine, fluorine & carbon) and HCFCs, (hydrogen, chlorine, fluorine & carbon), which contain chlorine, have been found in air samples taken from the stratosphere. When CFCs and HCFCs, are released into the atmosphere their **chlorine** content causes depletion of the ozone layer. When a chlorine atom encounters an ozone molecule, it takes one Oxygen atom from the ozone forming a compound called chlorine monoxide (ClO), leaving an oxygen O₂ molecule behind. The chlorine monoxide will collide with another ozone molecule, releasing its Oxygen atom, forming two O₂ molecules, leaving the chlorine free to attack another ozone molecule. A single chlorine atom can destroy up to **100,000 ozone molecules**.

There has been some controversy over the subject of ozone depletion. Some believed that the chlorine found in the stratosphere comes from natural sources such as volcanic eruptions. However, air samples taken over erupting volcanoes show that volcanoes add only small quantities of chlorine to the atmosphere compared to the amount of chlorine added to the atmosphere from chlorine-containing refrigerants. In addition, the rise in the amount of chlorine measured in the stratosphere over the past four decades matches the rise in the amount of Fluorine, which has different natural sources than chlorine over the same period. Also, the rise in the amount of chlorine measured by NASA and other agencies in the stratosphere over the past twenty years matches the rise in CFC and HCFC emissions over the same period. The evidence is clear, chlorine containing refrigerants have changed the natural balance, thus depleting the ozone layer.

Unlike other chlorine compounds and naturally-occurring chlorine, the chlorine in CFCs and HCFCs will neither dissolve in water nor break down into compounds that dissolve in water so they do not rain out of the atmosphere.

HFCs are made up of Hydrogen, Fluorine and Carbon. They do not contain chlorine that effects the ozone layer, but most HFCs have a high Global Warming Potential (GWP).


Ozone Depletion Potential

Ozone Depletion Potential (ODP) is a measurement of a substance such as CFC's and HCFC's ability to destroy ozone, and ranges from 0 to 1. CFCs have the highest ODP. HFCs (Hydrofluorocarbons/R-134a, R-32, & 400 series blends) and HFOs (hydrofluoroolefins/ R-1234yf, 1234ze & 1233zd) do not contain chlorine and have an Ozone Depletion Potential of zero.

Greenhouse Gases

Greenhouse gases (GHGs) warm the Earth in two ways; by absorbing energy, slowing the rate at which it escapes to space and by acting like a blanket insulating the Earth. Examples of greenhouse gases and their effects on the atmosphere are as follows:

Carbon dioxide (CO₂): CO₂ is a natural gas, created through respiration and absorbed through photosynthesis, a relatively balanced cycle. The addition of man-made CO₂ creates an overabundance and results in excess GHGs that enter the atmosphere as a result of burning fossil fuels (coal, natural gas, and oil), solid waste, wood/products, and is the result



of certain chemical reactions such as cement manufacturing. Carbon Dioxide is used as a very high-pressure refrigerant (R-744) with zero (0) ODP and a Global Warming Potential (GWP) of one (1). R-744 is used primarily in commercial and industrial process systems and does not require Section 608 certification for purchasing or servicing. Natural refrigerants such as R744 (carbon dioxide) that do not pose a threat to health or the environment according to EPA may be released back into the environment.

Flammable refrigerants: Equipment with flammable refrigerants requires a red color marking on all process tubes, service connections, and pipes through which a flammable refrigerant passes. The color marking must extend one inch in both directions from service locations. When propane (R-290) is used as refrigerant, it must meet the purity standards set for HVACR equipment. Propane purchased for grilling contains impurities which will damage refrigeration equipment. Propane and Isobutane are examples of “A3” flammable refrigerants that do not require recovery. Propane, Butane and other Hydrocarbon refrigerants are also known as HC refrigerants.

Fluorinated gases: Hydrofluorocarbons, perfluorocarbons, sulfur hexafluoride, and nitrogen trifluoride are synthetic, powerful greenhouse gases that are emitted from a variety of industrial processes. Fluorinated gases such as CFCs, HCFCs and HFCs are referred to as high Global Warming Potential gases (“High GWP gases”).

R-134a: (Tetrafluoroethane) is an HFC with an ozone depletion potential (ODP) of zero (0) and global warming potential (GWP) 1,430 times greater than carbon dioxide. R-134a is a medium-range pressure refrigerant used in auto, domestic refrigeration and commercial industries.



R-410A: (Hydrofluorocarbon) is a high-pressure, HFC refrigerant with an ODP of zero (0) and global warming potential (GWP) 2,090 times greater than carbon dioxide. R-410A is a near azeotrope refrigerant that does not fractionate during phase change in HVACR equipment. One disadvantage of R-410A is the operating pressure is approximately 50% higher than R-22 and cannot be considered as a replacement for retrofitting existing systems.

R-1234yf: (Tetrafluoropropene) R-1234yf is a medium pressure, HFO refrigerant with an (ODP) of 0 and global warming potential (GWP) only 4 times greater than carbon dioxide.

ASHRAE has grouped refrigerants by Class A (safest) or B, depending on their toxicity level to humans. Flammability is indicated by a 1 (no flammability), 2 (low flammability), or 3 (high flammability).

Clean Air Act

The United States Environmental Protection Agency (EPA) regulates Section 608 of the Federal Clean Air Act which establishes the rules for regulating all Class I (Ozone Depleting Substances such as CFCs), Class II (HCFCs), and substitute refrigerants. Failure to comply could cost you and your company.

		Safety Group	
Higher ↑ 	High Flammability	A3	B3
	Low Flammability	A2	B2
	Slight Flammability	A2L	B2L
	No Flammability	A1	B1
Low ↓		Low Toxicity →	Higher Toxicity → 

Companies and or service technicians who violate Clean Air Act provisions may lose their certification, be required to appear in Federal Court and be fined up to \$44,539 per day, per violation. The EPA may require technicians to demonstrate the ability to properly perform refrigerant recovery/recycling procedures. Failing to demonstrate these skills can result in revocation of certification. State and local jurisdictions may impose regulations that are equal to or greater than those under the EPA’s Section 608. Technicians not following stricter state and local government’s requirements may lead to other penalties.

It is a violation of Section 608 to:

- Falsify or fail to keep required records.
- Fail to reach required evacuation level prior to opening or disposing of appliances.
- Knowingly release (vent) ozone depleting and substitute refrigerants (such as CFCs, HCFCs or HFCs) while maintaining, installing, repairing or disposing of appliances or industrial process refrigeration with the exception of de-minimus releases.
- Service, maintain, or dispose of appliances designed to contain refrigerants without being appropriately certified.
- Fail to recover regulated refrigerants before opening or disposing of an appliance.
- Fail to have an EPA approved recovery device, equipped with low loss fittings that automatically close or have manually operated shut-off valves on the hoses.
- Add nitrogen to a fully charged system, for the purpose of leak detection, and thereby cause a release of the mixture.
- Dispose of a disposable cylinder without first recovering (to 0 psig) any refrigerant remaining in the cylinder. (Refrigerant must be recovered from the cylinder, the cylinder must be rendered useless, and then the metal cylinder can be recycled.)
- Release refrigerant during vandalism or theft of any HVACR equipment.

It is the responsibility of the final person in the disposal chain to ensure that refrigerant has been removed from appliances before scrapping.

Technicians disposing of mid-sized appliances with 5-50 pounds of refrigerant must keep the following records:

- The location, date of recovery, and type of refrigerant recovered for each disposed appliance.
- The quantity of refrigerant, by type, recovered from disposed appliances in each calendar month.
- The quantity of refrigerant, and type, transferred for reclamation or destruction, the person / company to whom it was transferred, and the date of the transfer.

Montreal Protocol

Following several years of negotiations, an international agreement (treaty) regulating the production and use of CFCs, HCFCs, halons, methyl chloroform and carbon tetrachloride entered into force in mid-1989. Known as The Montreal Protocol, this landmark agreement initially required a production and consumption freeze. The Montreal Protocol called for a stepwise reduction and eventual production phase-out of various ozone depleting substances (ODS) in developed countries. In the United States, CFCs were the first substance group that was phased-out of production. Some HCFC refrigerants are scheduled for phase-out as early as 2020, and by 2030 all HCFCs will be phased-out. When virgin supplies of restricted refrigerants are depleted, future supplies will come from only recovered, recycled, or reclaimed refrigerants.

The Three Rs (Recover - Recycle - Reclaim)

The processes of recovery, recycling, and reclaiming sound similar, but they are quite different.

Recover: Remove refrigerant, in any condition, from a system and store it in an external container to be put back into the same system, recycled, or reclaimed.

Recycle: Clean refrigerant by separating the oil from the refrigerant and removing moisture and other contaminants from the refrigerant by passing it through one or more filter driers. Recycled refrigerants may be placed back into the same system they came from or another system that is owned by the same owner.

Reclaim: Process refrigerant to a level equal to new (virgin) product specifications as determined by chemical analysis. Reclaimed refrigerants must meet AHRI 700 Standards before they can be reused or sold to another user.

Recovery Devices

Refrigerant recovery and/or recycling equipment manufactured after November 15, 1993 must be certified and labeled by an EPA approved equipment testing organization to meet EPA standards.

There are two basic types of recovery devices:

- 1) "System-dependent" which captures refrigerant with the assistance of components in the appliance from which refrigerant is being recovered. (Figure 4)
- 2) "Self-contained" which has its own means to draw the refrigerant out of the appliance. (Figure 5)



Figure 4. Recovery Bag 12 oz. only



Figure 5. Recovery Unit
Courtesy of Apion Inc.

Sales Restriction

The sale of CFC and HCFC refrigerants has been restricted to certified technicians since November 14, 1994. The sale of HFC and HFO refrigerants are restricted to certified technicians as of January 1, 2018. Only technicians certified under Section 609 of the Clean Air Act (Motor Vehicle Air Conditioning) are allowed to purchase refrigerants in containers smaller than 20 lbs.

CFCs or HCFCs can be used for servicing a system that uses the refrigerant after the phaseout. CFCs or HCFCs cannot be used in new equipment.

Substitute Refrigerants and Oils

Our industry is in a constant state of change. New refrigerants, blends of older refrigerants and different oils have appeared in the field. The potential to effect the internal components or oxidize the copper tubing must be evaluated. The EPA must review and approve new refrigerants before they are introduced for use in HVACR equipment. The Significant New Alternatives Policy program (**SNAP**) identifies and evaluates substitute refrigerants. EPA's decision on the acceptability of new substitutes proposed by manufacturers, formulators, or users is based primarily on the potential human health and environmental risks posed by the substitutes as compared to other substitutes available for a particular end-use. EPA's classifications of decisions on alternative substitutes may be listed as:

- Acceptable
- Acceptable subject to use conditions
- Acceptable subject to narrowed use limits
- Unacceptable alternatives

Any refrigerants that have not been reviewed and approved by EPA's SNAP program cannot be used to retrofit existing systems. The SNAP program limits approved refrigerants for use in the listed type(s) of systems for which they are approved.

R-134a is an HFC and was considered ozone friendly. R-134a was the leading candidate for CFC R-12 retrofit, but it is not a 'drop-in' substitute. In actuality, there is no such thing as a "drop-in" refrigerant, but some refrigerants can be used in most compatible systems by following appropriate retrofit procedures. HFC refrigerants will not mix with most refrigerant oils. The oils used with HFC and HFO HVACR systems are esters. Esters cannot be mixed with other oils. When retrofitting HCFC systems, polyolester (POE) type oil is commonly used as it can tolerate a small percentage of other types of oil. It is also important to remember that, when leak testing an HFC system, use pressurized nitrogen with only a trace amount of refrigerant vapor. In order to avoid contamination use the same refrigerant as the system charge. This is not considered to be a refrigerant that must be recovered.

There are several refrigerant blends commonly in use. Some blends are called ternary, which means they are a three-part blend. HCFC-22 and HCFC ternary blends are used with a synthetic alkylbenzene lubricant. Make certain you are using the correct oil for the particular refrigerant. Most refrigerant oils are hygroscopic. Hygroscopic oil has a high affinity for water. An oil sample should be taken and analyzed if a system has had burned compressor winding failure or a major leak, allowing moisture to enter the system.

Refrigerant blends are made up of two or more single component refrigerants. Depending on how strongly the refrigerant molecules are attracted to each other, they may be classified as azeotropic or zeotropic. An azeotropic mixture acts like a single component refrigerant over its entire temperature/pressure range. An azeotrope does not have a temperature glide, whereas, a zeotropic blend behaves like a mixture of the individual components with predictable properties based on combinations of the original refrigerant's properties. Temperature glide refers to the range of boiling or condensing temperature points that a refrigerant blend might experience at a specific pressure. Refrigerant fractionation can occur from a continuous leak due to the difference in pressures from the combined refrigerants.

The R-400 series of refrigerants are zeotropic blends that can leak from a system at uneven rates due to different vapor pressures which can effect the percentage of each refrigerant remaining in the system. The proper charging method for R-400 series blended refrigerants is to weigh the refrigerant into the high side of the system as a liquid. When adding refrigerant to an undercharged system, liquid refrigerant is throttled into the low side with the system operating.

Zeotropic blends use Bubble and Dew points to indicate condensing and evaporation temperatures on a pressure temperature saturation chart. Bubble point is used when charging by condenser subcooling and Dew point is used for charging by suction or evaporator superheat. The relationship of pressures and temperatures are based on the refrigerant's temperature glide. Temperature glide can range a few tenths of a degree to 12 degrees or more.

Even though the pressure temperature relationship, and the operating characteristics may be almost the same, the refrigerants cannot be interchanged. Due to flammability of some of the HC's and HFO's equipment must be designed to handle the refrigerant. Therefore, EPA regulates the maximum amount of refrigerant that can be used in the new systems by their type and use.

Recovery Techniques

EPA regulations require a service aperture or process stub on all hermetically-sealed appliances that use a regulated refrigerant in order to make it easier to recover refrigerant.

When servicing a system, if you discover that the refrigerant is contaminated, two or more refrigerants have been mixed in a system, you must recover the mixture into a separate tank to be turned in for reclamation. It is important NOT to mix different refrigerants in the same recovery tank because the mixture may be impossible to reclaim. Recover only one type of refrigerant into a recovery tank. The number of recovery tanks required by a person or company depends on the variety of equipment worked on and their types of refrigerants.

If a strong odor is detected during the recovery process, a compressor burn-out has likely occurred. When recovering refrigerant from a system that experienced a compressor burn-out, watch for signs of oil contamination. The contamination may be in the oil as sludge, moisture and acid. After recovering refrigerant, if nitrogen is used, with or without a flushing solution to flush debris out of the system, the nitrogen may be legally vented. A suction line filter drier should be installed to trap any debris that may damage the new compressor.

The size of the equipment, amount of moisture, length of the hose between the unit being recovered from and the recovery machine, and the ambient temperature can all effect the efficiency of the recovery process. Long hoses will cause excessive pressure drop, increased recovery time, and have a potential for increased emissions or venting from the recovery machine. Excessive venting of the recovery machine or cylinder is illegal. Since all refrigerants have a pressure/temperature relationship, the lower the ambient temperature surrounding the equipment being serviced, the slower the recovery rate.

After completing the transfer of liquid refrigerant between a recovery unit and a refrigeration system, you should guard against trapping liquid refrigerant between the service valves. Recovered refrigerant may not meet AHRI standard for virgin refrigerant therefore it can only be reused in the same system or another system of the same owner. It cannot change ownership.

Leak Detection

In order to determine the general area of a leak, use an electronic or ultrasonic leak detector after pressurizing the system with nitrogen and a trace amount of refrigerant. Once the general area of the leak is located, the use of soap bubbles will aid in pinpointing the leak. Finding and repairing leaks in a system will conserve refrigerant for future use.

When leak testing any flammable hydrocarbon or HFO refrigerant, install a fresh filter-drier and complete a standing-pressure leak check at the maximum system pressure before evacuating to 500 microns or lower.

Two verification tests are required when an appliance containing 50 pounds of refrigerant or more has triggered the leak rate threshold and subsequently has been repaired. One must be performed before the appliance is recharged and one after the appliance returns to normal operating conditions.

Section 608 of the Clean Air Act uses three categories to define applicable leak rates for systems other than small appliances.

Industrial Process Refrigeration (IPR), refrigeration equipment used in agriculture, crop production, oil and gas extraction, ice rinks, manufacture of frozen food, dairy products, food and beverages, ice, petrochemicals, chemicals, machinery, medical equipment, plastics, paper, and electronics.

Commercial Refrigeration, refrigerated warehousing and storage facilities, supermarkets, grocery stores, warehouse clubs, supercenters, convenience stores, and refrigerated transport.

Comfort Cooling, air conditioning equipment, and others not listed.

Note: When an appliance is designed for multiple uses, the category will be considered industrial process refrigeration equipment if 50 percent or more of its operating capacity is used for industrial process refrigeration.

Dehydration

The reason for dehydrating a refrigeration system is to remove water and water vapor and it is important to follow proper dehydration procedures. If moisture is allowed to remain in an operating refrigeration system, hydrochloric and hydrofluoric acids may form. Evacuation of a system is the suggested method of dehydration. It is not possible to over evacuate a system. Most manufacturers require an evacuation to 500 microns or lower which can be measured with a micron gauge (Figure 6).

Never evacuate a system to the ambient air without first following proper recovery procedures and attaining the mandated recovery level. (See Table 1, page 16).

The factors that affect the speed and efficiency of evacuation are; size of equipment being evacuated, ambient temperature, amount of moisture in the system, the size of the vacuum pump and suction line. In addition, vacuum lines should be equal to or larger than the pump intake connection. The piping connection to the pump should be as short a length as possible and as large in diameter as possible. The system vacuum gauge should be connected as far away from the vacuum pump as possible. Measuring a system's vacuum should be done with the system isolated and the vacuum pump turned off.



Figure 6. Vacuum Gauge
Courtesy of Apion Inc.



Figure 7. Vacuum Manifold
Courtesy of Apion Inc.



Figure 8. Vacuum Pump
Courtesy of Apion Inc.

A system that will not hold a vacuum probably has a leak. During evacuation you may wish to heat the refrigeration system to decrease dehydration time. Tapping a compressor with a rubber mallet will aid in releasing trapped refrigerant from the oil.

Never operate the compressor while the system is in a deep vacuum; internal electrical arcing could occur, burning the motor windings.

Dehydration is complete when the vacuum gauge shows that you have reached and held the required vacuum.

Recovery Cylinders

Recovery cylinders differ in many ways from disposable cylinders. Disposable cylinders are used only with virgin refrigerant and may NEVER be used for recovery. If the refrigerant in a recovery cylinder is suspected to be contaminated, a pressure reading of the cylinder should be taken and compared to a pressure/temperature chart.

Recovery cylinders are specifically designed to be refilled. Recovery cylinders have 2 ports, one liquid and one vapor. Care must be taken not to overfill or heat these cylinders, as it could cause an explosion. The EPA requires that a refillable refrigerant cylinder **MUST NOT BE FILLED ABOVE 80%** of its capacity by weight, and that the safe filling level can be controlled by mechanical float devices, electronic shut off devices (thermistors), or weight. Refillable cylinders must be hydrostatically tested and date stamped every 5 years.

Refillable cylinders must be Department of Transportation (DOT) approved. Approved refrigerant recovery cylinders can easily be identified by their colors; yellow tops and grey bodies. All refrigerant recovery cylinders should be inspected for rust. If a refillable cylinder shows signs of rust or appears to have been heated or damaged in any way, it should be reduced to 0 psig by recovering to another cylinder and discarded. Reclaimers will not accept visibly burned recovery tanks.

Safety

The EPA is concerned not only with the prevention of refrigerant venting, but with the technician's overall safety. When handling and filling refrigerant cylinders or operating recovery or recycling equipment, you should wear safety glasses, protective gloves, and follow all equipment manufacturer's safety precautions. Make sure your recovery machine is grounded when in use, especially when recovering a flammable refrigerant.



Figure 9. Recovery Tank

When pressurizing a system with nitrogen, you should always charge through a pressure regulator and a relief valve in the downstream line from the pressure regulator. Relief valves **MUST NOT** be installed in series. If corrosion build-up is found within the body of a relief valve, the valve **MUST** be replaced.

When leak checking a system, **NEVER** pressurize the system with oxygen or compressed air. When mixed with refrigerants, oxygen or compressed air can cause an explosion. To determine the safe pressure for leak testing, check the equipment data plate for the maximum low-side test pressure value.

When using recovery cylinders and equipment with Schrader valves, it is critical to inspect the Schrader valve core for leaks, bends, and breakage. Replace damaged valve cores to prevent leakage, and always cap Schrader ports to prevent accidental depression of the valve core. **NEVER** heat a refrigerant cylinder with an open flame. Do not cut or braze refrigerant lines on a charged unit.

In the event of a “large” release of refrigerant in a confined area, Self-Contained Breathing Apparatus (SCBA) is required. If a large leak of refrigerant occurs in an enclosed area, and SCBA is not available, **IMMEDIATELY VACATE AND VENTILATE** the area. In large quantities, all refrigerants can cause suffocation because they can displace oxygen. Inhaling refrigerant vapors or mist may cause heart irregularities, unconsciousness, and oxygen deprivation leading to death (asphyxia).

NEVER expose refrigerants to open flames or glowing hot metal surfaces. At high temperatures, refrigerants decompose and form acids. Hydrochloric acid is formed if the refrigerant contains chlorine and hydrofluoric acid is formed if the refrigerant contains fluorine. If oxygen is also present, it is possible to form carbon monoxide, carbon dioxide and phosgene gas. If a hydrocarbon refrigerant is released into a space, an explosion can occur if the refrigerant concentration is above the Lower Flammability Limit and below the Upper Flammability Limit with an ignition source.

Always review the Safety Data Sheets (SDS) when working with any solvents, chemicals, or refrigerants. Silicone elastomers, for use in seals and gaskets, are not compatible with HFO refrigerants.

Only use an alcohol spray to remove or clean ice from a sight glass when required.

Shipping & Transporting

Before shipping any used refrigerant cylinders, check that the cylinder meets DOT standards. Complete the shipping paperwork including the number of cylinders of each refrigerant, and properly label the cylinder with the type and amount of refrigerant before it is returned for reclaiming. Cylinders should be transported in an upright position. Each cylinder must be marked with a DOT classification tag indicating it is either a non-flammable or flammable gas. Some states may require special shipping procedures to be followed based on their classification of used refrigerants. Check with the DOT in your state.

EPA Section 608 Preparatory Manual

The following table lists refrigerants with characteristics that may be covered in each of the sections; Core, Types I, II & III.

Ref. No.	Type	Name	Ozone Depletion Potential (ODP)	Global Warming Potential (GWP)	Common Use	EPA Pressure Range	ASHRAE Class
R-11	CFC	Trichlorofluoromethane	1 Base	4000	Air-conditioning Chillers (Phased Out)	Low	A1
R-12	CFC	Dichlorodifluoromethane	1	10900	Automotive, Domestic, Commercial (Phased Out)	Medium	A1
R-22	HCFC	Difluoromonochloromethane	55	1810	Air-conditioning,	High	A1
R-123	HCFC	Dichloro-trifluoroethane	0.012	76	Commercial Chillers	Low	B1
R-502	CFC + HCFC	Chlorodifluoromethane/ Chloropentafluoroethane	33	4657	Low-temperature Commercial	High	A1
R-134a	HFC	Tetrafluoroethane	0	1430	Automotive, Domestic, Commercial	Medium	A1
R-404A	HFC	Pentafluoroethane, Trifluoroethane, Tetrafluoroethane	0	3920	Medium and low-temperature commercial and industrial	High	A1
R-407C	HFC	R-32/125/134a (23±2/25±2/52±2)	0	1770	Air-conditioning R-22 retrofit	High	A1
R-410A	HFC	Hydrofluorocarbon	0	2090	Air-conditioning	High	A1
R-422B	HFC	Pentafluoroethane Trifluoroethane, Isobutane	0	3143	Retrofit for medium & low temp., R-22, R-407, R-502 & other HCFC blends	High	A1
R441	HC	Ethane, Propane, Butane, Isobutane	0	0	Domestic Refrigerators & Freezers, Venting machines, & Self contained Commercial Refrigerators & Freezers	High	A3
R-170	HC	Ethane	0	6	Manufacturing	Very High	A3
R-290	HC	Propane	0	3	Commercial & Industrial Process Refrigeration	High	A3
R-600a	HC	Isobutane	0	3	Domestic Small Appliances, Commercial & Industrial Process Refrigeration	Medium	A3
R-744	HC	Carbon Dioxide	0	1 Base	Commercial & Industrial Process Refrigeration	Very High	A1
R-717	HC	Ammonia	0	0	Air-conditioning, Commercial & Industrial Process Refrigeration	High	B2
R-1234yf	HFO	Hydrofluoroolefin	0	4	Automotive,	Medium	A2L
R-1234ze	HFO	Hydrofluoroolefin	0	6	New Chillers, heat pumps, and vending	Medium	A2L
R-1233zd	HFO	Hydrofluoroolefin	0	1	New Chillers & Foam blowing	Low	A2L


Persons handling refrigerant during maintenance, service, or repair of Small Appliances must be certified as either a Type I Technician or as a Universal Technician, with the exception of motor vehicle air conditioning (MVAC). The EPA definition of a small appliance includes; products manufactured, charged, and hermetically sealed in a factory containing five pounds or less of refrigerant. Split-systems may not be serviced by Type I technicians. The sale of regulated refrigerants such as CFCs, HCFCs, HFCs and HFOs is restricted to certified technicians.

Note: MVAC certification is covered under Section 609 of the Clean Air Act.

Equipment Requirements

Passive (system dependent) or active (self-contained) recovery equipment must be certified by an EPA-approved testing laboratory, (example, U.L. or E.T.L). When using recovery equipment manufactured after November 15, 1993, it must be able to recover **90% of the refrigerant when the compressor in the appliance is functioning, or 80% of the refrigerant when the appliance's compressor is not functioning.** Evacuating the appliance to four inches of mercury vacuum is low enough to satisfy the rules.

All recovery equipment must be equipped with low-loss fittings that can be manually closed, or close automatically, when hoses are disconnected, to minimize the refrigerant loss.

 **Note:** Isobutane (R-600a), an HC, is approved as a substitute refrigerant for new household refrigerators, freezers, and combination refrigeration/freezers. R-600a cannot be used for retrofitting a small appliance.

Leak Repair Requirements

The EPA does not require leak repair for small appliances, but leaks should be repaired whenever possible to conserve refrigerant. Make sure the valve cores are tight and the caps are on the Schrader ports to prevent accidental depression and leaking from the valve cores.

Recovery Techniques

Before beginning a refrigerant recovery procedure, it is necessary to know the type of refrigerant that is in the system. After recovery, if contaminants are present in the oil, the system will have to be flushed with a cleaning solvent designed for the type of refrigerant in the system. To speed up the process, recover from both the low and high side of the system.

If a reclamation facility receives a tank of mixed refrigerant, they may refuse to process the refrigerant and destroy it at the owner's expense. **Do not mix refrigerants in a recovery tank.**

Self-contained (active) recovery equipment has its own means of pumping and removing refrigerant from an appliance and is capable of reaching the required recovery levels whether or not the appliance compressor is operable. Self-contained recovery equipment pumps the refrigerant into a recovery tank. Before operating a self-contained recovery machine, make sure that the tank inlet valve is open, and that the recovery tank does not contain excessive non-condensables (air). Obtaining accurate pressure and temperature measurements of refrigerant inside a recovery cylinder is necessary to detect excessive non-condensables and the type of refrigerant. The only way to identify the refrigerant is to measure the refrigerant pressure accurately at a stable, known temperature. Air in a refrigeration system will cause higher discharge pressures in the system and recovery equipment. Follow the operating instructions supplied by the recovery equipment manufacturer regarding purging of non-condensables. All refrigerant recovery equipment should be checked for oil level and refrigerant leaks on a daily basis, and replace filters as required. When using a recovery machine on very low horsepower systems such as domestic refrigerators and freezers that contain a few ounces of refrigerant, it is important to recover the refrigerant from the low and high sides to prevent oil migration.



Type I

A system-dependent (passive) recovery process for small appliances captures refrigerant into a non-pressurized container. This may be a special plastic “bag” container large enough to contain a few ounces of refrigerant. A standard vacuum pump can only be used as a recovery device in combination with a non-pressurized container. The vacuum pump is only used to reduce the pressure of a recovery cylinder or container into a vacuum before the recovery process.

With system-dependent recovery equipment, some special procedures may be necessary depending on the condition of the appliance. System dependent devices may only be used on appliances containing 15 lbs. of refrigerant or less. When using a system-dependent recovery process on an appliance with an *operating compressor*, run the compressor and recover from the high side of the system. Usually, one access fitting on the high side will be sufficient to reach the required recovery rate as the appliance compressor should be capable of pumping the refrigerant to the high side.

If the appliance has a *non-operating compressor*, access to both the low and high side of the system may be necessary. In order to achieve the required recovery efficiency, it will be necessary to take measures such as heating and tapping the compressor several times to help release trapped refrigerant from the compressor oil, turning on the defrost heater to warm the evaporator. Because appliances with non-operating compressors cannot always achieve desired evacuation level utilizing system-dependent recovery equipment, the EPA requires technicians to have at least one self-contained recovery device available at the shop to recover refrigerant from systems with non-operating compressors. The exception to this rule is persons working on their own small appliances. The rule is stated as: *“Persons who maintain, service, repair, or dispose of only appliances that they own and that contain pumpout units are exempt from the requirement to use certified, self-contained recovery and/or recycling equipment.”*

Small appliances are equipped with a straight piece of tubing, called a process tube, onto which a piercing type access fitting can be installed. When installing an access fitting onto a sealed system, the fitting should be leak tested before proceeding with recovery. It is generally recommended that solderless piercing type valves only be used on copper or aluminum tubing material. These fittings tend to leak over time and should not be left on an appliance as a permanent service fixture. If, after installing an access fitting, you find that the system pressure is 0 psig, do not begin the recovery process. If a strong odor is detected during the recovery process, a compressor burn-out has likely occurred. When recovering refrigerant from a system that experienced a compressor burn-out, watch for signs of contamination in the oil. After recovering refrigerant, if nitrogen is used to flush debris out of the system, the nitrogen may be legally vented.

Small appliances used in campers or other recreational vehicles may use refrigerants such as Ammonia, Hydrogen, or water, and therefore should not be recovered using current recovery equipment.

When filling a charging cylinder with a regulated refrigerant, the refrigerant vapor that is vented off the top of the cylinder must be recovered.

Safety & Shipping

Safety and shipping requirements are covered in the Core section of this manual.



Note: None of the hydrocarbon refrigerants are approved for retrofit into existing household refrigerators. The appliance must be designed for a hydrocarbon refrigerant and labeled as to the type of refrigerant. This label must be placed on the outside of the appliance in view of the service location.

Technicians maintaining, servicing, repairing or disposing of high-pressure to very high-pressure appliances, except small appliances and motor vehicle air conditioning systems (MVAC), must be certified as a Type II Technician or a Universal Technician.

Leak Detection

After the installation of any type of system, the unit should first be pressurized with nitrogen (an inert gas) and leak checked. To determine the general area of a leak use an electronic or ultrasonic leak detector. Once the general area of the leak is located the use of soap bubbles will pinpoint the leak. In order to use an electronic leak detector on a system that is pressurized with nitrogen, a trace of refrigerant must be added to the system.

A refrigeration unit using an open compressor that has not been used in several months is likely to leak from the rotating shaft seal. During a visual inspection of any type of system, traces of oil are an indication of a refrigerant leak. Excessive superheat caused by a low refrigerant charge is also an indication of a leak in a high-pressure system.

Leak Repair Requirements

EPA regulations require all comfort cooling (air conditioning) appliances containing 50 lbs. or more of a regulated refrigerant to have annual leak inspections to determine if the appliance is leaking. The appliance must be repaired within 30 days when the annual leak rate exceeds 10% of the total charge. A leak-test must be performed after each repair attempt, and a follow-up verification leak-test must be conducted within 10 days of the repair.

The time frame for mandatory leak repair can only be extended by a certified service technician. If the leaking appliance is not going to be repaired, it must be retired or mothballed. When an appliance is mothballed, the leaking component of the system must be isolated and the refrigerant recovered to prevent further leaking.

Type II appliances that will not be repaired must be retrofitted or retired in 12 months. If the appliance is using an exempt refrigerant then the owner has 18 months to retire the leaking system.

All commercial and industrial process refrigeration (IPR) containing more than 50 lbs. of refrigerant MUST be repaired when the annual leak rate is exceeds 20% for commercial appliances and 30% for IPR. When one appliance is used for both industrial process refrigeration and other applications, it will be considered industrial process refrigeration equipment when 50% or more of its operating capacity is used for industrial process refrigeration. **Commercial refrigeration appliances and IPR with a full charge of 500 pounds or more of a regulated refrigerant will require a leak inspection to be conducted every three months unless a refrigerant leak monitoring system is installed or it has not exceeded the leak rate for four quarters.**

The total system refrigerant charge can be calculated by adding the charge for each component and the piping. Using the calculated charge, the leak rate percentage can be determined for the quantity of refrigerant added to a system that is new, retrofitted, or adjusted for seasonal variance. **When an appliance containing 50 lbs. of a regulated refrigerant or more leaks 125% or more, the owner must submit a report to EPA describing efforts to identify leaks and repair. All records for leak inspections, initial verification, verification tests and records of recovered refrigerant from equipment with 5 to 50 lbs. must be kept for 3 years by the owner or operator.** This includes the quantity of refrigerant, by type added, recovered from disposed appliances in each calendar month and quantity of refrigerant, by type, sent for reclamation or destruction. Topping off a system is considered adding refrigerant due to a leak and must be accounted for in the leak-rate calculation.



Type II

Recovery Techniques

Proper recovery techniques begin with the use of appropriate recovery equipment that has been certified by an EPA approved laboratory (UL or ETL) to meet or exceed AHRI Standards.

Recovered refrigerants may contain acids, moisture, and oil. It is necessary to frequently check and change both the oil and filter on a recovery/recycling unit. Both recycling and recovery equipment using hermetic compressors have the potential to overheat when drawing a deep vacuum, because the unit relies on the flow of refrigerant through the compressor for cooling. Before using a recovery unit you should always check the service valve positions, the oil level of the recovery unit, and evacuate and recover any remaining refrigerant from the unit and receiver.

Technicians working with multiple refrigerants, before recovering and/or recycling a different refrigerant, must purge the recover/recycle equipment by recovering as much of the first refrigerant as possible, change the filter, and evacuate. The only exception to this rule is for technicians working with HFCs who must provide a special set of hoses, gauges, vacuum pump, recovery or recovery/recycling machine, and oil containers to be used with HFCs only.

Although recovering refrigerant in the vapor phase will minimize the loss of oil, recovering as much as possible in the liquid phase from the liquid line or receiver can reduce recovery time. The technician may choose to speed up the recovery process by packing the recovery cylinder in ice and/or applying heat to the appliance. After recovering liquid refrigerant, any remaining vapor is removed and condensed by the recovery equipment.

Very large capacity recovery machines may have a water-cooled condenser to aid in faster recovery. **The water-cooled condenser requires connection to a potable or municipal water supply.**

When performing refrigerant system service on an operating unit that has a receiver/storage tank, refrigerant should be pumped into the receiver. Refrigerant should be removed from the condenser outlet if the condenser is below the receiver. The compressor in a parallel-rack system with an open equalization connection must be isolated before recovering refrigerant.

After recovery, refrigerant may be returned to the appliance from which it was removed or to another appliance owned by the same person without being recycled or reclaimed. The technician should always evacuate an empty recovery cylinder before transferring refrigerant to the cylinder. Quick couplers, self-sealing hoses, or hand valves should be used (as low-loss fittings) to minimize refrigerant release when hoses are connected and disconnected.

Recovery Requirements

Anyone that services, repairs, or disposes of Type I, II or III equipment must have recovery equipment and/or recycling equipment that is certified and labeled by an EPA-approved equipment testing organization to meet EPA Standards. The purchase of recovery equipment does not need to be reported to the EPA.

After reaching the desired vacuum, the technician should wait a few minutes to see if the system pressure rises, indicating that there is still refrigerant in liquid form or in the oil. Appliances can be evacuated to atmospheric pressure (0 psig) if leaks make recovery (evacuation) to the prescribed level unattainable. System-dependent recovery equipment cannot be used on appliances containing more than 15 pounds of refrigerant.

A “major repair,” according to EPA regulations, is defined as any maintenance, service or repair involving the removal of any or all of the following components: the compressor, the condenser, the evaporator or an auxiliary heat exchanger coil.

Refrigeration Notes (Review vapor/compression system in introduction)

With the phase-out of CFCs and HCFCs, the industry has developed many different refrigerant blends for retrofit use. Read the nameplate and look for labels attached to a system to help identify the type of refrigerant used and the total charge.

Some systems are equipped with a moisture-indicating sight glass. When the sight glass changes color, the system contains excessive moisture and will need to be evacuated. In cold climates, **use isopropyl alcohol** to remove or clean ice from a sight glass.

The filter-drier should be replaced any time a system is opened for servicing. Filter driers will remove moisture from the refrigerant and oil in a system, but there is a limit to their capacity. If a strong odor is detected during the recovery process, a compressor burn-out may have occurred. When recovering refrigerant from a system that experienced a compressor burn-out, watch for signs of and test for contamination of the oil.

A crankcase heater is often used to prevent refrigerant from migrating into the oil during periods of low ambient temperature. Refrigerant in the oil will cause oil foaming in the compressor at start-up.

The more accurate and preferred method of measuring a deep vacuum is in microns. When evacuating a vapor compression system, the vacuum pump should be capable of pulling 500 microns (29.90" hg) of vacuum.

Do not energize a hermetic compressor's motor under a deep vacuum, as the compressor's motor windings can become damaged, also NEVER energize a compressor if the discharge service valve is closed, this can cause severe damage.

The use of a large vacuum pump could cause trapped water to freeze. During evacuation of systems with large amounts of water, it may be necessary to increase pressure by introducing nitrogen to counteract freezing.

The source of most non-condensables in a system is air. Non-condensables will cause higher discharge pressures. All refrigeration systems must be protected by one or more internal or external pressure relief valves.

When charging a large system, it is best to charge liquid through the liquid-line service valve. Large systems usually have service valves which will enable the system to be pumped-down allowing for faster liquid charging.

When there is a risk of freezing a liquid-type heat exchanger, charging should begin by introducing refrigerant vapor into the system until the system pressure corresponds, by means of the pressure/temperature relationship, to a temperature that is above 32 degrees. Once this pressure is reached, liquid charging can follow through the liquid-line service valve. This is the proper method to charge any water source system that contains a large quantity of refrigerant.

Safety (Additional safety and shipping/transportation information is covered in the Core section of this manual.)

ASHRAE Standard 15 requires a refrigerant sensor that will sound an alarm and automatically start a ventilation system in occupied equipment rooms where refrigerant from a leak will concentrate. Equipment rooms with ammonia, R-717 refrigerant, do not require a leak sensor if the room's mechanical ventilation system is continuously operated.

Type II & III



[Review the table on page 16 for ASHRAE’s refrigerant safety classifications.](#)

REQUIRED LEVELS OF EVACUATION FOR TYPE II & III APPLIANCES		
[Except for small appliances, MVACs, and MVAC-like appliances]		
Type of appliance	Using recovery and/or recycling equipment manufactured or imported	
	Before November 15, 1993	After November 15, 1993
Very high-pressure appliance	0" Hg	0" Hg
High-pressure appliance, or isolated component of such appliance, with a full charge of less than 200 lbs. of refrigerant.	0" Hg	0" Hg
High-pressure appliance, or isolated component of such appliance, with a full charge of 200 lbs. or more of refrigerant.	4" Hg	10" Hg
Medium-pressure appliance, or isolated component of such appliance, with a full charge of less than 200 lbs. of refrigerant.	4" Hg	10" Hg
Medium-pressure appliance, or isolated component of such appliance, with a full charge of 200 lbs. or more of refrigerant.	4" Hg	15" Hg
Low-pressure appliance	25 mm Hg absolute	25 mm Hg absolute

Table 1. Required recovery levels (in inches of mercury) for Type II and III appliances.

Section 608 Leak Repair Regulations		
The updated Section 608 regulations include new leak inspection and verification test requirements for owners/operators that will affect technicians starting January 1, 2019:		
Leak inspections are required for appliances that have exceeded the applicable leak rate, according to the schedule below. All visible and accessible components of an appliance must be inspected, using a method or methods that are appropriate for that appliance.		
Equipment	Full Charge	Frequency of Leak Inspections
Commercial Refrigeration and Industrial Process Refrigeration	> 500 pounds	Once every three months until the owner/operator can demonstrate through leak rate calculations that the leak rate has not exceeded 20% (commercial refrigeration) or 30% (IPR) for four quarters in a row.
	50 to 500 pounds	Once per calendar year until the owner/operator can demonstrate through the leak rate calculations that the leak rate has not exceeded 20% (commercial refrigeration) or 30% (IPR) for one year.
Comfort Cooling	50 or more pounds	Once per calendar year until the owner/operator can demonstrate through the leak rate calculations that the leak rate has not exceeded 10% for one year.
<p>Initial and follow-up verification tests: leak repairs are required for appliances that exceed the applicable leak rate. The verification tests must demonstrate that leaks were successfully repaired.</p> <ul style="list-style-type: none"> • An initial verification test must be performed before any additional refrigerant is added to the appliance. • A follow-up verification test must be performed only after the appliance has returned to normal operating characteristics and conditions. There is no minimum timeframe. 		

Technicians maintaining, servicing, repairing or disposing of low-pressure appliances must be certified as a Type III Technician or a Universal Technician. Most low-pressure appliances are used for comfort cooling and are subject to a lower allowable leak rate.

The owner and/or operator of the equipment is responsible for keeping records of all leak inspections and any completed leak repair verification tests. It is their responsibility to obtain service records from the servicing company doing any work on an appliance.

As of November 14, 1994, the sale of CFC and HCFC refrigerants is restricted to certified technicians. As of January 1, 2018, the sale of HFCs and HFOs are also restricted to certified technicians.



Note: If EPA regulations change after the technician is certified, it is the technician's responsibility to comply with these changes.

Leak Detection

Low-pressure systems are semi-hermetic and operate below atmospheric pressure (in a vacuum); leaks in the gaskets or fittings will cause air and moisture to enter the system. Leaks must be repaired to reduce the operation of the purge unit and loss of refrigerant.

The most efficient method of leak checking a charged, low-pressure refrigeration unit is to pressurize the system using controlled hot water or heater blankets. When controlled hot water or heater blankets are not feasible, use nitrogen to increase system pressure. When pressurizing a system, do not exceed 10 psig. Exceeding 10 psig can cause the rupture disc to fail. When leak testing a water box, be certain the water has been removed before placing the leak detector probe through the drain valve. To leak test a tube, use a hydrostatic tube test kit. Systems with open drive compressors are prone to leaks at the shaft seal.

Controlled hot water or heating blankets can be used to raise the pressure in a low-pressure system for the purpose of opening the system for a non-major repair. Under EPA regulations, a "major repair" means any maintenance, service or repair involving the removal of any or all of the following components: the compressor, the condenser, the evaporator or any auxiliary heat exchanger coil.

Leak Repair Requirements

Starting in 2019, EPA regulations require that **systems containing more than 50 lbs.** of refrigerant be repaired when the annual leak rate exceeds a percentage of the refrigerant charge. The appliance must be checked after each repair to verify the leak was successfully repaired.

Comfort cooling and other types of appliances 10%
(Such as dehumidifiers)

Commercial refrigeration 20%

Industrial process refrigeration 30%

(See Introduction for definition of commercial and industrial appliances.)

When the leak rate exceeds the maximum percentage on a low-pressure system, the system owner must repair the appliance enough to bring the leak rate below the threshold, or retrofit or retire the appliance. An appliance may be mothballed if it is shut down and the leaking section or component is isolated and evacuated of refrigerant to the EPA's required level.



Type III

When a system with a refrigerant charge of 50 lbs. or greater has exceeded the threshold leak rate, and it will be retrofitted or replaced using a refrigerant exempt from the venting prohibition, owners or operators have 18 months to replace/retrofit the appliance.

A low-pressure appliance leaking above the leak rate threshold must be repaired so that it leaks below the threshold and the initial verification test conducted within 30 days unless granted additional time.

An initial leak-test verification must be performed within 30 days (or 120 days if an industrial process shutdown is required) of an appliance exceeding the applicable leak rate. The follow-up leak-test must be performed within 10 days of the initial leak-test. When calculating the leak rate, the total system refrigerant charge can be calculated by adding the charge for each component and the piping. Each time a system is topped off or recharged the leak-rate must be recalculated.

The deadline to replace or retrofit an appliance cannot be extended when a certified service technician is not available to do the work. All records for leak inspections, initial verification, verification tests and records of recovered refrigerant from equipment with 5 to 50 lbs. of refrigerant must be kept for 3 years just as in Type II appliances.

Recovery Techniques

A recovery unit's high-pressure cut-out is set for 10 psig when evacuating the refrigerant from a low-pressure chiller and a rupture disc on a low-pressure recovery vessel relieves at 15 psig.

Refrigerant recovery from a system using R-11 or R-123 starts with liquid removal and is followed by vapor recovery.

A substantial amount of vapor will remain in the appliance after all liquid is removed. For example, an average 350 ton, R-123 chiller at 0 psig still contains approximately 100 lbs. of vapor after all the liquid has been removed.

Most low-pressure recovery machines utilize a water-cooled condenser that is connected to the potable or municipal water supply. Using a water-cooled recovery machine and cooling recovery cylinders will reduce the recovery time. When recovering refrigerant, the system water pumps, the recovery compressor, and the recovery condenser water should all be on circulating water to prevent freezing. Increasing the temperature in an equipment room will aid in faster recovery. If a chiller is suspected of tube leaks, the water sides of the evaporator and condenser should be drained prior to recovering the refrigerant.

ASHRAE Guideline 3 states that if the pressure in a system rises from 1 mm Hg to a level above 2.5 mm Hg during vacuum testing, the system should be leak checked.

When removing oil from a low-pressure system, a temperature of 130°F should be attained to reduce the amount of refrigerant in the oil.

Recharging Techniques

Always read the nameplate and look for labels attached to a system to help identify the type of refrigerant used and the total charge.

Refrigerant is added through the lowest access point on the system such as the evaporator charging valve. However, introducing liquid refrigerant into a deep vacuum will cause the

refrigerant to boil freezing water in the tubes. Therefore, initial charging is in the vapor phase to a pressure high enough to increase the saturation temperature of the refrigerant above the freezing temperature of water. Low-pressure refrigeration systems with refrigerants such as **R-123** require a vapor pressure equal to a saturation temperature of **36° F. or higher, to prevent freezing** of water-tubes when charging. Topping off a system is considered adding refrigerant due to a leak and must be accounted for in the leak-rate calculation. Adding refrigerant to a system that is new, retrofitted, or adjusted for seasonal variance does not need to be accounted for in the leak-rate calculation.

Recovery Requirements

Refrigerant recovery and/or recycling equipment must be certified and labeled by an EPA approved equipment testing organization to meet EPA standards. All equipment must have low loss fittings to minimize refrigerant loss when hoses are disconnected.

Recovery or recycling equipment manufactured or imported before or after Nov. 15, 1993, must be able to achieve a recovery level of **25 mm Hg absolute**.

Once the required vacuum has been achieved, the technician should wait for a few minutes and monitor the system pressure. If the pressure rises, indicating that there is refrigerant remaining in the system, recovery must be repeated. When leaks in an appliance make evacuation to the prescribed level unattainable, the appliance should be evacuated to the lowest attainable level prior to a major repair.

Refrigeration Notes (Review vapor / compression system in introduction)

The use of a large vacuum pump could cause trapped water to freeze. During evacuation of systems with large amounts of water, it may be necessary to increase pressure by introducing nitrogen to counteract freezing.

If a strong odor is detected during the recovery process, a compressor burn-out may have occurred. When recovering refrigerant from a system that experienced a compressor burn-out, watch for signs of contamination in the oil and perform an oil test.

Low-pressure chillers using refrigerants such as R-123 operate below atmospheric pressure, require a purge unit. The primary purpose of a purge unit is to remove non-condensables from the system. A centrifugal chiller's purge unit takes its suction from the top of the condenser, separates air and other non-condensables from the refrigerant, and then returns the refrigerant back to the evaporator.

Although a high efficiency purge unit discharges a low percentage of refrigerant with the air they remove, frequent purging and subsequent refrigerant loss can indicate that a leak is allowing air into the system. High discharge pressure is also an indication of air in the system. Excessive moisture collection in the purge unit can indicate tube leakage. To prevent air accumulation in an idle system, a slight positive internal pressure above atmosphere should be maintained.

To protect the system from over-pressurization, low-pressure chillers typically use a rupture disc mounted on the evaporator housing. The typical design burst pressure for a rupture disc is 15 psig.

Type III

Safety (Additional safety and shipping/transportation information is covered in the Core section of this manual.)

ASHRAE Standard 15 requires a refrigerant monitor to sense refrigerant leaks that will sound an alarm and automatically start a ventilation system in equipment rooms before the refrigerant concentration reaches the TLV-TWA, (threshold limit value-time weighted average).

A refrigerant monitor is required for all ASHRAE refrigerant safety groups.

Refrigerants are divided into two groups according to toxicity:

- Class A signifies refrigerants for which toxicity has **NOT** been identified at concentrations less than or equal to 400 ppm;
- Class B signifies refrigerants for which there is evidence of toxicity at concentrations below 400 ppm.

ASHRAE code classification for refrigerants CFC-12, CFC-11, and HFC-134a are grouped as A-1. Refrigerant HCFC -123 is code grouped as B-1.

Review the table on page 16 for ASHRAE's refrigerant safety classification.

All refrigeration systems must be protected by a pressure relief valve. If more than one relief valve is required they must be piped in parallel not series. Another safety device is the rupture disc located on the evaporator of a low-pressure chiller. The rupture disc should be piped to the outdoors in case of rupture to prevent the equipment room from filling with refrigerant.

°F	Low-Pressure Refrigerant <30psig			Medium-Pressure Refrigerant 30 to 155psig								°F
	HCFC R-123	HFC R-245fa	HFO R-1233zd	CFC R-12	HCFC R-124	HCFC R-409A Bubble	HFC R-409A Dew	HFC R-134a	Isobutane R-600a	HFO R-1234yf	HFO R-1234ze	
-40°	*	-13.9	28.3	11.0	22.1	6.7	14.8	14.8	21.6	11.5	19.1	-40°
-35°	*	-13.7	28.0	8.4	20.9	3.5	12.5	12.5	20.4	8.9	17.4	-35°
-30°	*	-13.5	27.6	5.5	19.4	0.0	9.9	9.8	18.9	6.0	15.4	-30°
-25°	*	-13.2	27.2	2.4	11.8	1.9	7.0	6.9	17.4	2.8	13.3	-25°
-20°	27.8	-13.0	26.7	0.5	16.0	4.0	3.8	3.1	15.6	0.4	10.9	-20°
-15°	27.4	-12.7	26.1	2.4	14.0	6.3	2.0	0.1	13.7	2.3	8.2	-15°
-10°	26.9	-12.2	25.5	4.5	11.8	8.8	1.8	1.9	11.5	4.4	5.3	-10°
-5°	26.4	-11.9	24.7	6.7	9.3	11.6	4.0	4.1	9.2	6.7	2.0	-5°
0°	25.9	-11.4	23.9	9.1	6.6	14.6	6.3	6.5	6.6	9.1	0.8	0°
5°	25.2	-11.0	23.0	11.7	3.6	17.8	8.8	9.1	3.8	12.0	2.7	5°
10°	24.5	-10.4	22.0	14.6	0.3	21.3	11.6	11.9	0.7	14.9	4.8	10°
15°	23.8	-9.5	20.8	17.7	1.6	25.1	14.7	15.0	1.3	18.1	7.2	15°
20°	22.8	-9.1	19.5	21.0	3.6	29.2	18.0	18.4	3.1	21.6	9.7	20°
25°	21.8	-8.0	18.1	24.6	5.7	33.6	21.6	22.1	5.0	25.4	12.5	25°
30°	20.7	-7.5	16.5	28.4	8.0	38.4	25.5	26.1	7.1	29.4	15.4	30°
35°	19.5	-6.8	14.7	32.5	10.5	43.4	29.7	30.4	9.4	33.8	18.7	35°
40°	18.1	-5.6	12.8	36.9	13.2	48.9	34.2	35.0	11.8	38.4	22.2	40°
45°	16.6	-4.2	10.7	41.6	16.1	54.7	39.1	40.1	14.4	43.4	26.0	45°
50°	14.9	-2.8	8.3	46.6	19.3	60.9	44.3	45.4	17.2	48.8	30.0	50°
55°	13.0	-1.8	5.8	51.9	22.7	67.5	49.9	51.2	20.2	54.5	34.4	55°
60°	11.2	0.0	3.0	57.6	26.3	74.5	55.9	57.4	23.5	60.6	39.1	60°
65°	8.9	1.9	0.0	63.7	30.2	81.9	62.3	64.0	26.9	67.0	44.1	65°
70°	6.5	3.5	1.6	70.1	34.4	89.8	69.2	71.1	30.6	73.9	49.5	70°
75°	4.1	5.9	3.4	76.8	38.9	98.2	76.5	78.7	34.5	81.3	55.2	75°
80°	1.2	7.9	5.3	84.0	43.7	107	84.2	86.7	38.6	89.0	61.3	80°
85°	0.9	10.2	7.3	91.6	48.8	116	92.5	95.2	43.0	97.2	67.8	85°
90°	2.5	12.8	9.5	99.6	54.3	126	101	104	47.7	106	74.8	90°
95°	4.3	15.8	11.9	108	60.1	137	111	114	52.7	115	82.1	95°
100°	6.1	19.0	14.4	117	66.2	148	120	124	57.9	125	89.9	100°
104°	7.7	21.3	16.6	124	71.4	157	129	133	62.3	133	96.5	104°
105°	8.1	23.0	17.1	126	72.7	159	131	135	63.4	135	98.2	105°
110°	10.3	26.0	20.0	136	79.6	171	142	146	69.3	146	107	110°
115°	12.6	30.0	23.1	146	86.9	184	153	158	75.4	157	116	115°
120°	15.1	33.0	26.5	157	94.6	197	166	171	81.9	169	126	120°
125°	17.8	36.0	30.0	169	103	211	179	185	88.7	182	136	125°
130°	20.6	41.0	33.8	181	111	226	192	199	95.8	195	147	130°
135°	23.6	46.0	37.8	193	120	241	207	214	103	209	158	135°
140°	26.8	52.0	42.0	206	130	257	222	229	111	223	171	140°
145°	30.2	57.0	46.5	220	140	274	237	246	120	239	183	145°
150°	33.9	61.0	51.3	234	150	291	254	263	128	255	196	150°

Remove this back page and bring with you to the examination.

High-Pressure Refrigerant 155 to 340psig														Very High Press over 340psig	
°F	HCFC	R-404A		R-407C		R-422D		R-422B		R-441A		HFC	Ammonia	C02	°F
	R-22	Bubble	Dew	Bubble	Dew	Bubble	Dew	Bubble	Dew	Bubble	Dew	R-410A	R-717	R-744	
-40	0.6	4.9	4.3	2.7	4.6	2.4	2.3	0.9	2.7	4	2	11	9	132	-40
-35	2.6	7.5	6.8	5.1	0.9	4.6	0.8	3.0	0.9	8	4	14	6	147	-35
-30	4.9	10.3	9.6	7.7	1.6	7.1	3.0	5.4	1.1	9	5	18	2	163	-30
-25	7.4	13.4	12.7	10.6	3.9	9.9	5.4	7.9	3.2	13	9	22	1	181	-25
-20	10.2	16.8	16.0	13.7	6.5	12.9	8.1	10.7	5.7	14	10	26	4	200	-20
-15	13.2	20.5	19.7	17.2	9.3	16.2	11.0	13.8	8.3	17	14	31	5	221	-15
-10	16.5	24.6	23.6	20.9	12.3	19.8	14.3	17.1	11.3	18	15	36	9	243	-10
-5	20.1	28.9	27.9	25.0	15.7	23.7	17.8	20.7	14.5	25	21	42	12	266	-5
0	24.0	33.7	32.6	29.5	19.4	27.9	21.7	24.7	18.0	28	24	48	16	291	0
5	28.3	38.8	37.7	34.3	23.5	32.5	25.8	29.0	21.9	33	27	55	20	318	5
10	32.8	44.3	43.1	39.5	27.9	37.5	30.4	33.6	26.1	38	33	62	24	346	10
15	37.8	50.2	49.0	45.2	32.7	42.8	35.3	38.6	30.6	44	35	70	28	376	15
20	43.1	56.6	55.3	51.2	37.9	48.5	40.7	43.9	35.5	49	44	78	33	407	20
25	48.8	63.4	62.2	57.7	43.5	54.7	46.4	49.7	40.8	54	47	87	39	441	25
30	55.0	70.7	69.3	64.7	49.6	61.3	52.6	55.9	46.6	66	51	97	45	476	30
35	61.5	78.6	77.1	72.2	56.1	68.4	59.3	62.5	52.7	66	60	107	51	513	35
40	68.6	86.9	85.4	80.2	63.2	75.9	66.4	69.6	59.4	74	68	118	58	553	40
45	76.1	96.8	94.2	88.8	70.7	84.0	74.0	77.2	66.5	80	74	130	66	595	45
50	84.1	105	104	97.9	78.8	92.6	82.2	85.3	74.1	88	80	143	74	638	50
55	92.6	115	114	108	87.5	102	90.9	94.0	82.2	97	89	156	83	684	55
60	102	126	124	118	96.8	111	100	103	90.9	105	97	170	93	733	60
65	111	137	136	129	107	122	110	113	100	115	106	185	103	784	65
70	121	159	147	141	117	133	121	123	110	125	117	201	114	838	70
75	132	162	160	153	129	144	132	134	120	133	124	218	126	895	75
80	144	175	173	166	141	156	144	145	132	145	135	236	138	955	80
85	156	190	188	180	153	169	156	158	143	155	145	255	151	1018	85
90	168	205	202	194	167	183	170	170	156	167	157	275	166	*	90
95	182	220	218	209	181	197	184	184	169	180	171	296	181	*	95
100	196	237	235	226	196	212	198	198	183	193	182	318	197	*	100
104	208	251	249	239	209	225	211	210	195	203	192	336	210	*	104
105	211	254	252	242	212	228	214	213	198	210	200	341	214	*	105
110	226	273	270	260	229	245	231	229	213	218	207	365	232	*	110
115	243	292	290	279	247	262	248	246	230	235	225	391	251	*	115
120	260	312	310	299	266	281	266	263	247	251	240	418	271	*	120
125	278	333	331	319	286	300	286	281	265	267	255	447	293	*	125
130	297	356	354	341	307	320	306	301	284	282	275	477	315	*	130
135	317	379	377	363	329	341	327	321	304	305	292	508	339	*	135
140	337	404	402	387	352	364	350	342	326	319	307	541	364	*	140
145	359	430	428	412	377	387	373	364	348	333	315	576	390	*	145
150	382	456.8	455	438	403	411	398	387	387	*	*	613	417	*	150

ISBN: 1-930044-60-7



6 51881 68004 3