

Handbook of Industrial Electric Heat Tracing







HEAT TRACE LIMITE	5
-------------------	---

•	The Innovation Culture – the Past, the Present and the Future	4-5
	Heat Trace Limited	6-7

INDUSTRIAL HEAT TRACING – An Introduction

What is it?	8
What is its purpose?	8
Steam or Electric?	8
The Need?	8
The System?	8
Safe Practice	9
Applicable Standards	9
Applications	10-11

SYSTEM DESIGN – General

Contents

Objective – A safe system that works	12-13
Considerations in Hazardous Areas	14-17
Heating Loads	18-19
Temperature control	20
Circuit monitoring	21

PRODUCTS AND PRODUCT SELECTION

 Heating Cables – Generic types Heating Cables – Selection Guide Typical Long Pipeline Applications 	22-25 26-27 28-29
 Parallel, self-regulating Parallel, constant power Series resistance, Longline 	30-35 36-39 40-43
Termination Components	44-45
Temperature Control – Selection Guide	46-47
 Type I Temperature controllers - Maintaining above a minimum point Type II Temperature controllers - Maintaining within a broad band Type III Temperature controllers - Maintaining within a narrow band 	48-49 50-51 52-53
Circuit Monitoring Equipment	54-55



	INSTALLATIONS 5
 Installation and System Testing Commissioning & Documentation Maintenance 	56-63 64-65 66-67
EVOL	.UTION – The Complete Design Tool 🌀
Evolution – The Complete Heat Tracing System Design Suite	68-69
A Customer's Perspective	70-71
Enquiry Management	72-73
 Enquiry Modelling Enquiry Details Design Selections Heater Selection Pipe Groups Pipe Dimensions Bill of Material Quotations and Reports 	74-83 74 75 76 77 78-79 80-81 82-85

Contents



The Past, the Present,and the Future

The Past

When Heat Trace Limited was founded in 1974, electric heat tracing was in its infancy – most heat tracing used steam as its heat source at that time.

In the four decades since, electric heat tracing has grown into an industry in its own right. Heat Trace Limited has played a prominent role in its growth throughout as a *Leader in Innovation*.

From the start, Heat Trace developed products and systems meeting Heat Trace's own corporate objectives of improving:-

safety, efficiency, reliability and performance.

The world's first parallel resistance cut-to-length Heat Tracer heating cable was patented, developed and launched by Heat Trace Limited in 1975. It remains within our product range to this day, bearing testament to the significance of this invention.

Heat Trace Limited were perhaps the first Heat Tracing company to recognise the important link between control technology and the "safety, efficiency, reliability and performance" of heat tracing installations.

The company patented PowerMatch, a self-regulating proportional controller that turns heater power up or down in response to changes in heat losses. Although launched almost 20 years ago, the benefits of ambient proportional control to safety and efficiency have only recently been recognised on a global basis.

Innovation-led technology resulted in Heat Trace Limited becoming the industry's technical leader...



The Present

Heat Trace's *Innovation Culture* has culminated in its position as the Technology Leader within our Industry today. This position is demonstrated by:-

1. The largest and best range of self-regulating heating cables

- Highest continuous 'maintain' temperature (200°C)
- Highest continuous 'withstand' temperature (300°C)
- Widest voltage range (12 to 1000V)
- All inherently temperature-safe (IT-S)

Heat Trace's range of self-regulating heating cables cater for most heat tracing applications

2. The highest temperature cut-to-length Heat Tracer in the world.

Heat Trace's patented mineral insulated, metal sheathed, type AHT heating cable can withstand 425°C continuously, and deliver up to 200W/m.

The AHT tracer can cater for virtually all applications outside the capability of the self-regulating tracer range.

3. EVOLUTION - the world's most advanced heat tracing Design Tool (See section 6).

Additionally, Heat Trace's range of electronic control and monitoring equipment extends from simple thermostats to microprocessor controls capable of integrating into overall plant SCADA and DCS systems.

Today, Heat Trace Limited is a global company providing complete heat tracing solutions. In addition to systems manufacture, services include consultancy, system design, installation and commissioning, project management, maintenance and training.

Heat Trace Limited continues to be...

The Heat Tracing Authority™



The Past, the Present,and the Future

The Future

Heat Trace's emphasis on an *Innovation Culture* has resulted in an extensive and active Research and Development Department, located at the Heat Trace Innovation & Technology Centre near Manchester UK.

In addition to test equipment the Centre has its own specialist pre-production, prototyping and compounding facilities, including polymer, elastomer, mineral and metal continuous extrusion capability.

The Technology Centre is fully equipped to carry out all international standard type testing. In addition, the Centre has a 40ft (12m) x 7ft (2.2m) x 6.5ft (2m) refrigerated cold room facility that allows us to carry out product and systems testing down to -40° C.

At the time that this brochure went to press, Heat Trace Limited had multiple patents/patent applications in the course of development, and an extensive Product Development project list, mainly involving semi-conductive polymer formulations.

These projects will result in many new and unique products and processes over the forthcoming decade ensuring Heat Trace Limited's position as the Technology Leader within its industry sector....

Heat Trace Limited will remain...



Gravimetric Blending System



Cold Room facility





Heat Trace Limited In the U.K.

Heat Trace Ltd has been manufacturing electrical heating cables in the U.K. since 1974.

The main manufacturing facility and headquarters of the company is at Helsby in the North West of England. This factory houses the main processing equipment for the manufacture of semi-conductive self-regulating heating cables; core compounding, heating matrix extrusion, and other more recognised standard cable making processes. The main item of capital equipment is the Electron Beam Unit – one of only two similar units in the U.K., and one of only a few in Europe.

The Helsby Headquarters handles sales to all countries around the world. Exports account for over 90% of Heat Trace sales.

In addition, the Heat Trace Innovation & Technology Centre is located close to Manchester, only 56 km from the Helsby headquarters. The Bredbury complex has been a Heat Trace owned premises for over 25 years, and constant power heating cables are made here.









Heat Trace Limited



Control Panel for 3m Pipe Test Rig




Extrusion Temperature Control Unit



24 Spindle Braider



3m Pipe Test Rig



Skin Effect Test Rig

Heat Trace Limited in the UK





INDUSTRIAL HEAT TRACING – An Introduction

Heat Tracing - What is it?

"Heat Tracing (or Trace Heating, or Surface Heating) is the method of applying heat to a body, or to a product (liquid, powder, or gas) contained within a system (pipework, vessel or equipment) for storage or transportation, in order to avoid processing problems or difficulties."

Heat may be applied, for example, to:-

Liquids

- to prevent freezing
- to enable pumping by reducing the viscosity of the liquid **Powders**
- to eliminate condensation from the walls of equipment that could result in 'clogging' of the product
- Gases
- to prevent hydration due to a drop in gas pressure across pipework fittings such as valves

Heat Tracing – What is its purpose?

Heat Tracing is usually provided to maintain a product or equipment at a temperature that will prevent processing problems. For example :-

- Above 5°C to freeze protect water or aqueous solutions
- Above, for example, 50°C to prevent oil from becoming too viscous to pump
- To maintain surfaces above a dew point temperature below which condensation could form on a surface and potentially create 'clogging' of a powder.


Heat Tracing may also be required to heat raise products or equipment from cold to the required maintain temperature. For example :-

- A pipeline is used infrequently to deliver fuel oil from an off-loading berth into a plant area. In such a case, the pipeline and its contents may be raised from the ambient temperature to the fuel oil pumping temperature over a period of, for example, 24 hours prior to the delivery of the fuel oil.

Heat Tracing - The Need

Whenever the contents of a pipe or equipment are maintained at a process temperature exceeding the ambient temperature, there will be a flow of heat from the product or equipment through the thermal insulation to the external air, and *the rate of heat loss varies directly with changes in ambient temperature.*

In order to prevent the temperature of the product from falling below its required level, this **variable** heat loss must be compensated for by heat tracing the pipeline or equipment.



Heat Tracing – Steam or Electric?

The energy source for heat tracing is most commonly electricity or steam.

When excess steam is available, it may, incorrectly, be perceived to be 'free'. But steam tracing is rarely controlled and may typically deliver six times the quantity of heat required to provide freeze protection to a pipe. Additionally, it has high running and maintenance costs due to leaks from steam traps.

In such circumstances, often the most efficient course of action is to use the excess steam to generate electricity, which is then used as the energy source for a controlled and highly efficient electric heat tracing system.

Heat Tracing - The System

An electric heat tracing system often comprises:-

- heating cable(s) together with termination components
- ancillary items such as junction boxes and fixing materials
- temperature control devices (sometimes / optional)
- monitoring / alarm facilities (sometimes / optional)
- power distribution / circuit protection facilities



INDUSTRIAL HEAT TRACING – An Introduction



INDUSTRIAL HEAT TRACING – An Introduction

Heat Tracing – Safe Practice

A heat tracing installation should provide the highest appropriate levels of Safety. This is mainly provided for by:-

- ensuring temperature safety
- over-current circuit protection
- earth-leakage protection

This is discussed in more detail in SECTION 3 – System Design.

Heat Tracing – Applicable Standards

Electric heat tracing is governed by a number of International and National Standards covering Industrial (Safe) and Industrial (Hazardous) locations. A list of the most important standards, to which many of Heat Trace's products are approved, are shown in the table below

Although Heat Trace can design and supply equipment approved to most national standards, for purposes of clarity, this document focuses on the standards developed especially for Electric heat tracing:-

- IEC62395 Electric Heat Tracing for Safe Industrial locations or commercial applications, and
- IEC60079-30 Electric Heat Tracing for Hazardous locations (formerly IEC62086)



This is because these are the most recent publications, and are truly international. The International Electro-technical Commission comprises most industrialised nations from all continents.

The trace heating industry is co-operating to produce harmonised standards. Currently the hazardous location part of IEEE515 and IEC60079 are being directly aligned into a single dual-logo standard.

Industrial Lo	cations	Hazardous Locations		
IEC 62395-1, (EN Electrical resistance trace heating commercial applications - Part 1: Gen IEC 62395 Electrical resistance trace heating system applications - Part 2: Application installation and ma	systems for industrial and eral and testing requirements -2 ms for industrial and commercial guide for system design,	IEC 60079-30-1 (EN 60079-30-1) Explosive atmospheres - Part 30-1: Electrical resistance trace heating - General and testing requirements IEC 60079-30-2 (EN 60079-30-2)		
IEC 60519-10 Safety in electroheat installations - Part 10: Particular requirements for electrical resistance trace heating systemsfor industrial and commercial applications		Explosive atmospheres - Part 30-2: Electrical resistance trace heating - Application guide for design, installatior and maintenance		
Re	2 No. 130-03 neating cables and heating device sets			
UL 1673 Electric Space Heat UL 1588 Roof and gutter de-icir	eating Cables UL 515 88 Parts 3 - 9:			
UL 515 Part 1: Commercial and industr Part 2: Heat tracing intended for sprinkler or standpi	rial ordinary locations use with fire suppression	Hazardous location requirements		
IEEE Std.515.1 Standard for the Testing, Design, Installation and Maintenance of Electrical Resistance Heat Tracing for Commercial Applications	IEEE Std.515 Standard for the Testing, Design, Installation, and Maintenance of Electrical Resistance Trace Heating for Industrial Applications			





Typical Applications / market sectors

Bakery equipment

- heating fuel oil pipes to the ovens
- bread fat heating
- anti-condensation for flour storage
- heating glucose and sucrose products

Brewing

- heating malt, glucose and water pipes and tanks
- fuel oil systems

Chemicals

- heating numerous viscous liquids and/or gases
- e research projects
- many refinery applications

Ceramic industry

- heating fuel oil
- paint and varnish heating

Chocolate and sweets

- heating chocolate in pipes and vats
- heating chocolate in road tankers
- heating liquid sugars
- heating cocoa butter and fats

Detergent and soaps

- heating various viscous liquids
- e general frost protection

Medicine

 many applications especially in the pharmaceutical industry where waxes, tallows and stearates are used.

Non-ferrous metal industries

- fuel oil heating and frost protection
- Oil industry
- fuel oil heating
- lubrication oil heating
- grease line heating
- oil additives heating
- many refinery processes require tracing

Drying and cleaning

- heating fuel oil
- dyestuffs manufacture

Electric motors

- curing glass-fibre banding tape
- heating commutators during manufacture
- anti-condensation heating

Electric transformers

- curing glass-fibre banding tapes
- drying out oil-filled transformers
- frost protection of water-filled transformers



Tank base heating



Pipe tracing



Internal pipe tracing

INDUSTRIAL HEAT TRACING – An Introduction





Final Settlement Tank de-icing



High Temperature Tank heating



Typical Applications / market sectors

Food processing

- heating many food process materials, eg malt, sugars, molasses, sauces, honeys, jams,
- Chocolates, waxes, fats, cooking oils
- keeping powdered food dry
- heating storage tanks
- tracing refrigeration rooms

Fertiliser industry

• tracing liquids used in manufacturing inorganic fertiliser

Power generation stations

- boron water
- carbon dioxide
- fuel oil
- caustic solutions instrument lines
- frost protection
- pre-heating steam lines to prevent stress
- Precipitator fly ash hoppers and silos
- flue gas desulphurisation processes, i.e. frost protection and liquid sulphur temperature maintenance

Road construction

- heating asphalt (bituminous tar) and pitch in road stone plants
 fuel oil
- frost protection of sand and aggregate in storage hoppers

Iron and steel

- fuel oil systems
- frost protection
- grease pipelines
- hopper heating

Printing

inks and dyes during manufacture and storage

Plastics industry

- curing thermosetting resins
- accelerated curing of glass fibre

Paints

 paints and varnishes during manufacture and in paint spray applications

Refrigeration

- heating drain lines and drip trays
- heating refrigerator doors
- anti-frost heave of concrete floors

Rubber

curing rubber sections and fabrications

Sprinkler & fire system manufacture

frost protection of water-filled lines

Tar distilleries

- heating bituminous materials
- heating road tankers

Buried pipeline tracing

Page 11 IN

INDUSTRIAL HEAT TRACING – An Introduction





Objective - a Safe system that works

A heat tracing installation should provide the highest appropriate levels of Safety. This is mainly provided for by:-

- ensuring temperature safety
- over-current circuit protection
- earth-leakage protection

Temperature safety is ensured by preventing the surface of the heat tracer from exceeding the limiting temperature. This limiting temperature may be the maximum rating of the tracer itself, or, for example, the Temperature Classification where the installation is within a hazardous area.

Ensuring temperature safety

Temperature safety may be provided in a number of ways. The choice open to a specifier, in descending order of preference are:-

- Inherently temperature-safe heat tracers.

Many self-regulating tracers are inherently temperature-safe, their power output reducing with rising temperature such that limiting temperatures e.g. Temperature Classification or temperature withstand of the heater, cannot be exceeded due to the heat produced by the tracer. *Inherently temperature-safe heat tracers therefore provide the highest level of temperature safety.*

Stabilised Design

Here, a calculation is made to ensure that, under the worst case conditions, a tracer always operates at below the limiting temperature, without the need for external temperature control. Where inherently temperature-safe heat tracers are not available, stabilised design provides the favoured form of temperature safety.

Stabilised design calculations are complex and should only be undertaken by persons suitably skilled. Heat Trace's Evolution software is able to automatically confirm whether a design is temperature-safe. When it is not, the designer has the choice of selecting tracers having a lower power output or opting for a less safe temperature controlled system.


Temperature control


Where a stabilised design cannot be assured, it is then necessary to employ temperature control. Here the safety of the system is reliant on the correct functioning of the controller and the correct location and operation of the temperature sensor. *This is therefore the least safe option.*

Specifiers should guard against being offered such designs, which may have capital benefits but with attendant safety risks.

Inherent Temperature Safety - Definition

"The inherent ability to self-regulate at a temperature level below the maximum product rating and withstand temperature of the insulating materials, without the use of temperature control."









Objective - a Safe system that works

Circuit Over-current Protection

Each heating circuit should be provided with over-current protection. Maximum safety is provided by a circuit breaker having a rating close to the operating current of the circuit.

Some self-regulating heat tracers exhibit a high in-rush current on start up from cold and require the use of a highly rated circuit breaker with a delayed breaker action. This reduces the level of safety provided.

Safety is maximised when Heat Trace Limited self-regulating heat tracers are specified and circuits are designed to incorporate the patented SSD SoftStart device. The SSD reduces in-rush currents by up to 50% and allows the use of circuit breakers having lower ratings more closely matched to the operating current.


Circuit Earth Leakage Protection

Each heating circuit should be provided with earth leakage protection.

The residual current device should normally have a sensitivity of 30mA and operate within 30ms. Exceptionally, for example where long heating circuits apply, it may be necessary to decrease the sensitivity level to avoid 'nuisance' tripping.



RCBO Earth leakage circuit breaker



SSD Softstart device can help reduce in-rush current



Design and equipment selection for use in hazardous areas will be influenced by:-

- the area classification
- the gas (or dust) group
- the temperature classification and equipment selected providing an appropriate type of protection

As stated above, this document focuses on the international standards developed especially for electric heat tracing, IEC62395 - for Safe Industrial locations and IEC60079-30 for Hazardous locations.

Area Classification

The probability of explosive conditions being present is defined by zone classification

- Zone 0 may have explosive gas-air mixtures present continuously or for long periods. Heat tracing is rarely, if ever, used in Zone 0 areas.
- Zone 1 may have explosive gas-air mixtures present in normal operation.
- Zone 2 may have explosive gas-air mixtures present only under abnormal conditions.

North American hazardous locations are catagorised in divisions rather than zones. As stated above IEC60079 and IEEE515 are being harmonised as a dual-logo standard. Therefore Heat Trace's product approvals cater for divisions as well as zone locations.

Gas Groups


Gas groups relevant to heat tracing in hazardous locations are:-

- IIA Acetone, benzene, butane, ethane, methane, propane, etc..
- **IIB** Ethylene, town gas etc..
- IIC Acetylene, hydrogen

Flammable Material Present Continuously Present Intermittently				Flammable Material Present Abnormally
IEC/CENELEC		Zone 0	Zone 1	Zone 2
		(Zone 20 Dust)	(Zone 21 Dust)	(Zone 22 Dust)
US	NEC 505	Zone 0	Zone 0 Zone 1	
	NEC 500	Division 1		Division 2

IEC classification per IEC 79-10 CENELEC classification per EN 60 079-10 US classification per ANSI/NFPA 70 National Electric Code (NEC) Article 500 or Article 505

IEC / CENELEC Example of hazardous area zones - Petrol Station Forecourt & Garage



NORTH AMERICAN APPROVAL MARKING

CLASSIFICATION EQUIVALENTS - GAS Flammable Material Present Material Present Material Present Continuously					
IEC / EU	Zone 0	Zone 1	Zone 2		
US NEC 505	Zone 0	Zone 0 Zone 1			
US NEC 500	Divis	Division 2			
CA CEC Section 18	Zone 0 Zone 1 Zone 2				
CEC Annex Division 1 Division 2					
IEC classification per IEC 60079-10 IEC classification per EN 60079-10 US classification per ANSI / NFPA 70 National Electrical Code (NEC) Article 505 CA classification per CSA C22.1 Canadian Electrical Code (CEC) Section 18 or Annex J					

NORTH AMERICAN / EUROPEAN AREA CLASSIFICATION EQUIVALENTS - DUST					
	Combustible Combustible Dust Present Continuously Intermittently Abnormally				
IEC / EU	Zone 20 Zone 21 Zone 22				
US NEC 506	Zone 20 Zone 21 Zone 22				
US NEC 500 Division 1 Division 2					
CA CEC Section 18 Division 1 Division 2					
US area classification per ANSI / NFPA 70 National Electrical Code (NEC) Article 500 or 506 CA area classification per CSA C22.1 Canadian Electrical Code (CEC) Section 18 EU area classification per EN 61241-10					

NORTH AMERICAN / EUROPEAN EQUIPMENT GROUPING EQUIVALENTS - GAS			
	US (NEC 505) CA (CEC Section 18) EU	US (NEC 500)	
Typical Gas	IEC	CA (CEC Annex J)	
Acetylene	Group IIC	Class I / Group A	
Hydrogen	(Group IIB + H ²)	Class I / Group B	
Ethylene	Group IIB	Class I / Group C	
Propane	Group IIA	Class I / Group D	
Methane	Group I*	Mining*	
"Not within scope of NEC. Under jurisdiction of MSHA. Not within scope of CEC.			


NORTH AMERICAN / EUROPEAN EQUIPMENT GROUPING EQUIVALENTS - DUST					
Typical Material	EU (60079-0) IEC (60079-0)			US (NEC 500) CA (CEC Section 18)	
Metal dusts	IIIC	N/A	D	Class II, Group E	
Carbonaceous dusts	IIIB	D	D	Class II, Group F	
Non-conductive dusts	IIIB	D	D	Class II, Group G	
Fibres and flyings	IIIA	D	D	Class III	





Temperature Classification

The maximum surface temperature of the heater must be kept below the auto ignition temperature of the explosive gas or vapour mixtures which could be present. The classifications are:-



In reality, most gases encountered will have an ignition temperature of T1 or T2. However, it will be recognised that the lower the operating temperature of the heater, the safer the system will be.

For this reason, self-regulating heaters which are inherently temperature-safe should be the preferred safety option. When this is not possible, a calculated stabilised design is preferable to a system that relies on temperature controls for the safety of the system.

Types of Protection

As non-sparking devices, most heaters are likely to be approved to the concept 'e' – increased safety (EExe).

Т6

T6

Sparking devices such as thermostats or circuit breakers are most commonly approved to the concept 'd' – flameproof or explosion proof (EExd), although concepts 'i' – intrinsic safety (EExi), and 'p' – pressurised apparatus (EExp) are also sometimes appropriate.

Heat Trace are able to uniquely provide tracers having a continuous metal extruded jacket. Such products can be provided with an EX'd' certificate, in addition to an Ex'e' certificate.

Sometimes, distribution boards and control panels can be located outside the hazardous area to avoid the need for the additional costly protection.

MORE DETAILED INFORMATION ON HAZARDOUS AREA CONSIDERATION IS AVAILABLE FROM THE HEAT TRACE LTD WALL CHART WHICH CAN BE FOUND ON THE WEBSITE www.heat-trace.com

Page 15

SYSTEM DESIGN – GENERAL



European Environmental Protection Classification - IP System

The IP rating system for enclosures containing moving and electrical equipment is recognised in most European countries, meeting a number of British and European standards. It is usually quoted as two digits, in the form IP11.

Relevant standards to which this rating system applies include:

BS EN 60529 and IEC 60529

- FIRST NUMERAL
- Protection against solid objects
- 0 No special protection
- 1 Objects > 50mm diameter (e.g. part of a hand)
- 2 Objects > 12.5 mm diameter
- (e.g. finger)
- 3 Objects > 2.5 mm diameter (e.g. tool)
- 4 Objects > 1.0 mm diameter
- (e.g. wire)
- 5 Dust protected
- 6 Dust tight

- Protection against water 0 - No special protection 1 - Vertically dripping water
- 2 Vertically dripping water

SECOND NUMERAL

- when enclosure tilted by 15°
 - 3 Sprayed water up to 60° from the vertical
 - 4 Sprayed water from all directions
- 5 Water jets
- 6 Powerful water jets
- 7 Temporary submersion to a depth of 1m
- ${\bf 8}$ Extended submersion to a depth > 1m

IEC Enclosure Ingress Classification

NEMA Equivalents of IP Ratings

The NEMA and IP Ratings (IEC) differ due to the parameters measured and, to some extent, the methods used. NEMA 250 tests for external environmental conditions such as corrosion, rust, oil and coolants, which are not specified in the IEC standards IEC 60529.

Note: as many of the NEMA standards meet or exceed the equivalent IP ratings, it is incorrect to use this table to determine IP equivalents of NEMA Ratings.

NEMA ENCLOSURE TYPE No. EQUIVALENT	IEC ENCLOSURE APPROXIMATION
2 - Drip tight indoor use	IP11
3 and 3S - Outdoor weather resistant to rain, sleet, ice and blown dust	IP54
3R - As 3/3S except dust	IP14
4 and 4X - Indoor/outdoor rain, ice, splashing and hosed water, blown dust. 4X - Also corrosion	IP56
5 - Dust tight indoor use	IP52
6 and 6P - Outdoor/indoor, occasional limited immersion, ice	IP67
12 and 12K - Indoor, dust/falling/non-corrosive liquid drips	IP52
13 - Indoor, dust, spraying water, oil and non-corrosive coolant	IP54



Methods of Protection

Protection Method	ID. Letter	IEC	IEC CENELEC CSA (IEC)			NEC 505	NEC 500		AS / NZS
Flameproof	d	IEC 60079-1 EN 60079-1 CSA E60079-1			CSA C22.2 No. 30	ISA 60079-1	FM 3618	AS/N2	S60079-1 / AS2380.2
Intrinsic Safety	ia	IEC 60079-11	EN 60079-11	CSA E60079-11	CSA C22.2 No. 157	ISA 60079-11	FM 3610	AS/NZ	\$60079-11 / A\$2380.7
Intrinsic Safety	ib	IEC 60079-11	EN 60079-11	CSA E60079-11	CSA C22.2 No. 157	ISA 60079-11	FM 3610	AS/NZ	\$60079-11 / A\$2380.7
Pressurisation	р	IEC 60079-2	EN 60079-2	CSA E60079-2	CSA TIL. E13 A	ISA 60079-2	FM 3620	AS/NZ	2560079-2 / AS2380.4
Increased Safety	е	IEC 60079-7	EN 60079-7	CSA E60079-7	-	ISA 60079-7	FM 3619	AS/NZ	S60079-7 / AS2380.6
Oil Immersion	ο	IEC 60079-6	EN 60079-6	CSA E60079-6	-	ISA 60079-6	FM 3621		AS/NZS60079-6
Encapsulation	m	IEC 60079-18	EN 60079-18	CSA E60079-18	-	ISA 60079-18	FM 3614		AS/NZS60079-18
Type 'n' Protection	n	IEC 60079-15	60079-15 EN 60079-15 CSA E60079-		CSA C22.2 No. 213	ISA 60079-15			AS/NZS60079-15
* Ventilation	v				-	-			AS 1482
Protection Method	ID. Letter		Type of Protectic	n	Mode of Fur	nction	NEC 500 / CEC Annex J Permitted Division		IEC / CENELEC Permitted Zone
Flameproof	d	E:	xplosion is Contai	ned	Enclosure contains int	ternal explosion	Division	2	Zone 1 or 2
Intrinsic Safety	ia	Sparks are no	ot ignition capable	e (Safe 2 faults)	I.S. circuits are unable	to cause ignition	Division 1 d	or 2	Zone 0, 1 or 2
Intrinsic Safety	ib	Sparks are no	ot ignition capable	e (Safe 1 faults)	I.S. circuits are unable	to cause ignition	Division	2	Zone 1 or 2
Pressurisation	р	Flammab	le atmosphere is	eliminated	Protection by over pre	ssured enclosure	Division 1 o	or 2	Zone 1 or 2
Increased Safety	е	Sour	ce of ignition elim	ninated	Electric sparks & high t eliminat		Division	2	Zone 1 or 2
Oil Immersion	0	Flammab	le atmosphere is	eliminated	Protection by Ir	nmersion	Division 1 o	or 2	Zone 1 or 2
Encapsulation	m	Flammab	le atmosphere is	eliminated	Encapsulated apparatus Divisio		Division	2	Zone 1 or 2
Type 'n' Protection	n	n Protection in	cludes several me protection	ethods of ignition	Non-Sparking a	pparatus	Division 2		Zone 2
* Ventilation	v	Flammab	le atmosphere is	eliminated	Protection by V	entilation	-		-



Off-Shore Helicopter platform, ice prevention systems



SYSTEM DESIGN – GENERAL



Heating Loads - Pipelines

Heat Trace's Evolution design software is able to automatically calculate the appropriate heating load in order to compensate for heat losses from a pipe, vessel and line equipment, or to heat raise the temperature of the equipment and its contents.

The following is a simplistic method for calculation of heating loads for pipes and vessels.

It should be stressed that the heat losses from pipeline fittings, such as valves, flanges, strainers, filters, pumps, are often significant, accounting for typically an additional 25% of the pipe work heating load requirements. Also, pipe supports, which are rarely detailed on drawings, can also account for significant heat losses unless the supports are thermally insulated.

Heat loss compensation for pipelines

As its name implies, this form of heating is used to balance or compensate for heat losses from a pipeline to the surrounding atmosphere. The following method may be used to calculate the amount of heat required:

- 1 Table 1a select loss factor for pipe size and insulation thickness.
- 2 Table 1b multiply the selected loss factor by the 'K' value of insulation used.
- 3 Multiply the resultant from Tables 1a and 1b by the temperature difference between lowest ambient and required temp ($\Delta t^{\circ}C$).
- 4 Multiply by an appropriate safety factor typically 1.2
- 5 The resultant number x is the heating load in watts/ metre of pipe

It should be noted that this heating load is only needed when the ambient temperature is at it's minimum design level. At all other times the heating load will be greater than necessary. <u>The excess heating load is normally accommodated by the</u> <u>temperature control system</u>.



Raising temperature of pipelines

In many cases, it is more economic to maintain the heating over short shutdown periods, eg. weekends, than to make provision for heating up from cold. Where it is essential to provide sufficient heat for warming up in addition to heat loss compensation, the time allowed for warming up should be at least 12-24 hours, as shorter periods normally involve inconveniently high loadings.

Heat required for warming up can be calculated as follows:

Formula 1

 $W= \frac{(P \times S) + (C \times Q) \times \Delta T}{E \times H \times 3600}$ W/m

where W = heating required in watts/metre

- P = weight of pipe work in kg/m
 - S = specific heat of pipe work in J/kg°C
 - C = weight of contents in kg/m
 - Q = specific heat of contents in J/kg°C
- ΔT = temperature rise °C
- H = time allowed in hours
- E = efficiency factor, use 0.73 but may vary

This figure must be added to the heat loss compensation calculated previously. It is not necessary to work on the full temperature because, during the heating-up period, the pipe temperature will be below the final temperature, therefore the following equation should be applied:

Total Load = heating up load + 2/3 steady loss at final temperature

Table 1a

Pipe	Pipe			In	sulation	thickne	SS		
nominal	O.D	12	25	37	50	75	100	125	150mm
bore		¹ /2	1	1 ¹ /2	2	3	4	5	6 in
in	mm			No	rmalise	d loss fa	ictor		
$\begin{array}{c} 1/2 \\ 3/4 \\ 1 \\ 1^{1}/2 \\ 2 \\ 2^{1}/2 \\ 3 \\ 4 \\ 6 \\ 8 \\ 10 \\ 12 \\ 14 \\ 16 \\ 18 \\ 20 \\ 24 \end{array}$	21.35 26.7 33.4 48.3 60.3 73.05 88.9 114.3 169.3 219.1 273 324 355 406 457 508 609	8.01 9.39 11.34 14.86 17.88 21.05 25.00	5.16 5.89 6.91 8.74 10.28 11.89 13.90 17.08 23.82 30.13 36.82 43.12 47.05 53.35 59.64 65.92 78.50	4.13 4.65 5.36 6.63 7.69 8.79 10.15 12.30 16.82 21.04 25.53 29.73 32.36 36.56 40.76 44.96 53.35	3.58 4.00 4.56 5.54 6.36 7.21 8.24 9.88 13.30 16.50 19.86 23.03 25.00 28.16 31.31 34.46 40.76	3.30 3.71 4.41 4.98 5.57 6.29 7.42 9.74 11.89 14.17 16.29 17.60 19.73 21.84 23.95 28.16	4.26 4.72 5.28 6.15 7.93 9.57 11.29 12.90 13.90 15.50 17.08 18.67 21.84	6.83 8.16 9.55 10.85 11.66 12.90 14.22 15.49 18.04	7.20 8.38 9.47 10.15 11.20 12.30 13.37 15.50
30	762		97.36	65.92	50.20	34.60	26.58	21.84	18.60



Heating Loads - Tanks & Vessels

Heat loss compensation for tanks, vessels & hoppers

Similarly the design criteria for calculating heat loss compensating and/or raising and maintaining temperature associated with tanks, vessels, or hoppers are as follows:

Formula 2a (for flat surfaces)

Loading required = $A \times K \times (T_1 - T_2)$ watts E x t

2b (for cylindrical surfaces)

Loading required = $2.72 \times K \times L \times (T_1 - T_2)$ watts

 $E \times log_{10}$ (D/d)

where A = total surface area of tank, vessel, etc. to be heated in square metres (m²)

- K = thermal conductivity of the insulation in W/m°C
- T_1 = temperature to be maintained °C
- T₂ = min. ambient temperature °C
- \overline{t} = thermal insulation thickness in mm
- L = length of surface
- D = diameter across insulation
- d = outside diameter of pipe
- E = efficiency factor, use 0.73 but may vary

Raising temperature of tanks, vessels and hoppers

Formula 3

Kilowatt loading required =

mass(kg) x sp heat (J/kg°C) x temp rise °CkWE(0.73) x 1000 x hours x 3600


As for pipe work, it is necessary to consider both the vessel and its contents. Therefore apply the above formula to both vessel and contents and add the respective loads together to arrive at the total kilowatt loading.

After raising the tank and contents to the required level, it will be necessary to allow for heat losses as in FORMULAE 2a or 2b.

Therefore the total heat required = Amount of heat to raise temperature of contents + 2/3 of amount of heat to maintain temperature.

Types of thermal insulation used for pipelines and vessels together with thermal conductivity, i.e. 'K' factor, are shown in Table 1b.

Table 1b





Page 19

SYSTEM DESIGN – GENERAL



Temperature Control

Temperature control may be provided to a system in order to:-

- Ensure temperature safety or
- Provide process temperature accuracy

Ensuring temperature safety

As previously stated, it is recommended that the provision of temperature controls to ensure that limiting temperatures are not exceeded should only be considered when the use of inherently temperature-safe heaters or a stabilised design is not possible.

Where this form of temperature safety cannot be avoided, it is necessary that:-

- In safe areas, a controller provided for process control may also act as over temperature controller
- In Zone 2 areas, two controllers, process temperature plus over-temperature are required, and
- In Zone 1 areas, two controllers, process temperature plus over-temperature are required, where the over-temperature device is a manually re-settable lock-out type, unless a monitored alarm is provided.

It is important that the sensor of the over-temperature controller is fitted to the pipe or work piece to limit the pipe to a temperature level at which the heater will not exceed the maximum limiting temperature.

Warning:

It is legal to fit the sensor of the over-temperature controller to the surface of the heater itself. However, this is a practice that Heat Trace Ltd. does not recommend because:-

- It will rarely be known to be sensing the hottest point of the heater (which is likely to be where the heater is out of contact with the equipment) and
- When the sensor is removed, for example during maintenance work, it cannot be guaranteed to be returned to the hottest part of the heater

THE PRACTICE OF FITTING A TEMPERATURE SENSOR TO THE HEATER TO ENSURE TEMPERATURE SAFETY IS DANGEROUS!



Temperature Controller

Process temperature accuracy

The IEC electric heat tracing standards define 3 levels of process temperature accuracy

Type I

A Type I process is one in which the temperature should be maintained **above a minimum point**. No temperature control or simple ambient sensing control may be acceptable. Large blocks of power may be controlled by means of a single device.

Type II

A Type II process is one in which the temperature should be maintained *within a moderate band*.

Type III

A Type III process is one in which the temperature should be controlled **within a narrow band**. Type III systems require strict adherence to flow patterns if surface sensing controls are utilised.



Circuit Monitoring

Circuit Monitoring

If failure of a heater can result in a safety or process problem, then the heat tracing system may be considered to be critical to the total process. The temperature control and circuit monitoring requirements of an application are defined by the IEC Electric Heat Tracing standards according to the temperature control types as previously described, together with the circuit monitoring criticality as described in the table below.

	Desired accuracy of process temperature control					
Is heat tracing a	Maintain	Maintain	Maintain			
critical component	above a	within a	within a narrow			
of the process?	minimum	moderate				
	point Type I	band Type II	band Type III			
Yes = Critical (C)	C – I	C – II	C – III			
No = Non-critical (NC)	NC – I	NC – II	NC – III			



Process types

When heat tracing is critical to the process, circuit monitoring for correct operation is recommended. Malfunction alarms, and back-up (redundant) heat tracers may also be considered. Spare or back-up controllers can be specified to be automatically activated in the event of a fault being indicated by the monitoring / alarm system. This is sometimes known as "redundancy". Back-up heat tracers will maintain availability and may allow maintenance or repairs to be performed without a process shutdown.

Temperature Controller with Monitoring



Page 21

SYSTEM DESIGN – GENERAL



There are four generic types of heat tracer

- Parallel Self-Regulating
- Parallel Constant Power

Parallel Self-Regulating


Self-Regulating (or self-limiting) tracers are most popular, as they can conveniently be cut-to-length and are often inherently temperature-safe, due to the positive temperature coefficient heating matrix. Thus temperature control is not usually needed to provide temperature safety.

Until recently, their availability for only low or moderate temperatures limited their use. Now though, Heat Trace Ltd. have pioneered new 3rd generation semi-conductive tracers able to withstand up to 300°C energised or power off. So now, Self-Regulating tracers can fulfil 90% of all applications within industrial heat tracing - but currently only from Heat Trace!


Ever since the introduction of self-regulating tracers, the high currents on start up from cold have created a problem requiring the need for larger than necessary feed cables and switchgear. Additionally, safety was compromised, as circuit protection had to be sized in excess of operating currents. Now however, Heat Trace has made significant reductions in start currents, thereby improving safety, and reducing distribution costs.

A patented SoftStart device (see illustrations below) having NTC (negative temperature coefficient) characteristics negates the PTC (positive temperature coefficient) of the heating matrix. Start currents are reduced by about 50% (see Figure below). This is further aided by a patented processing method known as Directional Conductivity. Here the conductive particles within the heating matrix are dispersed and distributed in such a way as to control the direction of current flow.

Single phase Self-Regulating tracers are typically limited in circuit length to 100 or 200 metres, and so are used mainly for in-plant applications. However Heat-Trace can now provide the world's first 3 phase self-regulating tracer capable of circuit lengths upto 600m.



Series Resistance Skin-Trace



Heat Trace's range of self regulating heat tracers

Heat Trace Limited is able to produce self-regulating tracers within the following range:

12 - 1000 Volts Up to 300°C withstand temperature Up to 150 W/m

Datasheets for some of the standard Heat Trace range are provided, pages 30 - 35 inclusive

Temperature ranges:

Low

F

FSLe	85°C On or Off - up to 31W/m
FSR	85°C On or Off - up to 40W/m
FSE	100°C On or Off - up to 60W/m

Hlgh

FS+	225°C On or Off - up to 60W/m
FSS	225°C On or Off - up to 75W/m
FSU	250°C On or Off - up to 100W/m
FSU+	275°C On or Off - up to 125W/m
AFS	300°C On or Off - up to 150W/m

PRODUCTS AND PRODUCT SELECTION




Parallel Constant Power

Parallel Constant Power (zonal) tracers can be conveniently cut-to-length, but are less popular than Self-Regulating heaters, because they often require thermostatic control to ensure temperature safety, (although sometimes a calculated temperature-safe stabilised design is possible).

Until recently, all constant power tracers were polymeric, and so were limited in temperature capability. However, Heat Trace has patented a parallel resistance, convenient cut-tolength metal sheathed, mineral insulated (MI) heater having a withstand temperature of 425 deg. C. This type **AHT** product caters for most applications that the new high temperature Self-Regulating heaters are unable to handle. Thus cut-tolength parallel tracers are now available for virtually all heat tracing applications.

This is particularly beneficial in the case of instrument lines, the lengths of which are usually unknown at the design stage of a project, and which are site run according to convenience.

Parallel Constant Power tracers are typically limited in circuit length to 100 or 200 metres, and so are used mainly for inplant applications



Parallel heating zones

Heat Trace's range of Parallel Constant Power heat tracers

Heat Trace Limited is able to produce tracers within the following limitations

Up to 425°C withstand temperature Up to 200 W/m

Datasheets of some of the standard Heat Trace range are provided, pages 36 - 39 inclusive

Temperature ranges:

weulum	Μ	edi	um
--------	---	-----	----

MTF	200°C On or Off - up to 50W/m	
EMTF	200°C On or Off - up to 50W/m	

High

PHT	425°C On or Off - up to 70W/m
AHT	425°C On or Off - up to 150W/m)





Series Resistance Tracers

Series Resistance Tracers have to be individually designed into particular length/load configurations and so are not so versatile as parallel types.

However, an advantage is that very long circuit lengths are possible – typically 3 phase 'Longline' tracers require electric supply points only at multi-kilometre intervals. So the major outlet for series heaters is long pipelines.

Traditionally, metal sheathed, mineral insulated (MI) series cables were used when process temperatures exceeded the capability of the more convenient polymeric parallel tracers. However, the introduction of Heat Trace's cut-to-length parallel type AHT MI tracer virtually eliminates the need for series MI tracers which require skill to terminate and are costly.

Series Resistance Tracers often require temperature controls to ensure temperature safety.

Heat Trace's range of series 'Longline' heat tracers

Heat Trace Limited is able to produce tracers within the following limitations


Up to 6.6kV Volts 3 phase Up to 300°C withstand temperature Up to 200 W/m of pipe

Datasheets of some of the standard Heat Trace range are provided, pages 40 - 43 inclusive

Temperature ranges

Low	Medium	High
HTP3	HTS3F	HT/A3F
HTP1	HTS1F	HT/A1F

Longline series resistance tracers are for the heating of very long pipelines, a very competitive option to Skin Trace.



Heating Circuit Configuration

A 3 phase circuit configuration comprises either 1 x three foil Longline heater or 3 x single foil Longline heaters.






Skin-Trace

Skin-Trace is induction-resistive heat tracing based on skin and proximity effects of an AC current within a ferromagnetic tube.


The heating element comprises a carbon steel tube into which is inserted an insulated non-magnetic conductor. The conductor and the steel tube are connected together at one end. At the other end an AC voltage is applied between the conductor and the tube. The relationship of conductor/tube sizes and voltage determines the output power developed.

The skin effect of the magnetic tube results in the current being concentrated towards the tube's inner surface, the potential to the outside being zero.

Skin-Trace's advantage is that long circuit lengths are possible – typically a pipeline of up to 20km may be heated from a single electric supply point. So Skin-Trace is most appropriate for the heating of cross-country pipelines.



- Typically up to 20 km lines heated from one supply point
- Robust and reliable system with outputs up to 120W/m
- Suitable for up to 200°C operating temperature
- Suitable for use in hazardous areas



Depending on the heating power required and the pipeline length, SKIN-TRACE may consist of either one, two, or three, heater tubes (see image above).


OPERATING TEMPERATURE -40°C to +200°C

POWER SUPPLY

up to 3kV AC 50 or 60 Hz

POWER OUTPUT

Rated power output of one heating element



Rated Power output of one heater tube, W/m

Heater Tube Dimension



Page 25

PRODUCTS AND PRODUCT SELECTION



Heating Cables – Selection Guide

🛑 In-plant areas


Heat tracers for in-plant areas are usually selected according to the maximum temperature to which the tracer will be subjected, and the power output required from the tracer.

The following table shows the relationship between temperature withstand and power output for various self-regulating, constant power, and series MI tracers. It may be seen that self-regulating tracers, which can be conveniently cut-to-length and which are usually temperature-safe, are available for exposure temperatures up to 300°C.

AHT constant power tracers can cater for higher exposure temperatures up to 425°C and high power outputs up to 150W/m.

Only exceptionally is it necessary to employ series MI cables, which must be specifically designed for a particular length and output.





PRODUCTS AND PRODUCT SELECTION



Heating Cables – Selection Guide

Transfer and long pipe runs

Until recently, parallel resistance heaters - selfregulating or constant power - were limited by volt drop to around 150 metres circuit length.

Now, Heat Trace's patented 3 phase self-regulating tracer, particularly when connected to an elevated voltage e.g. 600 volts, is capable of circuit lengths of up to 700 metres. Consequently, inherently temperature-safe heating systems are now available for applications previously not possible.


Beyond 700 metres, it is necessary to select series resistance 3 phase Longline heating cables, which have a capability to, for example 5km.

For very long pipe runs, e.g. >10km from a single electrical supply point, there was, until recently, no alternative to the Skin-Trace, skin-effect heating system. However, Heat Trace's new continuous metal extrusion facility has enabled Longline systems to heat up to 50km of pipe from a single electrical feed point.

The advantages of the Longline system over Skin-Trace are:-

- Lower capital cost
- Cheaper/ simpler installation
- Lower operating costs (Skin-Trace power factor is 0.85 against the unity factor of Longline)





Circuit Length (typical) - Metres

PRODUCTS AND PRODUCT SELECTION




Typical Long Pipeline Applications

Heater selection is usually governed by the pipe length. Some interesting selections and applications are:-

'Downhole' oilwells

In these, oil exits the reservoir into the production tube at high temperature, cooling as it rises to the surface. To prevent the oil temperature falling below its pour point where waxing can occur on the walls of the production tube, the upper sections of the tube may be heated.

In 'Downhole' applications of heated depths to 700 metres, the benefits of inherently temperature-safe self-regulating heaters are preferred. The principle of self-regulating is attractive, because progressively more heat is produced as the oil rises towards the surface, cools, and the temperature falls. In the past this has not been feasible, but Heat Trace have developed the world's first self-regulating 3 phase heater, a patented product based on it's unique phase-balanced load design.



In another well, requiring heating down to 2km, a unique Heat Trace Longline product can be provided with heating conductors whose power output varies from point to point along the pipe route within a single heating cable. Heat Trace's conductor extrusion facility is able to vary it's cross-section, and hence the power output, at will in a continuous extruded length.

Long Pre-insulated Pipelines

The picture below shows a typical long pipeline application where a pre-insulated pipeline is fitted with an HTS3F-CS LONGLINE series resistance heating cable. The preinsulated pipe is constructed with a metal "raceway" during construction. The heating cable is pulled through the raceway on site as the pre-fabricated pipe lengths are joined together at site, prior to being buried. The pipeline was carrying crude oil from the on-land oil well to a central gathering station.



Buried, Pre-insulated Pipe with Longline HTS3F

Skin Effect Heat Tracing

The picture below shows a completed skin effect tracing system prior to being buried. Skin effect tracing systems may be employed for very long cross-country pipelines. Skin trace is an inductive heating system and may be used for pipelines of up to 30km circuit lengths from a single power supply.



Completed Skin Trace system prior to burying

PRODUCTS AND PRODUCT SELECTION




Off-shore Applications

Off-shore Applications

As one of the world's leading suppliers of electric heat tracing products, Heat Trace Limited (HTL) can provide a wide range of heaters and ancillary products that are particularly suited to offshore applications.

In the harsh off-shore environment, safety and reliability are high priorities and HTL is able to supply high quality products and services to meet the demands of the industry. Heaters for subsea pipelines and risers, topside pipeline heating for both freeze protection and temperature maintenance, helicopter platform snow and ice prevention systems, under-floor heating for accommodation - these are just some of the application solutions available from Heat Trace Limited.



Typical subsea tie back from well head to production platform

Subsea Pipeline Heating

Heat Trace's 'Longline' heating system has recently been installed on the world's first reelable heat traced, subsea pipein-pipe for a 6.5km gas condensate pipeline, using 75km of heating conductors produced by our new continuous metal extrusion facility. The 2kV system is capable of maintaining the required pipeline temperatures from a single electrical supply point in a 3 phase balanced load configuration by a single heating cable. Temperature control and system monitoring is achieved through the use of fibre optic cables installed with the heaters on the inner production flowline. At the time of writing, several other larger subsea installations, for pipelines up to 50km in length, are in the process of being designed. Heat Trace's heat tracing system for pipe-in-pipe systems are suitable for relatively shallow water applications of around 80-100m depth or for deep sea applications down to 2500 -3000 metres.



Completed electrically heat-traced pipe-in-pipe being reeled onto the pipelay vessel.

In-shore Applications

Subsea pipelines for in-shore applications are also used extensively around the world. A typical application might be a fuel tanker off-loading facility for an on-shore plant or power station. These systems are generally run from the on-shore plant storage tank, across the shore line and out to a PLEM located on the seabed and attached to a CALM buoy. The subsea section of the pipe can vary, usually between 1 - 3km from the shore, depending on the depth of water. The pipelines for these applications generally use preinsulated pipe sections fitted with raceways for the heating cables. These sections are joined together on-shore and the completed pipeline floated/towed into position prior to sinking to the seabed. Alternatively, the pipe sections can be assembled and laid from a barge. Due to the shallow water, these pipelines are usually laid in a trench, or protected in some way, such as a "rock dump".



Helicopter platform, ice prevention systems

FOR FURTHER INFORMATION ON LONG PIPELINE HEATING SYSTEMS PLEASE VISIT OUR VEBSITE AND READ THE ARTICLE ABOUT " ELECTRIC HEAT TRACING OF LONG PIPELINES " www.heat-trace.com

Page 29

PRODUCTS AND PRODUCT SELECTION




FREEZSTOP MICRO

FSM withstand temperatures - 65°C

Product Data - Parallel Self-Regulating Heaters to 100°C


FREEZSTOP - Low Temperature Range Self-Regulating Heating Cables for exposure temperatures up to 100°C

A versatile range of industrial grade self-regulating heating cables for freeze protection and **low** process temperature maintenance duties. All cables are available with a choice of flexible metallic braid or continuous metallic extruded jacket. Further corrosion resisting overjacket in thermoplastic or fluoropolymer is optional. Approved for use in both safe and hazardous areas. Available for voltages 100 – 120VAC and 208 – 277VAC.



energised / 85°C un-energised.

FREEZSTOP REGULAR FSR withstand temperatures - 85°C energised / 85°C un-energised.



PRODUCTS AND PRODUCT SELECTION



35

30

25

15

10 5

> 0 5

31


23

17

12

Product Data - Parallel Self-regulating Heaters to 100°C

MICRO - FSMSpecification DataMAXIMUM LENGTH (m) vs. CIRCUIT BREAKER SIZECat115V230Vw/							
Ref	6A	16A	6A	16A			
11FSM	38	64	76	128			
17FSM	27	51	54	102			



10 15 20 25 30 35 40 45 50 55 60 65 70 75 80 85

Pipe Temperature (°C)

LITE - FSLe Specification Data MAXIMUM LENGTH (m) vs. CIRCUIT BREAKER SIZE Cat 115V 230V Ref 10A 16A 10A 16A 20A 20A W/m 20 12FSLe 38 90 180 132 17FSLe 31 73 104 146 23FSLe 23 62 76 124 _

REGULAR - FSR Specification Data

51

58

92

102

31FSLe


17

46

MAXIMUI Cat					KER S 230V	IZE	45 40 40 40 40 40 40 40 40 40 40 40 40 40
Ref	16A	20A	25A	16A	20A	25A	
10FSR	99	-	-	198	-	-	30 W/m 25
17FSR	77	-	-	154	-		20 17
25FSR	62	-	-	124	-		15 10 10
31FSR	37	46	55	74	92	110	5
40FSR	28	35	44	56	70	88	0 5 10 15 20 25 30 35 40 45 50 55 60 65 70 75 80 85 Pipe Temperature (°C)

Extra - FSE Specification Data MAXIMUM LENGTH (m) vs. CIRCUIT BREAKER SIZE

Cat Ref 25A	16A	115V 20A	25A	230V 16A 20A	
17FSE	60	74	-	120 148	w/
31FSE	41	55	-	82 104 110	
45FSEw	31	38	48	62 76 96	
60FSEw 82	26	33	41	52 66	



FULL TECHNICAL DATA SHEETS ARE AVAILABLE ON OUR WEBSITE FOR ALL PRODUCTS www.heat-trace.com

Low Temperature

Page 31

PRODUCTS AND PRODUCT SELECTION




Product Data - Parallel Self-Regulating Heaters to 250°C

FAILSAFE - High Temperature Range Self-Regulating Heating Cables for exposure temperatures up to 250°C

A versatile range of industrial grade self-regulating heating cables for freeze protection and **high** process temperature maintenance duties. All cables are available with a choice of flexible metallic braid or continuous metallic extruded jacket. Further corrosion resisting overjacket in silicone rubber or fluoropolymer is optional. Approved for use in both safe and hazardous areas. Available for voltages 100 – 120VAC and 208 – 277VAC.

FAILSAFE +

FS+ withstand temperatures - 225°C energised / 225°C un-energised.




PRODUCTS AND PRODUCT SELECTION





Product Data - Parallel Self-regulating Heaters to 250°C

Cat		115V			230V										
Ref 32A	20A	25A	32A	20A	25A		60		60						
15FS+	77	-	-	154	-	_ \	50 N/m 40	~	45						
30FS+	51	-	-	102	-	108	30	_	30		\geq				
45FS+	38	-	44	76	-	88	20		15			\sim	\mathbf{X}		
60FS+	31	-	38	62	-	76	10			 			\sim	\searrow	

Pipe Temperature (°C)







FULL TECHNICAL DATA SHEETS ARE AVAILABLE ON OUR WEBSITE FOR ALL PRODUCTS www.heat-trace.com

Page 33

PRODUCTS AND PRODUCT SELECTION



Product Data - Parallel Self-Regulating Heaters to 300°C


FAILSAFE - Ultra High Temperature Range Self-Regulating Heating Cables for exposure temperatures up to 300°C

A versatile range of industrial grade self-regulating heating cables for freeze protection and **ultra high** process temperature maintenance duties.

All cables are available with a continuous extruded patented metal coating for earth protection and mechanical strength and optionally with a fluoropolymer outer jacket. Approved for use in both safe and hazardous areas. Available for voltages from 12 - 1000V (AC or DC).

FAILSAFE ULTIMO+

FSU+ withstand temperatures - 275°C energised / 275°C un-energised.




<mark>ery High Temperature</mark>

PRODUCTS AND PRODUCT SELECTION




Product Data - Parallel Self-regulating Heaters to 300°C

ULTIMO - FSU+ Specification Data MAXIMUM LENGTH (m) vs. CIRCUIT BREAKER SIZE Cat 115V 230V								
Ref	20A	32A	20A	32A				
15FSU+	77	-	154	-				
30FSU+	51	54	102	108				
45FSU+	38	44	76	88				
60FSU+	31	38	62	76				
75FSU+	23	34	46	68				
100FSU+w	15	25	30	50				
125FSU+w	10	10	20	20				



AUTO - AFS	Specification	Data	
MAXIMUM LI	ENGTH (m) vs.	CIRCUIT	BREAKER SIZE
•	4451	100 C	0001/

Cat Ref	20A	115V 40A	63A		20A	230V 40A	63A	
15AFS	77	98	-		154	196	-	
30AFS	46	69	-		92	138	-	
50AFS	31	49	54		62	98	108	
75AFS	23	37	44		46	74	88	
100AFS	15	25	38		30	50	76	
125AFS	10	15	30		20	30	60	
150AFS	7	11	21		14	22	42	



Very High Temperature

FULL TECHNICAL DATA SHEETS ARE AVAILABLE ON OUR WEBSITE FOR ALL PRODUCTS www.heat-trace.com

Page 35

PRODUCTS AND PRODUCT SELECTION




Product Data - Parallel Constant Power Heaters to 200°C


MINITRACER - Low to Medium Temperature Range Parallel Constant Power Heating Cables for exposure temperatures up to 200°C

Types MTF and EMTF are parallel resistance, constant wattage, cut-to-length heating cables that can be used for freeze protection or low to medium process heating of pipe work and vessels. They can be cut to length at site and easily terminated. Suitable for use in both safe and hazardous areas. MTF and EMTF heaters are available with metallic braid, or braid and fluoropolymer outer jacket. As an alternative to the braid, a continuous metal jacket can be provided for additional mechanical protection.

Available for 100/120 and 208/240VAC. Installation of the heating cables is quick and simple and requires no special skills or tools. Termination and power connection components are all provided in convenient kits.



Low - Medium Temperature





PRODUCTS AND PRODUCT SELECTION



Product Data - Parallel Constant Power Heaters to 200°C

EMTF Specification Data MAXIMUM LENGTH (m) vs. CIRCUIT BREAKER SIZE			MAXIMUM PIPE / W NOM.	ORKPIECE TEMPE	ERATURES (°C)
OUTPUT	MAX. CIRCU	JIT LENGTH*	OUTPUT	EMTF-C	EMTF-CF
(W/m)	115V	230V	(W/m)	EMTF-A	EMTF-AF
6.5	82	164	6.5	190	190
13	58	116	13	175	185
23	44	87	23	145	155
33	36	73	33	100	100
50	30	59	50	60	70
			50	00	10

* For ±10% end to end power output variation

MTF Specification Data MAXIMUM LENGTH (m) vs. CIRCUIT BREAKER SIZE OUTPUT MAX. CIRCUIT LENGTH*		MAXIMUM PIPE / WORKPIECE TEMPERATURES (° CAT NOM. AREA CLASSIFICATION REF OUTPUT HAZARDOUS							RES (°C)		
(W/m)	115V	230V		(W/m)	Т6	T5	T 4	Т3	T2	T1	SAFE
6.5	106	212	MTFC	6.5	60	75	120	190	190	190	190
13	75	150	MTFA	13	40	55	95	175	180	180	180
23	56	113		23	-	30	65	155	155	155	155
33	47	94		33	-	-	40	115	120	120	120
50	38	76		50	-	-	-	70	80	80	80
* For ±10% end to	o end power outp	out variation	MTFCF	6.5	60	80	125	190	190	190	190
			MTFAF	13	35	50	100	185	185	185	185
				23	-	25	55	160	165	165	165
				33	-	-	35	115	120	120	120

POWER CONVERSION FACTORS

115V HEATING CABLE

50

125V	Multiply output by 1.18
120V	Multiply output by 1.09
110V	Multiply output by 0.91
100V	Multiply output by 0.76

230V HEATING CABLE

80 85 85

85

277V Multiply output by 1.45240V Multiply output by 1.09220V Multiply output by 0.91208V Multiply output by 0.82

For conditions other than worst case, or pipes of other materials (eg. plastic, stainless steel, etc..), consult Heat Trace Ltd. Tolerances: Voltage +10%; Resistance +10%; -0%

FULL TECHNICAL DATA SHEETS ARE AVAILABLE ON OUR WEBSITE FOR ALL PRODUCTS www.heat-trace.com

Page 37




Product Data - Parallel Constant Power Heaters to 425°C


POWERHEAT - High Temperature Range Parallel Constant Power Heating Cables for exposure temperatures up to 425°C

Powerheat range PHT and AHT are parallel circuit, mineral insulated, cut-to-length, constant power heating cables. They are used for freeze protection and process heating of pipe work and vessels, where very high withstand temperatures, or where high power outputs are required. Their cut-tolength capability means they can be easily terminated at site. They are suitable for use in both safe and hazardous areas.

Powerheat cables are insulated with multiple layers of non-hygroscopic mineral materials to withstand high temperatures. PHT is available with a metallic braid, or braid and fluoropolymer outer jacket. AHT cables have an aluminium outer jacket, giving a high mechanical strength, yet still retaining flexibility. Available for 100/120 and 208/277VAC.



POWERHEAT - PHT Withstand Temperature up to 285°C



PRODUCTS AND PRODUCT SELECTION



Product Data - Parallel Constant Power Heaters to 425°C

70

30

50 100

150

PHT Specification Data MAXIMUM LENGTH (m) vs. CIRCUIT BREAKER SIZE OUTPUT MAX. CIRCUIT LENGTH*				<mark>m Pip</mark> Iom. Itpu1	AF	REA (KPIE(CLAS: AZAR	SIFIC	ΑΤΙΟ		RES (°C)
(W/m)	115V	230V	(V	N/m)	Т6	Т5	T 4	тз	T2	T1	SAFE
10	79	152	PHTN	10	44	61	102	180	275	275	275
30	46	88		30	-	-	24	116	246	246	246
50	35	68		50	-	-	-	48	200	200	200
70	30	56		70	-	-	-	-	144	144	144
			PHTNF	10	40	60	105	186	275	275	275
* For ±10% end to end power output variation			30	-	-	22	132	255	255	255	
				50	-	-	-	63	215	215	215

AHT Specification Data									
MAXIMUM LENGTH (m) vs. CIRCUIT BREAKER SIZE									
OUTPUT	MAX. CIRCU	JIT LENGTH*							
(W/m)	115V	230V							
15	59	118							
30	42	83							
50	32	64							
100	23	46							
150	19	37							

MAXIMUM PIPE / WORKPIECE TEMPERATURES (°C)									
CAT	NOM.	AF	REA C	LAS	SIFIC	ATIO	N		
REF OUTPUT HAZARDOUS									
	(W/m)	T 6	T5	T 4	Т3	T2	T1	SAFE	
AHT	15	-	36	71	160	289	350	350	

28 100 246 323 39 178 276

48 140

36

168 168

168

323

276

140

36

* For ±10%	end to	end	power	output	variation
------------	--------	-----	-------	--------	-----------

POWER CONVERSION FACTORS

115V HEATING CABLE 230V HEATING CABLE

11

125V	Multiply output by 1.18	277V	Multiply output by 1.45
120V	Multiply output by 1.09	240V	Multiply output by 1.09
110V	Multiply output by 0.91	220V	Multiply output by 0.91
100V	Multiply output by 0.76	208V	Multiply output by 0.82

For conditions other than worst case, or pipes of other materials (eg. plastic, stainless steel, etc..), consult Heat Trace Ltd. Tolerances: Voltage +10%; Resistance +10%; -0%

FULL TECHNICAL DATA SHEETS ARE AVAILABLE ON OUR WEBSITE FOR ALL PRODUCTS www.heat-trace.com

Page 39



Product Data - Series Resistance Heaters to 125°C


LONGLINE - Low Temperature Range Series constant power heating cables for long pipelines. Exposure temperatures up to 125°C


Longline HTP3F and HTP1F are series resistance, constant power heating cables used for freeze protection, or, process temperature maintenance of long pipelines where low temperatures are encountered.

HTP3F cables are used typically for pipelines up to 2km between supply points. HTP1F cables are used where there is approx 10km between supply points.

Longline series heating cables minimise the number of electrical supplies needed and so minimise supply cabling / distribution equipment costs. Circuits are often fed at the pipe ends only. All cables are available with a choice of flexible metallic braid or continuous metallic extended jacket. A further corrosion resisting overjacket in thermoplastic or fluoropolymer is optional. This style of cable is specifically designed to suit each application. The output of the heater is a function of the circuit length, the size of the conductor foils and the supply voltage.

Longline is an extremely viable option to skin effect heating for very long pipelines.







PRODUCTS AND PRODUCT SELECTION



Product Data - Series Resistance Heaters to 125°C

HTP3F Specification Data MAXIMUM PIPE / WORKPIECE TEMPERATURES (°C) NOM. OUTPUT								
(W/m)	HTP3F-C HTP3F-A	HTP3F-CT/CF HTP3F-AT/AF						
10	109	100						
15	95	85						
23	80	70						

For conditions other than worst case, or pipes of other materials (eg. plastic, stainless steel, etc..), consult Heat Trace Ltd.

Tolerances: Voltage +10%; Resistance +10%; -0%


HTP1F Specification Data MAXIMUM PIPE / WORKPIECE TEMPERATURES (°C) NOM. OUTPUT

HTP1F-C HTP1F-A	HTP1F-CT/CF HTP1F-AT/AF
109	100
95	85
80	70
	HTP1F-A 109 95

For conditions other than worst case, or pipes of other materials (eg. plastic, stainless steel, etc..), consult Heat Trace Ltd.

Tolerances: Voltage +10%; Resistance +10%; -0%

Typical Longline applications for heating of pre-insulated pipe work with heaters in raceways.





Product Data - Series Resistance Heaters - 230°C


LONGLINE - Medium Temperature Range Series constant power heating cables for long pipelines. Exposure temperatures up to 230°C


Longline HTS3F and HTS1F are series resistance, constant power heating cables with silicone insulation, used for freeze protection, or process temperature maintenance of long pipelines where medium temperatures are encountered.


HTS3F cables are used generally for long pipelines up to 2km between supply points.

HTS1F cables are typically used where there is approx up to 10km between supply points. Longline series heating cables minimise the number of electrical supplies needed and so minimises supply cabling / distribution equipment costs. Circuits are often fed at the pipe ends only. All cables are available with metallic braid, braid and silicone rubber jacket, or braid and fluoropolymer jacket.

This style of cable is specifically designed to suit each application. The output of the heater is a function of the circuit length, the size of the conductor foils and the supply voltage. Longline is an extremely viable option to skin effect heating for very long pipelines.











Product Data - Series Resistance Heaters - 230°C

HTS3F Specification Data MAXIMUM PIPE / WORKPIECE TEMPERATURES (°C) CAT NOM. AREA CLASSIFICATION									
REF	OUTPUT			ZAR		-			
	(W/m)	T6	Т5	T 4	тз	T2	T1	SAFE	
HTS3	BF-C 10	48	66	107	181	218	218	218	
	-A 20	-	32	75	158	191	191	191	
	30	-	-	41	133	164	164	164	
	40	-	-	-	109	134	134	134	
	50	-	-	-	76	97	97	97	
	60	-	-	-	30	46	46	46	
HTS3F	-CS 10	58	74	112	181	208	208	208	
	-AS 20	37	54	94	166	180	180	180	
	30	-	31	74	153	158	158	158	
	40	-	-	51	127	127	127	127	
	50	-	-	27	93	93	93	93	
	60	-	-	-	-	-	-	57	
HTS3F	-CF 10	58	74	112	181	192	192	192	
	-AF 20	37	54	94	166	178	178	178	
	30	-	31	74	153	165	165	165	
	40	-	-	51	127	127	127	127	
	50	-	-	27	93	93	93	93	
	60	-	-	-	-	-	-	57	

For conditions other than worst case, or pipes of other materials (eg. plastic, stainless steel, etc..), consult Heat Trace Ltd.

Tolerances: Voltage +10%; Resistance +10%; -0%

HTS1F Specification Data MAXIMUM PIPE / WORKPIECE TEMPERATURES (°C) NOM. OUTPUT

	•		
(W/m)	HTS1F-C	HTS1F-CS	HTS1F-CF
	-A	-AS	-AF
10	218	208	192
20	191	180	178
30	164	158	165
40	134	127	127
50	97	93	93
60	46	57	57

For conditions other than worst case, or pipes of other materials (eg. plastic, stainless steel, etc..), consult Heat Trace Ltd.

Tolerances: Voltage +10%; Resistance +10%; -0%

FULL TECHNICAL DATA SHEETS ARE AVAILABLE ON OUR WEBSITE FOR ALL PRODUCTS www.heat-trace.com

Page 43



Termination Components

Terminations – power end

Heat Trace have three different methods for the termination of its parallel heat tracers at the power supply. All methods are available for both safe and hazardous locations:-

- Direct Entry Sealed Termination Unit (DESTU) This is an improved method, where the junction box is connected to the DESTU, which is mounted onto the pipe surface. The tracer passes through the DESTU into the junction box, avoiding the possibility of damage to the tracer where it exits the thermal insulation.
- StripFree Unit The StripFree connection box has been specially developed by Heat Trace to reduce installation time and component costs. Tracers can be terminated without the need to strip the ends of self-regulating tracers. StripFree units are available for connection to the power supply and also for series and tee connections. StripFree boxes are particularly useful for small diameter instrument lines which cannot support large junction boxes.
- Standard Method This uses tracer termination gland components and a junction box. To avoid the possibility of damage to the tracer where it exits from the thermal insulation, a separate lagging entry kit is required.










Termination Components

Terminations – remote end

Heat Trace have three different methods for the termination of its parallel heat tracers at the remote end. All methods are available for both safe and hazardous locations:-

- Moulded end seal The silicone rubber end seal is fixed with an adhesive. It is a simple and low cost form of sealing.
- StripFree end seal The StripFree end seal has been specially developed by Heat Trace to reduce installation time. The end of the tracer is simply pushed into the end seal which immediately seals. It cannot be removed without a tool, and therefore provides additional safety. This seal is considered to be the best form of end-sealing.
- Heat Shrink seal The fitting of shrink seals require the use of a hot air gun. This may not be practical in a hazardous area.







FULL TECHNICAL DATA SHEETS ARE AVAILABLE ON OUR WEBSITE FOR ALL PRODUCTS www.heat-trace.com

Page 45



TEMPERATURE CONTROL – Selection Guide

The selection of an appropriate temperature control system is dictated by its purpose or objective. This guide to selection considers two forms of control:-

- **Air-sensing**, where the air temperature is monitored and the heating load is either:
- a) fully applied at a set temperature, as traditionally used for freeze protection installations, or,
- b) varied with changes in ambient temperature, and hence heat losses (called PowerMatching).
- **Pipe or surface sensing**, where the controller sensor is located directly on the pipe or equipment surface. This method has been traditionally employed for all temperature maintenance duties.

The purpose or objective of the temperature control system may be any one or more of the following:-

1. Ensuring temperature safety

It has already been stated in Section 2 (page 12) that temperature control to ensure temperature safety is the least favoured option – inherently temperature safe self-regulating heaters, or a stabilised design provide greater safety. But where necessary for ensuring temperature safety, pipe or surface sensing is almost always required. Care is required to ensure that all pipes which can experience differing flow conditions are controlled independently – this may result in a large number of heating circuits.

2. Process temperature accuracy

The three levels of process temperature accuracy defined in IEC heat tracing standards, types I, II, and III, are explained in Section 3 (page 18). The approach to selecting the best control system for each type of process is described on page 47.



3. Energy efficiency

The highest levels of energy efficiency have usually required a pipe or surface sensing form of control system. This again often results in multiple heating circuits to accommodate the many permutations of flow conditions. In this case, sections of pipe having differing flow conditions need to be controlled independently.

The degree of energy efficiency is also influenced by the accuracy of the controller – electronic devices are often more accurate than mechanical types.

4. Low capital costs

The lowest capital costs will usually result from a temperature control system having the fewest number of heating circuits. This is normally achieved by an air-sensing form of temperature control system.





TEMPERATURE CONTROL – Selection Guide

Type I process control – maintaining above a minimum temperature level

It should be recognised that a Type I control system will be extremely energy wasteful. For example, a freeze protection installation controlled by an air-sensing thermostat will be 100% energised at all times when the ambient temperature falls below the thermostat setting (typically 2 or 3°C). However, the average heating requirement over the number of winter hours that the system is energised is likely to be less than 20%, i.e. **over 80% of the delivered heat will be wasted.**

Most of this waste heat can be avoided by upgrading the system to a Type II process, achieved at a very modest cost, where energy savings recover the additional cost in a very short period of time.

FOR THIS REASON, HEAT TRACE RARELY RECOMMEND A TYPE I TEMPERATURE CONTROL SYSTEM.

Type II process control – maintaining within a broad temperature band

This has traditionally been achieved by means of mechanical capillary thermostats, having their sensors located on the pipe surface.

However, in-plant piping systems are often complex, having multiple flow permutations. To control all possible permutations, a separate thermostat is required for each section of pipe having differing flow conditions. This results in many heating circuits within an expensive distribution system.

To meet the requirements of a Type II process, whilst at the same time reducing to a minimum the number of heating circuits, and hence, distribution and control panel costs, Heat Trace is able to recommend a heat tracing system where:-

- a) the tracers are spiralled to the pipes to just compensate for heat losses at the minimum ambient design temperature.
- b) the controller is Heat Trace's unique PowerMatch unit. This monitors the ambient temperature and varies the heat delivered by the tracer according to changes in ambient temperature, and hence, heat losses.

By monitoring the air rather than the pipe surface temperature, only one controller is needed for each different 'maintain' temperature. The system can be used equally for either freeze protection of process temperature maintenance.

This system may occasionally result in heat being delivered unnecessarily to some sections of pipe having flow conditions. However, the system is an excellent balance of process temperature accuracy, energy efficiency, and low capital costs.

Type III process control – maintaining within a narrow temperature band

To control all sections of a piping system within a narrow temperature band of 2°C, as required for temperature sensitive materials (e.g. chocolate), has traditionally required the use of numerous high accuracy electronic controllers, controlling several sections of pipe which may have differing flow conditions. This has necessarily been provided at a high capital cost.

However, Type III process temperature accuracy can now be achieved with the same PowerMatching control system described for Type II systems above, but with the addition of a fine tuning temperature control.

Again, the heating load delivered at any time is matched to losses according to the ambient conditions. To ensure a narrow band process accuracy, a further sensor is located on a short heated 'dummy' line incorporated into the piping system.

SUMMARY

Type I process control – maintaining above a minimum temperature level

 is very energy wasteful. Not recommended – upgrade to Type II process control

Type II process control – maintaining within a broad temperature band

 can be achieved by air-sensing PowerMatch control to provide good energy efficiency from the fewest number of heating circuits i.e. least capital cost

Type III process control – maintaining within a narrow temperature band

 can be achieved by air-sensing PowerMatch control plus fine-tune line control to provide good energy efficiency from the fewest number of heating circuits.



Type I Process Control - Maintain above a minimum point

Гуре	Description	Area Location	Air or pipe/ Equipment Sensing
AT-F AIRSTAT	The AT-F AIRSTAT is a non-adjustable controller that energises the heating circuit when the sensor temperature falls to +2°C. The system then de-energises as the sensor temperature rises above +5°C. It has a MAINS ON and HEATER ON indication.	Safe Areas	Air Sensing
CT CAPSTAT	The CAPSTAT is a temperature adjustable ON-OFF thermostat comprising a liquid filled sensing bulb connected to an electrical switch via a capillary tube. Expansion of the liquid on rise in temperature causes the switch to open and on cooling, it closes. The CAPSTAT sensing bulb may be positioned to sense the air temperature.	Safe Areas	Air Sensing
CT-FL CAPSTAT	The CAPSTAT CT-FL and CT-FL/DUAL are temperature adjustable ON-OFF thermostats but for use in Zone 1 and Zone 2 hazardous areas, with enclosures suitable for Gas Groups IIA, IIB and IIC . The sensing bulb may be positioned to sense the air temperature.	Hazardous Areas Zone 1 & Zone 2 Areas	Air Sensing
FULL TEC	CHNICAL DATA SHEETS ARE AVAILABLE ON OUR V www.heat-trace.com	VEBSITE FOR ALL PRODUC	STS

PRODUCTS AND PRODUCT SELECTION



Type I Process Control - Maintain above a minimum point



Page 49



Type II Process Control - Maintain within a broad band

Туре	Description	Area Location	Air or pipe/ Equipment Sensing
POWERMATCH Micro+	The POWERMATCH Micro+ is an electronic digital controller that senses changes in air temperature and then automatically adjusts the ratio of the periods in which the heaters are energised and switched off so that the heat delivered matches heat losses.	Safe Area - For hazardous areas protection is required.	Air Sensing.

IRE168

The IRE168 is a single point electronic temperature controller. When connected to RTD's will energise trace heating circuits at the desired set point.

Safe Area - For Hazardous areas, appropriate Ex protection is required. (consult Heat Trace Ltd) Air or Surface Sensing by PT100 sensor.

CT CT-FL CT-FL/Dual The CAPSTAT is a temperature adjustable ON-OFF thermostat comprising a liquid filled sensing bulb connected to an electrical switch via a capillary tube. Expansion of the liquid on rise in temperature causes the switch to open and on cooling, it closes. The CAPSTAT sensing bulb may be positioned to sense the line temperature or surface temperature of a vessel. Safe Area Hazardous Area Zones 1 & 2. Line Sensing.

FULL TECHNICAL DATA SHEETS ARE AVAILABLE ON OUR WEBSITE FOR ALL PRODUCTS www.heat-trace.com

PRODUCTS AND PRODUCT SELECTION



Type II Process Control - Maintain within a broad band

Switch Rating	Comments	
8 amps direct switching, or via	Unit located in control panel	
suitably rated contactor.	Powermatching is significantly more efficient than conventional air sensing thermostats	Franklin Barris
	 Large blocks of heating may be switched from a single controller - fewer heating circuits are required 	
	 May be used with self regulating heating cables 	
	Temperature range -50 to +80°C	CINERAL CONTRACTOR
Internal 16A or external switch-	Unit located in control panel	
ing via contactors, solid state	DIN Rail Mounting	
relays or Thyristor drives.	 Digital display 	
	 Accurate temperature control (0.5% scale range) 	14994
	● Temperature range -200 to +800°C	100 2
	Pt100 three wire sensing	
	 4-20mA temperature control output 	The second second
16 amps direct switching, or via suitably rated contactor.	 CT and CT-FL are adjustable thermostats with 3 temperature 	
	ranges: Type A 0–40°C	
	Type B 20–110°C	Station 1
	Туре С 20–300°С	
	Suitable for outdoor use	A TABANT
	One thermostat is required for each	S R. TALLER
- Ale	pipeline - more heating circuits may be required	and a second

Page 51



Type III Process Control - Maintain within a narrow band

Туре	Description	Area Location	Air or pipe/ Equipment Sensing
POWERMATCH Micro+	The POWERMATCH Micro+ is an electronic digital controller that senses changes in air temperature and then automatically adjusts the ratio of the periods in which the heaters are energised and switched off so that the heat delivered matches heat losses.	Safe Area - For hazardous areas protection is required	Air Sensing and line sensing
	A separate line sensing controller provides fine tune control. This sensor may be located on a "dummy" heated pipe section having no flow (dead leg).		
IRE168	The IRE168 is a single point electronic temperature controller. When connected to RTD's will energise trace heating circuits at the desired set point.	Safe Area - For Hazardous areas, appropriate Ex protection is required (consult Heat Trace Ltd)	Air or Surface Sensing by PT100 sensor
IRE8	The IRE8 is a user friendly multi-channel (4 or 8) electronic PID temperature controller. Control parameters for each output can be preset independently and are automatically set by auto-tuning. For monitoring purposes, 3 different alarm outputs are provided. Each channel is connected to air or pipe sensing PT100 RTD's.	Safe Area - For Hazardous areas, appropriate Ex protection is required (consult Heat Trace Ltd)	Air and Surface Sensing by PT100 sensor.
GUARDIAN ENERGY MANAGEMENT SYSTEM	Guardian is an 8 channel, computer assisted energy management, control and auditing system for large / critical heat tracing installations. It may be provided as a stand alone system or integrated into the plant's SCADA or DCS system. Details of the auditing / monitoring facilities are provided on page 55.	Safe Area - For hazardous areas protection is required	Line sensing
FULL TECHN	ICAL DATA SHEETS ARE AVAILABLE ON OUR W	EBSITE FOR ALL PRODUC	TS

PRODUCTS AND PRODUCT SELECTION



Type III Process Control - Maintain within a narrow band

Switch Rating	Comments
16 amps direct switching, or via suitably rated contactor.	 Unit located in control panel Powermatching is significantly more efficient than conventional air sensing thermostats. Type III accuracy is provided by the additional line sensing control Large blocks of heating may be switched from a single controller - fewer heating circuits are required May be used with self regulating heating cables Temperature range -50 to +80°C
Internal 16A or external switching via contactors, solid state relays or Thyristor drives.	 Unit located in control panel DIN Rail Mounting Digital display Accurate temperature control (0.5% scale range) Temperature range -200 to +800°C Pt100 three wire sensing 4-20mA temperature control output
Internal 3A or external switching via contactors, solid state relays or Thyristor drives.	 Unit located in control panel Fascia Mounted Multi Digital display Full navigation facilities Accurate temperature control (0.5% scale range) 3 alarm outputs Temperature range -199 to +600°C Pt100 three wire sensing Output: relay or SSR; (optional: TRIAC, 0-20mA or 4-20mA) RS485, RS422 & RS232 communication
Internal 5A relays or suitably rated, contactors or solid state relays.	 Unit located in control panel, DIN rail mounted Controls and monitors up to 8 individual heating circuits per Guardian Precise temperature control Full time surveillance of heating system integrity Pt100 three wire sensing Alarm Functions Output by Relay or SSR Local LCD Monitoring panel with full navigation (Optional) RS485 Modbus Communication to remote PC with "Guardian Consultant" package Trend analysis, Performance and Alarm Reports (Optional)

Page 53



Circuit Monitoring

Circuit Monitoring of smaller heat tracing installations

Where critical to the process, circuit health monitoring is provided by Heat Trace's Watchdog system. This is located in the control and monitoring panel and periodically energises the circuits to ensure that they are operating correctly. In the event of damage to a tracer, an alarm is raised to enable corrective action. This can often take place before the pipeline has time to cool to an unacceptable level.

Watchdog is available as a single or 5 circuit device.







Circuit Monitoring


Circuit Monitoring of large heat tracing installations


Large heat tracing installations, when critical to the process, may be monitored by the 5 circuit Watchdog monitoring devices shown opposite.

However, when the Guardian computer assisted energy management control and auditing system is selected, this provides the user with the ultimate in monitoring facilities. This SCADA type control has all the benefits of electronic control, complemented by the addition of computerisation. This development allows two-way communication between the control system and a remotely located computer. Additionally, all control parameters, collected data system drawings and system information can be stored and retrieved, and full visual indication is available.

Heating circuits are continuously monitored for correct function and temperature. Circuit currents and supply voltage may be measured and used by the software package to calculate the individual circuit power and running costs. Alarms are raised in the event of any non-compliance. A data link to the main process computer is also available, with the option of an internet protocol module for providing communications over TCP/IP and HTTP for web pages, or emailing of alarm messages.

Control and monitoring parameters may be inputted either remotely or locally as required. System parameters are stored in the computer and in each Guardian controller. This gives ultimate reliability, as all parameters are capable of being downloaded to replacement units.





Page 55



Pre-installation

It is essential that the heat tracing system is correctly installed, tested, commissioned, and maintained. Heat Trace will provide comprehensive instructions for the installation of the system equipment. However, we would recommend that the following points are taken into consideration:-

Personnel

Persons involved in the installation and testing of electric heat tracing systems should be suitably trained in all special techniques required. Installation should be carried out under the supervision of a qualified electrician who has undergone supplementary training in electric heat tracing systems. Where systems are for use in explosive gas atmospheres, additional qualifications apply, such as knowledge of system certifications.

Equipment verification


Prior to installation, the design data used for the heat tracing design should be verified and the as-built piping and other equipment should be checked against the enquiry drawings.

The installation of the heat tracing system should be co-ordinated with the piping, thermal insulation and instrument disciplines.

Pre-installation testing

Pre-installation tests shall be performed and documented on a checklist similar to that opposite. This also helps verify the heat tracing design.

- a) Heat tracers shall be visually checked for damage. Continuity and insulation checks should be made and insulation resistance measured from heat tracer conductors to the metallic braid or sheath, with a minimum 500 Vdc test voltage. The measured insulation resistance shall not be less than 20 M.Ohms.
- b) Controls shall be tested to ensure correct calibration of, for example, set points, operating temperature range and span.
- c) Control panels shall include documentation certifying that all wiring, layout and functions are correct and have been tested. A general inspection of the panels shall confirm that no damage has occurred in transit.





Pre-installation checks

Table 1 - Pre-installation checks

	Items to be checked	Remarks
1	Is the work piece fully erected and tested and all temporary supports removed? Is the surface to be heated free from sharp edges, weld spatter and rough surfaces?	Any welding or pressure testing after the installation of a heat tracer could damage the device
2	Is the surface upon which the heat tracer is to be applied normal steel or non-metallic?	If the surface is of polished stainless steel, very thin-walled pipe or non-metallic of any kind, special precautions may be necessary
3	Do the items to be heated correspond in size, position, etc with the design?	It is sometimes difficult to be sure that the correct pipe is being heated. A suitable line numbering system may be of assistance
4	Has it been specified that metallic foil be installed before the application of the heat tracer?	This may be used to aid heat distribution
5	Has it been specified that metallic foil be installed after the application of the heat tracer?	This may be used to prevent insulation from surrounding the heat tracer or to aid heat distribution
6	Can flow of product under normal or abnormal conditions reach temperatures greater than those that the heat tracer can withstand?	This would normally be covered in the design stage; however, further discussion with staff at the plant may show that incorrect or out-of-date information has been used
7	Is the heat tracing system documentation (working drawings, designs, and instructions) available?	No change should be contemplated without reviewing the heat tracing system documentation, as careful calculations are necessary to ensure safe operation
8	Can pipes or surfaces expand and contract so as to cause stress on any part of the heat tracing installation?	In this case precautions are necessary to avoid damage
9	Can sensors of temperature controllers be affected by external influences?	An adjacent heating circuit could affect the sensor
10	Is the heat tracer to be spiralled or zigzagged onto the work piece, according to the design?	Check design loading per unit length of pipe (or surface area) to determine if spiral or zigzag application is necessary
11	Are cold leads, when fitted, suitable for contact with the heated surface?	If the cold lead is to be buried under the insulation, it has to be able to withstand the temperature
12	Is the pipe work hung from a pipe rack?	In this case, special precautions are required to ensure the weatherproofing of the insulation at points of suspension
13	Does pipe work have its full complement of supports?	The addition of intermediate supports at a later stage could damage the heating system
14	Are sample lines/bleed lines, etc at the plant but not on drawings?	These could obstruct or prevent the fitting of the heat tracer, and a review of the heat tracing system documentation may be necessary
15	Are other parameters used in the design of the equipment as specified by the design documentation?	More or less lengths of trace heater may be required than was called for in the design. This may require for redesign of the circuit.
16	Are the heat tracers, controllers, junction boxes, switches, cable glands, etc, suitable for the environmental conditions and are they protected as necessary against corrosion and the ingress of liquids and particulate matter?	If the trace heater design does not meet the intended application, the circuit must be redesigned and the system documentation must be updated.

Page 57

INSTALLATIONS



Installation of heat tracers - General

Heat tracers should be attached to clean piping and equipment in accordance with the instructions. Care should be taken at flanges and fittings to position heaters so as to avoid damage. Check that the heater assembly can accommodate movement and vibration.

The installer should allow the appropriate amount of heater to compensate for additional heat losses from pipeline fittings, as allocated by the *Evolution* design software.

A heat tracer should be kept in as intimate a contact as possible to the heated surface. Where close contact is not possible, such as on valves, a heat-conductive covering of metal foil may be used.

It is recommended that the heat tracer is not folded, twisted, or allowed to overlap, cross or touch itself. Attention should be given to the minimum bending radius.

Where heat tracers cross possible sources of leaks, for example, flanges, they should be positioned to minimize contact with the leaking medium.

Only genuine Heat Trace components may be used or else the system certification will be invalidated.

Straight tracing runs on pipe

Single straight traced runs are usually positioned at the underside of the pipe, fixed at 300mm centres, using only the correct Heat Trace fixing tape.

Multiple straight heat tracers should be equally spaced around the circumference of the pipe. Extra lengths of heat tracer will have been provided for in the design to compensate for the additional heat losses at pipe fittings, valves etc..


Spiral tracing runs on pipe

The pipe and equipment should be marked at the design spiral pitch. Then apply the heat tracer in a uniform spiral from the power supply point maintaining slight tension in the tracer as it is applied. Fix at no more than 2 metre centres using only the correct Heat Trace fixing tape.

Spiral tracing runs should be applied in such a way that valves, etc.., can be easily removed or replaced.







INSTALLATIONS



Installation of heat tracers - General

Connections and terminations

It is essential that all heat tracers are terminated correctly with approved components to Heat Trace's instructions.

Longline heat tracers intended for site termination should be checked to ensure that the installed lengths correspond to the design length and loading.

Connection of the heat tracer to the power supply should be such as to prevent physical damage, and positioned to prevent the ingress of water.

Heat tracing circuits are connected into Heat Trace junction boxes specifically designed for connection of the tracer. The boxes provide appropriate protection and certification. Junction box lids should not be left open at any time.

The metallic braid or sheath of the heat tracer must be bonded to the earthing system to provide for an effective ground path.

Tracer end seals must be securely fitted to Heat Trace's instructions and protected to avoid mechanical damage and ingress of water.

Marking and tagging

After installation, all the circuits must be properly marked / tagged, as follows:-

- a) Branch circuit breaker
- b) Monitor and alarm apparatus
- c) Heat tracer power connection
- d) Circuit number and set point for each temperature controller

Marking shall be carried out for each heat tracing circuit, on the respective junction box.

Post installation testing

The pre-installation insulation resistance test described above shall be repeated on all heat tracer circuits after installation, using a minimum 500Vdc megger. The measured insulation resistance shall not be less than 20 M.Ohms.

Continuity and resistance checks shall be made for each circuit and the installed tracer load confirmed with the design load.

The type, length and electrical data of each heat tracer shall be noted for inclusion in the final documentation. The connection points shall be recorded for entry in the piping and instrumentation diagrams.









Installation of control and monitoring equipment

General

The installer is usually responsible for fixing the control and monitoring and distribution panels. These will, as a minimum, provide over-current and earth-leakage protection as well as means of isolation. Some form of temperature control or limitation is usually provided to ensure safe temperatures or for energy efficiency purposes.

Verification of equipment suitability

The supplied controllers, thermostats, sensors, and related devices shall be checked to match those specified in the design with regard to the service temperature, the IP rating, and, for hazardous areas, certification. The certification of heat tracing systems may prescribe the use of specific components. In these cases it is mandatory to use only parts specified by Heat Trace.

Temperature controller and monitoring devices

The sensors of the temperature controllers may be air sensing or applied directly to the pipe. The sensors are usually resistance temperature detectors, or capillary tube thermostats.

Water and corrosive vapour intrusion can cause failure of temperature controllers. The cover or lid of a controller housing should always be closed after installation, except when required for access.









Installation of control and monitoring equipment

General sensor installation

The sensor for surface temperature control is installed onto the surface of the pipe or equipment in accordance with the designer's instructions in a position that will provide a temperature representative of the overall circuit. The sensor should be positioned so as not to be influenced by the temperature of the heat tracer, or other factors such as heat sinks and solar gain.

Ambient temperature-sensing controllers should be sited in the most exposed position for the installation.

Line sensors should be strapped in good thermal contact with the pipe or equipment and protected so that thermal insulation cannot be trapped between the sensor and the heated surface. Care should be taken not to damage the capillary tube, or RTD leads, or to distort the sensor and thereby cause calibration error.

Care should be taken to ensure that the capillary tube, or RTD leads emerge from the thermal insulation in a manner that will not allow the ingress of moisture.

Sensor installation for temperature limiting device

When a system has to employ a temperature controller in order to ensure temperature safety, then clearly the positioning of the sensor is critical to the safety of the plant.

The sensor for the temperature limiting controller is installed onto the surface of the pipe or equipment in a position that will provide a temperature representative of the overall circuit. In order to assure that the safety temperature controller can accurately react to the maximum heat tracer surface temperature, particular attention must be paid to the location, method of attachment and set point. This method of sensor installation is based on the known relationship between the equipment temperature and the heater sheath temperature at a given power output.

It is important that the controller is set such that the heater sheath temperature does not exceed the limiting temperature under worst-case conditions (e.g. voltage +10%, tracer at upper limit of manufacturing power tolerance, heater out of contact with the pipe/equipment, high ambient, no external convection).



Warning

Some heat tracing companies offer low cost series resistance heaters of minimal mechanical strength that are designed for use with voltage regulating devices. These require the sensor of the over-temperature controller to be fitted to the surface of the heater itself. However, this is a practice that Heat Trace Ltd. does not recommend because:-

- It will rarely be known to be sensing the hottest point of the heater (which is likely to be where the heater is out of contact with the equipment) and
- When the sensor is removed, for example during maintenance work, it cannot be guaranteed to be returned to the hottest part of the heater

The practice of fitting a temperature sensor to the heater to ensure temperature safety is dangerous!





Installation of thermal insulation system

Precautions must be taken to protect tracers from mechanical damage and moisture intrusion after they have been installed and prior to the application of thermal insulation. The installation supervisor shall coordinate with the thermal insulation contractor, so that the thermal insulation is applied as soon as possible after the installation and testing of heat tracers.

It should be confirmed that the thermal insulation to be installed is of the size, specification and thickness used for the design of the heat tracing system.

When a tracer is installed onto the surface of a pipe, it's effective diameter is increased. The thermal insulation is usually provided in pre-formed sections. Thus a small gap may occur due to the addition of the tracer. In this case, 'filler' segments should be installed to ensure full insulation. Note that, if over-sized insulation is used (i.e. the next pipe size up), then heat loss calculations must be based on the over-sized pipe value.

The thermal insulation installation crew should be experienced /trained in fitting insulation over tracers, particularly with a view to avoiding mechanical damage, which is most likely when cutting and forming sheet metal cladding around flanges and other line equipment.

Warning labels must be fixed to the cladding at 6m intervals advising that electric tracers are installed beneath the thermal insulation and fitted to the cladding over each valve or item of equipment that may require periodic maintenance.

Field circuit insulation resistance test

The test procedure described above shall be conducted on all heat tracer circuits after lagging, with the requirement that the measured insulation resistance shall not be less than $20M\Omega$

Visual inspection

Carry out a visual inspection of the thermally insulated system to ensure that:

- 1. moisture cannot penetrate the insulation
- screws used for fastening cladding are short enough to preclude any possibility of damage to tracers or temperature sensors.
- 3. entry cut-outs in the cladding for heat tracers, temperature sensors, etc.., are dimensioned so as to render contact impossible.
- 4. cladding joints and thermal insulation entries are properly sealed with an elastic, non-hardening sealant resistant to chemical attack.

Documentation

The thermal insulation material and its thickness shall be documented.









The branch circuit wiring of each heat tracing circuit requires an over-current protective device. The size and type of distribution wiring, and the ratings of the branch circuit protective devices is based on heater start-up currents and their duration at the minimum temperature that the heat tracing device may experience.

An earth fault protective device RCD shall also be provided Check that protective devices are sized correctly to the rated current and, where applicable, have appropriate certificates.

Installation of electrical power





A FULL INSTALLATION, TESTING AND MAINTENANCE MANUAL IS AVAILABLE ON OUR WEBSITE www.heat-trace.com







Commissioning & Documentation

Functional check and final documentation

The heat tracing system(s) shall be commissioned after the thermal insulation has been installed and the electrical distribution is completed. The heat tracer commissioning record given in Table 2 shall be completed and retained.

- a) Close all branch circuits and verify proper current. A temporary bypass may be required for the temperature control device.
- b) Verify that monitor or alarm circuits are operable. A bypass may be required at field contacts.
- c) Fill out the heat tracer commissioning record (Table 2) for each circuit. This shall clearly document all testing and commissioning data.
- d) Record the electrical insulation resistance values for each measurement taken.
- e) Record the applied voltage and resulting current after five minutes of energization, and pipe temperature if required.
- f) Verify that the alarm and monitor components operate as intended.
- g) Verify that the calibration check at the temperature controller setpoint has been performed and the controller has been set at this value.

Final documentation

Adequate and uniform documentation of the electric heat tracing circuits is an essential precondition for economical maintenance of this equipment. This is especially important to facilitate rapid troubleshooting in the event of circuit problems. It also provides the basis for simpler, faster and less costly handling of any desired modifications and expansions by a specialist for electric heat tracing systems.

The documentation of each heating circuit of a heat tracing system shall include the following elements:

Design and testing documentation:


- a) Table of contents
- Piping diagram showing the heat tracing circuits and the location of power points, connections, splices, tees, end terminations, and temperature sensors for control and limitation
- c) For vessels: layout of the heat tracing
- d) Pipe and thermal insulation list
- e) Individual circuit length of heat tracers
- f) Calculation and dimensioning data
- g) Material list
- h) Heat tracer installation instructions
- i) Heater cabling plan
- j) Description of and installation instructions for temperature sensors
- k) Heater commissioning record (Table 2)
- I) Temperature profile measurement
- m) Installation certificate

Circuit diagrams:

- a) Wiring and circuit diagram
- b) Terminal connection diagrams, switchgear with parts list
- c) Installation instructions

Other:

- a) Technical descriptions and instruction manuals for the individual pieces of equipment
- b) Functional diagram as agreed to with the design engineer
- c) Certificates or declarations of conformity from a certification agency for explosive gas atmosphere equipment, as required





Commissioning & Documentation

Table 2 - He	at tracer commissioning r	ecord				Сотт	issioniı	ng & Do	cumentation		
	Location		System			Project	number	Refer drawi			
	Line number		Heat Trac	er num	ber	Area cl	assification		erature fication		
	Panel number		Location			Circuit	number	Circu	t amp/voltage		
	Heat Tracer manufacturer		Heat Trac	er mod	el	Heat Tr	Heat Tracer wattage unit length/voltage rating				
	Verify certification marking:										
	HEAT TRACER INFORMA	TION:									
	Heat Tracer total design ler	ngth				Heat Tra	cer total in	stalled leng	th		
	Thermal insulation type					Thermal	insulation	thickness			
	Workpiece maintain temper	ature				Maximun	n workpiec	e temperat	ıre		
	HEAT TRACER TESTING:	(data fro	om heat tra	cer ins	stallat	ion record)				
	Electrical resistance (contin	uity) test	, in ohms								
	Electrical insulation resistar	nce test, i	n Megohms	;							
	Test ambient temperature										
	PERFORMANCE DATA:	Volts a	.C.	Curr	ent in	amperes					
			Field	Sing phas	le- se	Three-ph	Three-phase				
				Line		A phase	B phase	e C phas	e Neutral		
	Start-up										
	After 5 min										
	After 4 h										
	Ambient temperature at tim	e of test									
	Pipe temperature at beginn	ing of tes	g of test After 4 h			4 h	1				
	Calculated watts per unit le	ngth (V x	A/m)		After	4 h					
	TEMPERATURE CONTRO	L: type									
	Heat Tracer controller	Ambie	nt sensing		Worl	Norkpiece sensing Temperature s			ire setpoint		
	High limit controller	Туре			Loca	cation Te		Temperati	ire setpoint		
	Heating controls calibrated										
	Heating controls operation	Heating controls operation verified									
	ALARMS/MONITORING: ty	/pe									
	Temperature	High se	tting		Low	setting		Operation	verified		
	Heat Tracer current	High se	tting		Low	setting		Operation	verified		
	Residual current				Settir	ng		Operation	verified		
	Loss of voltage							Operation	verified		
	Other							Operation	verified		
	RCD PROTECTION: type										
A	Setting		Measured	curren	t		Tested in	operation			
A Cast of	Performed by:						Company	/	Date		
BORE -	Witnessed by:						Company	/	Date		
	Accepted by:						Company	/	Date		
	Approved by:						Company	/	Date		
	A DECK OF THE OWNER										





General

It is recommended that the maintenance schedule given in Table 3 should be undertaken each year. All maintenance activities should be recorded in a maintenance log (such as that shown in Table 3) and retained in the system documentation.

Fault location

Specialised methods of fault location are necessary to find faults in electric heat tracing systems covered by thermal insulation and metallic cladding, and advice should be sought from the electric heat tracing system designer. Most commonly, faults are caused by mechanical damage, corrosion, overheating or ingress of moisture.

Fault rectification

When the fault has been located, the defective component should be replaced or repaired. Those parts of the installation that have been disturbed should be checked in accordance with Table 2 and recorded in accordance with Table 3.








Maintenance

Table 3 – Maintenance schedule and log record

Location system					Sys	stem	Reference drawing(s)				
			С	IR	CUIT INFO	RMATIO	1	· · · ·			
Heat tracer number			Circuit le	ngth		Br	eaker pa	nel no.			
Power connection					Design vol	tage		Breaker pole(s) no.			
Tee connection		Res	sidual curre	ent p	protection (type)					•	
Splice connection		Residual current trip s		rrent trip se	tting						
Process control type I, II or III		Heating		Heating	controller t	ype					
Circui	t Monitoring	YES	S / NO					•			
					VISUA	\L					
Panel no.	Circuit no.										
	Date										
	Initial										
Therm	al insulation		· · · · ·								
Damaged insulat	ion/ lagging										
Water seal	acceptable										
Insulation/lage	ing missing										
Presence	of moisture										
Heating system o	omponents										
Enclosures, b	oxes sealed										
Presence	of moisture										
Signs	of corrosion										
Heat tracer lead dis	scolouration										
Heating and/or high lin						1		1			
	ing properly										
Control	ler set point										
					ELECTR						
Insulation resistance te		contro	oller if nece	ssa	ary)			1	1		
	Test voltage										
	^r value, MΩ										
Heat tracer su								1	1		
	wer source										
Value at field	connection										
			Heat tr	ac	er circuit	current r	eadir	ng	1		
Amps reading at											
Amps reading a											
Ground-	fault current										
Comments	and actions										
Performed by:						Company				Date	
Approved by:	_					Company			C	Date	







Evolution – The Complete Heat Tracing System Design Suite

Heat Trace Ltd has taken it's 40 years of experience in design, manufacturing, installation and innovation and used it to produce an intuitive and comprehensive heat tracing design suite.

Heat Trace's **EVOLUTION** Software has been designed and written by Heat Trace utilising our understanding of the way in which Heat Tracing enquiries and projects are received, designed and installed. Evolution was not written by a software company having only limited understanding and appreciation of heat tracing system design.

The software is of value to users, engineering houses and contractors alike. From their own line lists, they can produce heat tracing budgets and a simple shopping list of requirements. Alternatively, the software can be used to validate a supplier's bid.

The software includes an intuitive drawing package having AutoCAD compatibility. Isometric pipe layout drawings, which have traditionally required a high design input and involved large costs, may be produced quickly and will determine heat losses, heat tracer selections, bills of material, and the final installation drawings.

The following pages of this brochure give a flavour of what **EVOLUTION** is capable of and what Heat Trace's Innovation culture has meant to Heat Tracing design. It extends not only to our products but also to the support and services that we provide to our customers.

The key features of Evolution are:

- Calculations and product selections are performed on all generic types of heat tracer: Parallel Self-Regulating, Parallel Constant Power and Series Resistance.
- Evolution can design systems for both Safe and Hazardous Areas, considering stabilised and temperature controlled designs.
- Heating applications such as Freeze Protection, Temperature Maintenance, Heat Raising, Long Pipes, Tanks and Vessels can all be calculated in a single enquiry.

 An enquiry entered into Evolution can be broken down into different sections or groups depending on the user's preferences. Individual bills of material can be produced for each group. This allows the user to break the quotation into different sections according to the format required.

For Example:

- The customer may wish that Plant Area 1 be itemised separately from Plant Area 2
- The user may wish to offer options for the customer to choose from.

This can now be done automatically under the same enquiry. The flexibility of the reports allows the user to present the quotation in an appropriate format.

- Large or small, simple or complex enquiries can be designed and quoted accurately, confidently, quickly and efficiently.
- Data is usually supplied in an electronic format. Whether typed into Microsoft Excel or exported from a Pipe Design Management System, it can be imported directly into Evolution. This saves time and eliminates data input errors.
- Evolution is multi-lingual with the facility to translate the software into your own language.
- There are no messages requesting you contact the manufacturer's design engineer for advice. For many applications, there is no need for a design engineer at all. Evolution empowers the user to design heat tracing systems with the knowledge that the system will be the safest system that works and having the greatest commercial advantages.
- Evolution goes beyond engineering principles, calculations and product selections. Evolution is firstly a piece of computer software. It is simple to use and does not require knowledge of heat tracing or electrical engineering. In the hands of a heat tracing engineer it becomes even more powerful and allows the design engineer to spend more time designing and less time on clerical activities. Secondly the software has been written from a Customer Perspective, providing tools that utilise the data in the enquiry for analysis, emails, reports and many other CRM activities.
- Evolution automatically updates itself from the Heat Trace website so you will always be working with the latest software, products and literature.



A Customer's Perspective

Evolution has been written with our customers in mind. Unlike other software Evolution is not limited to calculations and product selection. It contains many features to allow the user to consolidate all activities related to the preparation of designs, reports and quotations in a single piece of software.

Features to manage customer and contact information, pricing structures, product stock records, graphical product libraries, and a document designer can all be used to minimise time spent producing quotations and to maximise productivity.

Evolution can also be tailored to meet the requirements of the user. The user can modify software defaults, manipulate how Evolution performs calculations and makes product selections, further reducing data entry and time spent preparing quotations.

Collectively these programs empower the user to design heat tracing systems and produce professional quotations all within a single piece of software.

Product knowledge, catalogues, datasheets are no longer required. As a result, mistakes, time spent entering data and preparing quotations is substantially reduced and accuracy and productivity of expensive engineering resources are significantly increased.

Associates Records

The Associates Records allows the user to enter their customer addresses and contact details. The customer can then be selected from a drop down list when a new enquiry is entered. Address details will then be copied from the Associates Database into the enquiry, saving time and improving accuracy.

	_	of the second second	There is a lot of the state of	THE OWNER WHEN PARTY	Constantion of
	_		and the second se	_	
10					
No 82					
A COMPANY OF A DRIVEN	100				
Over Taxle	_				1
		Sector C Barres			
and sufficient on					
Party Contract					
Fastime					
88078.004	4				
Rocke 1					
in star fairest	100				
	Crist Sada Crist Sile Arturatura Arturatura Arturatura Arturatura	Hal Ro Drigo Lancold Collins Drigo Lancold C	And the second s	And a final state of the second state of the s	And and a second back in a second back in the secon

Pricing Structures

The Associates Records can be extended further to include a pricing structure. *Pricing Structures* allow Evolution to determine the selling price for the products selected when the bill of material is compiled. This ensures that the correct

prices are used and removes the need to enter prices for each quotation.

Pricing Structures can be simple or complex. Simple Pricing Structures take the form of Cost plus a percentage margin or a List Price less a percentage discount. Complex Pricing Structures allow the user to also add specific prices for individual products.

	56 (c)	
Customer Sell	ing Procest	80 · 8
(delarra fights)		
Cardoniae ha 5		
tend of the second		(Marcan)
THE PART & DAVID	-	
Special Sel2n	e Prices	-
Contraction of the local division of the loc		Children I.
All states		Contraction of the
10000	- 22	452.00
10/08/07	- 21	811-40
DEPENDING 1		114.00
SPECCF	-	1100
NO11214	10	60.2
NUMBER OF STREET		65.16
		12
		-

When a customer is selected from the Associates Database,

the *Pricing Structure* is copied along with the address. The *Pricing Structure* can be modified for each individual enquiry.

Stock Records

Customer Stock Records allow the user to record which Heat Trace products the customer holds in stock. Evolution is capable of importing stock data from most resource management or stock control systems.

Evolution can be instructed to design a heat tracing system using only cables that are currently in stock. This is particularly useful when quick delivery is required for the heat tracing system. It can also be beneficial when the user carries only a certain range of cables and wants the software to use only those cables.

Customer Stock Records can also be used to check against the bill of material to determine if the user has sufficient stock to supply the heat tracing system.

Padal 194		Served Thanker				
141		- POX30581, 8			 	
1.4.4		 CEIMER.2 	16		 	
		1000101	19	-		
everalized by a			0			
		n	12			
ing Tapes _	1993	*	198	1.		
		-				



A Customer's Perspective

Product Search

Evolution has a graphical *Product Search* that can be used to identify a particular product. A flexible search facility gives the user the ability to find the appropriate product quickly without the need for product knowledge.

Having identified the product, the user is only a click away from product datasheets, images, literature and pricing. There is no longer the need to shuffle through catalogues, datasheets and price sheets to find the information required.

Product data is continually updated from the company website.



Images, videos, literature and articles, contained within Evolution, can be used to compile the user's own literature and documentation.



System Information contains links to all the underlying information required by the program to allow evolution to calculate designs. Fluid materials, pipe sizes, insulation types can all be amended and added to by the user. This further empowers the user to use the software without reference to Heat Trace.

Document Text Library and Document Designer

The *Document Designer* allows the setting up of templates for an array of documents such as quotations. The documents are constructed on a "copy and paste" basis. The user enters paragraphs of text or images in the *Document Text Library*.



Entering the text can be done by typing or copying and pasting the text from the user's current documents. The text and images are then dragged and dropped into the document template. The user can also drop in reports such as Bills of Material, Technical Calculations and Product Datasheets.



The user can create as many document templates as required. A document template may be selected for a given enquiry and Evolution will do the rest compiling and collating your document into an interactive PDF document complete with bookmarks.



Enquiry Management

General Principles

An Enquiry consists of sections: Enquiry Details, Design Selections, Heater Selections, Pipe Group References, Pipe/ Tank Dimensions, Bill of Material and Reports.

An Enquiry can have as many different *Pipe Group References* as required and each *Pipe Group Reference* can have as many pipe or tank items as necessary. Enquiries can be added to or amended at any time. There is no practical limit to the number of enquiries, pipe groups references or pipe / tank line items that can be entered into Evolution.

Enquiry Management

The *Enquiry Management* manages all enquiries, allowing easy location and access to each. Enquiries are listed in descending date order so that the last one created appears at the top of the list. The list displays the main fields for identification and also displays the status and value of the enquiry. The information is useful for enquiry tracking and progressing.



Enquiry Search & Filter

This function allows the user to search and filter out enquiries according to the content of specific fields.

EllectToostAll Cookine Enquiry Search & Filter	
Ententro e materiante ha	2/94 (
Costgener Narie	Agents Nation
Encline Tile	Pedies
Customer Heferenze Ini	Tales Potential
Enclosers kunse	Action officiated Ta
Erouty Family	Action Data From Action Data To
Ensury States	Catagory Search DD
Value From Value To	Cautic Soda Chocolate lines
X 🗹 🔳	Hest Raise 🚽

For example, the user can enter a customer name and the enquiry list will be filtered to display all enquiries for the selected customer, again in descending date order, so that the most recent enquiries are at the top.

Data Protection

In Evolution the data is saved automatically as the user proceeds through the enquiry. The user never needs to remember to press a button to save the data. If your computer crashes you will not lose any data.

Backup Enquiry

It is important to backup data. A backup facility allows the user to create small text files that contain the input data required to re-build an enquiry in the event of a disaster. Even deleting Evolution only requires the user to re-install the software and import backup files. Within a few minutes Evolution is back up and running. Evolution allows the user to backup any number of enquiries in a single operation.



Enquiry Management

An additional feature of *Backup Enquiry* is that the backup file can be e-mailed directly to another user. This allows the user to get support from Heat Trace for an enquiry, or the user could send the file to a customer who also has a copy of Evolution, for review.

Import Enquiry

The *Import Enquiry* facility allows the user to import backup files, or to import an enquiry that has been sent to them by another user.

and a second second second second	
	XV

Enquiry Tracking

Enquiry Tracking allows the user to manage the progress of enquiries and analyse the content of enquiries.

indentità, i	racking			2			Sergie
anne bare :	No. of Concession, Name	_	Daryme:	1 Martin	COLUMN TWO IS NOT		++ 1
inter Presed	4.0		frank last	BHEAT.	100 100		
igents Rame	Feat furth-High	1	a margin	Manual Providence	00020		
hgter	Vota frieglass	3	Sectorial .	-			
-	(International	and the second se	1000			-	100
Add # Serie	(+ i uset	The between	1		2.0		× .
Hard Here		- Paultetania	- Des faire	1		April 1	4.
World Garage		- Des Ford	2	-		84-8 4a-8	1
more then		a filment and	-	4	1 1	44.00	7
			2		2.4	A-101	
aure a		2	1	-	2 4		*

Enquiries can be allocated to a geographical *Area, Region* and to an Agent or salesman.

Evolution contains various status/progress items in the management of an enquiry. The user can change these to tailor *Enquiry Tracking*.

Action Date	Status / Action		Actioned By		
04-Jul-12	Order Won		2	-	ľ
04-Jul-12	Chase Progress		Steve Royle		ľ
04-Jul-12	Quotation baued		Steve Royle		ľ
04-Jul-12	Preparing Quotation		Steve Royle		Ī
04-Jul-12	Information Requested	-	Paul Betteridge		l
19-Apr-09	Received & Logged		Paul Betteridge		ľ
04-Jul-12			1	+	ĩ

The example above shows various actions recorded against the enquiry, allowing the user to know the status of each enquiry, when the next action should be completed and the sales potential factor.

Reminders can be set to advise users that an action is required.

-	Neilling - Overdue Actions	Contrast of the	And the local division of the		
100	- Aller and -	and particular	RECEIPTION OF	2432	1 North Party
141	interfacers.	Dist Tal	2 9.74	4	- H -

The user can record comments against each status/progress item to detail conversations with the customer or actions required.

	racking			÷		Samp
	and the second s		Assessment.	Salar Prof.	0.5	
Alley Market	18.	- 4	province:	Distance of the	14	
aparty barrier	Peul Sutraitige	- 23	a length	Libroy CT		
Pages -	LINESS STATION		Lin house	*********	- 4	
100	Care Linter	and the second s	-	1.000		
Theorem Parante	A B Logard	Stationeras	-	11	1 34.00	14
18.84.75 (ritras	the Repúblic	Star hanna spo	denter.	Э	il have	×
18.84 T 1994			100 M	3		



Enquiry Details



Adding categories to your enquiry tracking allows the user to further analyse enquiries.

Categories group similar enquiries together. All categories are defined by the user.

The user can produce various reports detailing the status of enquiries, critical dates, extent of work and analysing the content and value of the enquiries.

The user can also analyse the success or failure to convert enquiries into orders. Collectively reports can be used to determine which enquiries the user is most likely to win and therefore allocate resources more effectively.

In the *Enquiry Details* screen the user can enter details of the enquiry such as reference numbers and customer details. The customer details can be selected from a drop down list of customers from the *Associates Records*.

	NORTH CARDIN	Engliny Vite
	NAL DATE	
		Engliny Vesse
		and the second s
	person Sectoria	and the first set for a first set of the set
Contraction of the local	California to a	
	interne Internet traige Character Stand Heinige Frankline Frankline	
	web : treat lipset	Destructio (Notes
No. of Lot of Lo		440 1

This form also contains an *Enquiry Status* field indicating the next task to be carried out on the enquiry or to indicate whether the enquiry was won or lost.

Enquiry Contacts

All contact details for the enquiry, the customer, main contractor, installation company can be added to the enquiry. These contacts can be emailed from Evolution.

Enquiry Associaties				
C. Designation	III Instanti Nat	ant line at the second of	assessing a	-
- Contraction -	-	-		

Enquiry Pricing

Each enquiry in Evolution can be set to different currencies for product costs, selling prices and a different currency for quoting. For example costs maybe in British Pounds Sterling, selling prices in local currency Euros and the quote is presented in US Dollars.

Pricing Method	List Less % Discount		% Discount	-45
Ceets Ourrency	Sterling		Costs Exchange Rate	10
Quote Currency	Sterling	*	Quote Exchange Rate	1.14
Payment Terms	30 day Terms		Quotation Name Quote 1	

Customer Selling Price

Customer Selling P	rices :	[3]+ + [3	ş
Concery Name			
Customer No.1			
Printplanke		CDramment .	
HIT Lett % Discount	1		ŧ.
	-		1
Special Selling Price	95	*	î
Product Patienage	1 6	ALL IN COLOR	
Manager and		L SCHLING!	
		i scelna)	
1022705	2	1 30x1nd) 612.00	
IDENTIFY IDESTO-CT	2	E1200 £1350	
106 87 106 1 107 580-07 177 580-07	2	612.00 612.00 613.60 714.00	
1061-1066 107 582-01 177 580-01 297 582-01		1 3097552) E12 00 E13 50 F14 00 F14 50	
112471845 10750-07 17750-07 39700-01 317542-07		1.3000x20 612:00 613:60 613:60 114:60 615:00	
1061-1066 107 582-01 177 580-01 297 582-01		1 3097552) E12 00 E13 50 F14 00 F14 50	
112471845 10750-07 17750-07 39700-01 317542-07	2	1.3000x20 612:00 613:60 613:60 114:60 615:00	

If the customer has been selected from the drop down list then the *Pricing Structure* for that customer will have been added to this enquiry.

The *Pricing Structure* can be individually set for each enquiry. Modifications are applied only to the individual enquiry.

EVOLUTION – Enquiry Modelling



Design Selections

Enquiry Settings

The *Enquiry Settings* screen allows the user to choose the units of measure for your pipe data. The software allows the use of various units of measure:

Property	Options
Temperature	Degrees Celsius (°C) Degrees Fahrenheit (°F)
Length	Metres (m) Feet (ft)
Output or Heat Loss	Watts/Metre (W/m) Watts/Foot (W/ft)
Insulation Thickness	Millimetres (mm) Inches ("ins)
Pipe Size	Millimetres (mm) Inches ("ins)

👪 Heat Trace Ltd - Evo	lution	
Enquiry Units of	f Measure	
Length of Pipe/Cable	Metres	• 🗸
Heat Losses	Watts/Metre	• 🗸
Pipe Sizes	Millimetres	• 🗸
Insulation Thickness	Millimetres	• 🗸
Temperature	Celsius	•
Pipe Maintain Temp	perature	\checkmark
Maximum Process 1	emperature	\checkmark
Critical Process Ter	nperature	\checkmark

The user can use any combination of units. Users can also change settings at any time. If the pipe length was entered as metres, but it should have been feet, then simply change the unit of measure and you can choose whether Evolution converts all the numbers you have entered. The *Design Selections* screen allows the user to control how Evolution determines which products and what quantity of product are calculated. For example the user can:

generations des taxes feite comp tegenerategeni Tax of teamy taxing date	Alter lated line up 11 15 15 16 16 16 16 17 17	Despective provides a strong of source to support the set of strong of the support to set of strong of the support to set of strongs Support (the set of strongs)	
Tarmination Opplane Terminalian Herbul Neuronalian Patiba Insue Yuninakian Dak Insue Yuninakian Dak Insue Yuninakian Dak Insue Hartis Stank	Tester 2 Adferningson († 2 Heat State 2 Heat State 2 Heat State State 4 Heat State State 4	Fixing Strap Option M Re-Catange V Universitie Rectaliation Trine Fac replation from	Son of Strageling Strangering Stanl Son
Automatically Update	Groupe 🖌 🔀		

- Choose whether cables are to be spiral traced around pipes or straight traced.
- Select the preferred termination method: Standard, DESTU or StripFree.



• Select fixing methods and calculation allowances

These options significantly increase the flexibility of the design, allowing the user to manipulate the system design determined by Evolution.

Cable Selection Options

Cable Selection Options allows the user to define for this enquiry how cable can be calculated and fitted to the piping system.

Spiral Tracing

The term "*Spiral Tracing*" refers to the method in which the heating tape is applied to the pipe.

Maximum Spiral Ratio

The user can set a *Maximum Spiral Ratio*. Evolution calculates the spiral ratio required. If this exceeds the *Maximum Spiral Ratio*, then Evolution reverts to a Straight Traced method using multiple tracers.



Heater Selection

The *Heater Selection* screen allows the user to restrict or influence which cables are selected. Evolution selects a cable based primarily on a *"safe system that works"* having the least cost per metre of pipe to provide the required heat output.



Method of Selection

The user can choose one of the following options:

- Full Cable Selection Evolution will choose the best solution from all cables.
- Select Only From Stock Evolution will choose the best solution from the cables listed in the stock records for the user.
- Manual Selection The user can now specify particular product styles or families that Evolution can choose from.

The final selection of a heater is based upon cost to provide the lowest cost per metre of pipe.

Approved Cables

If the heating cables must carry a specific approval, then the user selects this option to specify the *Approval Body*. Evolution will now only select cables that are approved by the selected *Approval Body*.

This option saves the user a lot of time looking through Heat Trace's extensive product approvals to determine if the cable is approved. This ensures that unapproved products are not selected.

ATEX		
CSA Ha	zardous	
CSA Sa	fe	
FM.		
GOST		
Lloyds	Register	
SEMKO		
VDE		



EVOLUTION – Enquiry Modelling




Pipe Groups

Pipe Groups allows the user to split the enquiry into different sections. Each section can then have different applications parameters or methods of circuit calculation.

Geologia	 Pipe Group References 	Pleat Ratise Decality
Unigit Direct Direct Direct	State State State The State State State State State State State State	
	Aperiation Spectration and a complete spectra	Circuit Determination & Control
	Design Conditions	Druk her meder (1 + 6,11+)
	An Jacket 1	Torusteeder tas
	for other 4 for a long 4	Aprile for APRIL
	Mediani en	Default, Pipe Properties
		Tanharana Later Der
		12.2 Per las
	the longitudes that has not	the star that the basis of the basis of
	Parameter addi	X databate has here
	trailionate that	X renames long to 1
	an Article Particle Carl Vice	X month and the
2 m	- C	203

There are various reasons for splitting an enquiry. It is at the user's discretion to split it in any way he chooses. Typical reasons for doing this are:

- The voltage to be used for calculations and product selections is set at the group level. Having more groups allows the user to have different voltages in the same enquiry.
- The enquiry may consist of both a Hazardous Area section and a Safe area section. It is good practice to separate the two areas. The enquiry may also consist of Hazardous areas with different T-Classes. A new group must be created for each T-Class as this is set at group level.
- Different applications such as Temperature Maintenance, Heat Raise and Tanks are set at group level. So if the enquiry consists of both Heat Raise and Temperature Maintenance, then a group must be created for each.
- The enquiry may specify, or the user may wish to split the quotation and bill of material into different areas of the plant. A group could be created for each area and then reports will present the data broken into these groups.
- The user may wish to provide different options for the customer. For instance, an option A using selfregulating heat tracers and an option B for constant power heat tracers. Setting up two groups named Option A and Option B will allow this to be done.





Pipe Dimensions – The Engine Room

The *Pipe / Tank Dimensions* screen is the engine room of Evolution. It is where the user enters the details of each pipe to be temperature maintained, heat raised or each tank to be heated.


The *Pipe Groups* are listed on the left and the user can select a group to display the pipe or tank data for that group.

sup References	Pipe Dime			a designed	1000	10000		W Details
1 (2) (2) (2) (2)	C Distances	80.00	EB	23	125	CHEER IS		Succession in which the succession of the succes
and the second se		10					COURS IN	
Two Ten Bet	and it is not the					10304	ALC: NOT THE	Charles and Print and
-	1.0461	1012	- 8	5.6	H		1.24	1 144 Miles
	121	181.7				- 14	1.6.4	1 100 ITAL
	1 48	136.2	- 2	- 11.6				144 19525-7
10 million (1997)	1. 1. 1. 1. 1. 1.	100.2		-34			- 26.2	8 14N MOGRE
Fam The Paul	4.1803	1.12	- 15	- 114	14	- 10	41.0	148 (Files)
·	1. 4001					- 10	- EVE	1 INC. 17100
	ACC	10.0	1.2				8.4	3 108 20420
	LA.1997	181					- 11.4	A UNI DESIGN
a', fang filaa	inter all interests	1.00	- 6	-15		- 2	100	
*	18 185 1	199.2	- 8			. 175		1.116
	17 M.T.	- 23		184			134	ALL ADDRESS OF THE OWNER
the second se	11.185.11			- 84				Liz mizio
and the second se	1.0.1403	100.2		15.6			- 10.5	1.111 47201
Netter Sold, Not	1.8.468	10.2			- 5	-	- 24	1.100 MINO
	12-14.1465.10	1.04	- 6	114		- 45	5.5	A LAS LIGHT
	3.854	- 254	- 5	-18.5		- 6	- 24-	10 200
		26.2		10.5		- 10	364	
	设设。	100		-35			- 35	8 100 MPAN
	1.0.100.0			-154				118 8262
	Life Decisi	1.114		1.11.4			- 16.2	1446 RESIDE
	0 20	10.0		-85		-	- 24	1 11N 101411
	10.000	104	-			- 15	344	8 1.94 articl
	AR DRIGHT	- 23		126.6				1.126 #3511
	LH DROF			- 24				
	1010034	10.4				- 25	- 14	8 158 Wildow
	1-29-147-20	184			- 3		34	1.126
	10.1216	- 21-2		- 55			- 63	8 141 Middle
	1.00		-	2.5		100	343	1.10. 4700
12	DRO	100	1.2				-	
		100 4						


When a line item of pipe data is added or edited Evolution performs numerous calculations to determine the best cable solution according to the user's selections. Evolution calculates for all possible heaters and selects the most appropriate in terms of safety and cost.

Tank Designer

The *Tank Designer* provides a simple intuitive screen to enable the user to enter the required information to calculate a tank design.



There are many different styles of tanks to choose from in order to perform your design.



Manual Heater Selection

When Evolution selects the most appropriate cable, it determines a solution for all cables selected in the Heater Selections section of the enquiry. All these solutions can be viewed by double-clicking the heater selection field. The user can override Evolution's selection and choose a different cable.

	JPRESST.	and in sector	and the later of	, may a service of the	
1 and 1	President, S. (1998), 2007. Internet Partnershild, 1992 (1997)	the internet of	14 Canad at April 1995	A.S. Server how	2
-		The second s	E Marine Aut	*	1
	ZPILLI CT	CONTRACTOR	-		
2	August Automatics and and	Contraction of the local division of the loc	Contract of Care And I	11.2	×.
-		+ + +	-	and the second second	
	21542 <t< td=""><td>Colds Interview</td><td>- Antonio and</td><td>at any second second</td><td></td></t<>	Colds Interview	- Antonio and	at any second second	
200	Pencing Region (1998), 1811, Security Conference on Automation Conference on Automation	No. Common Page 1	and the set of the set	Jan Constitute	4
		to more the	2 400 m	1,002 mental 3,0	
	407062-01	- Alexandra	Contra Local	- Constant	
	Instal Install Induit	the fragment of	and a	Hard Street Street	4
		* ****	2 4000		

The user may wish to make a manual selection for a number of reasons.

For every cable shown in the Full Heater Selection screen Evolution has determined the cost per metre of pipe, the maximum pipe temperature, performed stabilised design* calculations and assessed if any additional temperature control is required.

Cable Properties		Heating Solution						
Mor Everyond *C	85	Output at All m	26.9	Tabatsed Des	φ.	~		
Max Wetnetand *C	85	ford Rate In/m	1.008	Callie Selected		1		
Min. Bunding mittl. Fadua mittl.	30	Abumum Pipe +C	.51	10.000	v			

* stabilised design - see page 12





Maximum Pipe Temperature

Evolution can also generate a graph showing the intersection where the maximum pipe temperature occurs for each individual line item.

Pipe R	eferenc	e (ABC	1	
cash cristing and	-			-
ur-			/	
-	/	_		_
>		-		-
-		-	\sim	-
	1			-
20	30		50	- 60
		and prime prime		***

Data Import Wizard

The *Data Import Wizard* allows data to be imported directly into Evolution. Data can be imported from most Pipe Design Management Systems (PDMS) or from Excel compatible spread sheets.

	1 1		1.1.4	10.	1.1 *	1
1 1 1		lete 1	140	F	_	
Partie Partie St			ing the	t mul		
140.1						
(1) 日		104	- 1			
00000		100	- 15	9 1		
100				4		
				3-1		
(a) a				2-1		
1997.0			- 12-	3		
		100				
10.14		100	1	1		
140.0 10 140.0 10		100				
100.0	1	104	- 08			
100 10		58	- 5	3 1		
100100	1.0	104		2-2		
1409 K		100				
		descents	- 6-			
- 182 - 192		RA.		1 1		
223 3		58				
101-0-	-0	- 22 -	- 12-	4		
150 B			- 11	4		
10.5		N	14			

The order and format of the data is irrelevant as the *Data Import Wizard* validates and arranges the imported data for you.

Once imported, Evolution automatically performs all calculations and product selections.

Inputting line item data manually is the single biggest drain on resource in the design process. Importing data saves all this time, and eliminates data input error.

Pipe Dimensions – The Engine Room

	-		STREET, STREET, ST	10.00	10.35	6	How Have		
1.00		140,004	(County)	100.00	1000	10000	Distant I		
20	-	<u> </u>	Z	C	2	- C	ç		
				8	- E			5 - 1 I	
R66 1			14	3	10	10	5	1	
21-		f	3	P	A	2 · · · ·		2	
2110 1 Kiel 1	_		14. 	10	10	1		-	
		<u> </u>		ç	-E		(<u> </u>	
00		Q	<u>6</u>	fa	-2	- G	<u> </u>		
C-8 - 3		A	14	141	14	£	-	1	
Ka I		f	2	1	-	14	2	2	
201			×	12	10	P			
20-1		· · · · ·	<u>c</u> —	ç	· 2 ·	10	(
10.00		a .	<u>s</u>	<u></u>		5		5	
King 1		é	30	10	100	B	}		
Vir 4	_		9	N	1.	fa:			
		-							
		100	Sec. 2						and stole in
-		2 march					Service 1	1	a designed as a second

Mass Updates Wizard

The *Mass Updates Wizard* allows the user to update many properties of their design, or pipe dimension data, in a single action.

Enquiry design parameters often change between quotation and order placement. For example the effect of increasing or

the is passed build a real to the	CONTRACTOR OF THE
N. DESCRIPTION	
1 401	-
1000	10
11411	-
1 MIT	-
11411	1
P.M.F	12
1.201	12
8 46/9	18
8,46.4	8
THE MENT	14
ALCARCE.	
MOMOR.	1. K
-10.240(3.4	al.
9,900	1
# 14610	14
1 (MR N	
1 STANK	18
to 1 them for levines	100
	identitati and a second

reducing thermal insulation thickness, *Mass Updates Wizard* enables these changes to be realised in just a few minutes, significantly reducing the time spent on quotations and the commitments of an essential resource.

Pipe Transfer Wizard

The *Pipe Transfer Wizard* is used to transfer pipe and tank data from one Pipe Group to another. If the user enters many lines of data into a single group, then decides to split this into a

number of groups, the *Pipe Transfer Wizard* allows this to be done.

This can also work in reverse when the user has a number of groups and wishes to consolidate the pipe line item data into fewer groups.

The *Copy* button allows the pipe data to be copied instead of moved from one group to another and the cut button allows many lines to be removed in one operation.



Bill of Material

Evolution compiles a *Bill of Material* according to the user's product and cable selections. Evolution collates product descriptions, the user's cost prices, the customer's selling prices according to the enquiry *Selling Price Structure* and determines the margin for the products.

Evolution then displays the *Bill of Material* screen. This screen shows each separate product and the total quantity required for all groups. The function of this screen is for the user to adjust and check the selling prices to be applied for this enquiry.

ne rectu	1000000			-	1	100	411100	100	
+ Maharama			_		100		- 515-6	Contract of the local division of the local	10.00
(Call)	Parameteria, Phys. 16, 1664	-	_	11.1	- QHLA	10.1	1.48.0	144.1	-
and the second sec	and the second se			_	the second second	1.00		and the second se	. 11
the second se	· President rive, 174 res 2141, human		1.4	1.8	11,000.0	10.0	10,00,0	10.00175	
	* Promotion 200, [10716, [1071, 214000, 1	4			1,001.0	10114		21648.25	- 1
	· Autori, Generated	1.000		11.4	10.0	44.21	514.84	1.000.00	- 94
	2 Proceeding of the International States and the second		1100	4.8	1.000	_	184,217,82	192307-4	-94
	T APRIL BOT	14	- 1411	- 1.47	4.00.5	1.0		4.54.20	1.04
P. #15(4)	T The should be any following		175	41.75		100.00	10,84.45	14,412,00	84
A. (1814)	* Antonica in to avoid twelver the	144	- 107	- (4.15)	1,40.8		A,A,& H)	 P_Amind 	- 14
	I marinedanie, dwie 192 inch	1.4	1.1411	25.4	7,017.4	158	214,214 T	100,40101	1.04
	Press and being an and the being b		- 19	14.10	10444	10.0	1.00 h	4,04.4	- 14
a second	Transverting and the property	1.	- 10	11.14	10,044	21.6	100421116	10404016	-14
4 B428	a bid hard, much light but in 1	144	- 14	4.4		100	- 1653	1,047-10	64
a at-sur-	The a log specie doub	16		10.2	100	- 10.55	12014	1,1,011	- 11
1 april 1-0	President for diving 1144, house	17.	110	10	1000.0	1012	#P.1815	19621-16	- 14
4	+ Cornerst the	164		121.01	11.000	1.1.1.4	141-028-02	17,411.81	- 11
4 #411	Brandid, man Ada Ant. o. 1	164		10.00	100.0	C 404	1.24	1140111	- 4.4
rt Beri	Passing build, last	76		TAN	10.4A.B	1112	Dealers	11 years	- 14
11 875-1	· Party ing Co. Storage Sugger (inc.)	110	- 14	11.01	1.60.4	41.00	3,00,00	1,810,52	-14
il Belly	· now as Cr. Stock teach, for 1	114	4.0	10.00	9.00 8	1 400 Au	10.001 0	26.401.00	- 14
	· Petring it and - J and ppend	144	-	-	1.00.4	14.64	1. 1. A.A.A.	1,000,000	- 14
	"Past ing forms without passed.	1.6		17.91	1.000.10	. 404.04	1.44.10	* X.634 (%)	14
	Participation - Production	12	- 24	81.00	17.483.00	hard of	11.002	Marking	- 14
	The fully true is forth passed.	15	1.00	11.4	01.01.0	-	ad ma. It.	74,00.00	- 84
	There is shown in	1	-	104.40	1.100.0	1 140.40	\$1.40° B	10,100.00	
and the support of the support	the second second second second	100		-	_	-		-	-
N N N E	Jake State Jacks	- 1			1400.0		1010-00-00	10,00,00,00	12.4

The *Bill of Material* is the section in the enquiry where the user can view the results of the product selections made. The user is able to add additional Heat Trace Products. The products database also includes a number of miscellaneous items such as packing, shipping, engineering and documentation, which can be added to the *Bill of Material*.

Spares

The *Bill of Material* screen has input fields for the provision of up to three types of spares. Spares can be manually added, or calculated on a percentage basis of the total quantity of the product.

and read				-	1	100	411100	32	
				1.0	BORT		161	AL.1	and a
6 (POM10)	Parceptor, Orm. Distance			16.2	- UHUN	440.70	11,49,17	1014.3	- 11
a pre-station	· President rive, 174 re. 2181, history	0.1 m	1.18	10.8	11,000.0	100.00	10,08,01	16,01175	- 14
A DESCRIPTION OF	Property of the later, 1991, and the	8.4	176	4.0	1,140.00	\$1.10	4,64.0	71,68.25	- 11
4. Bullets	· Auton, Galarete	144	-	11.40	10.0	44.7	104.84	1.011.00	
1 217/82-17	Protocia di chia. Infereta gileti brame	0 0	1100	4.8	Stall at	-05071	184,3-7.50	100,007-00	11
1 31	TTAKKI, BM	- 1 ₄₄	- 1411	- 1.87	4,000.70	10.00	3.76.10	45.545.25	- 04
# #T1/5	The shore three three, to have to a		178	41.31	4,044	100.00	10.04.40	14,412,04	
P. Parkis	* Automation of the design transferrer into	4 44	- A.**	4.0	1,40.0	100	1,0,0,0,00	P_Amind	
1 04100-01	Tentinghamir. Owner 197 1444		1.2411	0.4	7,014	15 H	HARM T	101/40107	- 19
1 845-5	Descarated of a sing Parketers		- 19	14.00	10444	100.00	1,000.00	4,000.01	- 14
1 APRIL 1	Transferd in allers (10, 1996		100	11.0	10,044.4	216	100421116	1.404.00	- 14
4 Balls	A Did Date 2, manual Agent (and in-	1.00	140	4.4		100	146.5	1,047-68	
a straight	"Fring hope, specifier, divised	1.54		10.2	- File	- 40.00	120.4	1.1011	
a second	President day of the line of	E (T	110	10	1000.0	1012	#P.D# 25	-19C21-16	
4 44.0.	+ Gargering the	64	1.0	+1.0	10.000	1.1.4.4	81,08.40	17.yes #	- 10
4. #fat.	· Press Add, Street Add, Roll, M.	1.54	4.4	10.00	2,60.4	C 404	1120100	114/01/11	- 11
ra 8001	*Permatry but in deal	14	1.0	TAL	10.44.8	1112	24.20	11 years	
11 875.8	· Press and Ch. Storm Status, No. 1	1.0	- 14	11.0	1,62.4	41.00	1,000 m	1,101.02	- 10
il Belle	 how as 0, bucktone, to 1 	14	4.4	10.00	1.00.8	\$11.14	10,001.0	26,42110	- 14
· Press	· Pastrining in and - 1980 percent	144	100	44	4,001.4	14.68	1. 1. JUL-14	1,000,000	- 10
10 841000-	" Pass Putty forms will her passied."	194		15.00	1.000.00	- 808.0 6	1.1.1.1.1	· * XAM (9)	- 14
IN BRIDE	The first bas is directed	100	44	84,00	10,485.0	has-10	10,002.40	MANYN	- 04
- #11AB	The first true is in the second	444	1.40	11.0	01,000.00	100.000	and parage life	73, and 10	- 64
w But	There best in a	0.0	- 54	104.81	0,1014	147.48	\$1.50°-31	16,748-85	-04
15 5 5	E Las man in	2.0			2 Same A		1/1/2014	1,002	10.4



EVOLUTION – Enquiry Modelling




Bill of Material

Preview Products

The *Preview Products* button uses the features of the *Product Library* to display an image of each of the products listed in the *Bill of Material.*



With a few simple clicks, the user can navigate to view datasheets and product literature of the selected products. This further reduces the need for the user to have more than just basic product knowledge.



The *Bill of Material* can be compared to the user's current stock holding to determine if the user has enough stock to supply the products required.

of the local division of the local divisiono	All and the second	100				Sec.	and a		a second
STREET.	· Passes Lon, OKin, Dil, Inc.		181	- 32			1.14		1000
STRACT -	* Created Alers, 1787 8, 2200 Sci.		- #	1.1.4	. 4		1		
100000	" Properties (be, cowin, 2007, Bear		14				44		- 40
104	· Photomic Halant torry	14		1.1					1.1
PRACE.	Press Print Print Patrick 1991 Bush		1.100				114		-194
1. ·	T cardon indext	44	248	141	1.10		4.0		1 2 1 2 2
84.15	· No King Selas, Salasted	1.0	10				11		100
WATER A.	President Reputer, 40414, 2001; In		1.140	- 101	1.04	·	178		1.00
24.44	 Talapamori da Per olahur Scotterat 	14		+			14		
11-10031-12	· President Robins, 1980, 2001, 2019		540	1214	-14	1.18	31	. 10	110
and a	T Property at my, ship Barrade.								100
DOMESCI,	Presentia Errori, JPAcos, 2164, Bran		101			·	- 19		100
	 Und Law WC UPU Line Number Dom. 	14		- 1	. 4	1.1.1			
	Pring Tapp, wantidue, also roll	14				-	1 1	1.3	
4	Tod Said He, German Rosten Ross.	1.14	18		N		- 41		#0
0.6480	A Annual Re-	11	411		1	1	4.1		
	· Prevar Law EN, Gillione Hubber, In-	11	- 4						
141	 Pyla misering transati, head. 	44	++						11111
1011	I However Said Kin, Million and Addams, No.	1.	48				- 49		- 41
	· Due forg linese - 2 rolt pipese	14	- 8				14	1	
P1930	* Pue Arig Mous - Crub pipese.	41		1.1		- 11	1.11	1	1
	Takes here trees a titlet space	1.84							
1718	Part Party Street or Street stores	111	2.8	· •			10		100.00
101-047	A Creative pie, 20074, 2001, female		241	12	111		255	11	100

Evolution comes equipped with all the predefined reports required to satisfy everyone from the engineer and company accountant to the procurement officer and installer.

Bill of Material Reports

Bill of material reports are available both with and without unit pricing.

Bill of Material Summary

A summary of all products, quantities and selling prices but this report also includes 3D illustrations of the products.

Bill of Material List

A summary of all products, quantities and quotation selling prices.

and the second	-		-	perce.
-	and the second se	Chiefe .	and in	the second s
C Dates .				
1.4	the second se	1		
	Contract of the local division of the	1.1		
- 7			-	-
1.000		1111	10,000	1.00
Construction of the	Contraction of the second second	data		the second second
	(Martin Contraction)			
1 1000	Long K.	1111		
1 percent	ingridge and it was seen only	et et e	-	1000
1 Annual Content	Contraction of the Andrewson of the	et et e	1.00	the second s
1144	22 ····	111		_
	10 m		-	
19497	Carlo and and any other	100	10-10-1	1000
	ine a second second			Transf.
1 3 M 10 1	the set and the second rates of		A. A.	
1.000	service and in the service of			
1940	particity and the state of the	1913	100	
	the second secon			100
1.54	Concerning the Property of the	dit:		100
1.044		1821	241	
1.04		3E	扔	10.00
121				242
	the start has	:180)	121	
	the ball of			1 × m +
		귀문		0.00
1.048	(in spin)	110	97.74	100,000
	Shid haded		2.60	- united
18日	production (product		695	
	Section designed.			100
18.	Serverse (11 Part)	110	웃대	122
1.1.1.1				
120-	Differentiate in succession	12.73		1000
1.104	Contraction of the second second			1000
120-0	100 000 10 a	11.		
112	and the second s	312	2.11	-
1.100	the first state of the second state.		10.00	-
-	(Marca)	12.14		Acres 1
and the second		_		-



Bill of Material Spares

A report on the quantity of spares calculated according to the user's selections for each pipe group.

terre erri 1	and a second sec		-	
T Lat.	Prim.	2-11	641	1
-	and the second sec		151	100
	100.00			-
1.7.000	the state of the local state of the state of	0.457	7.94	-
- beinter	Contraction of the state of the	1411		- mark
Charles -	1013 H + 10 101 H		3.5	_
	And in the second second second	0.07	10,000	
1 Decision	The local and in the second	1.1	1760	-
- Territoria	Charlen of the second state	dübb		-
			-	_
Contraction of the	CALCULATE IN COLUMN 2 IN COLUM		1.441	-
1 Back	The second second second second second	100		-
1 Sector		ditte:		_
1.1446.	THE R. P. LEWIS CO., NAME AND ADDRESS OF	0.4		
1.664	lowing the international			1.4
1 3 M 10 1	The set is a manufacture of a set		1.4	-
	paral to it mineration.			365.0
10001	period by it more course.	dit:	11 M.A	1000
1.04	Sectors and in the sector of	- 10 -	12.413	1000
1 27	Supervised and Supervised and		소문	-22
7 S	Distance of the second second	332		1.000
	Station (see Second 1)	-15	1052	-
120	partial second for	- 12		1000
	Seation ()		181	- 10
138-	The second secon	312	125	-11
100-		-121-	4.52	
100-				
110	The second se	16	725	100
	String of Street	455-		- 23
1.40	Contraction of the second s	16		- 22
	State of the local state of the		192	
5 Sei	Service of the Lorentee of Concerning of Con		2.54	
	Service in the service of the servic			1000
124	2000-00-000-000-000	H.		100
1128-	3 m. m. mont 10 m.	- 10-	-85	
552	State of the local division of the local div	181-		223
110	The lot wide or summer list. "We	3E	9.10	- 12
	Condition .	1815	23)	
t. Berlint	No. of Concession, Name	귀문		12413



Bill of Material List by Group

Similar to the above report but this report is broken down to give an individual *Bill of Material* for each pipe group.

-	Paulat	Chan Latter	-	illean Ma
۹.	second.	Concession (2010), 1201, franklig Recognition methods Widtep: 200	•	
•	arides ct.	Transisting Takes, 80601, 2000 in prind, Narrospindle Maturial Biarbay Latte	-	
•	mance	Countral da Materia (Mr. Synamic Representation metalentet Replace) and	-	
-	10102-0	ation have, 100%, 10%, New dealers have	•	-
	18.865	Revaluation 43 for Milled Threadward Califies	. 94	
۰.	WENG .	Cont Your ME, Salvoria, Hutelan, Book, Mu. 2	1.00	
۰.	8852	Port Seal NR, URSIDIA Rabbar Sont, Ro. 1	1.79	
۰.	3810	Private Long MA. Statutes Bulline . M. R	. 74	
٠	8810	Protect Total Will Millions Rubbon, Mil. 7	1.04	
	and the second s	Plants Gascill, Ro 1	1.00	1.1
	investion in the second	Phases Mancing St. 1	15	1.1
Ð.,	ante:	Place Unit M. Ro. 1	1.00	
١÷	1000	Accepted Net	- Fa	1.4
Ρ.,	1911	The resurbed to examp level	1.10	- 49
	*****	Prominance throad in 2 companies to	1.74	1.1
	PTION	Page Training Strainer 1 stath pipetwork	14	
۰.	and the second s	Page Trang in spil - Writeh Japanese	1.00	
	****	The Take II and - 21 and Jackson	1.00	- 4
π.	arment .	Forma Tases, FOF, Dise-off	100	
	MA	Transien allere	- 104	
	BT10, 6-9417	ST'S Millione Brokest, Billio inder 178gt	1.64	- 44

HEAT VEADO

Ten Print 16.14 X12 Fee 2 01

EVOLUTION – Enquiry Modelling



Summary Reports

Installation Summary

This summary provides an estimate of the installation time required to install all the products required by pipe group.

Pipe Size Summary

A summary of each size of pipe and the total length of pipe for each group.


Insulation Summary

A summary of thermal requirements of the project.

insulation requirements for each pipe size by group. This report can be used to determine the insulation

Heater Summary

A summary of the range of heating cables required for the enquiry, showing the type and quantity for each group.



	Groupt				feature	1.0	
inalit.	Praner Internetion	Subscripted.	inter .		1 fills	116	
0.	114085-01	Presidentiale, Union, 2014, tenend, thermalistic preparation fracting Calor		2,8	13	- 974	
3	OPEND-CE	President Marco, 1720 vs. 2014, histoitel, Demographic property of trading Casia	м.	34	- 2		
	Sectors	Previolity Life 23Min, 2017, broket, have space- inequality mediag Carts	M	74	-2	- 49	
	SHOWERS	President Scher, 2004, 2007, Institut, Networkship, Stepping Ref President Calife		1953	- 2	2524	
20	40390.01	VDC1 Prestdap Register, CNVv. 2004, Institut, M. 2018 2 Interrogradie sergected Heating Calify					
	0070530-01	Providence Color, 1999/00, 2009, tradict thereaded to complete Provide Color.	w.	383	1	0.001	
1	WILEND-CT	President Cide, 404 in, 2004, preside, thereinsteets computer throating Cable		1104	1	200	
1	39/2.12-CF	Presented Life, 37Win, 202V. Involuti, freemoplantic preside that Presiding California		2001	1	9122	
.0	19/0224	Failure Super, Nillion, 2017, Mater Resched Heating Cable		6	- 1	1.00	
11	SPIELEA	Parlian Lane, 300 Nr. 2057, Midd reacted Hading Cole	۰.	- 1871	- 1	242	
0	APREST A	Patilak II.an, Writes, 2017, Metal relation Heating Calls		- 1942	- 4	200	
	307533-A	Failbrin T. and, 630/ks. 2507. Minut resorted Holding Calify		22	- 1	860	
10	75/023-A	Fe/Exter Super, 75//ms, 2007, Matel described Heating, Kiele		4105		0002	
19	TroMit:	Territoriation of the Michael Wasafred, Cables	TA.	2.28	1.1	. 453	
12	30612	Kind Casi KR, Straume Publier Sold, http://	EA.	- 21	15	- 360	
12	1013	(Feel Into 10 Statute Latter Field, No. 3	+A.	111	- 10.	3.01	
11	0913	Points Seaf 101, Silaura Politik, Nil. 1	±.Α,		17	: (85	
10	1993)	Prove Coal KI, Marin's Hubber, Ho. 3	T.A.	. 30	- 16	nan:	
22	P001	Phases David XX, No. 1	EA.	21		140	
- 21	PCD	Whether Gloved Kill, No. 3	+4	10	. 4	263	
12	PG55	Plants Discription No. 8	EA.	. 67	-16	410	
28	DAT	August Day	tA.	36	30	7900	
-97	Pac	Pipe marting ballats, Deal	24	38	10	2003	
73	PP SCUT	Pipe Fining Street, -= 2 Just pipework	EA.	08	- 6	400	
- 201	PP (DH)	Part Force Manager's such produced	84		1	300	
100	PT 1710	Pipe Faces Things on TO call apprends	TA.	1.22		143	
11	PTLEO	Plant Forms Manage on 28 mills separate	LA.	22	1	1116	
0.0	#1w15	Fung fern Uper atterne Creat	LA.	0.3	26	2010	
34	P Delle	Forty has Pro. Thread	84	13	14	00	

Page 83

EVOLUTION – Enquiry Modelling



Product Datasheet and Certification

Product Datasheets - allows a copy of all datasheets for the products listed in the *Bill of Material* to be printed.

If in the enquiry selections the user selected specific product approvals then a similar report can be produced covering all certificates according to the products in the bill of material.

6	sira
A DECEMBER OF	igotomit.
HIS.	
* Frightman	enteringen og som en som e Ter en som en Ter en som en
	1231

FSS	225°C
e - admand consultance a supplementance	FallSafe Super
BPC report temperature of your investor or architecture, automatic measurements p ² 0	Page paule is part to concern a rel (Court a supplicit court of a rel court of court
¥	
An year and the second	Anna and Anna anna a
CONTRACTOR FRAMEWORK SAFE	
The restored strategies and register as a subject to the strategies and register as a subject to the strategies and strategies and strategies of the strategies and strategies and strategies of the strategies and strategies and strategies of the strategies and strategies and strategies and and strategies and strategies and strategies and s	Million Contraction
LAT VERYOR	The second second


And and a standard standard and a standard standard and a standard standard and a standard stan	And Married To	in such segle wir a generative of an annual seg	ingen herr birte
reason after	1.	het e	100
dephile). 35156.	101	35	
The law and the law and	245	we -	40.46
STORE & BRANCHER	100	100	n =
the status may asking the	1010	105	4 8
to an units an	345	100	12 44
	mairie	des l'estat les	
FLIT SHEAT AN AND AD	TABLE A	date	1000000
No. 1 (No. 1) No. 1 No. 1 No. 1 Amilian Andrea No	R AZ REZ		


Technical Reports


Maximum Pipe Temperature Graphs

This report shows the point at which the heat loss of the pipe is equal to the maximum output of the cable at 110% of the voltage.

This report is available in three formats: 8 per page, 2 per page and 1 per page.









Temperature Control

On this report all pipe line items are expressed in terms of temperature and temperature control requirements. It can be seen at a glance which lines stabilise at a safe temperature and those lines requiring to be controlled to ensure temperature safety.



Technical Calculations

A detailed technical report showing circuit information such as in-rush current, run current, duty and heater requirements for each pipe line item on the enquiry split into pipe groups.

Technical data can also be exported to an Excel spread sheet.

	2000							1	2			
	1 min fr	101	Contract of the local division of the local					1.2.5	· · ·			
10		2.5		N	-	1.1			1.1	20		31.23
		10.0	-					-	1.00	_		-
	-					- 41	1	122				- A - A
		211					1. 100.000	104	100			
2							101000-011	194	10.00			
ē	-					1.00	2.772.5	- 22	100			1
-	- 222			- 2 -		- 5-	-	100	100		- 2	
	- 200				- 2-	- 2-	Contraction of the local division of the loc	100				
e		- C			- 2-	- 2 -	1.0000	- 62			- 2	
E	-	1					and interact of				- 2	
£	-	14					and the second second	1000				- 1 - 1
	-						11.245.000	1044	100			
÷ .							11000	104	100			
6 C -	-					- 61	1.000	100				
	-			- 2 -				- 22				
	-			- 21				100			- 2	
÷ -	- 22	- C		- 2 -	- 2-	- 2-		100			- 2	
	-				- 2 -	10.0	12879-0	100			- 2	
	-			- 2 -			100000	1000				
e	1000	- C		- 5-	191	1.0	10.000.000	100	100			
£	-					- 6.1	10000	-	100			C (C
	-	100				- 60	10.000	-	100			
	-					1.81	4.104.001		100			
	1000	100				- 10	The Photo P	100	100			
	-	P		- 2.		1.0	10.000	- 22	100.0		- 2	
£				- 21	- 21	- 21	and the second second	122	100			
	-			- 5-	- 21 -	- 2 -	the second second	100				
	100	- C		- 2 -		- 2-	Linkson					
	-	S			- H-		10.000	-	- ER - 1			
	-	- C					1.	122	1000			

Technical Calculations Temperature Maintenance

R	*****	1	-	#	14	=		1	1	12	TE.	100		12.	100	10		
		1	1		m			-		-	191	-				-	. #2	-
х.	4013	805	-	- 78	.0	12.1	PENNINCE:	1.0.0	181	1,000	8.078	11.5	8.542	12.7	106.2	17.8	101.0	11
2	ANO	108	46	18	20	31.6	318/56/12/01	16.5	UPT	1848	1.087	30.8	3,000	5.8	\$8.7	24.8	104.8	4
	100	200	1.0	10	28	21.2	21916422 CR	81	101	1,000	1.009	10.0	0.542	·	100.0	10.4	192.8	1.
6	ARCE .	296	- 19	-	28	31.8	INVECT.	36.0	SPT.	1.010	3 (60)	76.6	8.440	16.6	-	14.0	141.0	1
	Ab.3	- 19		10	28	12.8	ETF1480-CT	11.0	197	1.000	8.008	- 17.8	8.19	- 11	16.1	1.7	181.8	
6	ARCS.	146	N	28	10	11.8	10 M 10 CT	19.0	143	1.00	6.00	10.0	9.498	3.2	18.2	16.1	1068	8.
e	and a	1.00	84		10	16.2	INNERCE.	3.5	196	1.000	6.000	16.5	0.142	2.4	10.1	34.4	182.6	21
	A8/3	251	15	-	78	83	1015612-08	26.5	101	1,012	3.603	20.3	4.547	16.8	16.4	48.8	160.8	2.
£	APD .	10		10	10	11.0	ERSING CT	14.8	107	1.000	1,000	12.6	9.08		96.7	3.0	181.8	
	AICN.	100		20		15.4	TWEFFCT	307	MPT.	1.08	6.010	PL 8	8.147	6.7	18.8	47.8	182.8	3.
11	ARCH	100	104	18	30	84.7	49582-0	1912	1445	4,034	1.408	16.7	4,109	24.8	194.3	1064	40.8	5.
w	ALC:N	788		10		27.9	PENIZER	111.1	1PT	1.837	8.784	18.8	9.167	1.1	14.9	18.5	181.8	1
n	40015	100	10	39	10	34.9	481582-07	26.5	197	1.68	1,001	343	4.109	344	13.9	114.0	61.5	1
11	ADCH .	1.00	115		1.0	2.0	ARE SHE CT	100	101	1,00	1,000		8100	19.8	16.7	193.5	10.0	
	ALC 19	110	- 44	-26		11.8	10150-12103	16.0	44.0	1.000	6.008	8.8	8100	2.8	34.0	49.8	118.8	
ï	ARCM.	200	100	- 18	1.00	81.7	481182.02	1 89.5	100	1214	1.408	3.7	8.535	215	121.0	126.4	41.8	- 51
	MOCH	110	10	38	3	21.8	THE MALE CT	123	UPT	1,221	LUN	33	0.142	4.3	16.0	14.3	100.8	3.
÷	NICH		-	1.2	- 10	34.9	49100 CT	83	101	1.188	1.001	38.8	8.1.19	14.8	111.0	111.8	80.8	- 11
	48798	200	449		11	2.8	481502-01	38.2	SPT	1,200	1.016	17.8	4.129	18.8	144.9	934	45.5	41
÷	AND	1.00	10.	100		11.0	20F1A12-CT	19.0	101	1.000	1.009	10.0	8.00	2.9	4.4	12.5	128.8	
11	AUCH	100		100		15.4	1010612-03	10.0	197	1.108	8.052	84	8.549	6.1	10.0	12.4	190.4	3.
in.	100120	1.000	14	100		14.9	ant tab.cz	1.000	101	1.000	1.001	38.5	8.108	144	172.0	114.8	41.6	- 14
	ARCE	216	105			21.8	BE SUD CT	28.3	MPT	1,286	1.018	37.8	8108	14.8	164.0	1011.0	88.8	4
	ARC 21	1.94	10	10		11.0	APPROPRIATE N	1.8.0	594	1,000	8.008	81.7	10.000	12	11.0	12.5	ULK	
-		-			-			-			_	-				-		





Notes

EVOLUTION – The Complete Design Tool



Notes

Page 87

EVOLUTION – The Complete Design Tool



A Handbook of Industrial Electric Heat Tracing



Heat Trace Limited, Mere's Edge, Chester Road, Helsby, Frodsham, Cheshire, WA6 0DJ, England. Tel: +44 (0)1928 726 451 Fax: +44 (0)1928 727 846 www.heat-trace.com HTL INDHB Jan14