

# **MTS-2001 Appendix B**

# **Frequency of**

# **Maintenance Tests**

# **MAINTENANCE**

# **TESTING**

# **SPECIFICATIONS**

**FOR ELECTRICAL POWER  
DISTRIBUTION EQUIPMENT  
AND SYSTEMS**



**InterNational Electrical  
Testing Association Inc.**  
Quality Since 1972

© Copyright 2001

InterNational Electrical Testing Association

PO Box 687, 106 Stone Street

Morrison, CO 80465

Voice: 303.697.8441 Facismile: 303.697.8431

Email: [neta@netaworld.org](mailto:neta@netaworld.org) • Web: [www.netaworld.org](http://www.netaworld.org)

# **2001**

# Frequency of Maintenance Tests

## Appendix B from MTS-01

### *NETA Maintenance Testing Specifications for Electrical Power Distribution Equipment and Systems*

NETA recognizes that the ideal maintenance program is reliability-based, unique to each plant and to each piece of equipment. In the absence of this information and in response to requests for a maintenance timetable, NETA's Standards Review Council presents the following time-based maintenance schedule and matrix.

One should contact a NETA Full-Member company for a reliability-based evaluation.

The following matrix is to be used in conjunction with NETA's Frequency of Maintenance Tests table. Application of the matrix is recognized as a guide only.

Specific condition, criticality, and reliability must be determined to correctly apply the matrix. Application of the matrix, along with the culmination of historical testing data and trending, should provide a quality electrical preventive maintenance program.

MAINTENANCE FREQUENCY MATRIX				
		EQUIPMENT CONDITION		
		POOR	AVERAGE	GOOD
EQUIPMENT RELIABILITY REQUIREMENT	LOW	1.0	2.0	2.5
	MEDIUM	0.50	1.0	1.5
	HIGH	0.25	0.50	0.75



MTS-2001

InterNational Electrical Testing Association

# Inspections and Tests

(Frequency in Months)

## Multiplier for Inspections and Tests

(Multiply Value by Matrix)

Section	Description	Visual	Visual & Mechanical	Visual & Mechanical & Electrical
<b>7.1</b>	Switchgear & Switchboard Assemblies	12	12	24
<b>7.2</b>	Transformers			
<b>7.2.1.1</b>	Small Dry-Type Transformers	2	12	36
<b>7.2.1.2</b>	Large Dry-Type Transformers	1	12	24
<b>7.2.2</b>	Liquid-Filled Transformers	1	12	24
	Sampling	-	-	12
<b>7.3</b>	Cables			
<b>7.3.2</b>	Low-Voltage Cables	2	12	36
<b>7.3.3</b>	Medium- and High-Voltage Cables	2	12	36
<b>7.4</b>	Metal-Enclosed Busways	2	12	24
	Infrared Only	-	-	12
<b>7.5</b>	Switches			
<b>7.5.1.1</b>	Low-Voltage Air Switches	2	12	36
<b>7.5.1.2</b>	Medium-Voltage Metal-Enclosed Switches	-	12	24
<b>7.5.1.3</b>	Medium- and High-Voltage Open Switches	1	12	24
<b>7.5.2</b>	Medium-Voltage Oil Switches	1	12	24
<b>7.5.3</b>	Medium-Voltage Vacuum Switches	1	12	24
<b>7.5.4</b>	Medium-Voltage SF <sub>6</sub> Switches	1	12	24
<b>7.5.5</b>	Cutouts	12	24	24
<b>7.6</b>	Circuit Breakers			
<b>7.6.1.1</b>	Low-Voltage Insulated-Case/Molded-Case CB	1	12	36
<b>7.6.1.2</b>	Low-Voltage Power CB	1	12	36
<b>7.6.1.3</b>	Medium-Voltage Air CB	1	12	36
<b>7.6.2.1</b>	Medium-Voltage Oil CB	1	12	36
	Sampling	-	-	12
<b>7.6.2.2</b>	High-Voltage Oil CB	1	12	12
	Sampling	-	-	12
<b>7.6.3.1</b>	Medium-Voltage Vacuum CB	1	12	24
<b>7.6.4.1</b>	Extra-High-Voltage SF <sub>6</sub>	1	12	12
<b>7.7</b>	Circuit Switchers	1	12	12
<b>7.8</b>	Network Protectors	12	12	24



MTS-2001

InterNational Electrical Testing Association

**Inspections and Tests**  
(Frequency in Months)  
**Multiplier for Inspections and Tests**  
(Multiply Value by Matrix)

Section	Description	Visual	Visual & Mechanical	Visual & Mechanical & Electrical
<b>7.9</b>	Protective Relays			
	Electromechanical	1	12	12
	Electronic	1	12	12
<b>7.10</b>	Instrument Transformers	12	12	36
<b>7.11</b>	Metering Devices	12	12	36
<b>7.12</b>	Regulating Apparatus			
<b>7.12.1.1</b>	Step-Voltage Regulators	1	12	24
	Sample Liquid	-	-	12
<b>7.12.1.2</b>	Induction Regulators	12	12	24
<b>7.12.2</b>	Current Regulators	1	12	24
<b>7.12.3</b>	Load-Tap-changers	1	12	24
	Sample Liquid	-	-	12
<b>7.13</b>	Grounding Systems	2	12	24
<b>7.14</b>	Ground-Fault Protection Systems	2	12	12
<b>7.15</b>	Rotating Machinery			
<b>7.15.1</b>	AC Motors	1	12	24
<b>7.15.2</b>	DC Motors	1	12	24
<b>7.15.3</b>	AC Generators	1	12	24
<b>7.15.4</b>	DC Generators	1	12	24
<b>7.16</b>	Motor Control			
<b>7.16.1.1</b>	Low-Voltage Motor Starters	2	12	24
<b>7.16.1.2</b>	Medium-Voltage Motor Starters	2	12	24
<b>7.16.2.1</b>	Low-Voltage Motor Control Centers	2	12	24
<b>7.16.2.2</b>	Medium-Voltage Motor Control Centers	2	12	24
<b>7.17</b>	Adjustable Speed Drive Systems	1	12	24
<b>7.18</b>	Direct-Current Systems			
<b>7.18.1</b>	Batteries	1	12	12
<b>7.18.2</b>	Battery Chargers	1	12	12
<b>7.18.3</b>	Rectifiers	1	12	24



**Inspections and Tests**  
(Frequency in Months)  
**Multiplier for Inspections and Tests**  
(Multiply Value by Matrix)

Section	Description	Visual	Visual & Mechanical	Visual & Mechanical & Electrical
<b>7.19</b>	Surge Arresters			
<b>7.19.1</b>	Low-Voltage Devices	2	12	24
<b>7.19.2</b>	Medium- and High-Voltage Devices	2	12	24
<b>7.20</b>	Capacitors and Reactors			
<b>7.20.1</b>	Capacitors	1	12	12
<b>7.20.2</b>	Capacitor Control Devices	1	12	12
<b>7.20.3.1</b>	Reactors - Dry-Type	2	12	24
<b>7.20.3.2</b>	Reactors - Liquid-Filled	1	12	24
	Sampling	-	-	12
<b>7.21</b>	Outdoor Bus Structures	1	12	36
<b>7.22</b>	Emergency Systems			
<b>7.22.1</b>	Engine Generator	1	2	12
	Functional Testing	-	-	2
<b>7.22.2</b>	Uninterruptible Power Systems	1	12	12
	Functional Testing	-	-	2
<b>7.22.3</b>	Automatic Transformer Switches	1	12	12
	Functional Testing	-	-	2
<b>7.23</b>	Telemetry/Pilot Wire SCADA	1	12	12
<b>7.24</b>	Automatic Circuit Reclosers and Line Sectionalizers			
<b>7.24.1</b>	Automatic Circuit Reclosers, Oil/Vacuum	1	12	24
	Sample	-	-	12
<b>7.24.2</b>	Automatic Line Sectionalizers, Oil	1	12	24
	Sample	-	-	12
<b>7.27</b>	EMF Testing	12	12	12

