

REPORT ID: **16227.00.T35.RP1**

---

## Niagara Region Wind Farm – Turbine T35 IEC 61400-11 Edition 3.0 Measurement Report

---

Prepared for:


**1021702 B.C. Ltd**  
as general partner for and on behalf of FWRN LP

Prepared by:

A. Munro

---

**Allan Munro, B.A.Sc.**



---

**Payam Ashtiani, B.A.Sc., P.Eng.**

03 November 2017 – Revision #1



## Revision History

Revision Number	Description	Date
1	Issued Edition 3.0 test report	03.11.2017

**This report in its entirety, including appendices contains 74 pages.**

## Statement Qualifications and Limitations

This report was prepared by Aercoustics Engineering Limited in accordance with International Standard IEC 61400-11 (Edition 3.0, released 2012-11), “Wind turbine generator systems – Part 11: Acoustic noise measurement techniques”. This report is specific only to the Wind Turbine identified in this report.

Aercoustics Engineering Limited shall not be responsible for any events or circumstances that may have occurred since the date on which the Wind Turbine was tested and/or this report was prepared, or for any inaccuracies contained in information that was provided to Aercoustics Engineering Limited. Further, Aercoustics Engineering Limited agrees that this report represents test data analysed as per the above described standard for the specific Wind Turbine described in this report, but Aercoustics Engineering Limited makes no other representations with respect to this report or any part thereof.

Any use which a third party makes of this report, or any reliance on or decisions to be made based on it, are the responsibility of such third parties. Aercoustics Engineering Limited accepts no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions based on this report.

Any use of this report is subject to this Statement of Qualifications and Limitations. Any damages arising from improper use of this report or parts thereof shall be borne by the party making such use.

This Statement of Qualifications and Limitations is attached to and forms part of this report.

## Table of Contents

<b>Revision History</b>	<b>2</b>
<b>Statement Qualifications and Limitations</b>	<b>2</b>
<b>List of Appendices</b>	<b>6</b>
<b>1 Introduction</b>	<b>8</b>
<b>2 Wind Turbine Information</b>	<b>8</b>
2.1 Wind turbine equipment specific information.....	8
2.2 Wind Turbine Location.....	9
<b>3 Measurement Details</b>	<b>10</b>
3.1 Measurement Equipment.....	10
3.1.1 Acoustic Measurement Equipment.....	10
3.1.2 Meteorological Equipment.....	10
3.2 Measurement Setup.....	10
3.2.1 Microphone Placement.....	10
3.2.2 Double Windscreen Setup.....	11
3.3 Measurement Schedule.....	11
3.4 Meteorological Conditions.....	11
3.5 Turbine operational information.....	11
<b>4 Measurement Results</b>	<b>12</b>
4.1 Deviations from IEC-61400-11 Edition 3.0.....	12
4.2 Special Notes & Considerations.....	12
4.3 Analysis Details.....	12
4.3.1 Double Windscreen Adjustment.....	12
4.3.2 Wind Speed Correction.....	12
4.4 Type B uncertainties.....	12
4.5 Sound Pressure Level Measurements.....	13
4.6 Sound Power Level of Turbine.....	14
4.7 Tonality Analysis.....	14
<b>5 Closure</b>	<b>15</b>
<b>6 References</b>	<b>15</b>

## List of Figures

Figure A.01 – Site plan.....	Appendix A
Figure A.02 – Site photos .....	Appendix A
Figure B.01 – Power Curve.....	Appendix B
Figure B.02 – Rotor RPM vs. Wind Speed.....	Appendix B
Figure C.01 – Plot of overall measurement data pairs at Position 1 (Turbine ON &Background).....	Appendix C
Figure C.02 – Plot of measured total noise vs electrical power output.....	Appendix C
Figure C.03 - Plot of power curve relative to nacelle anemometer and 10m anemometer.....	Appendix C
Figure C.04 - Plot of rotor RPM vs. electrical power output.....	Appendix C
Figure C.05 – Plot of sound pressure spectrum in 1/3 Octave at 8.5 m/s.....	Appendix C
Figure C.06 – Plot of sound pressure spectrum in 1/3 Octave at 9 m/s.....	Appendix C
Figure C.07 – Plot of sound pressure spectrum in 1/3 Octave at 9.5 m/s.....	Appendix C
Figure C.08 – Plot of sound pressure spectrum in 1/3 Octave at 10 m/s.....	Appendix C
Figure C.09 – Plot of sound pressure spectrum in 1/3 Octave at 10.5 m/s.....	Appendix C
Figure C.10 – Plot of sound pressure spectrum in 1/3 Octave at 11 m/s.....	Appendix C
Figure C.11 – Plot of sound pressure spectrum in 1/3 Octave at 11.5 m/s.....	Appendix C
Figure C.12 – Plot of sound pressure spectrum in 1/3 Octave at 12 m/s.....	Appendix C
Figure C.13 – Plot of sound pressure spectrum in 1/3 Octave at 12.5 m/s.....	Appendix C
Figure C.14 – Plot of sound pressure spectrum in 1/3 Octave at 13 m/s.....	Appendix C
Figure C.15 – Plot of sound pressure spectrum in 1/3 Octave at 13.5 m/s.....	Appendix C
Figure D.01 – Plot of narrow band spectra – Turbine ON vs. Background at 8.5m/s...Appendix D	Appendix D
Figure D.02 – Plot of narrow band spectra – Turbine ON vs. Background at 9 m/s...Appendix D	Appendix D
Figure D.03 – Plot of narrow band spectra – Turbine ON vs. Background at 9.5 m/s.....Appendix D	Appendix D
Figure D.04 – Plot of narrow band spectra – Turbine ON vs. Background at 10 m/s...Appendix D	Appendix D
Figure D.05 – Plot of narrow band spectra – Turbine ON vs. Background at 10.5 m/s...Appendix D	Appendix D
Figure D.06 – Plot of narrow band spectra – Turbine ON vs. Background at 11 m/s...Appendix D	Appendix D
Figure D.07 – Plot of narrow band spectra – Turbine ON vs. Background at 11.5 m/s...Appendix D	Appendix D
Figure D.08 – Plot of narrow band spectra – Turbine ON vs. Background at 12 m/s...Appendix D	Appendix D
Figure D.09 – Plot of narrow band spectra – Turbine ON vs. Background at 12.5 m/s...Appendix D	Appendix D
Figure D.10 – Plot of narrow band spectra – Turbine ON vs. Background at 13 m/s...Appendix D	Appendix D
Figure D.11 – Plot of narrow band spectra – Turbine ON vs. Background at 13.5 m/s...Appendix D	Appendix D

## List of Tables

Table 1 - Wind Turbine Details .....	8
Table 2 - Operating Details.....	8
Table 3 - Rotor Details.....	9
Table 4 - Gearbox Details.....	9
Table 5 - Generator Details .....	9
Table 6 - Acoustic Measurement Equipment.....	10
Table 7 – Meteorological Measurement Equipment.....	10
Table 8 - Measurement Schedule Summary .....	11
Table 9 - Summary of Type B uncertainties .....	13
Table 10 - Summary of Sound Pressure Level Measurements.....	13
Table 11 - LWA <sub>10m, K</sub> at each integer wind speed .....	14
Table 12 - Tonality Assessment Summary.....	15
Table C.01 – Detailed apparent sound power level data at hub height.....	Appendix C
Table C.02 – Detailed apparent sound power level data at 10m height.....	Appendix C
Table C.03 – Type B measurement uncertainty summary.....	Appendix C
Table C.04 – Detailed measurement uncertainty at hub height.....	Appendix C
Table D.01 – Tonal Assessment Table – 8.5 m/s.....	Appendix D
Table D.02 – Tonal Assessment Table – 9 m/s.....	Appendix D
Table D.03 – Tonal Assessment Table – 9.5 m/s.....	Appendix D
Table D.04 – Tonal Assessment Table – 10 m/s.....	Appendix D
Table D.05 – Tonal Assessment Table – 10.5 m/s.....	Appendix D
Table D.06 – Tonal Assessment Table – 11 m/s.....	Appendix D
Table D.07 – Tonal Assessment Table – 11.5 m/s.....	Appendix D
Table D.08 – Tonal Assessment Table – 12 m/s.....	Appendix D
Table D.09 – Tonal Assessment Table – 12.5 m/s.....	Appendix D
Table D.10 – Tonal Assessment Table – 13 m/s.....	Appendix D
Table D.11 – Tonal Assessment Table – 13.5 m/s.....	Appendix D
Table E.01 – Measurement data –Turbine ON.....	Appendix E
Table E.02 – Measurement data – Background.....	Appendix E

## List of Appendices

### Appendix A – Site Details

- Figure A.01 – Site plan
- Figure A.02 – Site photos

### Appendix B – Turbine Information

- Figure B.01 – Power curve
- Figure B.02 – Rotor RPM vs. wind speed

### Appendix C – Apparent Sound Power Level

- Figure C.01 – Plot of overall measurement data pairs at Position 1 (Turbine ON & Background)
- Figure C.02 – Plot of measured total noise vs electrical power output
- Figure C.03 - Plot of power curve relative to nacelle anemometer and 10m anemometer
- Figure C.04 - Plot of rotor RPM vs. electrical power output
- Figure C.05 – Plot of sound pressure spectrum in 1/3 Octave at 8.5 m/s
- Figure C.06 – Plot of sound pressure spectrum in 1/3 Octave at 9 m/s
- Figure C.07 – Plot of sound pressure spectrum in 1/3 Octave at 9.5 m/s
- Figure C.08 – Plot of sound pressure spectrum in 1/3 Octave at 10 m/s
- Figure C.09 – Plot of sound pressure spectrum in 1/3 Octave at 10.5 m/s
- Figure C.10 – Plot of sound pressure spectrum in 1/3 Octave at 11 m/s
- Figure C.11 – Plot of sound pressure spectrum in 1/3 Octave at 11.5 m/s
- Figure C.12 – Plot of sound pressure spectrum in 1/3 Octave at 12 m/s
- Figure C.13 – Plot of sound pressure spectrum in 1/3 Octave at 12.5 m/s
- Figure C.14 – Plot of sound pressure spectrum in 1/3 Octave at 13 m/s
- Figure C.15 – Plot of sound pressure spectrum in 1/3 Octave at 13.5 m/s
- Table C.01 – Detailed apparent sound power level data at hub height
- Table C.02 – Detailed apparent sound power level data at 10m height
- Table C.03 – Type B measurement uncertainty summary
- Table C.04 – Detailed measurement uncertainty at hub height

### Appendix D – Tonality Assessment

- Figure D.01 – Plot of narrow band spectra – Turbine ON vs. Background at 8.5 m/s
- Figure D.02 – Plot of narrow band spectra – Turbine ON vs. Background at 9 m/s
- Figure D.03 – Plot of narrow band spectra – Turbine ON vs. Background at 9.5 m/s
- Figure D.04 – Plot of narrow band spectra – Turbine ON vs. Background at 10 m/s
- Figure D.05 – Plot of narrow band spectra – Turbine ON vs. Background at 10.5 m/s
- Figure D.06 – Plot of narrow band spectra – Turbine ON vs. Background at 11 m/s
- Figure D.07 – Plot of narrow band spectra – Turbine ON vs. Background at 11.5 m/s
- Figure D.08 – Plot of narrow band spectra – Turbine ON vs. Background at 12 m/s
- Figure D.09 – Plot of narrow band spectra – Turbine ON vs. Background at 12.5 m/s
- Figure D.10 – Plot of narrow band spectra – Turbine ON vs. Background at 13 m/s
- Figure D.11 – Plot of narrow band spectra – Turbine ON vs. Background at 13.5 m/s
- Table D.01 – Tonal Assessment Table – 8.5 m/s
- Table D.02 – Tonal Assessment Table – 9 m/s
- Table D.03 – Tonal Assessment Table – 9.5 m/s
- Table D.04 – Tonal Assessment Table – 10 m/s
- Table D.05 – Tonal Assessment Table – 10.5 m/s

Table D.06 – Tonal Assessment Table – 11 m/s  
Table D.07 – Tonal Assessment Table – 11.5 m/s  
Table D.08 – Tonal Assessment Table – 12 m/s  
Table D.09 – Tonal Assessment Table – 12.5 m/s  
Table D.10 – Tonal Assessment Table – 13 m/s  
Table D.11 – Tonal Assessment Table – 13.5 m/s

Appendix E – Measurement Data

Table E.01 – Measurement data – Turbine ON  
Table E.02 – Measurement data – Background

## 1 Introduction

Aercoustics Engineering Limited (Aercoustics) was retained by 1021702 B.C. Ltd as a general partner for and behalf of Niagara Region Wind Farm (“FWRN”) to conduct an acoustic measurement of turbine T35 at the Niagara Region Wind Farm. The purpose of the measurement was to provide verification of the maximum noise emission of the turbine. The measurement was carried out in accordance with International Standard IEC 61400-11 (Edition 3.0, released 2012-11), “Wind turbine generator systems – Part 11: Acoustic noise measurement techniques”. This report is specific only to Turbine T35.

## 2 Wind Turbine Information

### 2.1 Wind turbine equipment specific information

Wind turbine specific equipment information for turbine T35 was provided by FWRN and is summarized in Tables 1 – 5.

Table 1 - Wind Turbine Details

Wind Turbine Details	
Manufacturer	Enercon
Model Number	E-101
Turbine ID	1011189

Table 2 - Operating Details

Operating Details	
Vertical or Horizontal axis wind turbine	Horizontal Axis
Upwind or downwind rotor	Upwind
Hub height	124 M
Horizontal distance from rotor centre to tower axis	6 M
Diameter of rotor	101 M
Tower type (lattice or tube)	Tube
Passive stall, active stall, or pitch controlled turbine	Pitch controlled
Constant or variable speed	Variable speed
Power curve	See Figure B.01
Rotational speed at each integer standardised wind speed	See Figure B.02 from measurement data
Rated power output	3000 kW
Control software version	Main control board version 5.20. Pitch software version 5.87



Table 3 - Rotor Details

Rotor Details	
Rotor control devices	Electric pitch
Presence of vortex generators, stall strips, serrated trailing edges	Tip bows (90-degree curve blade tips)
Blade type	Composite (Epoxy resin, Balsa)
Serial number	N/A
Number of blades	3

Table 4 - Gearbox Details

Gearbox Details	
Manufacturer	N/A
Model number	N/A
Serial number	N/A

Table 5 - Generator Details

Generator Details	
Manufacturer	Enercon
Model number	G3 annular generator
Serial number	N/A

## 2.2 Wind Turbine Location

The Niagara Wind Farm is located in the Townships of West Lincoln and Wainfleet and the Town of Lincoln within the Niagara Region and within Haldimand County in Southern Ontario. The coordinates of Turbine T35 are 17T 627164 Easting and 4764483 Northing. The area surrounding T35 is flat and consists primarily of farmland.

A general layout of the area in which the turbine is located is provided in the site plan (Figure A.01).

### 3 Measurement Details

#### 3.1 Measurement Equipment

##### 3.1.1 Acoustic Measurement Equipment

A summary of acoustic equipment utilized by Aercoustics for the measurement of turbine T35 is summarized in Table 6.

Table 6 - Acoustic Measurement Equipment

Equipment	Manufacturer Name & Model	Serial Number
Acoustic Data acquisition system	LMS SCADA Mobile	22163146
Microphone	B&K 4189	2625417
Pre-amplifier	B&K 2671	2614900
Acoustic calibrator	B&K 4231	3012380

Calibration of the measurement setup was carried out before and after Aercoustics set of measurements.

##### 3.1.2 Meteorological Equipment

Wind speed for Turbine ON was derived from the power curve (as per procedures outlined in IEC 61400-11). Wind direction for turbine ON measurements was utilized from the yaw angle output provided from the turbine system from turbine T35. Data for background measurements was obtained from a 10m high anemometer, which was placed as per guidelines outlined in IEC-61400-11.

The meteorological equipment is summarized in Table 7

Table 7 – Meteorological Measurement Equipment

Equipment	Manufacturer Name & Model	Serial Number
Anemometer	VAISALA WXT520	G4420002
Serial to Analog Converter	NOKEVAL 7470	A159784

#### 3.2 Measurement Setup

##### 3.2.1 Microphone Placement

The measurement microphone was setup 147m from the base of the turbine in 'Position 1', (i.e. downwind of the turbine, as per IEC 61400-11) at an elevation of 0m relative to the base of T35. The microphone was placed in the centre of a circular, acoustically reflective board.

During the measurement period only, data points for which the microphone was within 15 degrees of downwind from the turbine were used. The microphone position relative to downwind of the turbine was monitored via the yaw angle output provided from the turbine

system (discussed further in Section 3.5). During placement of the microphone the turbine was parked and the reference yaw angle for that measurement logged.

When measurements of T35 were taken, the surrounding land was cleared farmland. There were no nearby reflecting surfaces (houses, barns etc.); as such the influence from reflecting surfaces was considered to be negligible.

Photos of the measurement setup are provided in Figure A.02, Appendix A.

### 3.2.2 Double Windscreen Setup

A double windscreen setup was not utilized.

### 3.3 Measurement Schedule

Table 8 provides a summary of the test date and times. Data was logged in 10 second intervals for post-processing (as per the measurement standard).

Table 8 - Measurement Schedule Summary

Date	Test Type	Start Time	Finish time
October 19, 2017	Turbine ON	2:36pm	3:20pm
	Background	3:24pm	3:54pm
	Turbine ON	4:21pm	4:51pm
	Background	4:55pm	5:23pm
	Background	5:33pm	6:01pm

### 3.4 Meteorological Conditions

Detailed meteorological data relevant to the measurement is provided in Appendix E.

As previously mentioned, wind speed for Turbine ON was derived from T35's power curve (as per the standard), while wind direction was provided by T35's yaw position. Background data was obtained from an anemometer located 10m above ground level near T35.

Temperature and pressure readings during the measurement period were provided by the 10m anemometer, located near turbine T35 for the duration of Aercoustics measurements.

### 3.5 Turbine operational information

Output data from the turbine (Power, yaw, RPM, pitch angle, and nacelle wind speed) were obtained as analog output signals that were simultaneously acquired with the acoustic and anemometer measurement data using Aercoustics data acquisition system.

## 4 Measurement Results

### 4.1 Deviations from IEC-61400-11 Edition 3.0

Due to Electromagnetic Interference affecting microphone signal in the test cabling at 1/3 octave frequency bands at 8 kHz and above, the analysis excludes these affected frequency bands. As wind turbines do not generate sound of notable levels at high frequencies, this has a negligible impact on the conclusions of the analysis.

### 4.2 Special Notes & Considerations

There were no other turbines in the immediate vicinity of T35.

### 4.3 Analysis Details

The following section outlines analysis of the measurement data acquired for T35. The data presented is exclusive of transient events such as vehicle traffic, wildlife, air traffic etc. The site has been assessed to have a roughness length of 0.05m, representative of farmland with some vegetation.

#### 4.3.1 Double Windscreen Adjustment

As previously mentioned, no double wind screen was used, as such the measurement data did not require adjustment.

#### 4.3.2 Wind Speed Correction

The wind speed for each measurement data point for Turbine ON was derived through the power curve (as per Section 8.2.1.1 of IEC-61400-11). For data points during Turbine ON that were outside the allowed range of the power curve, the wind speed was derived from the nacelle anemometer wind speed (as specified in Section 8.2.1.2 of IEC-61400-11).

Background wind speed was derived utilizing data acquired with the 10m anemometer and normalizing the wind speed (as per Section 8.2.2 of IEC-61400-11).

### 4.4 Type B uncertainties

Type B uncertainties were obtained through interpretation of information provided in Annex C of IEC-61400-11, and instrument uncertainties obtained from the calibration certificate. A summary of Type B uncertainties is provided in Table 9, while detailed information (including data in 1/3 octave) is provided in Appendix C.

Table 9 - Summary of Type B uncertainties

Component	Typical (dB)	Used (dB)
Calibration	0.2	0.2
Board	0.3	0.3
Distance & direction	0.1	0.1
Air absorption	0	0
Weather conditions	0.5	0.5
Wind speed measured	0.7	0.7
Wind speed derived	0.2	0.2
Wind speed from power curve	0.2	0.2

#### 4.5 Sound Pressure Level Measurements

Sound pressure level measurements are summarized in Table 10. Detailed 1/3 Octave band spectrum data, respective uncertainties, and analysis plots are provided in Appendix C. A copy of the measurement data used for analysis is provided in Appendix E and includes meteorological and turbine operational data.

Table 10 - Summary of Sound Pressure Level Measurements

Wind Speed (m/s)	Turbine ON		Background		Turbine ON, Background adjusted $L_{eq}$ , (dBA)
	$L_{eq}$ , (dBA)	# of data pts	$L_{eq}$ , (dBA)	# of data pts	
8.5	51.1	10	40.9	41	50.7
9	51.2	10	41.7	50	50.7
9.5	52.1	10	42.2	31	51.6
10	52.7	20	43.3	41	52.2
10.5	53.0	10	43.9	28	52.5
11	53.8	16	45.3	36	53.2
11.5	54.0	10	46.8	31	53.2
12	55.0	35	46.4	27	54.4
12.5	54.7	21	46.9	24	53.9
13	54.7	25	47.9	12	53.7
13.5	55.1	28	47.8	10	54.2

#### 4.6 Sound Power Level of Turbine

The calculated sound power level of the turbine T35 (as per IEC 61400-11) is summarized in Table 11 (hub height) and Table 12 (10m height). Detailed 1/3 Octave band spectrum data and respective uncertainties are provided in Appendix C.

Table 11 -  $L_{WA, K}$  at each integer wind speed

Wind Speed (m/s)	Apparent $L_{WA}$ , (dBA)	Uncertainty (dB)
8.5	101.6	1.2
9	101.5	1.0
9.5	102.5	1.0
10	103.1	0.9
10.5	103.3	0.9
11	104.1	0.8
11.5	104.0	1.0
12	105.3	0.9
12.5	104.8	0.9
13	104.6	0.9
13.5	105.1	1.0

Table 12 -  $L_{WA 10m, K}$  at each integer wind speed

Wind Speed (m/s)	Apparent $L_{WA}$ , (dBA)	Uncertainty (dB)
6	101.6	0.9
7	103.3	0.9
8	104.8	0.8
9	105.0	0.9

#### 4.7 Tonality Analysis

The tonality analysis for Turbine T35 is summarized in Table 13, while plots of narrow band spectra at each wind speed are provided in Appendix D. The  $\Delta L_{tn}$  and  $\Delta L_a$  values reported represent the energy average of all data points with an identified tone that falls within the same frequency origin (as specified in Section 9.5.8 in IEC-61400-11).

The narrow band spectra provided in the plots represents an energy average of all data points in the given wind speed bin for both Turbine ON and Background.

Table 13 - Tonality Assessment Summary

Wind Speed (m/s)	Frequency (Hz)	Tonality, $\Delta L_{tn}$ (dB)	Tonal audibility, $\Delta L_a$ (dB)	FFT's with tones	Total # of FFT's	Presence (%)
10.5	116	-4.9	-2.9	10	10	100%
11	116	-4.4	-2.4	16	16	100%
11.5	116	-5.0	-3.0	10	10	100%

## 5 Closure

Measurements and analysis were carried on Turbine T35 of the Niagara Region Wind Farm as per International IEC 61400-11 (Edition 3.0, released 2012-11), “Wind turbine generator systems – Part 11: Acoustic noise measurement techniques”.

Should you have any questions or comments please do not hesitate to contact the authors of this report.

## 6 References

1. International Standard IEC 61400-11 (Edition 3.0, released 2012-11), “Wind turbine generator systems – Part 11: Acoustic noise measurement techniques”.

---

## Appendix A Site Details

---



**Legend**

- ◊ FRWN Turbine
- Non-Participating Receptor
- Participating Receptor
- Vacant Lot Receptor



16227.00.T35.RP1  
 Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Oct 30, 2017  
 Revision: 1

**Project Name**  
 Niagara Region Wind Farm - Turbine T35 - IEC61400-11 Edition 3.0


**Figure Title**  
 Site Plan

**Figure A.01**



Google earth  
 © 2017 Google



	16227.00.T35.RP1	<b>Project Name</b>
	Scale: NTS Drawn by: AM Reviewed by: PA Date: Oct 30, 2017 Revision: 1	Niagara Region Wind Farm - Turbine T35 - IEC61400-11 Edition 3.0
		<b>Figure Title</b>
		Site Photos
		<b>Figure A.02</b>

---

## Appendix B Turbine Information


---



### Power Curve E-101 3050 kW OM 3000 kW

**Rated Power Output:** 3050 kW  
**Operation Mode:** OM 3000 kW  
**Designation:** PC\_E-101\_3050\_kW\_OM\_3000\_kW\_calculated\_V1.0  
**Standard Air Density:** 1.225 kg/m<sup>3</sup>

Wind Speed v [m/s]	Power P [kW]	Power Coefficient Cp [-]	Thrust Coefficient Ct [-]
1	0	0.00	-
2	3	0.08	-
3	37	0.28	-
4	118	0.38	-
5	258	0.42	-
6	479	0.45	-
7	790	0.47	-
8	1200	0.48	-
9	1710	0.48	-
10	2320	0.47	-
11	2830	0.43	-
12	2975	0.35	-
13	3000	0.28	-
14	3000	0.22	-
15	3000	0.18	-
16	3000	0.15	-
17	3000	0.12	-
18	3000	0.10	-
19	3000	0.09	-
20	3000	0.08	-
21	3000	0.07	-
22	3000	0.06	-
23	3000	0.05	-
24	3000	0.04	-
25	3000	0.04	-



**Document Information:**

Author: Benjamin Ahrens  
 Department: WRD Power Performance  
 Date: 15.09.2015

© Copyright ENERCON GmbH. All rights reserved.

Document No: D0428175/0

16227.00.T35.RP1

Project Name




Scale: NTS  
 Drawn by: NT  
 Reviewed by: PA  
 Date: Nov 6, 2017  
 Revision: 1

Niagara Region Wind Farm - IEC 61400-11 Edition 3.0 - Turbine T35

Figure Title

Power Curve

**Figure B.01**




---

## Appendix C

### Apparent Sound Power Level

---



16227.00.T35.RP1

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Nov 3, 2017  
 Revision: 1


**Project Name**


Niagara Region Wind Farm - Turbine T35 - IEC61400-11 Edition 3.0

**Figure Title**


Plot of overall measurement data pairs at Position 1 (Turbine ON & Background)


**Figure C.01**




	<b>16227.00.T35.RP1</b>	<b>Project Name</b> Niagara Region Wind Farm - Turbine T35 - IEC61400-11 Edition 3.0	<b>Figure C.02</b>
	Scale: NTS Drawn by: AM Reviewed by: PA Date: Nov 3, 2017 Revision: 1	<b>Figure Title</b> Plot of measured total noise vs electrical power output	







8.5 m/s - Hub Height



16227.00.T35.RP1

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Nov 3, 2017  
 Revision: 1

Project Name


Niagara Region Wind Farm - Turbine T35 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 8.5 m/s

Figure C.05

9.0 m/s - Hub Height



16227.00.T35.RP1

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Nov 3, 2017  
 Revision: 1

Project Name


Niagara Region Wind Farm - Turbine T35 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 9 m/s

Figure C.06

9.5 m/s - Hub Height



16227.00.T35.RP1

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Nov 3, 2017  
 Revision: 1

Project Name


Niagara Region Wind Farm - Turbine T35 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 9.5 m/s

**Figure C.07**

10.0 m/s - Hub Height



16227.00.T35.RP1

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Nov 3, 2017  
 Revision: 1

**Project Name**


Niagara Region Wind Farm - Turbine T35 - IEC61400-11 Edition 3.0

**Figure Title**

Plot of sound pressure spectrum in 1/3 Octave at 10 m/s

**Figure C.08**

10.5 m/s - Hub Height



16227.00.T35.RP1

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Nov 3, 2017  
 Revision: 1

Project Name


Niagara Region Wind Farm - Turbine T35 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 10.5 m/s

Figure C.09

11.0 m/s - Hub Height



16227.00.T35.RP1

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Nov 3, 2017  
 Revision: 1

**Project Name**

Niagara Region Wind Farm - Turbine T35 - IEC61400-11 Edition 3.0


**Figure Title**

Plot of sound pressure spectrum in 1/3 Octave at 11 m/s

**Figure C.10**



11.5 m/s - Hub Height



16227.00.T35.RP1

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Nov 3, 2017  
 Revision: 1

**Project Name**


Niagara Region Wind Farm - Turbine T35 - IEC61400-11 Edition 3.0

**Figure Title**

Plot of sound pressure spectrum in 1/3 Octave at 11.5 m/s

**Figure C.11**

12.0 m/s - Hub Height



16227.00.T35.RP1

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Nov 3, 2017  
 Revision: 1

**Project Name**


Niagara Region Wind Farm - Turbine T35 - IEC61400-11 Edition 3.0

**Figure Title**

Plot of sound pressure spectrum in 1/3 Octave at 12 m/s

**Figure C.12**

### 12.5 m/s - Hub Height



16227.00.T35.RP1

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Nov 3, 2017  
 Revision: 1

**Project Name**


Niagara Region Wind Farm - Turbine T35 - IEC61400-11 Edition 3.0

**Figure Title**

Plot of sound pressure spectrum in 1/3 Octave at 12.5 m/s

**Figure C.13**

### 13.0 m/s - Hub Height



16227.00.T35.RP1

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Nov 3, 2017  
 Revision: 1

**Project Name**


Niagara Region Wind Farm - Turbine T35 - IEC61400-11 Edition 3.0

**Figure Title**

Plot of sound pressure spectrum in 1/3 Octave at 13 m/s

**Figure C.14**

13.5 m/s - Hub Height



16227.00.T35.RP1

Scale: NTS  
 Drawn by: AM  
 Reviewed by: PA  
 Date: Nov 3, 2017  
 Revision: 1

Project Name

Niagara Region Wind Farm - Turbine T35 - IEC61400-11 Edition 3.0

Figure Title

Plot of sound pressure spectrum in 1/3 Octave at 13.5 m/s

Figure C.15

## Table C.01 Detailed apparent sound power level data at hub height

Project: Niagara Wind Farm - Turbine T35 - IEC 61400-11 Measurement  
Report ID: 16227.00.T35.RP1

Page 1 of 2  
Created on: 11/3/2017

1/3 Octave values marked with brackets [ ] denote less than 3 dB difference between Turbine ON and Background

Overall levels marked with an asterisk \* denote 3 to 6 dB difference between Turbine ON and Background, while Overall values with less than 3 dB difference between Turbine ON and Background are not reported

Wind Bin (m/s)	Parameter	1/3 Octave Band (Hz)																					Overall						
		20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600	2000		2500	3150	4000	5000	6300	
8.5	Turbine ON (dBA)	11.2	15.4	19.8	23.8	26.7	27.2	30.8	35.9	35.0	35.3	38.5	42.2	40.9	40.1	39.5	38.1	37.7	38.0	38.1	38.5	38.1	38.5	38.0	36.8	35.4	30.4	51.1	
	Background (dBA)	9.7	13.9	15.6	19.4	21.4	22.1	23.6	22.7	23.2	22.9	24.2	26.2	26.0	25.9	27.5	28.3	30.1	30.5	31.1	30.9	30.6	29.6	28.2	26.4	24.7	21.8	40.9	
	Turbine ON - background adj (dBA)	[8.2]	[12.4]	17.8	21.8	25.1	25.7	29.9	35.7	34.7	35.1	38.4	42.1	40.8	39.9	39.3	37.6	36.8	37.1	37.2	37.6	37.3	37.9	37.5	36.4	35.0	29.8	50.7	
	Signal to noise (dB)	1.5	1.5	4.2	4.4	5.3	5.2	7.2	13.2	11.8	12.4	14.3	16.0	14.9	14.2	12.1	9.8	7.6	7.5	7.0	7.6	7.6	9.0	9.8	10.4	10.7	8.6	10.2	
	Uncertainty (dB)	4.6	4.0	3.0	2.6	1.9	2.0	1.3	1.3	1.3	1.2	1.2	1.0	1.1	1.0	1.1	1.1	1.2	1.1	1.2	1.2	1.2	1.3	1.3	1.3	1.4	1.3	1.2	
	PWL (dBA)	[59.1]	[63.3]	68.6	72.7	76.0	76.5	80.8	86.6	85.5	85.9	89.3	92.9	91.7	90.8	90.1	88.5	87.7	88.0	88.0	88.5	88.2	88.8	88.4	87.3	85.9	80.7	101.6	
9.0	Turbine ON (dBA)	18.0	20.2	20.6	25.0	25.9	29.8	31.1	35.0	34.6	36.8	39.8	41.3	41.7	40.7	41.7	40.1	38.9	38.4	38.3	38.0	36.6	36.3	34.3	32.1	29.5	28.2	51.2	
	Background (dBA)	11.6	14.9	16.2	19.1	22.9	24.8	23.5	22.8	26.6	23.6	24.7	26.8	26.9	26.8	28.4	29.0	30.5	31.1	31.8	31.6	31.1	30.6	29.2	27.4	25.5	22.5	41.7	
	Turbine ON - background adj (dBA)	16.9	18.6	18.7	23.8	22.9	28.2	30.2	34.8	33.9	36.6	39.7	41.1	41.6	40.5	41.4	39.7	38.3	37.5	37.2	36.8	35.1	34.9	32.7	30.3	27.2	26.8	50.7	
	Signal to noise (dB)	6.4	5.3	4.4	5.9	3.0	5.0	7.6	12.2	8.0	13.2	15.1	14.5	14.9	13.9	13.3	11.0	8.4	7.3	6.5	6.3	5.5	5.7	5.2	4.7	3.9	5.7	9.5	
	Uncertainty (dB)	4.1	3.2	2.2	1.8	2.1	1.3	1.2	1.1	1.3	1.0	0.9	0.8	0.8	0.9	0.9	1.0	1.0	1.0	1.0	1.0	1.1	1.3	1.4	1.4	1.7	1.2	1.0	
	PWL (dBA)	67.8	69.5	69.6	74.6	73.8	79.0	81.1	85.6	84.7	87.5	90.6	92.0	92.5	91.4	92.3	90.6	89.1	88.4	88.1	87.7	86.0	85.8	83.6	81.2	78.1	77.7	101.5	
9.5	Turbine ON (dBA)	16.5	17.8	22.2	23.8	29.1	29.9	32.7	34.9	36.3	36.9	39.9	42.1	42.5	41.9	42.1	40.5	39.6	39.0	39.2	38.9	38.4	38.1	37.3	35.5	32.7	30.7	52.1	
	Background (dBA)	12.7	16.5	16.3	19.5	20.8	22.5	23.8	22.8	24.5	23.7	24.9	26.5	27.2	26.6	28.8	29.7	31.1	31.7	32.4	32.2	32.0	31.4	30.2	28.7	26.8	23.6	42.2	
	Turbine ON - background adj (dBA)	14.2	[14.8]	20.9	21.8	28.4	29.0	32.2	34.6	36.0	36.7	39.7	42.0	42.4	41.8	41.9	40.1	39.0	38.1	38.2	37.9	37.3	37.1	36.4	34.5	31.4	29.8	51.6	
	Signal to noise (dB)	3.8	1.3	5.9	4.3	8.4	7.4	8.9	12.1	11.8	13.1	15.0	15.5	15.3	15.3	13.3	10.8	8.5	7.3	6.8	6.7	6.5	6.7	7.1	6.8	5.9	7.1	9.9	
	Uncertainty (dB)	3.9	4.4	2.3	1.8	1.5	1.2	1.4	1.0	1.1	0.9	0.8	0.8	0.8	0.9	0.9	1.0	1.0	1.0	1.0	1.0	1.1	1.3	1.5	1.6	1.5	1.1	1.0	
	PWL (dBA)	65.1	[65.7]	71.8	72.7	79.3	79.9	83.0	85.5	86.8	87.5	90.6	92.8	93.3	92.7	92.8	91.0	89.9	88.9	89.0	88.7	88.2	88.0	87.3	85.4	82.2	80.7	102.5	
10.0	Turbine ON (dBA)	15.7	19.6	20.2	24.9	28.0	30.3	32.2	34.9	37.3	37.4	40.7	43.2	43.3	42.3	42.7	41.4	40.1	39.7	39.8	39.4	38.7	38.7	37.7	36.0	33.7	31.7	52.7	
	Background (dBA)	18.8	22.8	24.1	26.0	24.3	24.2	24.9	24.1	24.3	23.4	25.5	27.7	28.1	29.2	30.2	30.4	31.6	32.3	33.3	33.0	32.9	32.5	31.5	30.1	28.0	24.6	43.3	
	Turbine ON - background adj (dBA)	[12.7]	[16.6]	[17.2]	[21.9]	25.6	29.1	31.3	34.5	37.1	37.2	40.5	43.1	43.2	42.1	42.5	41.0	39.4	38.8	38.7	38.3	37.3	37.5	36.5	34.7	32.3	30.7	52.2	
	Signal to noise (dB)	-3.1	-3.1	-3.9	-1.1	3.7	6.1	7.3	10.8	13.0	14.0	15.2	15.5	15.2	13.2	12.5	11.0	8.5	7.4	6.5	6.4	5.7	6.2	6.2	5.9	5.7	7.1	9.4	
	Uncertainty (dB)	4.4	3.8	3.1	2.7	2.0	1.3	1.2	1.0	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.9	0.9	1.0	1.0	1.1	1.3	1.3	1.4	1.4	1.1	0.9
	PWL (dBA)	[63.6]	[67.5]	[68]	[72.8]	76.4	79.9	82.2	85.4	88.0	88.1	91.4	93.9	94.0	93.0	93.3	91.9	90.3	89.7	89.6	89.2	88.2	88.4	87.4	85.6	83.2	81.6	103.1	
10.5	Turbine ON (dBA)	17.9	19.3	21.2	25.7	27.6	31.1	30.4	34.4	40.6	37.7	40.7	43.3	43.1	42.5	43.0	41.8	40.7	39.8	40.0	39.5	38.8	38.6	37.8	36.5	34.4	32.7	53.0	
	Background (dBA)	17.9	21.5	24.3	23.6	23.8	23.7	25.0	24.0	24.9	24.4	25.7	27.3	28.2	28.1	30.0	30.9	32.6	33.1	34.1	33.9	33.8	33.6	32.6	31.2	28.9	25.4	43.9	
	Turbine ON - background adj (dBA)	[14.9]	[16.3]	[18.2]	[22.7]	25.3	30.2	28.9	34.0	40.5	37.5	40.6	43.2	42.9	42.3	42.8	41.4	40.0	38.7	38.8	38.1	37.2	37.0	36.3	35.0	33.0	31.9	52.5	
	Signal to noise (dB)	-0.1	-2.2	-3.2	2.1	3.8	7.4	5.4	10.4	15.7	13.3	15.1	16.0	14.9	14.4	13.1	10.9	8.1	6.7	6.0	5.6	5.1	5.0	5.2	5.3	5.5	7.3	9.1	
	Uncertainty (dB)	5.1	3.9	3.3	2.5	2.0	1.8	1.4	0.9	1.0	1.0	0.7	0.7	0.8	0.8	0.9	0.9	0.9	0.9	1.0	1.0	1.1	1.3	1.4	1.5	1.5	1.1	0.9	
	PWL (dBA)	[65.8]	[67.2]	[69]	[73.6]	76.1	81.1	79.8	84.9	91.3	88.4	91.5	94.1	93.8	93.2	93.7	92.3	90.9	89.6	89.6	89.0	88.1	87.9	87.1	85.9	83.9	82.7	103.3	
11.0	Turbine ON (dBA)	17.6	23.3	24.4	27.6	29.6	31.4	32.8	34.6	40.2	38.0	40.9	44.2	43.7	43.4	43.9	42.3	41.4	40.8	40.9	40.4	40.2	40.3	39.4	37.7	35.6	34.5	53.8	
	Background (dBA)	18.3	19.3	22.0	24.0	23.1	23.7	25.3	25.0	25.3	24.4	26.4	28.8	29.7	29.5	31.2	32.1	34.0	34.8	35.4	35.3	35.5	35.4	34.5	33.0	30.9	27.3	45.3	
	Turbine ON - background adj (dBA)	[14.6]	21.1	[21.4]	25.1	28.5	30.6	32.0	34.1	40.0	37.8	40.7	44.0	43.5	43.3	43.7	41.8	40.6	39.5	39.5	38.8	38.4	38.5	37.7	36.0	33.8	33.6	53.2	
	Signal to noise (dB)	-0.7	4.0	2.4	3.6	6.5	7.7	7.5	9.7	14.9	13.6	14.5	15.4	14.0	13.9	12.7	10.1	7.5	6.0	5.5	5.1	4.7	4.8	5.0	4.8	4.6	7.2	8.5	
	Uncertainty (dB)	3.6	3.0	3.0	2.1	1.4	1.2	1.2	0.9	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.9	1.0	1.0	1.1	1.3	1.3	1.3	1.3	0.9	0.8	
	PWL (dBA)	[65.4]	72.0	[72.3]	76.0	79.4	81.4	82.8	85.0	90.9	88.7	91.6	94.9	94.4	94.1	94.6	92.7	91.5	90.4	90.4	89.7	89.3	89.4	88.6	86.9	84.6	84.5	104.1	
11.5	Turbine ON (dBA)	21.7	24.6	31.3	30.0	31.0	33.2	33.0	34.5	39.9	37.9	41.8	44.6	44.0	43.5	44.0	42.2	41.7	41.0	41.4	40.7	40.2	40.0	38.9	37.7	35.9	35.3	54.0	
	Background (dBA)	20.0	23.0	24.6	23.0	24.1	24.9	26.2	25.7	26.0	25.5	26.9	29.3	29.9	30.4	32.8	33.6	35.2	36.0	36.6	36.9	37.1	37.1	36.4	34.9	33.0	29.1	46.8	
	Turbine ON - background adj (dBA)	[18.7]	[21.6]	30.3	29.1	30.0	32.5	31.9	33.9	39.7	37.7	41.7	44.5	43.8	43.2	43.7	41.5	40.6	39.3	39.7	38.4	37.2	[37]	[35.9]	[34.7]	[32.9]	[34.1]	53.2	
	Signal to noise (dB)	1.6	1.6	6.7	7.0	6.9	8.3	6.7	8.8	13.9	12.4	14.9	15.3	14.1	13.1	11.2	8.5	6.5	5.0	4.8	3.8	3.0	2.9	2.5	2.8	2.9	6.1	7.2	
	Uncertainty (dB)	5.0	5.0	4.4	2.3	2.1	1.9	1.6	1.1	1.0	1.0	0.8	0.7	0.8	0.7	0.8	0.8	1.0	1.2	1.2	1.4	1.9	2.2	2.3	2.4	2.4	1.1	1.0	
	PWL (dBA)	[69.6]	[72.5]	81.2	79.9	80.9	83.4	82.8	84.7	90.6	88.6	92.6	95.3	94.7	94.1	94.6	92.4	91.5	90.2	90.6	89.3	88.0	[87.9]	[86.8]	[85.6]	[83.7]	84.9	104.0	

# Table C.01 Detailed apparent sound power level data at hub height

Project: Niagara Wind Farm - Turbine T35 - IEC 61400-11 Measurement

Report ID: 16227.00.T35.RP1

1/3 Octave values marked with brackets [ ] denote less than 3 dB difference between Turbine ON and Background

Overall levels marked with an asterisk \* denote 3 to 6 dB difference between Turbine ON and Background, while Overall values with less than 3 dB difference between Turbine ON and Background are not reported

Wind Bin (m/s)	Parameter	1/3 Octave Band (Hz)																					Overall					
		20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600	2000		2500	3150	4000	5000	6300
12.0	Turbine ON (dBA)	20.3	22.5	24.7	30.0	31.2	32.0	34.7	33.3	37.3	36.7	40.0	44.6	43.3	44.2	45.4	44.9	44.6	44.0	43.2	42.6	41.6	41.3	40.2	38.7	37.1	36.2	55.0
	Background (dBA)	16.5	19.9	21.5	20.6	22.5	23.9	25.8	25.5	26.8	25.1	26.6	29.1	29.6	29.9	32.3	33.2	34.7	35.6	36.1	36.7	36.8	36.9	35.9	34.4	32.4	28.9	46.4
	Turbine ON - background adj (dBA)	17.9	[19.5]	21.8	29.5	30.6	31.3	34.1	32.5	36.9	36.4	39.8	44.5	43.1	44.0	45.2	44.6	44.1	43.3	42.2	41.3	39.8	39.3	38.2	36.7	35.3	35.3	54.4
	Signal to noise (dB)	3.7	2.6	3.2	9.4	8.7	8.1	8.9	7.8	10.5	11.6	13.4	15.5	13.8	14.3	13.0	11.7	9.9	8.4	7.1	5.9	4.7	4.3	4.3	4.3	4.8	7.3	8.7
	Uncertainty (dB)	2.8	3.3	2.7	1.1	1.2	1.1	1.2	1.1	1.0	0.9	0.8	0.8	0.7	0.7	0.7	0.8	0.8	0.9	0.9	1.0	1.2	1.5	1.5	1.6	1.4	1.0	0.9
	PWL (dBA)	68.7	[70.4]	72.7	80.3	81.5	82.1	85.0	83.4	87.8	87.3	90.6	95.4	94.0	94.9	96.0	95.5	95.0	94.2	93.1	92.2	90.7	90.2	89.1	87.6	86.2	86.2	105.3
12.5	Turbine ON (dBA)	18.9	21.7	25.2	30.0	30.4	31.1	34.3	33.1	36.4	37.1	39.1	44.4	43.2	43.7	44.9	44.8	44.4	43.4	42.8	42.1	41.5	40.9	39.7	38.2	36.5	36.1	54.7
	Background (dBA)	20.3	23.8	25.6	27.4	25.8	26.2	27.3	26.6	27.4	26.3	28.2	29.6	30.4	30.7	32.4	33.3	35.0	35.6	36.4	36.9	37.1	37.4	36.4	35.1	33.0	29.3	46.9
	Turbine ON - background adj (dBA)	[15.9]	[18.7]	[22.2]	[27]	28.5	29.4	33.3	31.9	35.8	36.8	38.8	44.2	43.0	43.5	44.7	44.5	43.8	42.6	41.7	40.5	39.6	38.3	37.0	35.3	33.9	35.0	53.9
	Signal to noise (dB)	-1.4	-2.1	-0.4	2.6	4.6	4.9	7.0	6.5	9.0	10.9	11.0	14.8	12.8	13.1	12.5	11.5	9.4	7.8	6.4	5.1	4.4	3.5	3.3	3.1	3.5	6.7	7.8
	Uncertainty (dB)	3.6	3.5	3.1	2.7	1.7	1.3	1.3	1.2	1.0	1.0	0.7	0.8	0.7	0.7	0.7	0.7	0.8	0.8	0.9	1.0	1.2	1.7	1.8	1.9	1.7	1.0	0.9
	PWL (dBA)	[66.7]	[69.6]	[73.1]	[77.9]	79.4	80.3	84.2	82.8	86.7	87.6	89.6	95.1	93.9	94.4	95.6	95.4	94.7	93.4	92.5	91.4	90.5	89.2	87.8	86.2	84.8	85.9	104.8
13.0	Turbine ON (dBA)	21.6	23.9	28.6	31.4	30.9	30.7	33.0	33.6	37.1	35.9	39.4	44.1	43.1	43.9	45.1	44.7	44.2	43.6	43.0	42.0	41.4	40.8	39.4	37.7	36.0	35.9	54.7
	Background (dBA)	22.2	23.6	27.9	30.9	29.1	28.2	30.9	29.6	29.1	28.2	28.8	30.7	32.1	31.3	33.4	34.3	35.5	36.3	37.3	37.6	37.9	38.2	37.4	36.0	33.7	29.9	47.9
	Turbine ON - background adj (dBA)	[18.6]	[20.9]	[25.6]	[28.4]	[27.9]	[27.7]	[30]	31.4	36.4	35.1	39.0	43.9	42.7	43.6	44.8	44.3	43.6	42.7	41.7	40.1	38.9	[37.8]	[36.4]	[34.7]	[33]	34.6	53.7
	Signal to noise (dB)	-0.6	0.3	0.7	0.5	1.8	2.5	2.1	4.0	8.0	7.7	10.6	13.4	11.0	12.5	11.7	10.4	8.7	7.3	5.8	4.4	3.6	2.6	2.0	1.8	2.3	5.9	6.8
	Uncertainty (dB)	4.0	3.8	4.0	3.7	3.2	2.4	2.4	1.9	1.0	1.0	0.8	0.8	0.8	0.7	0.7	0.8	0.8	0.9	1.0	1.2	1.5	2.0	2.0	2.0	2.0	1.1	1.0
	PWL (dBA)	[69.5]	[71.8]	[76.4]	[79.3]	[78.8]	[78.6]	[80.8]	82.2	87.2	86.0	89.9	94.8	93.6	94.5	95.7	95.2	94.5	93.6	92.6	91.0	89.8	[88.7]	[87.3]	[85.6]	[83.9]	85.4	104.6
13.5	Turbine ON (dBA)	23.1	26.4	28.8	32.4	31.1	32.4	34.5	34.1	37.2	36.2	38.9	43.9	42.9	43.1	45.2	45.0	45.2	44.4	43.9	42.8	42.4	41.9	40.8	39.3	37.3	36.5	55.1
	Background (dBA)	20.1	22.6	29.6	26.7	26.3	26.7	26.5	27.2	29.6	28.0	29.1	30.5	31.8	31.8	33.3	34.9	36.4	36.3	37.4	37.5	37.7	37.9	37.4	36.2	33.9	30.3	47.8
	Turbine ON - background adj (dBA)	[20.1]	24.2	[25.8]	31.0	29.3	31.0	33.8	33.1	36.4	35.5	38.4	43.6	42.5	42.8	44.9	44.6	44.6	43.6	42.8	41.3	40.6	39.7	38.1	36.3	34.6	35.3	54.2
	Signal to noise (dB)	3.0	3.9	-0.7	5.7	4.8	5.6	8.0	6.9	7.6	8.2	9.8	13.4	11.1	11.4	11.9	10.1	8.8	8.0	6.5	5.3	4.7	4.0	3.4	3.1	3.4	6.2	7.3
	Uncertainty (dB)	4.1	3.8	4.8	1.7	1.6	1.4	1.2	1.1	1.1	1.0	0.8	0.8	0.8	0.7	0.7	0.8	0.8	0.9	1.0	1.1	1.2	1.6	1.9	2.2	2.0	1.1	1.0
	PWL (dBA)	[70.9]	75.0	[76.7]	81.9	80.2	81.9	84.7	84.0	87.3	86.4	89.3	94.5	93.4	93.7	95.8	95.5	95.4	94.5	93.6	92.2	91.5	90.6	89.0	87.2	85.5	86.2	105.1

# Table C.02 Detailed apparent sound power level data at 10m height

Project: Niagara Wind Farm - Turbine T35 - IEC 61400-11 Measurement

Report ID: 16227.00.T35.RP1

1/3 Octave values marked with brackets [ ] denote less than 3 dB difference between Turbine ON and Background

Overall levels marked with an asterisk \* denote 3 to 6 dB difference between Turbine ON and Background, while Overall values with less than 3 dB difference between Turbine ON and Background are not reported

Wind Bin (m/s)	Parameter	1/3 Octave Band (Hz)																				Overall						
		20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600		2000	2500	3150	4000	5000	6300
6.0	Turbine ON (dBA)	15.4	17.7	19.7	24.1	26.4	28.8	31.3	35.4	34.9	36.1	39.4	41.7	41.5	40.8	41.1	39.5	38.5	38.2	38.3	38.3	37.5	37.4	36.1	34.4	32.4	29.4	51.2
	Background (dBA)	10.9	14.0	15.6	18.9	21.7	23.4	23.4	22.9	25.2	23.3	24.5	26.4	26.5	26.3	27.9	28.6	30.4	30.9	31.4	31.2	30.8	30.0	28.6	27.0	25.1	22.2	41.3
	Turbine ON - background adj (dBA)	13.6	15.2	17.6	22.6	24.5	27.3	30.5	35.2	34.4	35.9	39.2	41.6	41.4	40.6	40.9	39.1	37.8	37.3	37.3	37.3	36.5	36.6	35.3	33.5	31.5	28.5	50.8
	Signal to noise (dB)	4.5	3.7	4.1	5.3	4.7	5.4	7.9	12.6	9.7	12.8	14.9	15.3	15.0	14.5	13.2	10.9	8.1	7.3	6.9	7.1	6.7	7.4	7.5	7.4	7.3	7.2	10.0
	Uncertainty (dB)	2.9	2.9	2.0	1.6	1.5	1.4	1.1	1.0	1.1	1.0	0.9	0.8	0.8	0.8	0.9	0.9	0.9	1.0	1.0	1.0	1.0	1.1	1.2	1.2	1.3	1.1	0.9
	PWL (dBA)	64.4	66.1	68.5	73.5	75.4	78.2	81.4	86.1	85.3	86.8	90.1	92.4	92.2	91.5	91.7	90.0	88.7	88.2	88.2	88.2	87.4	87.4	86.2	84.4	82.4	79.3	101.6
7.0	Turbine ON (dBA)	17.0	21.2	22.2	25.8	28.7	30.9	32.2	34.6	39.1	37.6	40.6	43.3	43.1	42.6	43.0	41.7	40.7	40.0	40.1	39.7	39.1	39.1	38.3	36.7	34.4	32.7	53.0
	Background (dBA)	18.3	21.5	23.4	24.8	23.8	23.9	24.8	24.3	24.9	23.9	25.9	28.0	28.6	28.9	30.4	31.1	32.7	33.4	34.2	34.1	34.1	33.9	32.9	31.4	29.4	25.8	44.2
	Turbine ON - background adj (dBA)	[14]	[18.2]	[19.2]	[22.8]	27.0	30.0	31.4	34.2	39.0	37.4	40.4	43.2	43.0	42.4	42.8	41.3	39.9	38.9	38.8	38.3	37.5	37.6	36.8	35.1	32.7	31.7	52.4
	Signal to noise (dB)	-1.3	-0.2	-1.2	1.0	4.9	7.0	7.4	10.4	14.2	13.7	14.7	15.3	14.5	13.7	12.6	10.6	8.0	6.6	5.9	5.6	5.1	5.3	5.4	5.2	5.0	6.9	8.9
	Uncertainty (dB)	3.2	3.0	2.4	2.1	1.4	1.1	1.1	0.9	0.9	0.8	0.7	0.7	0.7	0.7	0.8	0.8	0.9	0.9	1.0	1.0	1.1	1.3	1.3	1.3	1.3	1.1	0.9
	PWL (dBA)	[64.8]	[69.1]	[70]	[73.6]	77.9	80.9	82.2	85.1	89.8	88.3	91.3	94.0	93.9	93.3	93.7	92.2	90.8	89.8	89.7	89.2	88.4	88.5	87.7	86.0	83.6	82.6	103.3
8.0	Turbine ON (dBA)	20.0	22.9	26.5	29.6	30.9	31.9	34.4	33.7	37.9	37.4	40.3	44.4	43.5	43.8	44.8	44.2	43.7	43.0	42.5	41.9	41.1	40.9	39.8	38.4	36.6	35.7	54.6
	Background (dBA)	18.8	22.2	23.3	22.2	23.2	24.2	26.3	25.1	26.1	25.3	26.6	29.1	29.7	30.0	32.3	33.1	34.8	35.5	36.2	36.6	36.7	36.8	35.9	34.5	32.4	28.8	46.4
	Turbine ON - background adj (dBA)	[17]	[19.9]	23.7	28.8	30.0	31.1	33.7	33.1	37.6	37.1	40.1	44.3	43.4	43.7	44.6	43.8	43.1	42.1	41.4	40.4	39.2	38.7	37.6	36.1	34.6	34.7	53.9
	Signal to noise (dB)	1.2	0.7	3.2	7.5	7.7	7.7	8.1	8.6	11.8	12.1	13.7	15.4	13.8	13.9	12.5	11.0	8.9	7.5	6.3	5.4	4.4	4.1	3.9	3.9	4.2	6.9	8.2
	Uncertainty (dB)	2.8	2.8	2.6	1.1	1.1	1.0	1.0	0.9	0.9	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.9	1.0	1.1	1.4	1.5	1.5	1.4	1.0	0.8
	PWL (dBA)	[67.9]	[70.8]	74.6	79.6	80.9	82.0	84.5	83.9	88.5	88.0	91.0	95.2	94.2	94.5	95.5	94.7	94.0	93.0	92.3	91.3	90.1	89.6	88.5	87.0	85.4	85.6	104.8
9.0	Turbine ON (dBA)	22.4	24.8	28.3	31.7	30.8	31.7	33.6	33.7	36.9	35.8	39.0	44.0	43.0	43.6	45.2	45.0	44.8	44.0	43.5	42.5	42.0	41.5	40.3	38.8	36.9	36.2	54.9
	Background (dBA)	21.3	23.3	28.6	29.6	27.8	27.3	28.9	28.3	28.9	27.5	28.9	30.2	31.4	31.3	33.0	34.1	35.6	36.1	37.0	37.3	37.5	37.7	37.0	35.7	33.5	29.7	47.5
	Turbine ON - background adj (dBA)	[19.4]	[21.8]	[25.3]	[28.7]	27.8	29.7	31.8	32.2	36.2	35.1	38.6	43.9	42.7	43.4	44.9	44.6	44.2	43.3	42.4	41.0	40.1	39.1	37.5	35.8	34.2	35.1	54.1
	Signal to noise (dB)	1.2	1.5	-0.3	2.1	3.0	4.4	4.7	5.4	8.0	8.3	10.1	13.8	11.6	12.4	12.2	10.8	9.2	8.0	6.5	5.2	4.5	3.7	3.3	3.1	3.4	6.5	7.4
	Uncertainty (dB)	3.0	3.0	2.8	2.3	1.9	1.6	1.4	1.2	1.0	1.0	0.8	0.8	0.8	0.7	0.7	0.8	0.8	0.9	0.9	1.0	1.2	1.5	1.7	1.8	1.6	1.1	0.9
	PWL (dBA)	[70.3]	[72.7]	[76.2]	[79.6]	78.7	80.5	82.7	83.0	87.0	86.0	89.5	94.7	93.6	94.3	95.8	95.5	95.1	94.1	93.2	91.8	91.0	90.0	88.4	86.7	85.1	86.0	105.0



## Table C.03 Type B measurement uncertainty summary

Project: Niagar Wind Farm - Turbine T35 - IEC 61400-11 Measurement  
 Report ID: 16227.00.T35.RP1

Page 1 of 1  
 Created on: 11/3/2017

Overall Equipment Uncertainties		
	Typical values	Used values
Calibration	0.2 dB	0.2 dB
Board	0.3 dB	0.3 dB
Distance	0.1 dB	0.1 dB
Air absorption	0 dB	0 dB
Weather	0.5 dB	0.5 dB

1/3 Octave Band Uncertainties		
Frequency (Hz)	Microphone Uncertainty	Overall (including overall equipment Uncertainties)
20	0.8 dB	1 dB
25	0.8 dB	1 dB
31.5	0.5 dB	0.8 dB
40	0.5 dB	0.8 dB
50	0.5 dB	0.8 dB
63	0.5 dB	0.8 dB
80	0.5 dB	0.8 dB
100	0.5 dB	0.8 dB
125	0.5 dB	0.8 dB
160	0.5 dB	0.8 dB
200	0.3 dB	0.7 dB
250	0.3 dB	0.7 dB
315	0.3 dB	0.7 dB
400	0.3 dB	0.7 dB
500	0.3 dB	0.7 dB
630	0.3 dB	0.7 dB
800	0.3 dB	0.7 dB
1000	0.3 dB	0.7 dB
1250	0.3 dB	0.7 dB
1600	0.3 dB	0.7 dB
2000	0.3 dB	0.7 dB
2500	0.5 dB	0.8 dB
3150	0.5 dB	0.8 dB
4000	0.5 dB	0.8 dB
5000	0.5 dB	0.8 dB
6300	0.5 dB	0.8 dB
8000	0.5 dB	0.8 dB
10000	1.3 dB	1.4 dB

# Table C.04 Detailed measurement uncertainty at hub height

Project: Niagara Wind Farm - Turbine T35 - IEC 61400-11 Measurement  
 Report ID: 16227.00.T35.RP1

Wind Bin (m/s)	Parameter	Average Wind Speed	# of data points	Parameter	1/3 Octave Band (Hz)																				Overall									
					20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250	1600		2000	2500	3150	4000	5000	6300			
8.5	Turbine ON	8.57	10	Average (dBA)	12.2	16.1	19.9	24.0	26.5	27.6	30.9	35.8	34.9	35.5	38.7	42.0	41.1	40.2	39.9	38.4	37.9	38.0	38.2	38.4	37.9	38.2	37.4	36.1	34.5	30.1	51.1			
				Uncertainty A (dB)	1.4	1.1	1.3	1.1	0.7	0.8	0.3	0.6	0.7	0.5	0.7	0.4	0.5	0.5	0.5	0.5	0.4	0.3	0.4	0.4	0.4	0.4	0.5	0.4	0.5	0.6	0.5	0.7	0.5	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	
				Combined Uncertainty (dB)	1.7	1.5	1.5	1.3	1.1	1.2	0.9	1.0	1.1	1.0	1.0	1.0	1.0	0.8	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.9	1.0	1.0	1.1	0.9	0.9	
8.5	Background	8.48	41	Average (dBA)	9.6	13.9	15.6	19.4	21.3	22.0	23.6	22.7	23.1	22.9	24.2	26.2	26.0	25.9	27.4	28.3	30.1	30.5	31.1	30.9	30.5	29.5	28.2	26.4	24.6	21.8	40.9			
				Uncertainty A (dB)	1.5	1.5	1.1	0.9	0.6	0.5	0.5	0.4	0.3	0.3	0.3	0.3	0.3	0.3	0.4	0.4	0.4	0.4	0.5	0.5	0.6	0.6	0.7	0.8	0.8	0.8	0.6	0.5		
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	
				Combined Uncertainty (dB)	1.9	1.8	1.3	1.2	1.0	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.9	0.9	1.0	1.1	1.2	1.1	1.0	1.0	
9.0	Turbine ON	9.00	10	Average (dBA)	18.0	20.2	20.6	25.1	25.9	29.8	31.1	35.0	34.6	36.8	39.8	41.3	41.7	40.7	41.6	40.1	38.9	38.4	38.3	38.0	36.6	36.2	34.3	32.1	29.4	28.2	51.2			
				Uncertainty A (dB)	3.0	1.9	1.0	1.0	0.5	0.3	0.6	0.6	0.7	0.5	0.5	0.3	0.4	0.5	0.5	0.6	0.5	0.4	0.4	0.4	0.3	0.3	0.3	0.4	0.5	0.4	0.4	0.4	0.4	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	
				Combined Uncertainty (dB)	3.1	2.2	1.3	1.3	0.9	0.9	1.0	1.0	1.1	1.0	1.0	0.8	0.8	0.8	0.8	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.9	0.9	0.9	0.9	0.9	
9.0	Background	8.99	50	Average (dBA)	11.6	14.9	16.2	19.1	22.9	24.9	23.5	22.8	26.7	23.6	24.7	26.8	26.9	26.8	28.4	29.0	30.8	31.1	31.8	31.6	31.1	30.5	29.2	27.4	25.5	22.5	41.7			
				Uncertainty A (dB)	1.5	1.4	1.1	0.8	0.7	0.7	0.5	0.4	0.6	0.4	0.4	0.3	0.4	0.3	0.4	0.4	0.4	0.4	0.4	0.4	0.5	0.5	0.6	0.6	0.7	0.7	0.6	0.5		
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	
				Combined Uncertainty (dB)	1.8	1.8	1.3	1.1	1.0	1.0	1.0	0.9	1.0	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.9	1.0	1.1	1.1	1.0	0.9	
9.5	Turbine ON	9.52	10	Average (dBA)	16.5	17.8	22.3	23.7	29.2	29.9	32.8	34.9	36.3	36.9	39.9	42.1	42.6	42.0	42.1	40.5	39.7	39.0	39.2	38.9	38.5	38.2	37.4	35.6	32.8	30.8	52.1			
				Uncertainty A (dB)	2.0	1.7	1.6	0.7	1.1	0.6	0.9	0.5	0.3	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.6	0.5	0.4	0.4	0.4	0.4	0.4	0.4	0.5	0.7	0.9	1.0	0.7	0.3
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	
				Combined Uncertainty (dB)	2.2	2.0	1.8	1.1	1.4	1.0	1.2	0.9	1.0	0.9	1.0	0.9	0.8	0.8	0.8	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.8	1.0	1.2	1.3	1.1	0.9	0.9	
9.5	Background	9.52	31	Average (dBA)	12.8	16.6	16.3	19.5	20.7	22.5	23.8	22.8	24.4	23.7	24.9	26.5	27.2	26.6	28.8	29.7	31.1	31.7	32.4	32.2	32.0	31.4	30.3	28.8	26.9	23.6	42.2			
				Uncertainty A (dB)	1.5	1.8	1.3	0.9	0.5	0.5	0.6	0.5	0.5	0.6	0.4	0.5	0.4	0.5	0.4	0.5	0.5	0.5	0.5	0.5	0.5	0.6	0.6	0.7	0.8	0.8	0.7	0.6		
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	
				Combined Uncertainty (dB)	1.8	2.1	1.5	1.2	1.0	1.0	1.0	0.9	1.0	1.0	1.0	0.9	0.8	0.8	0.8	0.8	0.9	0.9	0.8	0.8	0.8	0.9	0.9	0.9	1.1	1.1	1.1	1.1	1.0	
10.0	Turbine ON	10.00	20	Average (dBA)	15.7	19.6	20.1	24.9	28.0	30.3	32.2	34.9	37.3	37.4	40.7	43.2	43.3	42.3	42.7	41.4	40.1	39.7	39.8	39.4	38.7	38.7	37.7	36.0	33.7	31.7	52.7			
				Uncertainty A (dB)	1.6	1.1	0.8	0.7	0.6	0.5	0.5	0.4	0.4	0.3	0.3	0.3	0.3	0.3	0.2	0.3	0.3	0.4	0.2	0.3	0.3	0.3	0.3	0.3	0.5	0.5	0.6	0.5	0.3	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	
				Combined Uncertainty (dB)	1.9	1.5	1.1	1.0	1.0	0.9	1.0	0.9	0.9	0.9	0.9	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.9	1.0	1.0	0.8	
10.0	Background	10.00	41	Average (dBA)	18.8	22.8	24.1	26.0	24.3	24.2	24.9	24.1	24.3	23.4	25.5	27.7	28.1	29.2	30.2	30.4	31.6	32.3	33.4	33.0	32.9	32.5	31.5	30.1	28.0	24.6	43.3			
				Uncertainty A (dB)	2.1	2.2	2.0	1.5	0.9	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.6	0.7	0.6	0.5	0.4	0.5	0.5	0.6	0.7	0.7	0.8	0.8	0.7	0.6		
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	
				Combined Uncertainty (dB)	2.3	2.4	2.2	1.7	1.2	1.0	1.0	1.0	0.9	0.9	0.9	0.9	0.9	0.8	0.9	1.0	0.9	0.8	0.8	0.8	0.8	0.9	0.9	1.0	1.1	1.1	1.1	1.1	1.0	
10.5	Turbine ON	10.45	10	Average (dBA)	18.0	18.9	20.9	25.6	27.4	31.1	30.1	34.4	40.6	37.7	40.7	43.2	43.0	42.4	42.9	41.7	40.6	39.6	39.9	39.4	38.7	38.4	37.6	36.4	34.3	32.6	52.9			
				Uncertainty A (dB)	2.3	1.4	1.1	0.7	0.8	1.4	0.7	0.5	0.7	0.6	0.4	0.3	0.3	0.3	0.3	0.4	0.6	0.7	0.4	0.4	0.4	0.4	0.4	0.4	0.5	0.6	0.7	0.8	0.5	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	
				Combined Uncertainty (dB)	2.5	1.7	1.3	1.1	1.1	1.6	1.1	0.9	1.1	1.0	0.8	0.8	0.8	0.8	0.8	0.9	0.8	0.9	1.0	0.8	0.8	0.8	0.7	0.7	0.8	0.9	1.0	1.1	0.9	
10.5	Background	10.53	28	Average (dBA)	17.9	21.5	24.4	23.5	23.8	23.7	25.0	24.9	24.5	25.7	27.2	28.2	28.0	30.0	30.9	32.7	33.2	34.1	34.0	33.8	33.7	32.7	31.2	29.0	25.5	43.9				
				Uncertainty A (dB)	2.2	2.3	2.2	1.4	0.9	0.6	0.6	0.7	0.6	0.5	0.5	0.4	0.5	0.5	0.4	0.5	0.6	0.5	0.6	0.7	0.7	0.7	0.8	1.0	1.0	1.1	1.0	0.8		
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	
				Combined Uncertainty (dB)	2.4	2.5	2.3	1.6	1.2	1.0	1.0	1.1	1.0	1.0	0.9	0.8	0.8	0.8	0.8	0.9	0.9	0.9	0.9	0.9	1.0	1.0	1.1	1.2	1.3	1.3	1.2	1.1	1.1	
11.0	Turbine ON	10.92	16	Average (dBA)	16.9	23.1	23.3	27.2	29.4	31.1	32.8	34.6	40.2	38.0	40.7	44.1	43.7	43.4	43.9	42.3	41.4	40.8	40.8	40.4	40.2	40.3	39.5	37.8	35.5	34.4	53.8			
				Uncertainty A (dB)	1.4	1.6	1.1	0.7	0.9	0.8	0.8	0.5	0.4	0.4	0.3	0.3	0.3	0.3	0.3	0.3	0.2	0.2	0.3	0.2	0.4	0.5	0.5	0.4	0.4	0.4	0.2	0.2		
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	
				Combined Uncertainty (dB)	1.8	1.9	1.3	1.1	1.2	1.1	1.1	0.9	0.9	0.9	0.9	0.9	0.9	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.9	0.9	0.9	0.8	0.8	
11.0	Background	10.96	36	Average (dBA)	18.1	19.0	21.8	24.1	23.0	23.6	25.2	24.9	25.2	24.3	26.3	28.																		

# Table C.04 Detailed measurement uncertainty at hub height

Project: Niagara Wind Farm - Turbine T35 - IEC 61400-11 Measurement


Report ID: 16227.00.T35.RP1


Wind Bin (m/s)	Parameter	Average Wind Speed	# of data points	Parameter	1/3 Octave Band (Hz)																			Overall									
					20	25	31.5	40	50	63	80	100	125	160	200	250	315	400	500	630	800	1000	1250		1600	2000	2500	3150	4000	5000	6300		
11.5	Turbine ON	11.52	10	Average (dBA)	21.9	24.7	31.7	30.1	31.1	33.3	33.0	34.5	39.9	37.9	41.9	44.6	44.0	43.5	44.0	42.2	41.7	41.0	41.5	40.7	40.2	40.0	38.9	37.7	35.9	35.3	54.1		
				Uncertainty A (dB)	2.2	2.1	3.5	1.7	1.5	1.5	1.0	0.6	0.6	0.5	0.4	0.3	0.3	0.2	0.3	0.3	0.3	0.3	0.4	0.4	0.3	0.4	0.6	0.6	0.7	0.7		0.2	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8		0.8	0.8
				Combined Uncertainty (dB)	2.4	2.3	3.6	1.9	1.7	1.7	1.3	1.0	1.0	0.9	0.8	0.7	0.8	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	1.0	1.0	1.0	1.0		0.8	
	Background	11.46	31	Average (dBA)	20.3	23.2	24.8	23.2	24.2	24.9	26.3	25.7	26.0	25.5	26.9	29.3	29.9	30.4	32.8	33.7	35.3	36.0	36.6	36.9	37.2	37.1	36.4	35.0	33.0	29.2	46.8		
				Uncertainty A (dB)	1.9	2.1	1.6	0.9	0.7	0.6	0.7	0.8	0.5	0.5	0.4	0.6	0.5	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.7	0.9	1.0	1.1	1.1	1.1		0.9	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8		0.8	
12.0	Turbine ON	12.01	35	Average (dBA)	20.2	22.5	24.5	30.0	31.2	32.0	34.8	33.3	37.2	36.7	39.9	44.6	43.3	44.2	45.4	44.9	44.6	44.0	43.2	42.6	41.6	41.3	40.2	38.7	37.1	36.2	55.1		
				Uncertainty A (dB)	1.1	0.9	0.8	0.5	0.7	0.5	0.7	0.5	0.4	0.3	0.3	0.3	0.2	0.2	0.2	0.3	0.3	0.3	0.3	0.2	0.2	0.3	0.3	0.4	0.4	0.4		0.4	0.2
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8		0.8	0.8
				Combined Uncertainty (dB)	1.5	1.4	1.1	0.9	1.1	1.0	1.0	0.9	0.9	0.9	0.9	0.9	0.7	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.9	0.9	0.9		0.9	0.8
	Background	12.05	27	Average (dBA)	16.1	19.6	21.2	20.4	22.3	23.8	25.7	25.4	26.9	25.1	26.6	29.1	29.5	29.9	32.3	33.1	34.6	35.5	36.1	36.7	36.8	36.9	35.8	34.4	32.3	28.9	46.3		
				Uncertainty A (dB)	1.6	1.8	1.9	0.9	0.7	0.6	0.6	0.9	0.9	0.6	0.5	0.6	0.6	0.6	0.5	0.6	0.6	0.6	0.7	0.6	0.7	0.8	0.9	0.9	1.0	1.0		0.9	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8		0.8	
12.5	Turbine ON	12.55	21	Average (dBA)	18.7	21.6	25.3	30.0	30.3	31.0	34.3	33.0	36.3	37.2	39.0	44.4	43.2	43.7	44.9	44.8	44.3	43.3	42.8	42.0	41.5	40.8	39.6	38.1	36.4	36.0	54.7		
				Uncertainty A (dB)	1.3	1.2	1.1	0.7	0.8	0.5	0.8	0.5	0.4	0.6	0.3	0.4	0.3	0.3	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.4	0.4	0.4	0.4	0.4		0.4	0.2
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8		0.8	0.8
				Combined Uncertainty (dB)	1.6	1.6	1.3	1.1	1.1	0.9	1.1	1.0	0.9	1.0	0.8	0.8	0.8	0.7	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.9	0.9		0.9	0.8
	Background	12.58	24	Average (dBA)	21.0	24.5	26.3	28.6	26.4	26.6	27.6	26.8	27.4	26.5	28.4	29.7	30.5	30.8	32.5	33.3	35.1	35.6	36.5	37.0	37.2	37.4	36.5	35.2	33.2	29.4	47.0		
				Uncertainty A (dB)	2.1	2.1	2.0	1.9	1.1	0.9	0.9	0.9	0.7	0.6	0.6	0.4	0.5	0.5	0.4	0.5	0.5	0.5	0.5	0.5	0.6	0.7	0.8	0.8	0.9	0.9		0.9	
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8		0.8	
13.0	Turbine ON	12.97	25	Average (dBA)	21.5	23.7	28.5	31.4	30.9	30.6	32.9	33.6	37.1	35.9	39.4	44.1	43.1	43.9	45.1	44.7	44.1	43.5	43.0	42.0	41.4	40.8	39.3	37.6	35.9	35.8	54.6		
				Uncertainty A (dB)	1.4	1.2	1.5	0.8	0.8	0.5	0.5	0.5	0.4	0.4	0.4	0.3	0.3	0.3	0.2	0.3	0.3	0.3	0.4	0.3	0.3	0.3	0.4	0.4	0.4	0.4		0.3	0.2
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8		0.8	0.8
				Combined Uncertainty (dB)	1.7	1.6	1.7	1.1	1.1	0.9	0.9	0.9	0.9	0.9	0.9	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.9		0.9	0.8
	Background	12.95	12	Average (dBA)	22.3	23.7	27.4	31.3	29.4	28.4	31.3	29.9	28.9	28.2	28.7	30.7	32.1	31.2	33.4	34.2	35.4	36.2	37.2	37.6	37.9	38.2	37.4	35.9	33.7	29.9	47.9		
				Uncertainty A (dB)	2.3	2.4	2.5	3.2	2.7	1.6	1.7	1.9	1.3	1.1	0.9	0.9	1.0	0.8	0.9	0.9	0.7	0.8	0.7	0.8	0.9	1.0	1.0	1.0	1.0	0.9			
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8		0.8	
13.5	Turbine ON	13.46	28	Average (dBA)	23.0	26.5	28.9	32.4	31.1	32.3	34.6	34.1	37.3	36.2	38.9	43.9	42.8	43.1	45.2	45.0	45.2	44.4	43.9	42.8	42.4	41.9	40.8	39.3	37.3	36.5	55.1		
				Uncertainty A (dB)	1.6	1.8	1.4	0.8	0.6	0.6	0.7	0.5	0.5	0.3	0.3	0.4	0.3	0.2	0.2	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.4	0.4		0.3	0.2
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8		0.8	0.8
				Combined Uncertainty (dB)	1.9	2.1	1.7	1.1	1.0	1.0	1.0	0.9	0.9	0.9	0.9	0.9	0.7	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.9		0.9	0.8
	Background	13.42	10	Average (dBA)	21.4	22.8	31.9	28.0	27.1	27.0	27.0	27.8	30.6	28.5	29.4	30.7	32.0	32.3	33.4	35.2	36.5	36.4	37.5	37.7	37.8	38.0	37.5	36.3	34.0	30.4	48.0		
				Uncertainty A (dB)	2.4	3.1	4.4	2.6	1.8	1.4	0.8	1.2	1.9	1.3	1.2	0.8	1.0	0.9	0.7	1.2	0.9	0.7	0.9	1.0	1.1	1.3	1.5	1.6	1.6	1.6			
				Uncertainty B (dB)	1.0	1.0	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8		0.8	


---


## Appendix D Tonality Assessment

---
































# Table D.01 Tonality Assessment Table - 8.5 m/s

Project: Niagara Region Wind Farm- Turbine T35 - IEC 61400-11 Measurement  
Report ID: 16227.00.T35.RP1

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
No Reportable Tones									



# Table D.02 Tonality Assessment Table - 9 m/s

Project: Niagara Region Wind Farm- Turbine T35 - IEC 61400-11 Measurement  
Report ID: 16227.00.T35.RP1

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
No Reportable Tones									

# Table D.03 Tonality Assessment Table - 9.5 m/s

Project: Niagara Region Wind Farm- Turbine T35 - IEC 61400-11 Measurement  
Report ID: 16227.00.T35.RP1

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
No Reportable Tones									

# Table D.04 Tonality Assessment Table - 10 m/s

Project: Niagara Region Wind Farm- Turbine T35 - IEC 61400-11 Measurement  
Report ID: 16227.00.T35.RP1

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
No Reportable Tones									

# Table D.05 Tonality Assessment Table - 10.5 m/s

Project: Niagara Region Wind Farm- Turbine T35 - IEC 61400-11 Measurement  
 Report ID: 16227.00.T35.RP1

Page 1 of 1  
 Created on: 11/3/2017

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
311	115			24.7	43.0	40.3	-2.7	-2.0	-0.7
379	115			25.7	43.9	42.2	-1.7	-2.0	0.3
57	115			25.5	43.8	40.0	-3.9	-2.0	-1.8
302	115			24.7	43.0	37.7	-5.3	-2.0	-3.3
268	115			25.4	43.7	39.0	-4.7	-2.0	-2.7
344	116			25.3	43.6	33.0	-10.6	-2.0	-8.6
391	116			25.2	43.5	36.6	-6.9	-2.0	-4.9
381	116			25.9	44.2	33.8	-10.3	-2.0	-8.3
351	116			25.7	44.0	39.1	-5.0	-2.0	-2.9
64	116			27.3	45.6	39.7	-5.8	-2.0	-3.8
Average	115.5						-4.9	-2.0	-2.9

# Table D.06 Tonality Assessment Table - 11 m/s

Project: Niagara Region Wind Farm- Turbine T35 - IEC 61400-11 Measurement  
 Report ID: 16227.00.T35.RP1

Page 1 of 1  
 Created on: 11/3/2017

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
65	115			26.3	44.6	41.2	-3.3	-2.0	-1.3
312	116			25.6	43.9	40.8	-3.0	-2.0	-1.0
61	116			27.0	45.3	39.9	-5.4	-2.0	-3.4
372	116			25.5	43.8	41.9	-1.9	-2.0	0.1
276	116			25.1	43.4	39.6	-3.7	-2.0	-1.7
271	116			25.6	43.9	40.8	-3.1	-2.0	-1.1
62	116			27.2	45.5	39.0	-6.5	-2.0	-4.5
342	116			25.8	44.1	39.5	-4.6	-2.0	-2.6
24	116			25.8	44.1	40.6	-3.5	-2.0	-1.5
270	116			24.9	43.1	33.6	-9.6	-2.0	-7.6
370	116			25.7	44.0	39.7	-4.3	-2.0	-2.3
349	116			24.7	43.0	37.2	-5.8	-2.0	-3.8
303	116			25.2	43.5	40.2	-3.3	-2.0	-1.3
51	116			26.0	44.3	38.2	-6.1	-2.0	-4.1
237	116			25.6	43.9	33.7	-10.2	-2.0	-8.1
277	117			25.8	44.1	39.8	-4.3	-2.0	-2.3
Average	116						-4.4	-2.0	-2.4

# Table D.07 Tonality Assessment Table - 11.5 m/s

Project: Niagara Region Wind Farm- Turbine T35 - IEC 61400-11 Measurement  
 Report ID: 16227.00.T35.RP1

Page 1 of 1  
 Created on: 11/3/2017

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
63	115			28.4	46.7	38.1	-8.6	-2.0	-6.6
265	115			26.2	44.4	38.9	-5.6	-2.0	-3.6
88	116			26.2	44.5	34.3	-10.2	-2.0	-8.2
193	116			26.4	44.7	34.0	-10.6	-2.0	-8.6
275	116			25.1	43.3	39.9	-3.5	-2.0	-1.5
285	116			25.2	43.5	40.0	-3.5	-2.0	-1.5
371	116			25.5	43.8	36.7	-7.0	-2.0	-5.0
272	116			25.5	43.8	41.2	-2.6	-2.0	-0.6
284	116			25.6	43.9	42.3	-1.6	-2.0	0.4
300	118			25.0	43.3	37.2	-6.1	-2.0	-4.1
Average	116						-5.0	-2.0	-3.0

# Table D.08 Tonality Assessment Table - 12 m/s

Project: Niagara Region Wind Farm- Turbine T35 - IEC 61400-11 Measurement  
Report ID: 16227.00.T35.RP1

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
No Reportable Tones									

# Table D.09 Tonality Assessment Table - 12.5 m/s

Project: Niagara Region Wind Farm- Turbine T35 - IEC 61400-11 Measurement  
Report ID: 16227.00.T35.RP1

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
No Reportable Tones									



# Table D.10 Tonality Assessment Table - 13 m/s

Project: Niagara Region Wind Farm- Turbine T35 - IEC 61400-11 Measurement  
Report ID: 16227.00.T35.RP1

Page 1 of 1  
Created on: 10/30/2017

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
No Reportable Tones									

# Table D.11 Tonality Assessment Table - 13.5 m/s

Project: Niagara Region Wind Farm- Turbine T35 - IEC 61400-11 Measurement  
Report ID: 16227.00.T35.RP1

Measurement #	Centre frequency (Hz)	Energy average of all masking lines (dB)	Background (dB)	Background adjusted criterion level (dB)	Masking level (dB)	Tone level (dB)	Determination of tonality (dB)	Frequency dependent audibility criterion (dB)	Tonal Audibility (dB)
No Reportable Tones									

---

## Appendix E Measurement Data

---

# Table E.01 Measurement data - Turbine ON

Project: Niagara Wind Farm - Turbine T35 - IEC 61400-11 Measurement  
Report ID: 16227.00.T35.RP1

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	Wind	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (Pa)	Relative Humidity (%)
1	12.6	55.7	2989	209.0	209.8	0.0	14.5	12.4	12.4	18	99	65
2	16.0	55.9	2972	209.0	209.8	0.0	15.0	15.7	11.8	18	99	65
3	16.2	56.4	2981	209.0	209.8	0.0	14.5	16.0	11.1	18	99	65
4	15.7	54.1	3001	209.0	209.8	0.0	14.3	15.5	11.5	18	99	65
5	15.8	55.4	2992	209.0	209.8	0.0	14.5	15.6	9.2	18	99	65
6	14.4	54.0	2992	209.0	209.8	0.0	14.4	14.1	10.8	18	99	65
7	15.0	55.5	2990	209.0	209.8	0.0	14.2	14.8	10.1	18	99	65
8	14.3	54.4	2972	209.0	209.8	0.0	14.5	14.1	12.6	18	99	65
9	16.3	55.8	3008	209.0	209.8	0.0	14.3	16.0	11.8	18	99	65
10	14.1	54.9	3001	209.0	209.8	0.0	14.4	13.9	8.0	18	99	65
11	12.0	56.6	3006	209.0	209.8	0.0	14.4	11.9	11.8	18	99	65
12	12.7	54.7	3000	209.0	209.8	0.0	14.7	12.5	12.0	18	99	65
13	13.5	55.7	2988	209.0	209.8	0.0	14.5	13.3	12.3	18	99	64
14	13.0	55.2	3029	209.0	209.8	0.0	14.2	12.8	11.8	18	99	64
15	14.0	54.2	3023	209.0	209.8	0.0	14.2	13.8	12.3	18	99	64
16	12.8	55.9	3003	209.0	209.8	0.0	14.3	12.3	18	99	64	
17	12.8	54.2	2989	209.0	209.8	0.0	14.1	12.6	10.8	18	99	64
18	2993	209.0	209.8	0.0	14.3	11.4	10.1	18	99	64		
19	12.1	54.1	3008	209.0	209.8	0.0	14.2	11.9	12.4	18	99	64
20	2685	209.0	209.8	0.0	13.8	11.9	11.8	18	99	64		
21	2259	209.0	209.8	0.0	13.5	12.5	12.1	18	99	64		
22	2210	209.0	209.8	0.0	13.5	10.8	11.8	18	99	64		
23	2475	209.0	209.8	0.0	13.7	10.5	11.2	18	99	64		
24	10.9	53.7	2769	209.0	209.8	0.0	13.9	10.5	10.5	18	99	64
25	12.9	55.5	2999	209.0	209.8	0.0	14.4	12.7	12.4	18	99	64
26	13.6	54.4	2999	209.0	209.8	0.0	14.3	13.4	14.5	18	99	64
27	15.2	56.7	3002	209.0	209.8	0.0	14.3	14.9	13.9	18	99	64
28	15.6	56.5	3001	209.0	209.8	0.0	14.3	15.3	11.8	18	99	64
29	16.5	56.2	2972	209.0	209.8	0.0	14.4	16.3	11.8	18	99	64
30	13.9	55.8	2976	209.0	209.8	0.0	14.3	13.7	13.0	18	99	64
31	15.4	55.4	2979	209.0	209.8	0.0	13.9	12.3	11.7	18	99	64
32	13.6	55.9	2983	209.0	209.8	0.0	14.3	13.4	11.5	18	99	63
33	2998	209.0	209.8	0.0	14.2	11.4	13.0	18	99	63		
34	2957	209.0	209.8	0.0	14.3	10.9	12.7	18	99	63		
35	3011	209.0	209.8	0.0	14.8	11.4	12.0	18	99	63		
36	11.8	55.5	2972	209.0	209.8	0.0	14.0	11.6	12.1	18	99	63
37	3012	209.0	209.8	0.0	14.4	11.4	11.8	18	99	64		
38	13.3	54.1	3025	209.0	209.8	0.0	14.2	13.1	10.5	18	99	64
39	13.8	54.5	2992	209.0	209.8	0.0	14.2	13.6	8.2	18	99	64
40	14.5	55.6	3015	209.0	209.8	0.0	14.4	14.3	12.1	18	99	64
41	3049	209.0	209.8	0.0	14.4	14.5	11.1	18	99	64		
42	3043	209.0	206.1	0.0	14.1	13.9	12.3	18	99	64		
43	14.8	54.9	2994	209.0	209.8	0.0	14.6	14.6	12.1	18	99	64
44	12.7	54.0	2994	209.0	209.8	0.0	14.3	13.5	10.9	18	99	64
45	13.3	54.3	2994	209.0	209.8	0.0	14.3	13.1	10.6	18	99	64
46	12.7	54.6	3001	209.0	209.8	0.0	14.4	12.5	8.6	18	99	64
47	2996	209.0	209.8	0.0	14.5	11.3	9.5	18	99	64		
48	13.1	54.7	3002	209.0	209.8	0.0	14.3	12.9	8.0	18	99	64
49	2943	209.0	209.8	0.0	14.1	11.2	8.0	18	99	65		
50	2943	209.0	209.8	0.0	14.0	10.6	8.3	18	99	65		
51	11.1	54.2	2842	209.0	209.8	0.0	13.9	11.5	8.2	18	99	65
52	2976	209.0	209.8	0.0	14.4	11.1	10.6	18	99	65		
53	2733	209.0	209.8	0.0	13.8	12.0	12.7	18	99	65		
54	2283	209.0	209.8	0.0	13.5	10.3	11.8	18	99	65		
55	2308	209.0	209.8	0.0	13.5	10.9	12.1	18	99	64		
56	2145	209.0	205.9	0.0	13.4	9.4	10.6	18	99	64		
57	10.4	52.1	2521	209.0	209.8	0.0	13.7	10.8	10.0	18	99	64
58	9.6	52.3	2067	209.0	209.8	0.0	13.4	9.6	9.4	18	99	64
59	10.1	53.3	2384	209.0	209.8	0.0	13.6	9.9	8.3	18	99	64
60	2284	209.0	205.8	0.0	13.5	10.9	10.9	18	99	64		
61	10.8	54.2	2715	209.0	209.8	0.0	13.8	11.1	9.2	18	99	65
62	10.8	54.0	2748	209.0	209.8	0.0	13.9	10.7	8.5	18	99	65
63	11.4	54.5	2890	209.0	209.8	0.0	13.9	10.8	8.6	18	99	65
64	10.7	53.2	2693	209.0	209.8	0.0	13.8	11.6	8.9	18	99	65
65	10.8	54.8	2746	209.0	209.8	0.0	13.8	10.8	9.2	18	99	65
66	13.0	55.3	3031	209.0	209.8	0.0	14.3	12.8	11.8	18	99	65
67	2959	209.0	209.8	0.0	14.0	10.6	10.1	18	99	65		
68	14.0	56.2	2983	209.0	209.8	0.0	14.7	13.8	11.8	18	99	65
69	13.8	54.9	2973	209.0	209.8	0.0	14.6	12.6	11.3	18	99	65
70	12.2	56.6	3001	209.0	209.8	0.0	14.5	12.0	9.1	18	99	65
71	15.5	54.3	3020	209.0	209.8	0.0	14.1	15.3	10.3	18	99	65
72	15.4	56.5	3002	209.0	209.8	0.0	14.3	15.2	10.1	18	99	65
73	13.9	55.2	3021	209.0	209.8	0.0	14.5	13.7	10.7	18	99	65
74	15.1	55.4	3030	209.0	209.8	0.0	14.3	14.7	10.1	18	99	65
75	15.3	55.4	2998	209.0	209.8	0.0	14.4	15.1	9.8	18	99	65
76	3001	209.0	209.8	0.0	14.4	11.2	8.2	18	99	65		
77	12.8	54.9	2976	209.0	209.8	0.0	14.6	12.6	9.2	18	99	65
78	13.1	55.6	3004	209.0	209.8	0.0	14.2	13.0	10.0	18	99	65
79	3020	209.0	209.8	0.0	14.0	11.4	8.9	18	99	66		
80	14.0	54.7	3008	209.0	209.8	0.0	14.3	13.8	7.3	18	99	66
81	15.1	53.3	3006	209.0	209.8	0.0	14.3	14.9	8.9	18	99	66
82	3019	209.0	209.8	0.0	14.4	11.0	8.0	18	99	66		
83	14.8	54.6	3007	209.0	209.8	0.0	14.4	14.6	10.9	18	99	66
84	3020	209.0	209.8	0.0	14.3	11.5	9.7	18	99	66		
85	14.3	54.8	3004	209.0	209.8	0.0	14.5	12.8	10.1	18	99	66
86	13.0	55.6	3002	209.0	209.8	0.0	14.5	14.1	8.9	18	99	66
87	3020	209.0	209.8	0.0	14.0	10.8	8.8	18	99	65		
88	11.3	53.7	2869	209.0	209.8	0.0	13.9	10.5	8.3	18	99	65

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	Wind	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (Pa)	Relative Humidity (%)
89			3024	209.0	205.8	0.0	14.3	10.6	7.7	18	99	65
90	12.9	54.2	2996	209.0	205.8	0.0	14.1	12.7	7.0	18	99	65
91			3023	209.0	205.8	0.0	14.4	11.4	10.5	18	99	66
92	11.8	54.7	3021	209.0	205.8	0.0	14.2	11.6	8.3	18	99	66
93	13.1	53.9	3020	209.0	205.8	0.0	14.2	12.9	9.2	18	99	66
94	12.4	53.9	3005	209.0	205.8	0.0	14.2	12.3	7.4	18	99	66
95			2985	209.0	205.8	0.0	14.3	11.2	8.9	18	99	66
96			2991	209.0	205.8	0.0	14.0	11.1	8.3	18	99	66
97	12.0	54.5	2983	209.0	205.8	0.0	15.0	11.8	10.1	18	99	66
98	13.3	54.9	2997	209.0	205.8	0.0	14.5	13.1	12.1	18	99	66
99	12.3	54.7	3008	209.0	205.8	0.0	14.2	12.2	12.4	18	99	66
100	12.0	54.6	3033	209.0	205.8	0.0	14.4	11.8	12.0	18	99	66
101	12.0	54.1	2995	209.0	205.8	0.0	14.7	11.9	9.5	18	99	66
102	12.6	55.5	3002	209.0	205.8	0.0	14.5	12.4	9.1	18	99	66
103	13.3	56.0	3013	209.0	205.8	0.0	14.2	13.1	8.3	18	99	65
104	12.2	56.8	3018	209.0	205.8	0.0	14.5	12.0	12.0	18	99	65
105			2976	209.0	205.8	0.0	14.4	11.4	13.9	18	99	65
106	15.0	52.8	2986	209.0	205.8	0.0	14.2	14.7	10.8	18	99	65
107	13.7	54.2	2991	209.0	207.9	0.0	14.2</					

Table E.01 Measurement data - Turbine ON  
 Project: Niagara Wind Farm - Turbine T35 - IEC 61400-11 Measurement  
 Report ID: 16227.00.T35.RP1

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	URef	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (Pa)	Relative Humidity (%)
177	14.0	55.1	2977	209.0	211.8	0.0	14.6	13.8	11.3	18	99	66
178	13.5	55.0	2998	209.0	211.8	0.0	14.5	13.3	11.1	18	99	66
179	13.7	56.0	3007	209.0	211.8	0.0	14.3	13.5	10.3	18	99	66
180	14.4	54.7	2965	209.0	211.8	0.0	14.4	14.2	10.9	18	99	66
181	13.3	56.6	3009	209.0	211.8	0.0	14.3	13.1	11.5	18	99	66
182	12.8	54.2	3010	209.0	211.8	0.0	14.2	12.7	13.2	18	99	66
183	12.5	53.9	2993	209.0	211.8	0.0	14.2	12.3	10.3	18	99	66
184			3018	209.0	211.8	0.0	14.3	11.3	10.6	18	99	66
185	12.2	55.7	2994	209.0	211.8	0.0	14.3	12.1	10.3	18	99	66
186	13.1	56.0	3000	209.0	211.8	0.0	14.3	12.9	10.1	18	99	66
187	12.2	56.8	3017	209.0	211.8	0.0	14.2	12.0	10.7	18	99	66
188	13.3	56.5	3025	209.0	211.8	0.0	14.4	13.1	10.8	18	99	66
189	14.9	55.0	2992	209.0	211.8	0.0	14.5	14.7	12.6	18	99	66
190	14.7	54.3	2953	209.0	211.8	0.0	14.2	14.5	12.0	18	99	66
191	13.6	53.2	2913	209.0	211.8	0.0	14.0	13.4	12.7	18	99	66
192	13.9	54.6	3028	209.0	210.7	0.0	14.4	13.7	10.9	18	99	66
193	11.3	54.7	2875	209.0	207.9	0.0	13.9	10.8	11.4	18	99	66
194			2996	209.0	207.9	0.0	14.2	10.7	12.6	18	99	66
195	12.5	54.5	3034	209.0	207.9	0.0	14.1	12.3	10.4	18	99	66
196	13.1	52.8	3028	209.0	207.9	0.0	14.1	12.9	12.4	18	99	66
197	15.5	54.7	3012	209.0	207.9	0.0	14.2	15.3	11.6	18	99	66
198	14.1	55.3	3015	209.0	207.9	0.0	14.3	13.9	10.8	18	99	66
199	12.6	53.6	3005	209.0	207.9	0.0	14.2	12.4	10.9	18	99	66
200	12.3	54.5	2970	209.0	207.9	0.0	14.5	12.1	11.2	18	99	66
201	13.4	56.2	3013	209.0	207.9	0.0	14.6	13.2	11.5	18	99	66
202	13.3	54.7	3013	209.0	207.9	0.0	14.3	13.1	9.4	18	99	66
203	12.7	54.3	2964	209.0	207.9	0.0	14.2	12.5	8.3	18	99	66
204	13.3	55.3	3006	209.0	207.9	0.0	14.4	13.1	11.4	18	99	66
205	12.0	54.7	3013	209.0	207.9	0.0	14.4	11.8	9.8	18	99	66
206			3019	209.0	207.9	0.0	14.3	10.9	11.7	18	99	66
207			3017	209.0	207.9	0.0	14.3	11.5	12.2	18	99	66
208	12.0	55.9	3012	209.0	207.9	0.0	14.5	11.8	12.6	18	99	66
209	12.2	54.4	3005	209.0	207.9	0.0	14.5	12.0	12.8	18	99	66
210	14.1	54.1	3012	209.0	207.9	0.0	14.2	13.9	11.4	18	99	66
211	12.4	55.0	3020	209.0	207.9	0.0	14.1	11.6	11.4	18	99	66
212	12.5	55.3	3010	209.0	207.9	0.0	14.3	12.3	12.7	18	99	66
213	11.9	55.9	2990	209.0	207.9	0.0	14.5	11.7	10.7	18	99	66
214	12.5	54.5	3006	209.0	207.9	0.0	14.4	12.3	9.5	18	99	66
215	15.9	55.4	3009	209.0	207.9	0.0	14.0	15.6	10.5	18	99	66
216	14.9	54.9	2985	209.0	207.9	0.0	14.7	14.7	9.2	18	99	66
217	15.6	56.1	3009	209.0	207.9	0.0	14.5	15.4	12.0	18	99	66
218	16.0	55.8	2995	209.0	207.9	0.0	14.4	15.7	10.1	18	99	66
219	14.6	56.4	2997	209.0	207.9	0.0	14.4	14.4	13.3	18	99	66
220	14.8	55.6	3007	209.0	207.9	0.0	14.4	14.6	10.7	18	99	66
221	15.5	55.4	3000	209.0	207.9	0.0	14.2	15.3	10.1	18	99	66
222	13.6	55.2	3009	209.0	207.9	0.0	14.4	13.4	10.1	18	99	66
223			3015	209.0	207.9	0.0	14.2	11.5	10.8	18	99	66
224	13.8	56.4	3006	209.0	207.9	0.0	14.4	13.6	10.1	18	99	66
225			2980	209.0	207.9	0.0	14.8	13.5	11.5	18	99	66
226	15.6	54.8	3020	209.0	207.9	0.0	14.4	15.4	12.0	18	99	66
227	15.5	55.0	2984	209.0	207.9	0.0	14.4	15.2	10.4	18	99	66
228	13.9	55.5	2991	209.0	207.9	0.0	14.2	13.7	10.8	18	99	66
229			3019	209.0	207.9	0.0	14.4	11.4	9.4	18	99	66
230	14.5	55.0	3000	209.0	207.9	0.0	14.3	14.3	9.4	18	99	66
231	12.7	54.0	2988	209.0	210.9	0.0	14.5	12.5	11.3	18	99	66
232			3006	209.0	210.9	0.0	14.3	13.9	11.2	18	99	66
233	13.0	56.1	3008	209.0	210.9	0.0	14.5	12.8	14.5	18	99	66
234	12.7	55.3	3023	209.0	210.9	0.0	14.5	12.5	13.6	18	99	66
235	11.9	54.8	3044	209.0	210.9	0.0	14.2	11.7	12.0	18	99	66
236			3011	209.0	210.9	0.0	14.1	11.6	13.3	18	99	66
237	11.2	54.1	2852	209.0	210.9	0.0	13.9	10.8	12.3	18	99	66
238			2982	209.0	210.9	0.0	14.6	10.8	13.2	18	99	66
239	12.4	54.2	3009	209.0	210.9	0.0	14.1	12.3	11.5	18	99	66
240	14.4	56.7	3030	209.0	210.9	0.0	14.3	14.2	10.7	18	99	66
241	15.1	55.1	2991	209.0	210.9	0.0	14.4	14.9	11.2	18	99	66
242	12.6	55.1	2964	209.0	210.9	0.0	13.8	12.5	8.9	18	99	66
243	13.1	55.5	3008	209.0	210.9	0.0	14.1	12.9	9.2	18	99	66
244			2971	209.0	210.9	0.0	14.4	10.4	8.5	18	99	66
245	11.8	56.2	2996	209.0	210.9	0.0	14.3	11.6	10.5	18	99	66
246	13.7	53.6	2987	209.0	210.9	0.0	14.2	13.5	12.1	18	99	66
247			2497	209.0	210.9	0.0	13.6	12.5	12.1	18	99	66
248			2999	209.0	210.9	0.0	13.6	12.3	10.1	18	99	66
249			2179	209.0	210.9	0.0	13.4	12.1	11.6	18	99	66
250			2011	209.0	210.9	0.0	13.6	11.1	11.8	18	99	66
251			2607	209.0	208.8	0.0	13.8	11.8	11.5	18	99	66
252			2290	209.0	205.0	0.0	13.5	8.5	10.1	18	99	66
253			2463	209.0	203.8	0.0	13.7	10.7	10.9	18	99	66
254			2318	209.0	203.8	0.0	13.5	12.1	11.5	18	99	66
255			2964	209.0	203.8	0.0	14.2	11.5	10.7	18	99	66
256	12.0	54.4	2989	209.0	203.8	0.0	14.9	11.9	10.0	18	99	66
257	13.3	55.6	2982	209.0	203.8	0.0	14.7	11.1	8.9	18	99	66
258	14.4	54.9	3010	209.0	203.8	0.0	14.5	14.2	7.8	18	99	66
259	13.8	53.9	2994	209.0	203.8	0.0	14.4	13.6	7.8	18	99	66
260			3020	209.0	203.8	0.0	14.6	11.1	7.8	18	99	66
261			3012	209.0	203.8	0.0	14.2	12.1	10.9	18	99	66
262			1819	209.0	210.9	0.0	13.1	10.3	11.0	18	99	66
263	9.7	51.9	2135	209.0	210.9	0.0	13.4	10.4	9.1	18	99	66
264	10.2	53.1	2431	209.0	210.9	0.0	13.6	9.5	7.7	18	99	66

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	URef	Turbine Power Output (kW)	Reference Yaw Angle (°)	Yaw Angle (°)	Pitch Angle (°)	Rotor RPM	Nacelle Anemometer Wind Speed (m/s)	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (Pa)	Relative Humidity (%)
265	11.5	53.1	2896	209.0	210.9	0.0	13.9	12.4	7.6	18	99	66
266	13.6	54.9	3005	209.0	208.8	0.0	14.1	13.4	7.9	18	99	66
267	9.8	52.6	2183	209.0	206.8	0.0	13.4	10.2	8.6	18	99	66
268	10.6	52.6	2605	209.0	206.8	0.0	13.8	10.3	7.1	18	99	66
269	12.9	53.6	3030	209.0	206.8	0.0	14.4	12.7	6.0	18	99	66
270	10.9	52.4	2797	209.0	206.8	0.0	13.8	10.8	5.9	18	99	66
271	10.8	53.2	2736	209.0	206.8	0.0	13.8	10.2	6.4	18	99	66
272	11.7	53.4	2828	209.0	206.8	0.0	13.9	11.0	6.8	18	99	66
273	11.8	53.7	3020	209.0	206.8	0.0	14.4	11.6	8.3	18	99	66
274			2993	209.0	206.8	0.0	14.2	10.9	8.2	18	99	66
275	11.5	54.8	2898	209.0	206.8	0.0	13.9	10.1	7.3	18	99	66
276	10.8	53.4	2729	209.0	206.8	0.0	13.8	10.9	6.8	18	99	66
277	11.2	55.4	2864	209.0	206.8	0.0	13.9	9.7	7.0	18	99	66
278	12.2	54.3	2964	209.0	206.8	0.0	14.0	12.0	7.7	18	99	66
279	13.1	53.6	3007	209.0	206.8	0.0	14.1	12.9	9.3	18	99	66
280			2988	209.0	206.8</							



# Table E.02 Measurement data - Background

Project: Niagara Wind Farm - Turbine T35 - IEC 61400-11 Measurement  
 Report ID: 16227.00.T35.RP1

Page 1 of 3  
 Created on: 11/3/2017

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (C)	Pressure (Pa)	Relative Humidity (%)
1	12.3	46.1	0.0	10.4	18	99	65
2	12.0	48.6	0.0	10.1	18	99	65
3	10.8	50.2	0.0	9.1	18	99	65
4	11.3	51.6	0.0	9.5	18	99	66
5	11.3	51.2	0.0	9.5	18	99	66
6	11.3	49.6	0.0	9.5	18	99	66
7	9.2	48.2	0.0	7.8	18	99	66
8	9.1	10.3	0.1	8.3	18	99	66
9	13.3	51.6	0.2	11.2	18	99	66
10	12.2	52.7	0.1	10.3	18	99	66
11	12.6	50.8	0.0	10.6	18	99	66
12	13.1	49.3	0.0	10.9	18	99	66
13	11.4	47.3	0.0	9.5	18	99	65
14	12.1	50.3	0.0	10.1	18	99	66
15	14.3	47.3	0.0	12.0	18	99	66
16	15.6	46.8	0.2	13.1	18	99	65
17	15.0	49.5	0.1	12.6	18	99	65
18	12.5	50.8	0.3	10.5	18	99	65
19	10.3	48.4	0.4	9.5	18	99	65
20	10.3	48.4	0.0	8.6	18	99	65
21	10.3	46.1	0.0	8.6	18	99	65
22	10.2	49.8	0.0	8.9	18	99	66
23	11.4	46.1	0.0	9.5	18	99	66
24	8.8	45.9	0.0	7.4	18	99	66
25	12.1	47.5	0.3	10.1	18	99	66
26	12.2	49.1	0.4	10.3	18	99	66
27	10.2	49.8	0.4	8.6	18	99	66
28	10.1	47.5	0.1	8.5	18	99	66
29	10.1	49.5	0.0	8.5	18	99	66
30	10.3	47.3	0.1	8.6	18	99	66
31	10.1	44.0	0.0	8.5	18	99	66
32	13.2	46.1	0.0	11.1	18	99	66
33	11.9	45.8	0.0	10.1	18	99	65
34	11.9	44.1	0.0	10.0	18	99	65
35	10.3	44.1	0.0	8.6	18	99	65
36	10.2	44.6	0.0	8.6	18	99	65
37	11.5	49.2	0.0	9.7	18	99	65
38	10.8	50.5	0.1	9.1	18	99	65
39	13.1	46.4	0.0	10.9	18	99	65
40	11.2	47.9	0.0	9.4	18	99	65
41	12.8	46.6	0.0	10.8	18	99	65
42	12.8	46.1	0.0	10.8	18	99	65
43	12.1	47.3	0.0	10.1	18	99	65
44	14.0	47.2	0.0	11.8	18	99	65
45	15.9	46.5	0.0	13.3	18	99	65
46	15.9	49.4	0.0	13.3	18	99	65
47	14.9	46.5	0.0	12.5	18	99	65
48	12.2	45.8	0.0	10.3	18	99	65
49	15.9	47.3	0.0	13.3	18	99	65
50	16.1	51.5	0.0	13.5	18	99	65
51	14.5	50.7	0.0	12.2	18	99	65
52	12.7	51.0	0.0	10.7	18	99	65
53	13.3	51.5	0.0	11.2	18	99	65
54	12.1	47.6	0.0	10.1	18	99	65
55	15.9	48.1	0.0	13.3	18	99	65
56	14.3	44.1	0.0	12.0	18	99	65
57	14.4	46.4	0.0	12.1	18	99	65
58	14.4	43.4	0.0	12.1	18	99	64
59	14.7	44.5	0.1	12.4	18	99	64
60	12.7	46.2	0.1	10.7	18	99	64
61	11.3	45.9	0.1	9.5	18	99	64
62	10.2	48.1	0.1	8.6	18	99	64
63	13.3	48.0	0.0	11.2	18	99	64
64	12.2	47.8	0.0	10.3	18	99	65
65	12.8	48.5	0.0	10.8	18	99	65
66	13.7	47.6	0.0	11.5	18	99	65
67	10.6	43.8	0.0	8.9	18	99	65
68	12.7	43.8	0.0	9.1	18	99	65
69	13.3	46.4	0.0	11.2	18	99	65
70	11.5	46.3	0.0	9.7	18	99	65
71	10.2	45.0	0.0	8.6	18	99	65
72	12.9	45.5	0.0	10.9	18	99	65
73	10.8	45.2	0.0	9.1	18	99	65
74	12.6	46.8	0.2	10.6	18	99	65
75	11.4	46.6	0.1	9.5	18	99	65
76	11.6	45.7	0.1	9.8	18	99	66
77	12.7	48.2	0.1	10.7	18	99	66
78	12.6	48.7	0.1	10.6	18	99	66
79	13.3	47.7	0.1	11.2	18	99	66
80	10.7	49.3	0.4	8.9	18	99	66
81	12.6	45.8	0.5	10.6	18	99	66
82	10.4	45.4	0.5	8.8	18	99	65
83	12.6	44.6	0.1	10.6	18	99	65

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (C)	Pressure (Pa)	Relative Humidity (%)
84	14.3	44.8	0.1	12.0	18	99	65
85	15.1	42.7	0.0	12.7	18	99	65
86	10.9	44.0	0.0	9.2	18	99	65
87	14.6	43.0	0.0	12.3	18	99	65
88	14.1	45.1	0.0	11.9	18	99	65
89	12.7	43.0	0.1	10.7	18	99	65
90	10.6	42.3	0.1	8.9	18	99	65
91	10.3	41.6	0.1	8.6	18	99	65
92	8.8	44.7	0.1	7.4	18	99	65
93	10.9	45.0	0.1	9.2	18	99	65
94	11.3	43.3	0.0	9.5	18	99	64
95	10.8	42.1	0.0	9.1	18	99	64
96	12.1	45.6	0.0	10.1	18	99	64
97	11.5	45.5	0.0	9.7	18	99	64
98	10.8	45.1	0.0	9.1	18	99	64
99	12.2	46.0	0.0	10.3	18	99	64
100	12.6	44.0	0.0	10.6	18	99	64
101	12.8	47.1	0.0	10.8	18	99	64
102	13.6	43.4	0.0	11.4	18	99	64
103	13.7	42.2	0.1	11.5	18	99	64
104	11.4	42.7	0.1	9.5	18	99	64
105	10.6	42.8	0.0	8.9	18	99	64
106	10.4	45.4	0.0	8.5	18	99	64
107	11.2	43.3	0.0	9.4	18	99	65
108	9.8	46.0	0.0	8.3	18	99	65
109	12.0	43.3	0.1	10.1	18	99	65
110	10.7	43.0	0.1	8.9	18	99	65
111	9.6	45.6	0.5	8.0	18	99	65
112	9.2	49.4	0.3	7.8	18	99	65
113	8.4	48.1	0.1	7.1	18	99	65
114	11.7	47.8	0.1	9.8	18	99	65
115	10.8	48.2	0.0	9.1	18	99	65
116	11.9	46.4	0.0	10.6	18	99	65
117	12.1	47.9	0.0	10.1	18	99	65
118	11.9	46.5	0.0	10.0	18	99	64
119	11.0	48.4	0.0	8.5	18	99	64
120	11.0	48.4	0.0	9.3	18	99	64
121	12.3	47.4	0.0	10.4	18	99	64
122	13.8	48.6	0.0	11.6	18	99	64
123	14.4	49.9	0.0	12.1	18	99	64
124	12.3	45.9	0.0	10.4	18	99	63
125	13.9	46.6	0.0	11.7	18	99	63
126	12.5	46.9	0.0	10.5	18	99	63
127	10.9	44.4	0.0	9.2	18	99	63
128	12.3	47.1	0.0	10.4	18	99	63
129	10.7	45.0	0.0	8.9	18	99	63
130	11.5	48.5	0.0	9.7	18	99	64
131	11.3	48.3	0.0	9.5	18	99	64
132	12.6	47.5	0.0	10.6	18	99	64
133	11.6	48.6	0.0	9.8	18	99	64
134	13.1	49.7	0.0	10.9	18	99	64
135	12.8	52.4	0.0	10.8	18	99	64
136	12.8	46.7	0.0	10.8	18	99	63
137	11.5	48.0	0.2	9.7	18	99	63
138	12.7	48.0	0.1	10.7	18	99	63
139	11.4	48.8	0.0	9.5	18	99	63
140	10.8	49.0	0.2	9.1	18	99	63
141	11.7	48.5	0.1	9.8	18	99	63
142	14.4	46.3	0.0	12.1	18	99	64
143	13.4	43.5	0.0	11.3	18	99	64
144	12.7	42.1	0.0	10.7	18	99	64
145	11.0	42.1	0.0	9.3	18	99	64
146	11.2	41.6	0.0	9.4	18	99	64
147	9.7	41.8	0.0	8.2	18	99	64
148	9.4	42.3	0.0	7.9	18	99	65
149	9.6	46.0	0.0	8.0	18	99	65
150	8.7	42.3	0.0	7.3	18	99	65
151	9.8	41.0	0.0	8.3	18	99	65
152	11.0	42.5	0.0	9.3	18	99	65
153	9.0	40.3	0.0	7.6	18	99	65
154	9.0	43.5	0.0	7.6	18	99	65
155	10.1	41.7	0.0	8.5	18	99	65
156	9.5	43.5	0.1	9.7	18	99	65
157	8.8	43.5	0.0	7.4	18	99	65
158	10.0	44.9	0.0	8.3	18	99	65
159	10.8	44.2	0.0	9.1	18	99	65
160	10.7	43.2	0.0	8.9	18	99	65
161	11.5	43.5	0.0	9.7	18	99	65
162	9.5	44.9	0.1	8.0	18	99	65
163	8.5	44.5	0.1	7.2	18	99	65
164	9.6	42.6	0.0	8.0	18	99	65
165	9.2	40.1	0.0	7.8	18	99	65
166	9.8	41.0	0.0	8.3	18	99	65

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (C)	Pressure (Pa)	Relative Humidity (%)
167	11.5	41.0	0.0	9.7	18	99	65
168	12.2	41.8	0.0	10.3	18	99	65
169	12.7	44.2	0.0	10.7	18	99	65
170	10.0	46.9	0.0	8.3	18	99	65
171	9.6	46.5	0.0	8.0	18	99	65
172	10.8	44.0	0.0				

Table E.02 Measurement data - Background  
 Project: Niagara Wind Farm - Turbine T35 - IEC 61400-11 Measurement  
 Report ID: 16227.00.T35.RP1

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (C)	Pressure (Pa)	Relative Humidity (%)
250	8.8	41.4	0.0	7.4	17	99	69
251	7.4	40.7	0.0	6.2	17	99	69
252	6.7	41.0	0.0	5.6	17	99	69
253	8.7	39.1	0.0	7.3	17	99	69
254	7.6	40.5	0.0	6.3	17	99	69
255	9.5	39.0	0.0	7.9	17	99	69
256	9.0	39.1	0.0	7.5	17	99	69
257	8.9	40.2	0.0	7.4	17	99	69
258	8.9	38.9	0.0	7.5	17	99	69
259	9.2	40.3	0.0	7.7	17	99	69
260	9.4	41.0	0.0	7.8	17	99	68
261	8.8	40.4	0.0	7.4	17	99	68
262	9.1	43.4	0.0	8.6	17	99	69
263	9.1	41.9	0.0	7.7	17	99	68
264	8.2	38.5	0.0	6.9	17	99	68
265	9.1	39.3	0.0	7.6	17	99	68
266	7.9	39.3	0.0	6.6	17	99	68
267	7.9	38.1	0.0	6.5	17	99	68
268	7.9	37.8	0.0	6.6	17	99	68
269	9.6	39.7	0.0	8.0	17	99	68
270	11.0	42.4	0.0	9.2	17	99	68
271	10.0	41.3	0.0	8.4	17	99	68
272	9.6	39.2	0.0	8.0	17	99	68
273	9.3	39.5	0.0	7.8	17	99	68
274	10.1	37.5	0.0	8.5	17	99	68
275	10.7	37.2	0.0	9.0	17	99	68
276	9.1	38.1	0.0	7.6	17	99	68
277	11.0	40.2	0.0	9.2	17	99	68
278	9.7	41.2	0.0	8.1	17	99	68
279	10.0	43.2	0.0	8.4	17	99	68
280	8.9	42.8	0.0	7.5	17	99	68
281	7.8	40.6	0.0	6.5	17	99	68
282	10.8	45.5	0.0	9.0	17	99	68
283	10.1	39.8	0.1	8.5	17	99	68
284	9.6	39.4	0.0	8.1	17	99	68
285	10.5	40.4	0.0	8.8	17	99	68
286	11.2	40.4	0.0	9.4	17	99	68
287	10.6	40.5	0.0	8.8	17	99	68
288	10.0	39.8	0.0	8.3	17	99	68
289	10.7	41.2	0.0	9.0	17	99	68
290	11.6	42.1	0.0	9.7	17	99	68
291	10.9	40.6	0.0	9.2	17	99	68
292	11.6	41.0	0.0	9.2	17	99	68
293	11.3	40.6	0.0	9.5	17	99	68
294	9.6	40.5	0.1	8.0	17	99	68
295	8.4	38.1	0.0	7.0	17	99	68
296	9.5	37.6	0.0	7.9	17	99	68
297	8.5	37.5	0.0	7.1	17	99	68
298	9.2	36.9	0.0	7.7	17	99	68
299	9.6	38.4	0.0	8.0	17	99	68
300	8.6	42.4	0.0	7.2	17	99	68
301	8.4	42.3	0.0	7.0	17	99	68
302	9.6	40.9	0.0	8.3	17	99	68
303	8.2	40.2	0.0	6.9	17	99	68
304	8.2	40.6	0.0	6.8	17	99	68
305	9.2	42.9	0.0	7.7	17	99	68
306	8.4	40.2	0.0	7.0	17	99	68
307	6.9	39.9	0.0	5.8	17	99	69
308	7.0	40.5	0.0	5.9	17	99	69
309	8.4	41.0	0.0	7.1	17	99	69
310	8.6	43.6	0.0	7.2	17	99	69
311	8.2	44.6	0.0	6.9	17	99	69
312	7.1	44.5	0.0	6.0	17	99	69
313	6.9	43.7	0.0	5.8	17	99	69
314	8.5	42.2	0.0	7.1	17	99	69
315	9.0	42.6	0.0	7.5	17	99	69
316	10.0	41.6	0.0	8.4	17	99	69
317	8.8	41.4	0.0	8.2	17	99	69
318	8.9	41.1	0.0	7.5	17	99	69
319	7.7	41.2	0.0	6.5	17	99	69
320	8.0	39.1	0.0	6.7	17	99	69
321	8.1	38.3	0.1	6.8	17	99	69
322	8.8	39.7	0.0	7.4	17	99	69
323	9.9	39.3	0.0	8.3	17	99	69
324	12.0	40.2	0.0	10.1	17	99	69
325	10.7	38.3	0.0	9.0	17	99	69
326	10.6	38.6	0.0	8.9	17	99	68
327	8.8	38.9	0.0	8.2	17	99	68
328	8.8	38.6	0.0	7.4	17	99	68
329	9.4	41.3	0.0	7.9	17	99	68
330	8.9	39.5	0.0	7.5	17	99	68
331	9.7	40.3	0.1	8.1	17	99	68
332	8.8	39.4	0.0	7.4	17	99	69

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (C)	Pressure (Pa)	Relative Humidity (%)
333	10.2	40.2	0.0	8.5	17	99	69
334	7.5	42.6	0.0	6.3	17	99	69
335	7.7	41.7	0.0	6.7	17	99	69
336	7.7	38.8	0.0	6.4	17	99	69
337	4.0	37.4	0.0	6.2	17	99	69
338	6.9	36.9	0.0	5.8	17	99	69
339	8.6	39.7	0.0	7.2	17	99	69
340	9.4	43.0	0.0	7.9	17	99	69
341	9.9	39.7	0.0	8.3	17	99	69
342	7.9	40.0	0.0	6.6	17	99	69
343	8.1	40.0	0.0	6.8	17	99	69
344	9.6	39.4	0.0	8.0	17	99	69
345	7.6	41.6	0.0	6.3	17	99	69
346	7.1	40.6	0.0	5.9	17	99	69
347	7.6	40.6	0.0	6.4	17	99	69
348	7.0	41.7	0.0	5.9	17	99	69
349	9.1	40.6	0.0	7.6	17	99	70
350	9.1	40.5	0.0	7.4	17	99	70
351	9.0	41.4	0.0	7.6	17	99	70
352	7.9	40.0	0.0	6.6	17	99	70
353	8.8	40.2	0.0	7.4	17	99	70
354	8.4	41.4	0.0	7.0	17	99	70
355	8.3	45.1	0.0	7.0	17	99	70
356	8.9	43.1	0.0	7.4	17	99	70
357	7.6	45.8	0.0	6.4	17	99	70
358	5.7	41.0	0.0	4.8	17	99	70
359	7.1	38.9	0.0	5.9	17	99	70
360	7.8	38.1	0.0	6.8	17	99	71
361	8.5	37.9	0.0	7.1	17	99	71
362	8.0	37.0	0.0	6.7	17	99	71
363	7.2	38.7	0.0	6.1	17	99	71
364	6.0	39.2	0.0	5.0	17	99	71
365	8.3	38.2	0.0	6.3	17	99	71
366	7.1	38.7	0.0	6.0	17	99	71
367	7.8	43.4	0.0	6.6	17	99	71
368	8.3	42.5	0.0	7.0	17	99	71
369	7.6	44.7	0.0	6.4	17	99	71
370	8.0	43.1	0.0	6.9	17	99	71
371	7.4	42.1	0.0	6.2	17	99	71
372	6.3	39.9	0.0	5.3	17	99	71
373	7.3	43.9	0.0	6.1	17	99	71
374	7.1	39.5	0.0	6.0	17	99	71
375	6.4	39.1	0.0	5.4	17	99	71
376	5.8	41.3	0.0	4.9	17	99	71
377	7.4	42.7	0.0	6.2	17	99	71
378	7.7	39.7	0.0	6.5	17	99	71
379	10.2	39.9	0.0	8.6	17	99	71
380	10.5	40.2	0.0	8.8	17	99	71
381	9.5	40.3	0.0	8.0	17	99	71
382	9.2	38.6	0.0	7.7	17	99	71
383	9.4	39.6	0.0	7.9	17	99	71
384	8.5	39.1	0.0	7.1	17	99	71
385	7.5	38.6	0.0	6.5	17	99	71
386	7.9	37.1	0.0	6.6	17	99	71
387	8.2	38.7	0.0	6.8	17	99	71
388	8.9	38.0	0.0	7.4	17	99	71
389	8.9	37.2	0.0	7.5	17	99	71
390	7.7	38.2	0.0	6.4	17	99	71
391	7.4	40.0	0.0	6.2	17	99	71
392	6.7	38.0	0.0	5.6	17	99	71
393	6.9	38.9	0.0	5.8	17	99	71
394	7.1	39.6	0.0	5.9	17	99	71
395	6.6	39.3	0.0	5.6	17	99	71
396	6.2	40.7	0.0	5.2	17	100	72
397	5.9	35.7	0.0	4.9	17	100	72
398	7.2	36.9	0.0	6.0	17	100	72
399	8.0	37.0	0.0	6.7	17	100	72
400	7.1	39.6	0.0	5.9	17	100	72
401	9.0	38.4	0.0	7.5	17	100	72
402	6.9	38.9	0.0	5.8	17	100	72
403	7.2	41.6	0.0	6.1	17	100	72
404	8.2	40.7	0.0	6.9	17	100	72
405	9.4	40.2	0.0	7.9	17	100	72
406	9.2	42.6	0.0	7.7	17	100	72
407	8.7	38.3	0.0	7.3	17	100	72
408	8.2	37.3	0.0	6.9	17	100	72
409	7.7	37.1	0.0	6.5	17	100	72
410	7.1	37.8	0.1	6.0	17	100	72
411	8.1	42.3	0.0	6.8	17	100	72
412	6.8	42.6	0.0	5.7	17	100	72
413	7.9	43.2	0.0	6.6	17	100	72
414	7.6	45.6	0.0	6.4	17	100	72
415	6.2	46.2	0.0	5.2	17	100	72

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording

Data Point #	Standardized Wind Speed	LAeq	Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (C)	Pressure (Pa)	Relative Humidity (%)
416	6.5	42.5	0.0	5.5	17	100	72
417	6.1	42.7	0.0	5.1	17	100	72
418	5.4	41.5	0.1	4.5	17	100	72
419	6.3	41.5	0.0	5.3	17	100	72
420	9.2	40.8	0.0	7.7	17	100	72
421	9.9	38.5	0.0	8.3	17	100	72
422	8.7	38.1	0.0	7.3	17	100	72



# Table E.02 Measurement data - Background

Project: Niagara Wind Farm - Turbine T35 - IEC 61400-11 Measurement  
 Report ID: 16227.00.T35.RP1

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording.

Data Point #	Standardized Wind Speed	LAeq	Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (Pa)	Relative Humidity (%)
499	6.9	40.3	0.0	5.8	17	100	73
500	6.3	37.1	0.0	5.3	17	100	73
501	6.2	40.0	0.0	5.2	17	100	73
502	6.3	37.2	0.0	5.3	17	100	73
503	6.3	36.6	0.0	5.3	17	100	73
504	7.0	38.1	0.0	5.8	17	100	73
505	7.4	36.0	0.0	6.2	17	100	73
506	7.4	35.7	0.0	6.2	17	100	73
507	7.2	36.6	0.0	6.0	17	100	73
508	6.6	35.8	0.0	5.6	17	100	73
509	8.5	35.7	0.0	7.1	17	100	73
510	6.9	36.1	0.0	5.8	17	100	73
511	8.1	37.9	0.0	6.8	17	100	73
512	8.0	36.4	0.0	6.7	17	100	73
513	8.3	36.9	0.0	7.0	17	100	73
514	8.3	36.7	0.0	6.9	17	100	73
515	6.7	37.8	0.0	5.6	17	100	73
516							
517							
518							
519							
520							
521							
522							
523							
524							
525							
526							
527							
528							
529							
530							
531							
532							
533							
534							
535							
536							
537							
538							
539							
540							
541							
542							
543							
544							
545							
546							
547							
548							
549							
550							
551							
552							
553							
554							
555							
556							
557							
558							
559							
560							
561							
562							
563							
564							
565							
566							
567							
568							
569							
570							
571							
572							
573							
574							
575							
576							
577							
578							
579							
580							
581							

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording.

Data Point #	Standardized Wind Speed	LAeq	Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (Pa)	Relative Humidity (%)
582							
583							
584							
585							
586							
587							
588							
589							
590							
591							
592							
593							
594							
595							
596							
597							
598							
599							
600							
601							
602							
603							
604							
605							
606							
607							
608							
609							
610							
611							
612							
613							
614							
615							
616							
617							
618							
619							
620							
621							
622							
623							
624							
625							
626							
627							
628							
629							
630							
631							
632							
633							
634							
635							
636							
637							
638							
639							
640							
641							
642							
643							
644							
645							
646							
647							
648							
649							
650							
651							
652							
653							
654							
655							
656							
657							
658							
659							
660							
661							
662							
663							
664							

\*\*\*Blank data denotes values that were omitted in the analysis due to an extraneous event during recording.

Data Point #	Standardized Wind Speed	LAeq	Rotor RPM	10m Anemometer Wind Speed (m/s)	Air Temperature (°C)	Pressure (Pa)	Relative Humidity (%)
665							
666							
667							
668							
669							
670							
671							
672							
673							
674							
675							
676							
677							
678							
679							
680							
681							
682							
683							
684							
685							
686							
687							
688							
689							
690							
691							
692							
693							
694							
695							
696							
697							
698							
699							
700							
701							
702							
703							
704							
705							
706							
707							
708							
709							
710							
711							
712							
713							
714							
715							
716							
717							
718							
719							
720							
721							
722							
723							
724							
725							
726							
727							
728							
729							
730							
731							
732							
733							
734							
735							
736							
737							
738							
739							
740							
741							
742							
743							
744							
745							
746							
747							

---

**End of Report**

---