

Client Devon Canada	Date of Inspection 08/13/2012 - 08/17-20'	Report Number RB - 120817 -001
Facility Maple Glen Gas Plant	Time of Inspection 17:00	W.O. Number 20015628
Attention Cam Busby	NDE Procedure UT-0001	P.O. Number NA

Job Description and Details

Equipment ID Condensate Storage Bullets	Surface Condition Painted, Acceptable
Material Type and Thickness SA 612	Surface Temperature Ambient

Method and Reference Documentation

Method / Type Contact P/A	Cable Type, Length Integral PAUT
Instrument Used Olympus MX2 PA 32/128	2nd Cable Type & Length Integral PAUT
Instrument S.N. 600427 / 100843	Couplant Used Water
Last Inst. Cal. Date Mar-12	Acceptance Criteria Client Information

Transducer						dB Settings			
Manufacturer	Type	Serial No.	Angle	Frequency	Size	Reference	Scan	(-) Transfer Value (+)	
Olympus	A105L16	J4220	44°-70°	5MHz	NA	1.5mm SDH	6+	NA	NA
Olympus	A105L16	K0249	44°-70°	5MHz	NA	1.5mm SDH	6+	NA	NA

Calibration Data						Additional Equipment	
Calibration / Reference Block(s)	Serial No.	Last Cal. Date	Reference Reflector(s)	Indication Amplitude(s)	Distance Reading(s)	Equipment Type	Serial No.
IIW	110411	08-13-2012	1.5mm SDH	80%	NA		

Scope

We were asked to perform Phased Array inspection of 100% of the welds on the following two Condensate Storage Bullets located at the Maple Glen Gas Plant (16-36-036-16W4). A0151944 and A0151945. This is an in-service client information inspection only.

The scan plan shall be built to employ sectorial PAUT to observe the inner 1/3rd of the weld in order to quantify any signs of ID cracking. To note, the weld profile has been built according to available data from the U1-A form. Actual bevel angle may be different.




Figure 1 - PAUT Scan Plan

* See continuation report for further scope and results.

Technician Name Henk Stinis	Client Representative Cam Busby
CGSB Level & Cert. Number UT III 13457	Signature
Signature	

This form property of Ultratest NDT Services • 5925 91St Edmonton, Alberta T6E 6A7 • www.ultratest.ca

Report is an interpretation of test results, not a guarantee. The client representative's signature indicates acceptance of results and applicable charges.

Client Devon Canada
Facility Maple Glen Gas Plant
Attention Cam Busby

Date of Inspection 08/13/2012 - 08/17-201:
Time of Inspection 17:00
NDE Procedure UT-0001

Report Number RB - 120817 -001
W.O. Number 20015628
P.O. Number NA

Scope - Continued

When discontinuities are encountered that may be indicative of ID connected cracking, they shall be imaged with TOFD to determine extent and only whether the indication is crack like or not. Due to the original joint efficiency requirements, this inspection shall not be utilized to determine acceptability of the weld in accordance to code of construction.

The Bullet on the North side of the plant is called tank north, the Bullet on the South side is called tank south. The 'direction of flow' of the tanks is assumed to be from west to east, naming the outer most circular weld on the west side number 1. All circular welds are scanned in four sections, 12 to 3 o'clock, 3 to 6 o'clock, 9 to 6 o'clock and 12 to 9 o'clock. The longitudinal welds on the heads are scanned clockwise, naming the 12 o'clock position 'zero'.

Summary Report

146 data sets were captured, giving 100% coverage of all welds for each vessel. 19 relevant indications were detected, 2 of which are interpreted as crack like. As a cautionary note the other 17 indications may pose a risk to develop into cracks in the future. A monitoring protocol may be wise until such time that a visual internal can be completed. Refer to Figures A and B for crack like indication detail.

Detail Report - PAUT Data sets and description.

Filename:	Tank	Weld	Nr	WT	Scan length	Indications	Filename:	Tank	Weld	Nr	WT	Scan length	Indications
N_U_12_3_1_S01	North	Circular	1	20mm	12 to 3 o'clock	Yes, Nr 1	S_U_12_3_1_S01	South	Circular	1	20mm	12 to 3 o'clock	Yes, Nr 14
N_U_3_6_1_S01	North	Circular	1	20mm	3 to 6 o'clock		S_U_3_6_1_S01	South	Circular	1	20mm	3 to 6 o'clock	
N_U_9_6_1_S01	North	Circular	1	20mm	9 to 6 o'clock		S_U_9_6_1_S01	South	Circular	1	20mm	9 to 6 o'clock	Yes, Nr 15
N_U_12_9_1_S01	North	Circular	1	20mm	12 to 9 o'clock		S_U_12_9_1_S01	South	Circular	1	20mm	12 to 9 o'clock	
N_U_12_3_2_S01	North	Circular	2	20mm	12 to 3 o'clock		S_U_12_3_2_S01	South	Circular	2	20mm	12 to 3 o'clock	Yes, Nr 16
N_U_3_6_2_S01	North	Circular	2	20mm	3 to 6 o'clock	Yes, Nr 2	S_U_3_6_2_S01	South	Circular	2	20mm	3 to 6 o'clock	
N_U_9_6_2_S01	North	Circular	2	20mm	9 to 6 o'clock		S_U_9_6_2_S01	South	Circular	2	20mm	9 to 6 o'clock	
N_U_12_9_2_S01	North	Circular	2	20mm	12 to 9 o'clock		S_U_12_9_2_S01	South	Circular	2	20mm	12 to 9 o'clock	
N_U_12_3_3_S01	North	Circular	3	20mm	12 to 3 o'clock		S_U_12_3_3_S01	South	Circular	3	20mm	12 to 3 o'clock	
N_U_3_6_3_S01	North	Circular	3	20mm	3 to 6 o'clock		S_U_3_6_3_S01	South	Circular	3	20mm	3 to 6 o'clock	
N_U_9_6_3_S01	North	Circular	3	20mm	9 to 6 o'clock	Yes, Nr 3	S_U_9_6_3_S01	South	Circular	3	20mm	9 to 6 o'clock	
N_U_12_9_3_S01	North	Circular	3	20mm	12 to 9 o'clock		S_U_12_9_3_S01	South	Circular	3	20mm	12 to 9 o'clock	
N_U_12_3_4_S01	North	Circular	4	20mm	12 to 3 o'clock	Yes, Nr 4	S_U_12_3_4_S01	South	Circular	4	20mm	12 to 3 o'clock	
N_U_3_6_4_S01	North	Circular	4	20mm	3 to 6 o'clock		S_U_3_6_4_S01	South	Circular	4	20mm	3 to 6 o'clock	
N_U_9_6_4_S01	North	Circular	4	20mm	9 to 6 o'clock	Yes, Nr 5	S_U_9_6_4_S01	South	Circular	4	20mm	9 to 6 o'clock	
N_U_12_9_4_S01	North	Circular	4	20mm	12 to 9 o'clock	Yes, Nr 6	S_U_12_9_4_S01	South	Circular	4	20mm	12 to 9 o'clock	
N_U_12_3_5_S01	North	Circular	5	20mm	12 to 3 o'clock	Yes, Nr 7	S_U_12_3_5_S01	South	Circular	5	20mm	12 to 3 o'clock	
N_U_3_6_5_S01	North	Circular	5	20mm	3 to 6 o'clock	Yes, Nr 8	S_U_3_6_5_S01	South	Circular	5	20mm	3 to 6 o'clock	
N_U_9_6_5_S01	North	Circular	5	20mm	9 to 6 o'clock	Yes, Nr 9	S_U_9_6_5_S01	South	Circular	5	20mm	9 to 6 o'clock	
N_U_12_9_5_S01	North	Circular	5	20mm	12 to 9 o'clock		S_U_12_9_5_S01	South	Circular	5	20mm	12 to 9 o'clock	
N_U_12_3_6_S01	North	Circular	6	20mm	12 to 3 o'clock		S_U_12_3_6_S01	South	Circular	6	20mm	12 to 3 o'clock	
N_U_3_6_6_S01	North	Circular	6	20mm	3 to 6 o'clock		S_U_3_6_6_S01	South	Circular	6	20mm	3 to 6 o'clock	
N_U_9_6_6_S01	North	Circular	6	20mm	9 to 6 o'clock		S_U_9_6_6_S01	South	Circular	6	20mm	9 to 6 o'clock	
N_U_12_9_6_S01	North	Circular	6	20mm	12 to 9 o'clock		S_U_12_9_6_S01	South	Circular	6	20mm	12 to 9 o'clock	
N_U_12_3_7_S01	North	Circular	7	20mm	12 to 3 o'clock		S_U_12_3_7_S01	South	Circular	7	20mm	12 to 3 o'clock	
N_U_3_6_7_S01	North	Circular	7	20mm	3 to 6 o'clock		S_U_3_6_7_S01	South	Circular	7	20mm	3 to 6 o'clock	
N_U_9_6_7_S01	North	Circular	7	20mm	9 to 6 o'clock		S_U_9_6_7_S01	South	Circular	7	20mm	9 to 6 o'clock	
N_U_12_9_7_S01	North	Circular	7	20mm	12 to 9 o'clock		S_U_12_9_7_S01	South	Circular	7	20mm	12 to 9 o'clock	
N_U_12_3_8_S01	North	Circular	8	20mm	12 to 3 o'clock		S_U_12_3_8_S01	South	Circular	8	20mm	12 to 3 o'clock	
N_U_3_6_8_S01	North	Circular	8	20mm	3 to 6 o'clock	Yes, Nr 10	S_U_3_6_8_S01	South	Circular	8	20mm	3 to 6 o'clock	
N_U_9_6_8_S01	North	Circular	8	20mm	9 to 6 o'clock		S_U_9_6_8_S01	South	Circular	8	20mm	9 to 6 o'clock	
N_U_12_9_8_S01	North	Circular	8	20mm	12 to 9 o'clock	Yes, Nr 11	S_U_12_9_8_S01	South	Circular	8	20mm	12 to 9 o'clock	
N_U_12_3_9_S01	North	Circular	9	20mm	12 to 3 o'clock		S_U_12_3_9_S01	South	Circular	9	20mm	12 to 3 o'clock	
N_U_3_6_9_S01	North	Circular	9	20mm	3 to 6 o'clock	Yes, Nr 12	S_U_3_6_9_S01	South	Circular	9	20mm	3 to 6 o'clock	Yes, Nr 17
N_U_9_6_9_S01	North	Circular	9	20mm	9 to 6 o'clock		S_U_9_6_9_S01	South	Circular	9	20mm	9 to 6 o'clock	
N_U_12_9_9_S01	North	Circular	9	20mm	12 to 9 o'clock		S_U_12_9_9_S01	South	Circular	9	20mm	12 to 9 o'clock	Yes, Nr 18
N_U_12_3_10_S01	North	Circular	10	20mm	12 to 3 o'clock		S_U_12_3_10_S01	South	Circular	10	20mm	12 to 3 o'clock	
N_U_3_6_10_S01	North	Circular	10	20mm	3 to 6 o'clock		S_U_3_6_10_S01	South	Circular	10	20mm	3 to 6 o'clock	
N_U_9_6_10_S01	North	Circular	10	20mm	9 to 6 o'clock		S_U_9_6_10_S01	South	Circular	10	20mm	9 to 6 o'clock	
N_U_12_9_10_S01	North	Circular	10	20mm	12 to 9 o'clock	Yes, Nr 13	S_U_12_9_10_S01	South	Circular	10	20mm	12 to 9 o'clock	
N_U_12_3_11_S01	North	Circular	11	20mm	12 to 3 o'clock		S_U_12_3_11_S01	South	Circular	11	20mm	12 to 3 o'clock	
N_U_3_6_11_S01	North	Circular	11	20mm	3 to 6 o'clock		S_U_3_6_11_S01	South	Circular	11	20mm	3 to 6 o'clock	
N_U_9_6_11_S01	North	Circular	11	20mm	9 to 6 o'clock		S_U_9_6_11_S01	South	Circular	11	20mm	9 to 6 o'clock	
N_U_12_9_11_S01	North	Circular	11	20mm	12 to 9 o'clock		S_U_12_9_11_S01	South	Circular	11	20mm	12 to 9 o'clock	Yes, Nr 19
N_U_12_3_12_S01	North	Circular	12	20mm	12 to 3 o'clock		S_U_12_3_12_S01	South	Circular	12	20mm	12 to 3 o'clock	
N_U_3_6_12_S01	North	Circular	12	20mm	3 to 6 o'clock		S_U_3_6_12_S01	South	Circular	12	20mm	3 to 6 o'clock	
N_U_9_6_12_S01	North	Circular	12	20mm	9 to 6 o'clock		S_U_9_6_12_S01	South	Circular	12	20mm	9 to 6 o'clock	
N_U_12_9_12_S01	North	Circular	12	20mm	12 to 9 o'clock		S_U_12_9_12_S01	South	Circular	12	20mm	12 to 9 o'clock	

Technician Name Henk Stinis
CGSB Level & Cert. Number UT III 13457
Signature

Client Representative Cam Busby
Signature

This form property of Ultratest NDT Services • 5925 91St Edmonton, Alberta T6E 6A7 • www.ultratest.ca

Report is an interpretation of test results, not a guarantee. The client representative's signature indicates acceptance of results and applicable charges.

Client Devon Canada
Facility Maple Glen Gas Plant
Attention Cam Busby

Date of Inspection 08/13/2012 - 08/17-2012
Time of Inspection 17:00
NDE Procedure UT-0001

Report Number RB - 120817 -001
W.O. Number 20015628
P.O. Number NA

Detail Report - PAUT Data sets and description - Continued.

Filename:	Tank	Weld	Nr	WT	Scan length	Indications
N_L_1_S01	North	Longitudinal	1	20mm	2200mm	
N_L_2_S01	North	Longitudinal	2	20mm	2200mm	
N_L_3_S01	North	Longitudinal	3	20mm	2200mm	
N_L_4_S01	North	Longitudinal	4	20mm	2200mm	
N_L_5_S01	North	Longitudinal	5	20mm	2200mm	
N_L_6_S01	North	Longitudinal	6	20mm	2200mm	
N_L_7_S01	North	Longitudinal	7	20mm	2200mm	
N_L_8_S01	North	Longitudinal	8	20mm	2200mm	
N_L_9_S01	North	Longitudinal	9	20mm	2200mm	
N_L_10_S01	North	Longitudinal	10	20mm	2200mm	
N_L_11_S01	North	Longitudinal	11	20mm	2200mm	
S_L_1_S01	South	Longitudinal	1	20mm	2200mm	
S_L_2_S01	South	Longitudinal	2	20mm	2200mm	
S_L_3_S01	South	Longitudinal	3	20mm	2200mm	
S_L_4_S01	South	Longitudinal	4	20mm	2200mm	
S_L_5_S01	South	Longitudinal	5	20mm	2200mm	
S_L_6_S01	South	Longitudinal	6	20mm	2200mm	
S_L_7_S01	South	Longitudinal	7	20mm	2200mm	
S_L_8_S01	South	Longitudinal	8	20mm	2200mm	
S_L_9_S01	South	Longitudinal	9	20mm	2200mm	
S_L_10_S01	South	Longitudinal	10	20mm	2200mm	
S_L_11_S01	South	Longitudinal	11	20mm	2200mm	
N_H_E_1_S01	North	Head East	1	14mm	1665mm	
N_H_E_2_S01	North	Head East	2	14mm	1665mm	
N_H_E_3_S01	North	Head East	3	14mm	1665mm	
N_H_E_4_S01	North	Head East	4	14mm	1665mm	
N_H_E_5_S01	North	Head East	5	14mm	1665mm	
N_H_E_6_S01	North	Head East	6	14mm	1665mm	
N_H_E_C_S01	North	Head East	C	14mm	5300mm	
N_H_W_1_S01	North	Head West	1	14mm	1665mm	
N_H_W_2_S01	North	Head West	2	14mm	1665mm	
N_H_W_3_S01	North	Head West	3	14mm	1665mm	
N_H_W_4_S01	North	Head West	4	14mm	1665mm	
N_H_W_5_S01	North	Head West	5	14mm	1665mm	
N_H_W_6_S01	North	Head West	6	14mm	1665mm	
N_H_W_C_S01	North	Head West	C	14mm	5300mm	
S_H_E_1_S01	South	Head East	1	14mm	1665mm	
S_H_E_2_S01	South	Head East	2	14mm	1665mm	
S_H_E_3_S01	South	Head East	3	14mm	1665mm	
S_H_E_4_S01	South	Head East	4	14mm	1665mm	
S_H_E_5_S01	South	Head East	5	14mm	1665mm	
S_H_E_6_S01	South	Head East	6	14mm	1665mm	
S_H_E_C_S01	South	Head East	C	14mm	5300mm	
S_H_W_1_S01	South	Head West	1	14mm	1665mm	
S_H_W_2_S01	South	Head West	2	14mm	1665mm	
S_H_W_3_S01	South	Head West	3	14mm	1665mm	
S_H_W_4_S01	South	Head West	4	14mm	1665mm	
S_H_W_5_S01	South	Head West	5	14mm	1665mm	
S_H_W_6_S01	South	Head West	6	14mm	1665mm	
S_H_W_C_S01	South	Head West	C	14mm	5300mm	

Technician Name Henk Stinis
CGSB Level & Cert. Number UT III 13457
Signature

Client Representative Cam Busby
Signature

This form property of Ultratest NDT Services • 5925 91St Edmonton, Alberta T6E 6A7 • www.ultratest.ca

Report is an interpretation of test results, not a guarantee. The client representative's signature indicates acceptance of results and applicable charges.

Client Devon Canada
Facility Maple Glen Gas Plant
Attention Cam Busby

Date of Inspection 08/13/2012 - 08/17-2012
Time of Inspection 17:00
NDE Procedure UT-0001

Report Number RB - 120817 -001
W.O. Number 20015628
P.O. Number NA

Detail Report - Discontinuity Identification

Nr	Filename:	Tank	Weld	Nr	WT	Scan length	Crack-like
1	N_C_12_3_1_500mm_S01	North	Circular	1	20mm	500-620	No
2	N_C_3_6_2_1900mm_S01	North	Circular	2	20mm	1700-1900	No
3	N_C_9_6_3_2400_S01	North	Circular	3	20mm	2400-2700	No
4	N_C_12_3_4_250mm_S01	North	Circular	4	20mm	250-400	No
5	N_C_9_6_4_0mm_S01	North	Circular	4	20mm	0-2700	No
6	N_C_12_9_4_1000mmS01	North	Circular	4	20mm	1000-1150	No
7	N_C_12_3_5_1400mm_S01	North	Circular	5	20mm	1400-1700	No
8	N_C_3_6_5_1400mm_S01	North	Circular	5	20mm	1400-1500	No
9	N_C_9_6_5_2000mm_S01	North	Circular	5	20mm	2000-2100	No
10	N_C_3_6_8_1100mm_S01	North	Circular	8	20mm	1100-1200	YES
11	N_C_12_9_8_300mm_S01	North	Circular	8	20mm	300-600	No
12	N_C_3_6_9_0mm_S01	North	Circular	9	20mm	0-1000	YES
13	N_C_12_9_10_200mm_S01	North	Circular	10	20mm	200-400	No
14	S_C_12_3_1_2200mmS01	South	Circular	1	20mm	2200-2400	No
15	S_C_9_6_1_500mm_S01	South	Circular	1	20mm	500-700	No
16	S_C_12_3_2_1200mm_S01	South	Circular	2	20mm	1200-1700	No
17	S_C_3_6_9_2200mm_S01	South	Circular	9	20mm	2200-2400	No
18	S_C_12_9_9_400mm_S01	South	Circular	9	20mm	400-550	No
19	S_C_12_9_11_1200mm_S01	South	Circular	11	20mm	1200-1600	No




Figure A - Indication number 10

Technician Name Henk Stinis
CGSB Level & Cert. Number UT III 13457
Signature

Client Representative Cam Busby
Signature

This form property of Ultratest NDT Services • 5925 91St Edmonton, Alberta T6E 6A7 • www.ultratest.ca

Report is an interpretation of test results, not a guarantee. The client representative's signature indicates acceptance of results and applicable charges.

Client Devon Canada
Facility Maple Glen Gas Plant
Attention Cam Busby

Date of Inspection 08/13/2012 - 08/17-201:
Time of Inspection 17:00
NDE Procedure UT-0001

Report Number RB - 120817 -001
W.O. Number 20015628
P.O. Number NA

Detail Report - Discontinuity Identification





Figure B - Indication number 12

Comments on Figures A and B (Indications 10 and 12)

Indication 10 measures Length: 46mm (1129 to 1175) Height: 3mm (17 to 20). Indication 12 measures Length: 103mm (100 to 203) Height: 1.5mm (18.5 to 20). While these indications certainly appear to be ID connected, without full knowledge of the weld bevel and internal weld profile (caps ground flush?) these has to be some caution in analysis. These indications may turn out to be undercut or small areas of cold lap. Future monitoring to look for signs of growth would be prudent, however these indications may be easily classified with the next internal inspection by visual or magnetic particle methods.

Images of Relevant Indications

The following pages contain the images of both the PAUT and TOFD for the 19 relevant indications detected during the inspection.



Technician Name Henk Stinis
CGSB Level & Cert. Number UT III 13457
Signature

Client Representative Cam Busby
Signature


This form property of Ultratest NDT Services • 5925 91St Edmonton, Alberta T6E 6A7 • www.ultratest.ca

Report is an interpretation of test results, not a guarantee. The client representative's signature indicates acceptance of results and applicable charges.


Client Devon CanadaFacility Maple Glen Gas PlantAttention Cam BusbyDate of Inspection 08/13/2012 - 08/17-2012Time of Inspection 17:00NDE Procedure UT-0001Report Number RB - 120817 -001W.O. Number 20015628P.O. Number NA

Images of Relevant Indications - Continued


Indication 2 in PA




Indication 2 in TOFD




Indication 3 in PA




Indication 3 in TOFD



Indication 4 in PA



Indication 4 in TOFD

Technician Name Henk StinisCGSB Level & Cert. Number UT III 13457

Signature _____

Client Representative Cam Busby


Signature _____

This form property of Ultratest NDT Services • 5925 91st Edmonton, Alberta T6E 6A7 • www.ultratest.ca

Report is an interpretation of test results, not a guarantee. The client representative's signature indicates acceptance of results and applicable charges.

Client Devon CanadaFacility Maple Glen Gas PlantAttention Cam BusbyDate of Inspection 08/13/2012 - 08/17-2012Time of Inspection 17:00NDE Procedure UT-0001Report Number RB - 120817 -001W.O. Number 20015628P.O. Number NA

Images of Relevant Indications - Continued

Technician Name Henk StinisCGSB Level & Cert. Number UT III 13457

Signature _____

Client Representative Cam Busby

Signature _____

This form property of Ultratest NDT Services • 5925 91st Edmonton, Alberta T6E 6A7 • www.ultratest.ca







Report is an interpretation of test results, not a guarantee. The client representative's signature indicates acceptance of results and applicable charges.

Client Devon Canada
Facility Maple Glen Gas Plant
Attention Cam Busby

Date of Inspection 08/13/2012 - 08/17-201:
Time of Inspection 17:00
NDE Procedure UT-0001

Report Number RB - 120817 -001
W.O. Number 20015628
P.O. Number NA

Images of Relevant Indications - Continued

Indication 8 in PA**Indication 8 in TOFD****Indication 9 in PA****Indication 9 in TOFD****Indication 10 in PA****Indication 10 in TOFD**

Technician Name Henk Stinis
CGSB Level & Cert. Number UT III 13457
Signature

Client Representative Cam Busby
Signature

This form property of Ultratest NDT Services • 5925 91st Edmonton, Alberta T6E 6A7 • www.ultratest.ca


Report is an interpretation of test results, not a guarantee. The client representative's signature indicates acceptance of results and applicable charges.

Client Devon Canada
 Facility Maple Glen Gas Plant
 Attention Cam Busby

Date of Inspection 08/13/2012 - 08/17-2012
 Time of Inspection 17:00
 NDE Procedure UT-0001

Report Number RB - 120817 -001
 W.O. Number 20015628
 P.O. Number NA

Images of Relevant Indications - Continued



Technician Name Henk Stinis
 CGSB Level & Cert. Number UT III 13457
 Signature _____

Client Representative Cam Busby
 Signature _____

This form property of Ultratest NDT Services • 5925 91st Edmonton, Alberta T6E 6A7 • www.ultratest.ca


Report is an interpretation of test results, not a guarantee. The client representative's signature indicates acceptance of results and applicable charges.

Client Devon Canada
Facility Maple Glen Gas Plant
Attention Cam Busby

Date of Inspection 08/13/2012 - 08/17-201:
Time of Inspection 17:00
NDE Procedure UT-0001

Report Number RB - 120817 -001
W.O. Number 20015628
P.O. Number NA

Images of Relevant Indications - Continued



Technician Name Henk Stinis
CGSB Level & Cert. Number UT III 13457
Signature

Client Representative Cam Busby
Signature

This form property of Ultratest NDT Services • 5925 91st Edmonton, Alberta T6E 6A7 • www.ultratest.ca

Report is an interpretation of test results, not a guarantee. The client representative's signature indicates acceptance of results and applicable charges.

Client Devon Canada

Facility Maple Glen Gas Plant

Attention Cam Busby

Date of Inspection 08/13/2012 - 08/17/2012

Time of Inspection 17:00


NDE Procedure UT-0001

Report Number RB - 120817 -001

W.O. Number 20015628

P.O. Number NA

Images of Relevant Indications - Continued



Technician Name Henk Stinis

CGSB Level & Cert. Number UT III 13457

Signature

Client Representative Cam Busby

Signature

This form property of Ultratest NDT Services • 5925 91st Edmonton, Alberta T6E 6A7 • www.ultratest.ca

Report is an interpretation of test results, not a guarantee. The client representative's signature indicates acceptance of results and applicable charges.