



---

# Refrigeration Load Estimating Manual (RLE)

Technical Bulletin

---

Products that provide lasting solutions.



---

# **Engineering Manual**

## *Refrigeration Load Estimating*

**Krack Corporation**

©1992 Krack Corporation. All rights reserved. This work shall not be reproduced in whole or in part without expressed written permission.

Price \$5.00  
Printed in U.S.A.  
RLE-593

---

This Krack Manual was published for the purpose of providing a concise, complete and convenient load estimating reference volume for the commercial refrigeration industry. Application suggestions and unit cooler selection examples are representative for halocarbon direct expansion fed systems.

Load estimating data can be used for industrial refrigeration systems using ammonia or brine as the refrigerant.

Estimating guidelines and rules of thumb, are necessarily general in nature, and should not be utilized as the sole design criteria.

Product freezing and cooling data was developed in the Krack product testing laboratory. Other data has been extracted by permission from various ASHRAE Guide and Data Book publications.



# TABLE OF CONTENTS

---

<b>I.</b>	PRINCIPLES OF HEAT TRANSMISSION	4-5
<b>II.</b>	JOB SURVEY	6
<b>III.</b>	LOAD ESTIMATE	6-12
<b>IV.</b>	PSYCHROMETRICS	8
<b>V.</b>	APPLICATION EXAMPLES:	
	Fruit Chilling & Storage	13
	Blast Freezing	14
	Beef Carcass Chilling	15
	Beer Storage	16
	Nut Storage	17
	Distribution Centers	18
	Walk-In Coolers	19
<b>VI.</b>	APPENDIX – TABLES	20-48
<b>VII.</b>	APPENDIX – CHARTS	49-51
<b>VIII.</b>	INDEX OF APPENDIX	52

---

# PRINCIPLES OF HEAT TRANSMISSION

## PRELIMINARY CONSIDERATIONS

Calculation of the heat transfer through the walls, floor and ceiling of a refrigerated space requires determination of the overall coefficient of heat transmission (or 'U' value, as it is commonly called) for the building structure.

Accordingly, the procedures utilized to determine this coefficient, and the several factors which affect its value, are briefly discussed below.

It is to be noted that rapidly increasing energy costs have made obvious the desirability of optimum insulation efficiency. First-versus-operating cost comparisons are therefore worthwhile, and will often justify an increase in the indicated insulation thickness.

Letter symbols utilized herein are those most commonly employed to designate the various heat transfer factors.

## THERMAL CONDUCTIVITY (K)

Thermal conductivity is defined as the rate of heat transfer through a homogeneous material in Btu per hour per square foot of area per °F temperature differential per inch of thickness (NOTE: A homogeneous material is one whose thermal conductivity is essentially unaffected by a change in surface area or thickness).

Conduction heat transfer varies directly with thermal conductivity, surface area, temperature differential and time, and varies inversely with material thickness. Accordingly, the heat transfer into a refrigerated space may be reduced either by selecting an insulating medium with a lower K value, or by increasing the insulation thickness.

The daily heat transfer through any homogeneous material of a given thickness may be calculated by utilizing the following formula:

$$Q \text{ Btu} / 24 \text{ hrs} = \frac{K \times \text{Area}_{\text{sq ft}} \times \text{TD}_{\text{°F}} \times 24}{\text{Thickness}_{\text{in}}}$$

K always expresses a heat transfer value per inch of thickness in air conditioning and refrigeration considerations.

## CONDUCTANCE (C)

Thermal conductance (C) differs from thermal conductivity (K) only in that it is a heat transfer factor for a specific building material having a standard thickness. All non-homogeneous materials are necessarily rated in this manner (as opposed to K), examples being tile & concrete block. Building boards and paper, flooring materials, air spaces and various materials common in general construction are also rated by C values.

Thermal conductance is by definition, therefore, the rate of heat transfer through a specific material in Btu per hour per square foot of area per °F temperature differential.

Conductances for various material categories are tabulated in Table 1B in the Appendix.

It is to be noted that the formula listed above for calculating heat transfer through various thicknesses of homogeneous substances would not apply for materials rated by conductance.

## SURFACE FILM CONDUCTANCE (f)

The surface of any material offers an additional resistance to heat flow, with the absolute value being dependent upon its reflectivity, degree of roughness, attitude (vertical or horizontal), length and the air velocity over the surface.

The reciprocal of this resistance is the surface film conductance (f) which is expressed in the same units as conductance (ie, Btu per hour per square foot of area per °F temperature differential.)

Inside surface film conductance is designated by  $f_i$ , and may usually be estimated at **1.60** for walls in still air not exposed to outdoor conditions.

Outside surface film conductance is designated by  $f_o$ , and may be approximated at **6.0** for outdoor walls not exposed to winds in excess of 15 MPH.

# PRINCIPLES OF HEAT TRANSMISSION

## THERMAL RESISTANCE (R)

Thermal resistance is the resistance of a material to heat flow and is, by definition, the reciprocal of a given heat transfer coefficient (ie, C,  $f_i$ ,  $f_o$  etc.):

$$R = \frac{1}{C}$$

As an example, the conductance (C) of ½ inch plaster board (as obtained from Table 1B) is 2.25 Btu per hour per °F temperature differential per sq. ft. Accordingly, its resistance is:

$$R = \frac{1}{2.25} = 0.449^\circ\text{F TD} / \text{sq ft} / \text{Btu} / \text{hr}$$

This means that a temperature differential of 0.449°F would be required to transfer 1 Btu of heat across 1 square foot of ½ inch plasterboard surface in 1 hour.

The practical significance of resistance (R) is that its values are additive thereby enabling the calculation of overall coefficients of heat transfer for compound structures, ie:

$$R_{\text{Total}} = R_1 + R_2 + R_3 \text{ ( etc )}$$

### OVERALL COEFFICIENT OF HEAT TRANSFER (U)

The overall coefficient of heat transfer of a given material or compound structure with parallel surfaces is commonly known as the U factor, and is expressed in the same units as conductance (ie, Btu per hour per square foot of area per °F temperature differential). It is most generally applied to compound structures such as roofs or walls.

As stated previously, resistance is the reciprocal of conductance and the individual resistances of a structure are additive. Accordingly, it is necessary to determine the overall resistance to heat transfer, and then its reciprocal, to calculate the U factor.

Overall resistance in a compound structure is:

$$R_{\text{Total}} = \frac{1}{C} + \frac{X_1}{K_1} + \frac{X_2}{K_2} + \frac{1}{f_1} + \frac{1}{f_0}$$

Where,

- C is the conductance (if it applies.)
- $X_1, X_2$ , etc. are material thicknesses.
- $K_1, K_2$ , etc. are conductivities.
- $f_i$  is the inside film conductance.
- $f_o$  is the outside film conductance.

The U factor is then calculated as follows:

$$U = \frac{1}{R_{\text{Total}}}$$

An example is useful in illustrating the above. A representative compound structure with parallel surfaces as depicted in Figure A has been selected for this purpose since it is dealt with frequently in refrigeration applications.




FIGURE A: EXAMPLE CROSS SECTION

In the above example,  $R_{\text{Total}}$  would equal:

$$R_{\text{Total}} = \frac{1}{0.90} + \frac{4}{0.38} + \frac{4}{0.38} + \frac{0.5}{0.80} + \frac{1}{1.60} + \frac{1}{6.0}$$

or,

$$R_{\text{Total}} = 23.58$$

and,

$$U_{\text{Overall}} = \frac{1}{R_{\text{Total}}} = \frac{1}{23.58} = 0.042$$

# JOB SURVEY AND LOAD ESTIMATE

---

## JOB SURVEY

Part II of Krack Survey and Load Estimate Form LE-1 is devoted to the job survey. All factors which affect the **rate** of heat gain must be detailed. It is suggested that each application be thoroughly reviewed with the operating personnel to determine facility operational characteristics, product pulldown requirements, packaging specifics and such other details as are peculiar to a given application.

Particular attention should be given to the means and frequency of product entrance, adjacent area pressure differentials, existing or required ventilation systems, and related operating characteristics which may produce infiltration loading above the norm (the average air changes detailed in Tables 4A and 4B are intended for standard applications only, and should not be used when specialized conditions prevail).

The product entrance rate, condition and type packaging must be determined to assure an accurate product load estimate. If an individual product is treated as a heat exchanger, the product refrigeration load is then

dependent upon its shape, size and type of packaging, as well as the more usual considerations of entering and leaving temperature differential, product type, entrance rate into the cooler, air temperature and velocity over the product and process duration. A prime purpose of the survey, therefore, is to determine the **rate of product heat evolution** (or rate of heat transfer from the product to the room). Specific examples of various product situations are given in the section devoted to the load estimate.

Part IV of Form LE-1 provides for a sketch of the refrigerated space. All relevant construction features such as column, door and partition locations, ceiling clearances, adjacent area conditions, etc. should be detailed. Supplemental photographs of significant building features are often part of a good survey. Additional survey requirements such as ambient design, room temperature, dimensional data, insulation type & thickness, electrical service and the various miscellaneous loads are self-explanatory.

---

## LOAD ESTIMATE

### GENERAL

Part III of Krack Form LE-1 is devoted to calculation of the refrigeration load. Five sources of heat gain must be estimated:

- **Wall, floor, & ceiling transmission load**
- **Solar load**
- **Infiltration load**
- **Product load**
- **Supplemental load**

Optimum and efficient equipment selection is dependent upon an accurate determination of each of the above loads.

A brief discussion of each heat gain source follows, with references made where appropriate to factors and data charted in the appendix.

### TRANSMISSION LOAD

The heat transmission into a refrigerated space through its ceiling, floor and walls is a function of the outside surface area, the temperature differential between the room and its surrounding area and the thermal conductivity of the insulation utilized.

Table 1A converts thermal conductivity ('K' in Btu / hour / sq ft / °F temperature differential / inch of thickness) to 24 hour heat gain factors for various thicknesses of commonly used insulation materials at temperature differentials from 1 to 130°F. These factors should be inserted where indicated in Part III, Section A of Form LE-1, and multiplied by surface area to obtain the 24 hour transmission heat gain.

For materials other than those tabulated, or for compound structures, refer to Table 1B for the appropriate thermal conductivities and calculate the overall coefficient of heat transfer (U) as illustrated in the foregoing section. This is then converted to a daily heat gain factor by utilizing the following formula:

# LOAD ESTIMATE

$$\text{Heat Gain Factor} = 24 \times U \times TD$$

Btu / sq ft / 24 hrs                      °F

It is common practice in calculating heat transmission for low temperature rooms to ignore the resistances of both surface films and the building structure proper since their overall effect is quite nominal.

Heat gain factors for various floor designs are tabulated at the bottom of Table 1A. It is the usual practice to assume a factor of 1 Btu / sq ft / °F / 24 hrs for freezer floors with conventional insulation.

## SOLAR LOAD

The heat gain through solar radiation is a function of the exposure, type of surface, latitude, altitude, time of year, time of day and other factors. For load estimating purposes, however, this sun effect can be compensated for by adding the degrees shown in Table 2 to the normal temperature differential as indicated in Section A of the load calculation form.

In instances where the refrigerated facility is on (or adjacent to) a highly reflective surface such as sand or water, the allowances shown in Table 2 should be increased by 50%

## INFILTRATION LOAD

Infiltration into a refrigerated room will occur when a door is opened as a result of the difference in density between the warm and cold air.

Since door openings vary widely, it the usual practice to estimate infiltration in air changes per 24 hours as shown in Tables 4-A and 4-B. This may then be factored by the room volume and the heat removed in cooling outside air to storage conditions in Btu/cu ft as tabulated in Table 5 to obtain the infiltration load. Space is provided in Part III, Section B of Form LE-1 for computation of this load.

Infiltration may be determined more precisely by calculating the air velocity through the door, the door area and the heat removed in cooling entering air to room conditions, and then estimating the average number of minutes per hour that the door will be open.

The average air velocity in either half of a door 7 feet high at a 60°F temperature differential is 100 feet per minute. Since velocity varies directly with the square root of the doorway height and the square root of the temperature differential across the door, actual air

velocity for any set of conditions may be calculated by utilizing the following formula:

$$\text{Vel fpm} = 100 \times \frac{\sqrt{H}}{\sqrt{7}} \times \frac{\sqrt{TD}}{\sqrt{60}}$$

or,

$$\text{Vel fpm} = 4.88 \times \sqrt{H} \times \sqrt{TD}$$

As an example, the velocity thru a door 8 ft wide and 9 ft high, with a temperature differential of 100°F, is:

$$\text{Vel} = 4.88 \times \sqrt{9} \times \sqrt{100}$$

$$\text{Vel} = 146.4 \text{ fpm}$$

Were the door in this example open 15 min per hour in a 12 hour shift operation, the 24 hour infiltration would be computed as follows:

$$\text{Cu ft} = \text{Vel fpm} \times \frac{\text{Door Area ft}^2}{2} \times \text{Time Open min}$$

or,

$$\text{Cu ft} = 146.4 \times \frac{(8 \times 9)}{2} \times 180 = 948,672$$

This would then be factored by the heat gain per cu ft from Table 5 in the usual way. An alternate approach is to determine the enthalpy difference between room and entering air from the psychrometric chart, and utilize the following formula:

$$\text{Heat Gain Btu / 24 hrs} = 24 \times 4.5' \times \text{Cfm} \times \Delta h$$

or,

$$\text{Heat Gain Btu / 24 hrs} = 108 \times \text{Cfm} \times \Delta h$$

In cases where positive ventilation is applied to a space, this load would then replace the infiltration load (if greater).

Note 1: Converts Cfm to lbs/hr (refer to Table 48, Pg. 47).



# LOAD ESTIMATE

## PSYCHROMETRICS

The Psychrometric Chart is utilized to determine the infiltration heat gain for specialized conditions, or for temperature changes not tabulated in Table 5.

Charts 2 and 3 at the rear of the Appendix are applicable to normal temperature (32°F to 130°F) and low temperature (-40°F to 50°F) conditions, respectively. Both charts are based on a standard atmospheric (or sea level) pressure of 29.921 in Hg, and must be corrected for other altitudes.


For purposes of approximating infiltration loads at higher altitudes, it may be assumed that:

- Relative humidity (rh) remains constant,
- Enthalpy (h) and humidity ratio (w) increase 2% and 5% respectively per 1000 ft increase in altitude, and,
- Volume (v) for a given dry bulb and humidity ratio is inversely proportional to atmospheric pressure.

Atmospheric pressures at various altitudes are tabulated at the bottom of Chart 3.

An example is useful in demonstrating the use of the psychrometric chart in the calculation of infiltration heat gain. Assuming an infiltration rate of 500 Cfm, an entering air condition of 95°F dbt & 50%rh and a cooler temperature of 45°F, characteristics of the entering and cooled air are first determined as in Figure B:

**CHART 2 (Pg. 50)**  
29.921 in Hg



**SCHEMATIC SOLUTION OF EXAMPLE**

As indicated in Figure B, the properties of the entering and cooled air are:

$$\begin{aligned} h_1 &= 42.58 \text{ Btu / lb of dry air} \\ w_1 &= 0.01780 \text{ lb H}_2\text{O / lb of dry air} \\ v_1 &= 14.25 \text{ Cu ft / lb of dry air} \\ h_2 &= 17.70 \text{ Btu / lb of dry air} \\ w_2 &= 0.00635 \text{ lb H}_2\text{O / lb of dry air} \end{aligned}$$

Infiltration heat gain may then be calculated as follows:

$$\begin{aligned} \text{Heat Gain Btu / hr} &= 4.5 \times \text{Cfm} \times (h_1 - h_2) \\ \text{or,} \\ Q &= 4.5 \times 500 \times (42.58 - 17.70) = 55,980 \text{ Btu / hr} \end{aligned}$$

For an 8 hour shift operation, the 24 hr infiltration heat gain would therefore be 447,840 Btu, and this load would be inserted in the space provided in Part III, Section B of Form LE-1.

The above calculation provides a conservative load estimate since it presupposes that the total heat removed from the entering air is transferred to the evaporated refrigerant. This is not the case in as much as heat leaves the coil box as well via the heat content of the condensate. Accordingly, precise calculation of the refrigeration load in any instance in which entering air is cooled below its dew point would be calculated as follows:

$$Q \text{ Btu / hr} = 4.5 \times \text{Cfm} [(h_1 - h_2) - (w_1 - w_2) h_w]$$

This effect is illustrated by comparing the 1.746 Btu / cu ft  $\left( \frac{42.58 - 17.70}{14.25} \right)$  heat removal indicated with the 1.710 Btu / cu ft tabulated in Table 5 for comparable conditions.

Additionally, the factor of 4.5 utilized to convert Cfm to lbs / hr incorporates the standard (70°F) dry air conversion factor of 13.33 cu ft / lb. Obviously, therefore, additional safety is built into the sample calculation since utilization of the actual entering volume of 14.25 cu ft / lb would result in a lower mass flow.

It is to be noted that the psychrometric chart is useful in calculating numerous other processes involving the conditioning or mixing of moist air, and that no attempt was made in this manual to fully develop the subject.

# LOAD ESTIMATE

## PRODUCT LOAD

The heat gain from product loading may consist of one or more of the following:

- Sensible heat removal above freezing
- Latent heat
- Sensible heat removal below freezing
- Heat of respiration

Sensible heat is calculated by factoring the **daily rate** of product in lbs per 24 hours by the temperature reduction and the product specific heat (the specific heat being the number of Btu's required to lower 1 lb of a substance 1 degree fahrenheit).

Latent heat is calculated by factoring the **daily rate** of product in lbs per 24 hours by the product latent heat of fusion (the latent heat being the number of Btu / lb required to freeze the product).

Applicable formulas are:

$$Q_{\text{Sens Btu}} / 24 \text{ hrs} = \text{Daily Rate} \times \Delta T \times \text{Sp. Ht.}$$

$$Q_{\text{Lat Btu}} / 24 \text{ hrs} = \text{Daily Rate} \times h_L \text{ Btu} / \text{lb}$$

Specific heats (above and below freezing) and the latent heats of fusion for commonly encountered products are detailed in Table 9. Product loads may be figured in the space provided under Part III, Section C of Form LE-1.

As stressed in prior comments relating to the job survey, it is imperative that the rate of product heat evolution be accurately determined. Therein is the significance of **daily rate**, since it is, by definition, the amount of product cooled or frozen per hour multiplied by 24 hours. This may be illustrated by considering two freezers, each of which has been loaded with 10,000 lbs of unfrozen product. In the first instance, eviscerated chickens are to be blast frozen in 2 hours, with the resultant **daily rate** being:

$$\text{Daily Rate}_{\text{lbs}/24 \text{ hrs}} = \frac{10,000}{2} \times 24 = 120,000$$

In the second case, the product is packaged, boxed, and palletized, and therefore requires 16 hours to give up its heat. Accordingly, the **daily rate** is:

$$\text{Daily Rate}_{\text{lbs}/24 \text{ hrs}} = \frac{10,000}{16} \times 24 = 15,000$$

## PRODUCT CHILLING

Product chilling is a process wherein product temperatures are rapidly reduced to a level acceptable for processing or shipment. Examples are freshly slaughtered carcasses and recently harvested fruits or vegetables. The benefits of rapid temperature reduction, in each instance, are a reduction in shrinkage and the deterrence of bacterial growth.

The introduction of hot product into a chill room results in the concentration of a significant load segment during the initial cooling period. This initial high rate of product heat evolution is caused by the high temperature and vapor pressure differentials between the product and the room. The effect is illustrated in Figure H, Page 29, wherein temperature reduction versus chill time for hogs is graphically depicted.

**Load factors** (or chill factors as they are sometimes called) have been developed to compensate for the non-uniform distribution of product load which results. These are utilized to increase the average hourly product load which would otherwise apply. Factors for the products most commonly encountered in chilling applications are charted in Table 10, and should be inserted in the space provided in Part III, Section C of Form LE-1 when applicable. The overall refrigeration requirements for beef and pork chilling rooms are charted in Page 28, Tables 11 and 12, respectively.

As an example, laboratory testing has shown that hogs tend to give up their heat during the initial portion of their chill at a 45% greater rate than is average for the complete period. Accordingly, the load factor indicated is 1.45.

# LOAD ESTIMATE

---

## PRODUCT CHILLING (CON'T.)

Failure to apply a load factor to the average hourly load (when applicable) will result in an unacceptably high initial room temperature, and an extension of the chill time required.

The substantial reduction in product load during the latter portion of the chill (**15-25%** of peak load) makes it mandatory that the refrigeration system be designed for proper function under a wide variance in load condition. Properly staged capacity reduction, in conjunction with evaporator pressure regulating valves, is commonly employed. Other approaches include the application of multi-circuit DX coils, and the combining of other (and more constant) side loads with the basic chill room load to enable high side equipment to stay on line and track the chill load as it tails off.

**Suction accumulators** and **liquid-suction heat exchangers** are strongly recommended with close coupled DX halocarbon systems.

## PRODUCT CHILLING & HOLDING

Frequently, the same room is utilized to accommodate both the product chilling and long term storage requirements. This is particularly true in the case of apples and pears.

In such rooms, the peak load varies with the duration of the loading period and the maximum percentage loaded on any given day. Normally, however, it is **neither necessary nor advisable** to apply a load factor to the average hourly load since an unacceptable disparity between the peak and holding requirements will result (see Note 5, Table 10).

A common load estimating technique for combined fruit chilling and storage applications is to add the 24-hour pulldown requirement for the last day's loading to the normal room holding load (the apple storage loads charted in Table 16 were computed on this basis).

A prime consideration in this regard is that the on-hand pre-chilled product produces a flywheel effect which minimizes the increase in room temperature which would otherwise result.

Combined chilling and holding facilities may require that existing prechilled product be segregated (either by physical partition or zoned air distribution) from the newly introduced hot product. Otherwise, the significant increase in room relative humidity which results upon the introduction of hot product will produce condensation on the prechilled product. Meat, for example, will sweat and slime, and the bacterial growth rate will be greatly enhanced (meat processed under such conditions would not meet with USDA acceptance).

As is the case with rooms applied for product chilling only, particular attention must be given in the refrigeration plant design to the wide disparity between the peak and normal holding loads. In a fruit storage facility, for example, the winter holding load will approximate 10 to 15% of the peak refrigeration requirement, and the coil TD under holding conditions may, therefore, be only 2-3°F (versus the 15°F and higher TD's experienced under peak pulldown conditions).

Accordingly, flooded or recirculated refrigerant systems are the most frequently utilized since they adapt well to the wide control variance required. When a DX halocarbon system is applied, the comments detailed above under "Product Chilling" apply. Unit coolers with multi-speed fans are sometimes utilized, but should be applied with discretion given the necessity for positive air circulation through the load during storage.

As a final consideration, the refrigeration design engineer should remember that his responsibility is confined to the creation and maintenance of a specific room environment. It is neither his function or purpose, nor is it within his capability, to guarantee a given product core temperature within a specified time frame given the many variables (product condition, packaging, wrapping, entrance rate, means of storage, etc).

# LOAD ESTIMATE

## PRODUCT BLAST FREEZING

Air blast freezing offers an alternative to the conventional contact method wherein the product is placed in direct contact with pipes or plates thru which refrigerant or brine is piped.

**Batch freezing** is a process wherein the complete product load is placed in the room and frozen in one loading. The resultant load profile approximates that previously described for chill rooms in that a major portion of the load is concentrated during the initial freezing period<sup>1</sup>. Accordingly, a factor of 1.5 is applied to the average hourly load, and the Daily Rate on Form LE-1 is computed by:

$$\text{Daily Rate} = \frac{\text{Product Load lbs}}{\text{Freezing Period hrs}} \times 24 \times 1.5$$

The 1.5 factor is **not** to be used when products are frozen over an extended period (these usually being products which are packaged or otherwise not susceptible to significant moisture loss during freezing).

**Continuous load freezing** is a process wherein the product is fed continuously thru the freezer via a conveyor or systemized manual feed. In this type of application, the estimated time of product heat removal has little effect on the total refrigeration load (it does, however, affect room size, conveyor belt size and speed, etc).

Accordingly, **no load factor is applicable** and the Daily Rate is computed by:

$$\text{Daily Rate} = \frac{\text{Product Load lbs}}{\text{Process Duration hrs}} \times 24$$

Air temperature, air velocity, product loading technique, and space requirements are critical considerations in the design of blast freezing systems (it seems that adequate space for both the equipment and product is never available). Additional comments, and general guidelines, are detailed in the preamble to Example II, Pg. 14.

Figures C, D & E depict typical room layouts for batch and conveyor-fed blast freezers.




FIGURE C: BATCH FREEZING (FLOOR MOUNT)




FIGURE D: BATCH FREEZING (CEILING MOUNT)




FIGURE E: PROCESS BLAST FREEZING

Note 1: As a product freezes, its outer frozen portion becomes an insulator and its rate of heat evolution decreases accordingly.

# LOAD ESTIMATE

## RESPIRATION

Fruits and vegetables are living organisms which continue to respire and carry on certain other life processes after harvesting. The carbon in the product combines with the oxygen in the air with the resulting chemical process being exothermic. This, in turn, results in an additional room heat gain.

The heats of respiration for various products in Btu/lb/24 hrs are tabulated in Table 9 at the temperatures recommended for both long and short term storage. Respiration heat (or reaction heat as it is sometimes called) varies with temperature, and decreases significantly with a reduction in storage temperature. There is no correlation, however, between respiration and relative humidity.

Since living organisms are involved, the temperature in long term storage rooms should be controlled within 1°F; otherwise, the physiology of the product will be affected, and the dormant state in which it has been maintained will be disturbed.

Meats and fish have no continuing life process, and therefore generate no heat in storage.

The respiration heat in controlled atmosphere (CA) storage will be less than the values charted in Table 9 as a result of the reduction in room oxygen content.

## SUPPLEMENTAL LOAD

All additional heat dissipated in the refrigerated space must be accounted for in computing the overall load. This includes energy utilized for motors, heaters, lights, people, forklifts and related miscellaneous heat sources. Supplemental loads of this type are computed in Part III, Section D of Form LE-1.

**Occupancy loads** are tabulated in Table 6. The heat equivalents noted should be increased by 20% if occupancy periods are of short duration. Utilize the average number of personnel in the space.

Heat equivalents for **electric motors** are listed in Table 3 for each possible application (ie, motor and connected load in the refrigerated space, connected load only in the refrigerated space and motor only in the refrigerated space). Equivalent horsepower is determined by multiplying the motor horsepower by the fraction of each hour operated.

Storage room **lighting** may usually be assumed at 1 to 1 ½ watts/sq ft. Doors, offices and work rooms require 2 ½ to 3 watts / sq ft. **Forklifts** may be estimated at 4 to 5 hp if more precise data is unavailable, and should be converted to equivalent horsepower as above.

The **defrost heat load** in a refrigerated space varies with the rate and time which heat is required, and, in some cases, with the unit cooler design<sup>1</sup>. In section D of

Form LE-1, 25% of the heat imposed is arbitrarily allocated to room load (the assumption being that this amount is either radiated to the room or retained by the coil mass, with the remainder leaving via the coil condensate).

**Charts, trays, racks, pallets**, etc. seldom contribute a significant load, but must be accounted for in high volume operations.

Electric energy from any source may be estimated by multiplying the applicable wattage by 82 (24 hrs × 3.4 Btu / Watt / hr).

## HOURLY LOAD CONVERSION

The 24 hour total obtained by adding Sections A thru D of Part III, Form LE-1 is converted to design refrigeration load in Btu/hr by applying time cycle and safety factors.

**Time cycle factors** for various applications are charted in Table 8. The divisors listed in column 1 represent anticipated operating hours under various frost conditions. The operating times noted are **average**, and are not applicable to all applications. Some freezers, for example, may require defrosting only once daily (or, in extreme cases, once weekly). The factor selected, therefore, represents a judgment consideration based upon the amount of moisture expected to enter the space from infiltration, product shrinkage, etc.

A **safety factor** correction of 5 to 10% to the hourly load resulting above is suggested. The figure selected is, again, a judgment consideration. Factors in excess of 10% should not be necessary.

## OTHER CONSIDERATIONS

Data herein, and the overall format of Form LE-1, both presuppose a "total load" estimating approach (ie, the combining of sensible and latent loads). Accordingly, evaporative loads such as those resulting from product moisture loss, wash water, etc. have not been considered since they have no net effect on the total room load (the resultant latent heat gains serve as credits to the sensible heat load due to the evaporative cooling effect).

This approach satisfies the requirements of most applications. This is particularly the case with freezers at 15°F or below since variation of the Apparatus Dew Point (ie, the average coil surface temperature) has little or no effect on the sensible heat factor, or the moisture removal capability of the coil.

Further, adherence to the guidelines charted in Tables 17 and 18 for recommended coil TD will produce required room relative humidities in most instances. In those cases where long storage under close humidity control is indicated, however, the possible requirement for reheat or re-humidification must be investigated.

# APPLICATION EXAMPLE

## I. FRUIT CHILLING AND STORAGE:

The example below illustrates the load profile for a typical combination chilling/holding facility. Three common product load estimating techniques are shown, with the pre-calculated values charted in Table 16 offering the simplest approach (note that respiration heat is neglected when a load factor is applied to the average hourly pulldown load).

Room design dry bulb varies with product variety. The control temperature for apples, as an example, ranges from 38°F for McIntosh (as shown) to 32°F for Golden Delicious. Relative humidity is maintained at 85% for apples, and 92-95% for pears. Room condition is not significantly affected by daily product loading due to the flywheel affect of the on-hand pre-chilled fruit. (Note that room temperature only should be guaranteed, and that no commitment as to time required for product pulldown should be made due to the many uncontrollable factors. (ie, type of packaging, position in the load, method of stacking, etc.).

Fruit stored for extended periods (over 3 months) is usually maintained under controlled atmosphere (or C.A.) storage conditions wherein the O<sub>2</sub> concentration is reduced from the normal 20% to a level of 3-7%, with a corresponding increase in the CO<sub>2</sub> level from a trace to 2-5% (the purpose of C.A. storage being to minimize product deterioration during storage). Respiration heat is reduced to a fraction of the normal rate as a result of the low O<sub>2</sub> concentration. C.A. storage facilities are commonly sub-divided into 50' x 100' x 20'

modules to enable product availability in saleable quantities when the room seals are broken. Water defrost and 460V TENV motors are frequently utilized to maximize reliability, and control devices are externally mounted for serviceability given the non-accessible environment.

Apples are usually containerized in lug or wood boxes, or in fiber cartons. The fruit may be individually tissue wrapped, or placed in poly-bags. Ungraded fruit is stored in 1000 lb 2 1/2' x 4' x 4' tote bins. Product loading density averages 25 lb/cu ft.

The refrigeration system for a combination chilling/holding facility must be specifically designed for adequate function under the widely divergent pulldown and winter holding loads. Since operational coil TD's will range from 15°F (or higher) during pulldown to 2°F (or less) with the winter holding load, flooded or recirculated systems are the most readily adapted to fruit storage applications.

When a DX system is applied, it must incorporate properly staged capacity reduction in consideration of the wide load variance. Multi-speed fan motors may also be applied, but have an obvious adverse effect on air movement thru the load.

Coils should be selected for a 6-8°F TD to maintain required humidity. Since all rooms require defrosting, a 4 FPI coil design is recommended.

Refer to the text, Pg. 10, for more detailed information.

## FORM LE-1

**PART II — SURVEY DATA:**

**A. FACILITY DESIGN DATA:**

DESIGN DATA	AMBIENT DESIGN		INSULATED DOORS	
	DRY BULB, °F	REL. HUMID., %	NO. DOORS	THICKNESS, IN.
PHYSICAL DATA	ROOM DESIGN		VENTILATION FANS	
	DRY BULB, °F	REL. HUMID., %	TYPE	TYPE DEFROST (✓)

**B. ELECTRICAL SERVICE:**

POWER CHARACTERISTICS: PHASE, HERTZ, CONTROL VOLTAGE, DISCONNECT BY REFRIG. CONTR., BY OTHERS TYPE REQD.

POWER TRANSFORMER (NONE): KVA REQ'D, NO. REQ'D, CONTROL TRANSFORMER, SERVICE AVAILABILITY, EXISTING CONNECTED LOAD, AMPS, (A), AVAILABLE SERVICE, AMPS, (A-B)

**C. PRODUCT DATA:**

APPLES DESCRIPTION (McINTOSH): WAREHOUSE TYPE, PACKAGING, ENTERING TEMP., FINAL TEMP., PULLEDOWN TIME, RESPIRATION, CONTAINERS, PALLETS

**D. MISCELLANEOUS LOAD DATA:**

PEOPLE, FAN MOTOR HP, OTHER MOTORS HP, FORKLIFTS HP, LIGHTS, WATTS/SQ. FT., APPLIANCES, WATTS, OTHER HEAT GAINS

**E. SUPPLEMENTAL DATA:**

WILL DEPEND ON PACKAGING, STACKING & POSITION IN THE LOAD

**PART III — LOAD CALCULATIONS:**

**A. HEAT TRANSMISSION LOAD:**

FLOOR	CEILING	N. WALL	E. WALL	S. WALL	W. WALL	TD	INSULATION	AREA	FACTOR	BTU/24 HRS
17	9	42	42	42	42	300	200	14	82	492,000

**B. INFILTRATION LOAD:**

720,000 M. VOL. FT. X 0.5 FACTOR X 680 FACTOR = 504,000

**C. PRODUCT LOAD (NOTE 1):**

PRODUCT COOLING: 8778,480

PRODUCT FREEZING: 196,341

RESPIRATION: 4730,250

**D. SUPPLEMENTAL LOAD:**

OCCUPANCY: 80,000

LIGHTS: 492,000

MOTORS: 357,000

FORKLIFTS: 576,000

DEFROST HEAT: 0

**EQUIPMENT SELECTION AND DESIGN DATA:**

QUANTITY: 14

MODEL NO.: BT-990

CONDENSING UNITS: 15-15-17

CONDENSERS: 317,400

CFM EA.: 16,150

EVAP. TEMP. °F: 31.7

SUCTON TEMP. °F: 30.7

COND. TEMP. °F: 30.7

**BTU/24 HR TOTAL (A+B+C+D): 21,634,071**

CONVERT TO HOURLY LOAD (TABLE 8): 900

**BTU/HR TOTAL WITH TIME CYCLE CORRECTION: 1,081,704**

APPLY SAFETY FACTOR: 1.05

**BTU/HR TOTAL WITH S.F. CORRECTION: 1,135,789**

CONVERT TO TONS OF REFRIGERATION: 12.000

**GRAND TOTAL: 94.6 TONS**

SQ. FT./TON: 634.2

# APPLICATION EXAMPLE

## II. BLAST FREEZING:

As illustrated in the example, the load profile of a batch blast freezing process dictates the application of a **load factor** to the average hourly load which would otherwise apply. The result is a refrigeration system properly adapted to the initial high rate of product heat evolution. The usual factor is 1.5, but a lower number is sometimes applied based on experience. In general, products with high surface-to-weight ratios freeze in 2 to 4 hours, and lower factors are therefor applicable when an extended freezing period is allowed. Note that **no load factor should be applied to conveyor fed blast freezers, or to rooms equipped with single halocarbon refrigeration systems** (in the latter, freezing time should be extended, and the room temperature allowed to rise).

Special design considerations include the provision for room pressure relief, and the consistent problem of obtaining adequate space to accommodate both the equipment and product. Provision for heater pull space must be made with electric defrost units. Utilization of coils with variable fin spacing minimizes the defrost requirement.

The following procedure should be followed in arriving at a blast freezer design:

**STEP 1:** Determine whether a conveyor or batch loaded freezer is best applied. This judgment is usually based on product test data wherein freezing time with various air temperatures and velocities has been determined. In general, batch loaded freezing is applied with products requiring 1 1/2

hours or more to freeze satisfactorily; products which freeze in less than 1 1/2 hours are conveyor fed.

**STEP 2:** Determine the space limitations of the room (remember that the space initially allocated by others is frequently insufficient to accommodate both the equipment and the product).

**STEP 3:** Finalize the room design criteria, keeping in mind that design air velocity and temperature are most critical, and that these factors are the prime considerations in the selection of a blast freezing unit.

**STEP 4:** Select equipment as dictated by room size and product mass, and which is in conformance with the required air temperature and velocity as finalized in Step 3 (following review of the pilot freezing test results). The equipment employed should be specifically designed for blast freezing application, and should be capable of producing extremely high air velocities and volumes.

**STEP 5:** The last step is to position the unit in the room. Refer to Figures C & D, Pg. 11, for typical batch loaded blast freezers. Note that the air travels from right to left in these diagrams, passing thru the product and gradually warming up before being returned to the coil. A critical requirement in blast freezing of this type is that product be loaded across the complete room width thereby precluding the cold air bypass which would otherwise destroy the effectiveness of the freezer.

Refer to the text, Pg 10, for further discussion, and to Table 13, pg. 28, for test blast freezing data on selected products.

## FORM LE-1

**PART II — SURVEY DATA:**

**A. FACILITY DESIGN DATA:**

DESIGN DATA	AMBIENT DESIGN		INSULATED DOORS	
	90 DRY BULB, °F	2 NO THICKNESS, IN.	5	THICKNESS, IN.
	60 WET BULB, °F	7 HGT., FT. <b>OVERLAP</b>		TYPE
	60 REL. HUMID., %	4.6 WDH., FT.		TIME OPN. MIN/HR
PHYSICAL DATA	ROOM DESIGN		VENTILATION FANS	
	-20 DRY BULB, °F	26 LENGTH, FT.	NONE	NO
	19 WET BULB, °F	19 WIDTH, FT.	HP (EA)	AIR
	13 REL. HUMID., %	13 HEIGHT, FT.	CPM (EA)	HOT GAS
ELECTRICAL SERVICE:	POWER CHARACTERISTICS		DISCONNECT	
	3 PHASE	60 HERTZ	440 VOLTAGE	BY REFRIG. CONTR.
	110 CONTROL VOLTAGE			BY OTHERS <b>FUSED</b>
	NO KVA REQ'D	NO KVA REQ'D	NO KVA REQ'D	TYPE RECD.
	1 PRIM/SEC. VOLTAGE	EXISTING PRIM/SEC. VOLTAGE		BY OTHERS
	BY OTHERS	BY OTHERS	BY OTHERS	BY OTHERS
CONTROL TRANSFORMER		SERVICE AVAILABILITY		
NO	NO	OK	EXISTING SERVICE, AMPS. (A)	
			EXISTING CONNECTED LOAD, AMPS. (B)	
			AVAILABLE SERVICE, AMPS. (A-B)	
<b>C. PRODUCT DATA:</b>				
FISH DESCRIPTION (PILLET)		CONTAINERS		PALLETS
BAG TYPE PACKAGING (PLASTIC)		NONE TYPE		NONE SIZE (LxWxH), FT.
80 SP. HT.		CONT. WDH., LB.		NUMBER
35 ENTERING TEMP., °F		PRODUCT WDH., LB.		WEIGHT (EA), LB.
-20 FINAL TEMP., °F		MATERIAL		MATERIAL
6 UNLOADING TIME, HRS.		SP. HT., TABLE 44		SP. HT., TABLE 44
5000 LBS TON GAL BBL BOX CASE PER (LOADING HOUR DAY HR. SHIFT)		RESPIRATION		ROOM CAPACITY
		HOLDING LOAD, LB.		ROOM VOLUME, CU. FT.
		RATE, BTU/LB/24 HR. TABLE 9		LOADING DENSITY, LB/CU. FT. TABLE 14
				EST. PROD. LOAD, LB. (Vol. x L.D. x 24)
<b>D. MISCELLANEOUS LOAD DATA:</b>				
NEGLECT PEOPLE		RACK PULLDOWN		EST. OPERATING HOURS
10 FAN MOTOR HP. (ESTIMATE)		STEEL MATERIAL		18 FAN MOTORS
OTHER MOTORS, HP.		1800 TOT. WDH. LBS.		FORKLIFTS
FORKLIFTS, HP. (EST. @ 4 HP. EA.)		12 SP. HT. TABLE 44		6 DEFROST HEATERS
1 LIGHTS, WATTS/SQ. FT.		FAN MTR. EQUIV. HP. = 10 HP. x (45) MIN/HR OPER. TIME = 450		
APPLIANCES, WATTS		FORKLIFT EQUIV. HP. = HP. x ( ) MIN/HR OPER. TIME =		
OTHER HEAT GAINS ( )				
<b>E. SUPPLEMENTAL DATA:</b>				
* STD. CONSTRUCTION MATERIALS CAN BE NEGLECTED (U OF INSULATION ONLY: U = 29/10 = 2.9; U CONSIDERING RESISTANCES OF BLOCK AND FILMS R = 1/60 + 10/24 + 1/40 + 1/16 = 43.56, & U = 1/43.56 = .023)				

**PART III — LOAD CALCULATIONS:**

**A. HEAT TRANSMISSION LOAD:**

FLOOR	75	26	14	53	19 292
CEILING	110	20	14	75	27 300
N. WALL	50	26	14	29	10 556
E. WALL	110	6	14	67	13 132
S. WALL					
W. WALL					
SUBTOTAL A—TRANSMISSION BTU/24 HRS					70 280
<b>B. INFILTRATION LOAD:</b>					
5096 RM. VOL. FT. X 5.6 FACTOR X 117 FACTOR					33 389
NO. DOORS X VEL. FPM X ( ) DOOR AREA FT. X MIN. OPEN/24 HRS. X FACTOR					
VENTILATION CFM X FACTOR X 1440 30°F @ 70°F RH.					
SUBTOTAL B—INFILTRATION BTU/24 HRS					33 389
<b>C. PRODUCT LOAD:</b>					
5000 LBS/HR. X 7 T.D.°F X 12 SP. HT. X 24					139 994
6000 LBS/HR. X 110 BTU/LB X 24					2 749 890
6000 LBS/HR. X 48 T.D.°F X 23 SP. HT. X 24					5 519 979
1600 LBS/HR. X 50 T.D.°F X 12 SP. HT. X 24					38 399
RESPIRATION HEAT					
SUBTOTAL C—PRODUCT BTU/24 HRS					3 444 262
<b>D. SUPPLEMENTAL LOAD:</b>					
OCCUPANCY: NO. OF PERSONS X BTU/PERSON/DAY					
LIGHTS: 26 LGTH. FT. X 14 WDH. FT. X 1 WATTS/SQ. FT. X 82 BTU/WATT/24 HRS.					29 848
MOTORS: 7.5 EQUIV. HP. X 2552 BTU/HP-HR. X 24					531 000
FORKLIFTS: EQUIV HP X 7200 BTU/HP/24 HRS					
DEFROST HEAT: 6 HRS. X 9000 WATTS X 3.4 BTU/WATT/HR. X 25					204 000
OTHER ( ) ESTIMATE @ 4000 SQFT SURFACE/10W/SQFT.					
SUBTOTAL D—SUPPLEMENTAL BTU/24 HRS					764 848
<b>EQUIPMENT SELECTION AND DESIGN DATA:</b>					
QUANTITY	UNIT	CONDENSING COMPRESSOR	CONDENSERS	BTU/24 HR TOTAL (A+B+C+D)	4 312 779
MODEL NO.	81446124	KPCC-36	25-25	CONVERT TO HOURLY LOAD (TABLE B) ... ÷ 18	
CAP. EA.	BTU/HR.	245 200	124 210	BTU/HR TOTAL WITH TIME CYCLE CORRECTION	239 599
CFM EA.	27600			APPLY SAFETY FACTOR ... X 1.05	
EVAP. TEMP. °F	-35			BTU/HR TOTAL WITH S. F. CORRECTION	251 579
SUCTION TEMP. °F	-36			CONVERT TO TONS OF REFRIGERATION ... ÷ 12,000	
COND. TEMP. °F				GRAND TOTAL	20.96
NOTES: NOTE ①: WERE THE FREEZING PERIOD SHORTER, THE STD. BATCH BLAST FREEZING LOAD FACTOR OF 1.5 WOULD APPLY.					

# APPLICATION EXAMPLE

## III. BEEF CARCASS CHILLING:

The load characteristics of a carcass chill room (or the "Hot" cooler, as it is commonly called) are such that the application of a load factor to the average hourly product load is mandatory. The initial rate of heat evolution has been shown by test to exceed the average hourly rate by 50%. Hence the load factor applicable is 1.50. The typical load profile is illustrated in figure H, Page 29, wherein time/temperature curves for Hot Chilling are plotted.

Other specialized design and operational requirements apply. Rail height as dictated by USDA must be 11'2", and a 4 to 5 ft clearance above the rails is required for supporting structure and equipment placement; accordingly ceiling height should be 16 ft at a minimum. BTR units are specifically designed for this application, and should be utilized whenever possible (these units will accommodate 2 rails on either side).

Small plants can present particular problems. Frequently, 12 or 14 ft ceiling heights are encountered, as is the placement of structural steel within the envelope. In an application of this type, it is essential that the refrigeration be coordinated with the structure to assure a clear air flow at the discharge of the unit coolers. Hite-saver® or draw-thru type unit coolers must be flush mounted with the ceiling around the periphery of the room.

An additional USDA requirement is that drain pans be insulated to prevent drippage on the product; stainless

enclosures as found on the BTR series are optimum.

Unit coolers should be of 4 FPI coil construction, and be selected for a 10-12°F TD (the initial TD will approach 18-20°F, but will drop rapidly with the fall-off in load). Variable fin spacing (wherein the first 2 rows are of 2 FPI construction) minimizes the defrost requirement, but is not recommended for DXF applications since a 2 fin per inch coil face produces marginal superheat.

Defrost is usually accomplished 4 times daily, with each cycle being of 15 to 20 min duration. Small rooms usually approximate 40 sq ft / ton, with large facilities approaching 65-70 sq ft / ton. The following guidelines may be applied:

- 5 head per ton
- 8 sq ft per head

The refrigeration plant should be designed to adapt to the wide load variance. Multiple compressors with unloaders are recommended (a twin unit is illustrated in the example). Improperly applied equipment will short cycle, pump-down the coils, and thereby dry out the product.

As a final consideration, it should be noted that round temperature cannot be pulled down in 18-24 hours. Accordingly, a product load must be estimated for the holding cooler which will approximate a 15 degree, 24 hour pull-down of 10% of the carcass weight (utilize 20% of the overall weight for small rooms).

Refer to USDA handbook 191 for detailed meat packing-plant design guidelines, and to tables 11 & 12, Pg. 28, for pre-calculated chill room loads.

## FORM LE-1

**PART II — SURVEY DATA:**

**A. FACILITY DESIGN DATA:**

DESIGN DATA	AMBIENT DESIGN		INSULATED DOORS	
	DRY BULB, °F	95	NO	THICKNESS, IN.
	WET BULB, °F	70	HGT., FT.	TRACK
	REL. HUMID., %	50	WIDTH, FT.	5
	ROOM DESIGN	VENTILATION FANS	TYPE DEFROST (✓)	
	DRY BULB, °F	30	NO	AIR
	WET BULB, °F	20	NO	HOT GAS
	REL. HUMID., %	16	HP (EA)	WATER
			CFM (EA)	KOOLGAS
				ELECTRIC
				NONE

**PHYSICAL DATA**

FLOOR	CONSTRUCTION	TYPE	INSULATION (THICK, IN.)	U VALUE	SOLAR LOAD (BTU)	ADJACENT AREA TEMP. °F	T.D. °F
CEILING	6" CONCRETE (CEILING)	STYRENE	4	0.25	55	22	
N. WALL	GLASS BRICK	URETHANE	3	0.12	90	57	
E. WALL	PANEL	II	3	0.12	90	57	
S. WALL	II	II	3	0.12	35	2	
W. WALL	II	II	3	0.12	35	2	

**B. ELECTRICAL SERVICE:**

POWER CHARACTERISTICS: 3 PHASE, 60 HERTZ, 460 VOLTAGE, DISCONNECT BY REFRIG. CONTR. TYPE REQD.

POWER TRANSFORMER: NONE, CONTROL TRANSFORMER: 460/230, SERVICE AVAILABILITY: NEW CONSTRUCTION

**C. PRODUCT DATA:**

DESCRIPTION: BEEF (HALVES), TYPE PACKAGING: 77, ENTERING TEMP.: 106, FINAL TEMP.: 40, TIME: 24

CONTAINERS: NONE, PALLETS: NONE

RESPIRATION: NONE, ROOM CAPACITY: NONE

**D. MISCELLANEOUS LOAD DATA:**

2 (MAX) PEOPLE, 2 FAN MOTOR HP, 1 OTHER MOTORS, 1 FORKLIFTS, 1 LIGHTS, 1 APPLIANCE, 1 OTHER HEAT GAINS

**E. SUPPLEMENTAL DATA:**

1. AVG. DRESSED WGT/HD - 550#

2. 24 HR. LOADING

3. SLAUGHTERING 2 TO 3 TIMES PER WEEK.

**PART III — LOAD CALCULATIONS:**

**A. HEAT TRANSMISSION LOAD:**

FLOOR	TD	22	AREA	22	BTU/24 HRS
CEILING	20	82	20	85	19,200
N. WALL	67	57	16	57	57,000
E. WALL	67	57	16	57	20,320
S. WALL	2	2	16	2	10,880
W. WALL	2	2	16	2	960

SUBTOTAL A—TRANSMISSION BTU/24 HRS: 112,360

**B. INFILTRATION LOAD:**

RM. VOL. FT<sup>3</sup>: 12,000, VENTILATION CFM: 1200, VELOCITY: 488

SUBTOTAL B—INFILTRATION BTU/24 HRS: 767,759

**C. PRODUCT LOAD:**

PRODUCT COOLING: 2,064,562

RESPIRATION: 2,064,562

SUBTOTAL C—PRODUCT BTU/24 HRS: 2,064,562

**D. SUPPLEMENTAL LOAD:**

OCCUPANCY: 2, LIGHTS: 30, MOTORS: 1.8, FORKLIFTS: 1.8, DEFROST HEAT: 270,400

SUBTOTAL D—SUPPLEMENTAL BTU/24 HRS: 270,400

**EQUIPMENT SELECTION AND DESIGN DATA:**

QUANTITY	UNIT	CONDENSING UNITS	COMPRESSOR UNITS	CONDENSERS
4	4	1	1	1
MODEL NO.	87R24	DR180E	HP180	
CAP. EA. BTU/HR	36,000	146,000	182,200	
CFM EA.	6,000			
EVAP. TEMP. °F	20			
SUCTION TEMP. °F	21			
COND. TEMP. °F	105			

**BTU/24 HR TOTAL (A+B+C+D): 3,203,081**

CONVERT TO HOURLY LOAD (TABLE 8): 145,594

BTU/HR TOTAL WITH TIME CYCLE CORRECTION: 145,594

APPLY SAFETY FACTOR: 1.5

BTU/HR TOTAL WITH S.F. CORRECTION: 145,594

CONVERT TO TONS OF REFRIGERATION: 12.13

GRAND TOTAL (NOTE D): 49.6



# APPLICATION EXAMPLE

## IV. BEER STORAGE:

Beer storage facilities are refrigerated for the purpose of maintaining product quality with an extended shelf life (from the usual 90 days, to as much as 180 days at 40°F). The expense is justified by the cyclical nature of industry sales. Storage temperatures vary from 40°F to 76°F, with the control point being adjusted in accordance with the dew point profile of a given area (the reason being that cartoning would otherwise disintegrate upon exposure to ambient conditions). Draught beer (kegs) is stored in a separate cooler since it must be maintained at a constant temperature year-round (the range being from 34°F to 38°F).

The product leaves the brewery's pasteurizer at a maximum temperature of 85°F, with its temperature range prior to arrival at the distribution point increasing (decreasing) 1°F if shipment is by truck, or 1°F per day if shipment is by rail.

Beer is shipped by pallet, with a rail car containing 50 pallets. Car loadings are mixed in accordance with a distributor's sales profile. Kegs may be included with a can or bottle load behind a bulkhead packed with dry ice. Pallets are wood, and vary in weight with location from 36 to 44 lbs. (for cans), to 55 lbs. (for kegs); 42 lbs. is the most common weight encountered with cans or bottles. Dimensions are 32" x 37" x 73".

Pallet refrigeration loads based on a 45°F/24 hour product pull-down are as follows:

TYPE CONTAINER	CASES/ PALLET	BTU/45°F/ 24 HR
• 12 oz tray steel can	98	85,000
• 12 oz tray alum. can	98	84,800
• 12 oz Mich <sup>l</sup> , N.R.	56	54,000
• 12 oz N.R., 4/6	77	75,400
• 12 oz ret, 24	49	51,200
• 16 oz tray steel can	77	89,500
• Quart, N.R.	49	63,200

## FORM LE-1

The following procedure should be followed in estimating the refrigeration load:

**STEP 1:** Determine facility operational specifics such as method of truck loading (end or side), the percent of pre-sold/scheduled deliveries vs. driver sales, the required number of pallet facings, a 5 year sales projection, the average number of inbound car loads/day, etc.

**STEP 2:** Following review of the above with operating personnel, define the space to be refrigerated (the primary concern being whether the loading and staging areas should be refrigerated). It is the usual practice to size for expansion planned over a 5 year period.

**STEP 3:** Determine the distributor's annual sales profile by product category, and compute the average pallet refrigeration load on a weighted average basis.

**STEP 4:** Obtain the area dew point profile, and subsequently establish minimum storage temperature by month.

**STEP 5:** Estimate the heat gain for each of several representative months to determine the peak load. (NOTE: As illustrated in the example, the peak load will occasionally occur during a winter month due to maximum product pull-down requirements).

**STEP 6:** Review alternate insulation options to those assumed in Step 5 above. A compound U value of .080 is a commonly accepted design, but values as low as .035 are sometimes justified.

**STEP 7:** Design the refrigeration system for proper function under the load variance determined in Step 5 above. Coil TD is not critical; utilize 6 FPI construction.

See Tables 29 thru 32, Page 37, for additional product load and container data.

### PART II — SURVEY DATA:

A. FACILITY DESIGN DATA:			
DESIGN DATA	AMBIENT DESIGN	INSULATED DOORS	
	DRY BULB, °F: 30	NO. DOORS: 1	THICKNESS, IN.: 3
	WET BULB, °F: 18	HGT., FT.: 11.07	MAN. SLIDE TYPE: 5
	REL. HUMID., %: 70	WIDTH, FT.: 3.34	TIME OPEN, MIN/HR: 1
PHYSICAL DATA	ROOM DESIGN	VENTILATION FANS	
	DRY BULB, °F: 40	NONE	TYPE DEFROST (✓):
	WET BULB, °F: 18	AIR	HOT GAS
	REL. HUMID., %: 70	HP (EA):	ELECTRIC
B. ELECTRICAL SERVICE:	POWER CHARACTERISTICS		
	PHASE: 3	HERTZ: 60	VOLTAGE: 480
	CONTROL VOLTAGE: 120	DISCONNECT BY REFRIG. CONTR. (✓)	
	POWER TRANSFORMER		
C. PRODUCT DATA:			
BEER		CONTAINERS	
CAN/BOTTLE TYPE PACKAGING (NOTE 2): 92		CAN TYPE (1/2 BOTTLE): 32 x 32 x 3 1/2	
ENTERING TEMP., °F: 84		CONT. WGT., LB.: 50	
FINAL TEMP., °F: 40		PRODUCT WGT., LB.: 42	
STORAGE TIME, HRS: 24		MATERIAL: WOOD	
LOADING RATE: 4373		RESPIRATION: 0.67	
D. MISCELLANEOUS LOAD DATA:			
PEOPLE: 2		RACK PULLDOWN: NONE	
FAN MOTOR HP (ESTIMATE): 8		EST. OPERATING HOURS: 24	
OTHER MOTORS, HP: 1		TOT. WGT., LBS.: 3	
FORKLIFTS, HP (EST. @ 4 HP, EA.): 1		DEFROST HEATERS: NONE	
LIGHTS, WATTS/SQ. FT.: 1		FAN MTR. EQUIV. HP. = 8	
APPLIANCES, WATTS: 1		FORKLIFT EQUIV. HP. = 4	
OTHER HEAT GAINS: 1		MIN/HR OPER. TIME = 8	
E. SUPPLEMENTAL DATA:			
① CONTROL PT. VARIABLE BETWEEN 40-73°F.			
② INVENTORY IS 85% CANS - ALL STEEL EXCEPT LIGHT BEER			

### PART III — LOAD CALCULATIONS:

A. HEAT TRANSMISSION LOAD:				BTU/24 HRS	
FLOOR	15	156	49	72	650,368
CEILING	20	156	49	72	588,528
N. WALL	10	156	16	13	(52,448)
E. WALL	10	156	16	13	(52,448)
S. WALL	10	156	16	13	(52,448)
W. WALL	10	156	16	13	(52,448)
SUBTOTAL A—TRANSMISSION BTU/24 HRS				1,101,020	
B. INFILTRATION LOAD: (NONE - CLR. SAME TEMP AS STAGING AREA)					
SUBTOTAL B—INFILTRATION BTU/24 HRS					
C. PRODUCT LOAD:					
50 PALLETS/DAY x 78,432 BTU/PALLET x 74/45				3,883,342	
SUBTOTAL C—PRODUCT BTU/24 HRS				3,883,342	
D. SUPPLEMENTAL LOAD:					
OCCUPANCY: 2				40,400	
LIGHTS: 156				626,808	
MOTORS: 8				516,000	
FORKLIFTS: 1.33				95,760	
SUBTOTAL D—SUPPLEMENTAL BTU/24 HRS				1,578,968	
EQUIPMENT SELECTION AND DESIGN DATA:					
QUANTITY	6	2			
MODEL NO.	073096	KDPC-26-10-10-N2			
CAP. EA. BTU/HR	69,339	192,000			
CFM EA.	10,000				
EVAP. TEMP. °F	26				
SUCTION TEMP. °F	25				
COND. TEMP. °F					
BTU/24 HR TOTAL (A+B+C+D)				6,563,330	
CONVERT TO HOURLY LOAD (TABLE B) ...				18	
BTU/HR TOTAL WITH TIME CYCLE CORRECTION				364,629	
APPLY SAFETY FACTOR ...				1.06	
BTU/HR TOTAL WITH S. F. CORRECTION				382,860	
CONVERT TO TONS OF REFRIGERATION ...				12.000	
GRAND TOTAL				31.90	
				239.6	

# APPLICATION EXAMPLE

## V. NUT STORAGE:

Nuts are received from growers during the October thru February harvest season packed in burlap bags. Bag weights vary from 90 lb (for high quality) to 150 lb (for small size, or seedlings); average bag weight is 125 lb, with a truck load being 360 to 400 bags.

Upon receipt at the processing and storage facility, the product is cleaned, sized, and graded, with miscellaneous shells, trash, etc. being removed. It is then segregated into 7 or 8 categories by size, and packed loose in 60" x 42" x 42" wood tote boxes for transfer to storage. Box weights average 170 lbs, with each containing 1800 to 2000 lbs of product. Entrance rate into the cooler is a function of the grading machinery capacity (and not the rate of inbound shipments from growers).

Tote boxes are generally stacked 4 high (or 20 ft). The box bottoms and sides are perforated with small holes, and these, in combination with the loosely packed nature of the product, enable adequate air movement thru the load.

Customer orders are filled from storage, with the appropriate size and grade nuts being transferred to the plant area where shelling, cutting and repackaging for customer shipment occur.

Proper storage room design is 28°F to 32°F with a 65% relative humidity; maintenance of constant humidity is critical. Processing and plant areas are not usually air condi-

tioned. Since the product enters storage during the fall and winter months, the peak pull-down, transmission and infiltration loads are not coincident (note that incoming product during the summer months usually represents inter-warehouse transfer, and is pre-refrigerated).

The usual practice, therefore, is to estimate the load on the basis of the maximum transmission, infiltration and miscellaneous loads only, with the product load neglected. An alternate load estimating technique is to compute the product load based on 24 hr pull-down at the maximum entrance rate, and add the usual transmission, infiltration and miscellaneous loads recomputed for a lower design ambient (were the example refigured on this basis with a 75°F outdoor design, the net effect would be to reduce the transmission and infiltration loads to 1.8 million and 1.6 million Btu/24 hrs, respectively, with the overall load becoming slightly overstated at 60 tons).

Coils should be selected for a 12°F TD, and may be of 4 or 6 FPI construction. Multiple compressors are recommended to adapt to the widely divergent peak and holding loads.

Provision for reheat is usually necessary to assure maintenance of constant humidity under light load conditions. The simplest approach is to de-energize one refrigeration system while continually operating all unit fans, lights, and a predetermined number of defrost heaters (the net effect being to false load the operative refrigeration unit). This approach requires the addition of a humidistat and humidity relay (the function of the latter being to de-energize the required refrigeration circuitry and to activate the defrost heaters).

## FORM LE-1

**PART II — SURVEY DATA:**

**A. FACILITY DESIGN DATA:**

DESIGN DATA	AMBIENT DESIGN		INSULATED DOORS					
	95 DRY BULB, °F	2 NO. 4 THICKNESS, IN.						
	50 WET BULB, °F	6 HST. FT. <i>REWORKING</i> TYPE						
	50 REL. HUMID., %	6 WTH. FT. 20 TIME OPN. MIN/HR						
PHYSICAL DATA	ROOM DESIGN		VENTILATION FANS					
	28 DRY BULB, °F	134 LENGTH, FT.	NONE NO. AIR	TYPE DEFROST (V)				
	134 WET BULB, °F	134 WIDTH, FT.	HP (EA)	WATER				
	65 REL. HUMID., %	24 HEIGHT, FT.	CFM (EA)	ELECTRIC NONE				
PHYSICAL DATA	FLOOR	TYPE CONSTRUCTION	INSULATION TYPE	THICK (IN)	COMPOUND U VALUE	SOLAR LOAD (V)	ADJACENT AREA TEMP. °F	T.D. DB. °F
	CEILING	CONCRETE	BLOCK	4	↑	55	27	
	N. WALL	ON GRADE	STYRENE	6	↑	95	67	
	E. WALL	PANEL	INSULATE 5	6	↑	95	67	
	S. WALL			6	↑	95	67	
	W. WALL			6	↑	95	67	

**B. ELECTRICAL SERVICE:**

POWER CHARACTERISTICS	DISCONNECT
3 PHASE 60 HERTZ 460 VOLTAGE	EXISTING BY REFRIG. CONTR.
115 CONTROL VOLTAGE	BY OTHERS TYPE REQ.
POWER TRANSFORMER N/A	CONTROL TRANSFORMER
115 KVA REQ'D NO. REQ'D	600 KVA REQ'D 2 NO. REQ'D
1 PRIM/SEC. VOLTAGE	460 / 115 PRIM/SEC. VOLTAGE
BY OTHERS BY REFRIG. CONTR.	BY OTHERS BY REFRIG. CONTR.
	120 AVAILABLE SERVICE, AMPS. (A)
	120 AVAILABLE SERVICE, AMPS. (A) (B)

**C. PRODUCT DATA:**

REGANS DESCRIPTION 60x42x42	CONTAINERS	PALLETS
LOOSE TYPE PACKAGING (N TOTE BOX)	TOTE BOX TYPE	NONE SIZE (LxWxH), (EA).
25 SP. HT.	170 CONT. WGT., LB.	NUMBER
75 ENTERING TEMP., °F (MAX)	1800 PRODUCT WGT., LB.	WEIGHT (EA), LB.
28 FINAL TEMP., °F	WOOD MATERIAL (PINE)	MATERIAL
24 HOLDING TIME, HRS.	167 SP. HT.	SP. HT.
240,000 (NOTE 1)	RESPIRATION	ROOM CAPACITY
TON GAL BBL BOX CASE	HOLDING LOAD, LB.	ROOM VOLUME, CU. FT.
PER DAY	RATE, BTU/LB/24 HRS. TABLE 9	LOADING DENSITY, LB/CU. FT. TABLE 14
PER 12 HR. SHIFT		EST. PROD. LOAD, LB. (Vol. x L.D. x 40) TABLE 14
		6,000,000 LB. PER YEAR

**D. MISCELLANEOUS LOAD DATA:**

2 PEOPLE	RACK PULLDOWN	EST. OPERATING HOURS
2 FAN MOTOR HP. (ESTIMATE)	NONE MATERIAL	18 FAN MOTORS
OTHER MOTORS, HP.	TOT. WGT., LBS.	6 FORKLIFTS
2 FORKLIFTS, HP. (EST. @ 4 HP. EA.)	SP. HT. TABLE 44	6 DEFROST HEATERS
1 LIGHTS, WATTS/SQ. FT. (NOTE 2)	FAN MTR. EQUIV. HP. = 24 HP. x (14) MIN/HR OPER. TIME = 18	
APPLIANCES, WATTS	FORKLIFT EQUIV. HP. = 8 HP. x (30) MIN/HR OPER. TIME = 4	
OTHER HEAT GAINS		

**E. SUPPLEMENTAL DATA:**

① GRADING MACHINE CAPACITY 20000 LB/HR  
 ② HG. VAPOR - TO OPERATE 24 HRS./DAY

**PART III — LOAD CALCULATIONS:**

**A. HEAT TRANSMISSION LOAD:**

FLOOR	27	27	134	134	29	520	724
CEILING	67	15	134	134	29	1418	824
N. WALL	67	4	134	134	69	205	824
E. WALL	67	4	134	134	69	221	904
S. WALL	67	4	134	134	69	205	884
W. WALL	67	4	134	134	69	221	904

TABLE 2 SUBTOTAL A—TRANSMISSION BTU/24 HRS 2 794 704

**B. INFILTRATION LOAD:**

RM. VOL. FT <sup>3</sup>	FACTOR	TABLE 4A or B	FACTOR	TABLE 5	BTU/24 HRS
180	1.8	1.8	240	233	3 027 732
2 NO. DOORS X 12 VEL. FPM X 140 DOOR AREA, FT <sup>2</sup>	FACTOR	TABLE 4	FACTOR	TABLE 5	
240	1.2	1.2	1.2	1.2	
VENTILATION CFM X FACTOR	TABLE 5	TABLE 5	TABLE 5	TABLE 5	
120	1.2	1.2	1.2	1.2	

SEE PG 7 — VEL = 4.88 x Vn. FT. = V.T.D. °F  
 VEL = 180 x 1.8 x 1.2 = 112.8  
 SUBTOTAL B—INFILTRATION BTU/24 HRS 3 027 732

**C. PRODUCT LOAD:**

PRODUCT COOLING	240,000	24	47	25	24	2 120 000
PRODUCT FREEZING						
PRODUCT SUB-COOLING						
CONTAINER COOLING	1800	47	67	24	711 989	
PALLET COOLING						
RESPIRATION HEAT					133	

Applying to certain chill rooms and batch loaded blast freezers only. See pages 9 thru 11, and note 3 Table 10.  
 SUBTOTAL C—PRODUCT BTU/24 HRS 3 531 909 (NOTE 1)

**D. SUPPLEMENTAL LOAD:**

OCCUPANCY	2	NO. OF PERSONS	22800	BTU/PERSON/DAY	46 600
LIGHTS	134	LGTH. FT. X 134	WDTH. FT. X 1	WATTS/SQ. FT. X 82	1 172 592
MOTORS	18	EQUIV. HP. X 24	2420	BTU/HP-HR. X 24	1 836 000
FORKLIFTS	4	EQUIV. HP. X 2000	BTU/HP/24 HRS. TABLE 3		288 000
DEFROST HEAT	6	HRS. X 4	WATTS X 3.4	BTU/WATT/HR. X .25	1 183 200
OTHER					

NOTE: ① NEGLECT PRODUCT LOAD — SEE COMMENTS ABOVE  
 ② MAKE PROVISION FOR REHEAT

CONVERT TO TONS OF REFRIGERATION → 12,000  
 SUBTOTAL D—SUPPLEMENTAL BTU/24 HRS 4 825 192

**EQUIPMENT SELECTION AND DESIGN DATA:**

QUANTITY	UNIT	CONDENSING COMPRESSOR	CONDENSERS
2	2		
MODEL NO.	05C 240	352,000	56-30-30-N2
CAP. EA., BTU/HR.	98,604	352,000	
CFM EA.	168.50		
EVAP. TEMP. °F	16		
SUCTION TEMP. °F	15		
COND. TEMP. °F			

BTU/24 HR. TOTAL 10 647 628  
 CONVERT TO HOURLY LOAD (TABLE 8): → 18  
 BTU/HR TOTAL WITH TIME CYCLE CORRECTION 591 534  
 APPLY SAFETY FACTOR → X 1.10  
 BTU/HR TOTAL WITH S. F. CORRECTION 650 688  
 GRAND TOTAL TONS 58.2  
 SQ. FT./TON 337

# APPLICATION EXAMPLE

## VI. DISTRIBUTION CENTERS:

The refrigeration load in a food distribution facility differs substantially from that common to holding rooms utilized for the extended (or, long term) storage of seasonal and process foods. Product movement, and the activity level in general, is high, with the result being significantly increased infiltration and supplemental heat gains.

The produce cooler depicted in the example is illustrative of the application in general. Rooms of this type are maintained at 32-35°F with high humidity, and open into a staging or loading area most frequently controlled at 50-55°F. There is a significant infiltration heat gain resulting from the high frequency of product movement (it is not uncommon for the entrance doors to be open 50% or more of the time). Vestibule and air doors, or strip curtains, appreciably reduce this load, but are often not employed. Consequently, the infiltration load can approach 2 to 2.5 tons per door. An additional characteristic of this type room is the significant product load resulting from reaction heat; this load may usually be estimated at .003 to .004 tons/sq ft, and the room load overall will generally fall between 150 and 200 sq ft/ton. Proper equipment application dictates unit coolers selected for a 6-9°F coil T.D., with face velocities not in excess of 600 FPM for wet coil operation, or 700 FPM for light frosted operation. The over-riding design consideration in these rooms is the prevention of product damage from shrinkage, drying, or mold growth.

Deli coolers are generally maintained at a slightly lower temperature (30-33°F), and represent an even more severe

application from the standpoint of infiltration. In many rooms, the doors are never closed, with the resulting infiltration gain being 3.5 to 4 tons/door. The overall room load usually approximates 200 to 225 sq ft/ton.

The load in holding freezers is dependent in large measure on the condition of the inbound product. Frequently, a 10 to 15°F pulldown load is imposed, and, since movement is heavy, this load is significant. Infiltration can be estimated at 2 tons/door. A load estimating guideline of 200 to 300 sq ft/ton applies due to the wide variance in product load.

The refrigeration requirements for loading docks are difficult to estimate. The activity level is high (personnel, forklifts, etc.), as is the rate of infiltration. Dock seals may be either worn or damaged, or not adaptable to certain trailer cavities. Forced ventilation is sometimes utilized to evacuate exhaust fumes, and, when present, will supplant the usual infiltration load (if greater). Docks are maintained at 35 to 55°F, with the lower temperatures affording the dual advantage of increased flexibility and decreased load imposition on adjacent rooms. Unit coolers should have face velocities under 650 FPM, and be placed such that they blow toward and above the doors to create an air curtain effect. The load range is 150 to 175 sq ft/ton.

Ripening rooms are usually located at the rear of the loading area, and may be of 1/2, 1 or 2 car capacity. The load range is 3 to 12 tons per room, and is accommodated most effectively with individual halocarbon systems specifically designed for this application. Since the full complement of rooms are seldom (if ever) in simultaneous service, a load diversity factor of .75 can be applied if a central refrigeration plant is utilized.

## FORM LE-1

**PART II - SURVEY DATA:**

**A. FACILITY DESIGN DATA:**

DESIGN DATA	AMBIENT DESIGN	INSULATED DOORS
	95 DRY BULB, °F 50 WET BULB, °F REL. HUMID., %	NO. 3 THICKNESS, IN. HGT., FT. 8 WIDTH, FT. 6 TYPE: <u>GLASS</u>
PHYSICAL DATA	ROOM DESIGN	VENTILATION FANS
	35 DRY BULB, °F 75 WET BULB, °F 85 REL. HUMID., %	NO. NONE TYPE: NONE
PHYSICAL DATA	FLOOR	CEILING
	CONCRETE	INSULATED PANELS
	N. WALL	E. WALL
	S. WALL	W. WALL
	TYPE: STYRENE	TYPE: FOAMED-IN PLACE URETHANE
	THICK (IN): 6	THICK (IN): 4
PHYSICAL DATA	INSULATION	ADJACENT AREA
	TYPE: SOLAR LOAD (L.V.)	TEMP. °F
	55	20
	95	60
	95	60
	55	20

**B. ELECTRICAL SERVICE:**

POWER CHARACTERISTICS: 3 PHASE, 60 HERTZ, 460 VOLTAGE  
CONTROL VOLTAGE: 115  
DISCONNECT: BY REFRIG. CONTR. TYPE REQ.

POWER TRANSFORMER: NONE  
CONTROL TRANSFORMER: NONE  
EXISTING SERVICE, AMPS. (A)  
EXISTING CONNECTED LOAD, AMPS. (B)  
AVAILABLE SERVICE, AMPS. (A+B)

**C. PRODUCT DATA:**

PRODUCE DESCRIPTION: CARTON TYPE PACKAGING  
90 SP. HT. (AVG.)  
40 ENTERING TEMP., °F  
35 FINAL TEMP., °F  
24 PULDDOWN TIME, HRS.

CONTAINERS: CARTON TYPE  
AVG. 2.5 CONT. WGHT., LB.  
35 PRODUCT WGHT., LB.  
EIBER MATERIAL  
0.33 SP. HT. TABLE 44

PALLETS: SIZE (LxWxH), FT.  
NUMBER  
WEIGHT (EA.), LB.  
MATERIAL  
SP. HT. TABLE 44

RESPIRATION: 1700 HOLDING LOAD, LB.  
1.5 RATE, BTU/LB/24 HR. TABLE 9  
6 AVERAGE

ROOM CAPACITY: ROOM VOLUME, CU. FT.  
LOADING DENSITY, LB./CU. FT.  
EST. PROD. LOAD, LB./CU. FT. TABLE 14  
6 1700, 000 LB. (CONVEYED)

**D. MISCELLANEOUS LOAD DATA:**

2 PEOPLE  
16 FAN MOTOR HP. (ESTIMATE)  
OTHER MOTORS, HP.  
2 FORKLIFTS, HP. (EST. @ 4 HP. EA.)  
1 LIGHTS, WATTS/SQ. FT.  
APPLIANCES, WATTS  
OTHER HEAT GAINS

RACK PULLDOWN: MATERIAL, TOT. WGHT. LBS., SP. HT. TABLE 44  
FAN MTR. EQUIV. HP. = 16 HP. x 150 MIN/HR. OPER. TIME = 13.4  
FORKLIFT EQUIV. HP. = 8 HP. x 10 MIN/HR. OPER. TIME = 5.8

**E. SUPPLEMENTAL DATA:** STORAGE PERIOD MAY EXTEND FROM 10 TO 15 DAYS - HUMIDITY CRITICAL - USE 7°F COIL T.D.

**PART III - LOAD CALCULATIONS:**

**A. HEAT TRANSMISSION LOAD:**

FLOOR	TD	AREA	FACTOR (TABLE 1)	BTU/24 HRS
20	20	100 LGHT. FT. X 75 WIDTH. FT. X 19	19	142,500
100	100	100 LGHT. FT. X 75 WIDTH. FT. X 76	76	570,000
100	100	100 LGHT. FT. X 20 HGT. FT. X 38	38	116,000
60	60	75 WIDTH. FT. X 20 HGT. FT. X 62	62	23,000
20	20	100 LGHT. FT. X 20 HGT. FT. X 19	19	38,000
40	40	75 WIDTH. FT. X 20 HGT. FT. X 63	63	64,500
SUBTOTAL A - TRANSMISSION BTU/24 HRS				895,000

**B. INFILTRATION LOAD:**

RM. VOL. FT. X FACTOR TABLE 44 X B X FACTOR TABLE 5 (NOTE 1)  
1 NO. DOORS VEL. FPM X 1.48 DOOR AREA, FT. X 1.80 MIN. OPEN/24 HRS. X 1.8 FACTOR TABLE 5  
VENTILATION CFM X FACTOR TABLE 5 X 1440 TABLE 5

VEL. = 488 x V<sup>0.8</sup> = 120 = 61.87  
SUBTOTAL B - INFILTRATION BTU/24 HRS 487,516

**C. PRODUCT LOAD:**

PRODUCT COOLING: 200,000 LBS./HR. X 5 T.D. °F X 90 BTU/HR. HT. X LOAD FACTOR\* X 24 TABLE 10  
24

PRODUCT FREEZING: LBS./HR. X T.D. °F X SP. HT. X LOAD FACTOR\* X 24 TABLE 10

PRODUCT SUB-COOLING: 24,285 LBS./HR. X 5 T.D. °F X 2 SP. HT. X 24 TABLE 9

CONTAINER COOLING: 24,285 LBS./HR. X 5 T.D. °F X 2 SP. HT. X 24 # CARTONS/DAY  
24,285

PALLET COOLING: 1700,000 LBS. X 3.0 BTU/LB/24 HRS. X 24 TABLE 44  
5,100,000

RESPIRATION: 1700,000 LBS. X 1.5 BTU/LB/24 HRS. X 24 TABLE 9  
6,120,000

APPLIES TO CERTAIN CHILL ROOMS AND BATCH LOADED BLIST FREEZERS ONLY. SEE PAGES 9 THRU 11, AND NOTE 5 TABLE 10.

SUBTOTAL C - PRODUCT BTU/24 HRS 6,024,285

**D. SUPPLEMENTAL LOAD:**

OCCUPANCY: 100 NO. OF PERSONS X 2500 BTU/PERSON/DAY TABLE 6  
LIGHTS: 2 LGHT. FT. X 75 WIDTH. FT. X 1 WATTS/SQ. FT. X 82 BTU/WATT/24 HRS. 615,000  
MOTORS: 13.4 EQUIV. HP. X 92.82 BTU/HP-HR. X 24 1,366,800  
FORKLIFTS: 5.8 EQUIV. HP. X 72000 BTU/HP/24 HRS. X 24 388,800  
DEFROST HEAT: 3 HRS. X 14000 WATTS X 3.4 BTU/WATT/HR. X 25 367,200  
OTHER: EST. EQUIV. WATTS/UNIT @ 18000 (8 UNITS)

SUBTOTAL D - SUPPLEMENTAL BTU/24 HRS 2,780,800

**EQUIPMENT SELECTION AND DESIGN DATA:**

QUANTITY	UNIT	CONDENSING UNITS	CONDENSERS
MODEL NO.	DT6C/190		
CAP. EA. BTU/HR.	67,339		
CFM EA.	302.50		
EVAP. TEMP. °F	30		
SUCTION TEMP. °F			
COND. TEMP. °F			

BTU/24 HR TOTAL (A+B+C+D) 10,187,601  
CONVERT TO HOURLY LOAD (TABLE 8) ... 20  
BTU/HR TOTAL WITH TIME CYCLE CORRECTION 509,380  
APPLY SAFETY FACTOR ... X 1.10  
BTU/HR TOTAL WITH S. F. CORRECTION 560,318  
CONVERT TO TONS OF REFRIGERATION ... -12,000  
GRAND TOTAL TONS 46.6  
SQ. FT./TON 160.2

NOTES: NOTE 1: 24 X 2.5 = 12.5 = 9.0 BTU/LB. SP. VOL. = 13.15 CU. FT./LB. BTU/CU. FT. = 20/13.15 = 1.52

# APPLICATION EXAMPLE

## VII. WALK-IN COOLERS:

### GENERAL

Pre-fabricated walk-in coolers and freezers are utilized for a wide variety of refrigerated storage, chilling and freezing applications, the most common of which is the point-of-sale holding room.

Since standard configurations with an extensive experience factor are involved, loads may be precalculated and charted as a matter of convenience.

A brief description of the precalculated walk-in cooler data included herein is as follows:

### TABLE NO. DESCRIPTION

40	<p>Tabulates transmission, infiltration, lighting, occupancy and related miscellaneous loads for 8' and 10' prefabricated coolers in the 40 most common configurations. Note that product load is <b>excluded</b> for the purpose of enabling greater applicational flexibility. Loads are based on:</p> <ul style="list-style-type: none"> <li>• 95°F ambient design</li> <li>• Average usage</li> <li>• Indoor installation</li> <li>• 3" urethane (or equivalent) insulation</li> <li>• 18 hour compressor operation</li> </ul> <p>Correction factors are noted for other ambients, and for light or heavy usage situations.</p>
41	<p>Tabulates average product loads by room volume. Data is based on actual Hussmann experience with field applications, and is intended for use with holding rooms <b>only</b> when the specific product loading is unknown.</p>
42	<p>Tabulates specific product loads on the basis of 24 hour pulldown with 18 hour operation. This table should be used for all pulldown coolers and freezers, or when the specific product entering rate and condition is known. Note: batch blast freezing, and certain other specialized applications such as ice cream hardening, require adjustment of the 24 hr pulldown data. The applicable formula is:</p>

$$Q_{\text{Btu}} / 24 \text{ hrs} = \frac{\text{Charted Value} \times 24}{\text{Pulldown or Freezing Time hrs}}$$

43	Tabulates additional infiltration loads for glass display doors.
----	--

Additionally, Table 32 tabulates the total capacity requirements for walk-in beer storage coolers.

Product loads not tabulated in Table 42, or loads for specialized applications, may be estimated in the usual manner utilizing Form LE-1.

### SPECIFIC EXAMPLES:

#### I. Cooler — Average Product Load:

- 10' W × 12' L × 8' H @ 36°F
  - 95°F ambient design
- 
- Refrig. load less product (Table 40) . . . . . 7,000 Btu/hr
  - Average product load (Table 41) . . . . . 1,800 Btu/hr
- Total refig. load . . . . . 8,800 Btu/hr

#### II. Milk Cooler — Specific Product Load:

- 10' W × 12' L × 8' H @ 35°F
  - 300 gal/day entering @ 45°F
  - 10 hour pulldown
  - 80°F ambient design (air cond. space)
  - (3) 30" × 66" glass display doors
- 
- Refrig. load less product (Table 40)  
7125 × 0.75 (C.F. @ 80°F) . . . . . 5,444 Btu/hr
  - Product load (Table 42)  
456 Btu/hr / 100 gal ×  $\frac{300}{100} \times \frac{24}{10}$  . . . . . 3,283 Btu/hr
- 
- Display door infiltration (Table 43)  
960 × 3 . . . . . 2,880 Btu/hr
- Total refig. load . . . . . 11,607 Btu/hr

#### III. Holding/Pulldown Freezer:

- 16' W × 32' L × 10' H @ -20°F
  - 2000 lbs fish/day entering @ 35°F
  - 100°F ambient design
  - Product packaged & boxed
  - 16 hour pulldown
- 
- Refrig. load less product (Table 40)  
26,600 Btu/hr × 1.10 (C.F. @ 100°F) . . . . . 29,260 Btu/hr
  - Product load (Table 42)  
817 Btu/hr/100 lbs ×  $\frac{2000}{100} \times \frac{24}{16}$  . . . . . 24,510 Btu/hr
- 
- Total refig. load . . . . . 53,770 Btu/hr

#### IV. Ice Cream Hardening/Storage Freezer:

- 30' W × 30' L × 10' H @ -20°F
  - Soft mix @ 28°F
  - Assume maximum daily capacity
  - 100% overrun; wgt/gal = 4.6 lbs
  - 95°F ambient design
- 
- Refrig. load less product (Table 40) . . . . . 37,000 Btu/hr
  - Product load (Table 42)  
Assuming 3.3 gal/sq ft (see Table 7, Note 7), the no. of gal to be hardened is:  
900 sq ft × 3.3 gal/sq ft = 2970 gal,  
and the product load based on a 10 hr hardening time is therefore:  
3284 Btu/hr/100 gal × 2970/100 × 24/10 . . . . . 234,083 Btu/hr
- 
- Total refig. load . . . . . 271,083 Btu/hr

#### V. Beer Cooler:

- 12' W × 20' L × 10' H @ 35°F
  - 900 case capacity with 20% daily turn
  - Product entering temp. of 50°F
  - 95°F ambient design
- 
- Refrig. load less product assuming heavy usage (Table 40)  
11,100 × 1.15 (C.F. @ heavy usage) . . . . . 12,765 Btu/hr
  - Product load (Table 42)  
2670 Btu/hr/100 Cases ×  $\frac{900}{5 \times 100}$  . . . . . 4,806 Btu/hr
- 
- Total refig. load . . . . . 17,571 Btu/hr

# APPENDIX—TABLES

TABLE 1A			HEAT GAIN FACTORS IN BTU/SQ FT /24 HRS FOR COMMON INSULATING & BUILDING MATERIALS																													
			TEMPERATURE DIFFERENCE — °F (AMBIENT LESS STORAGE TEMPERATURE)																													
	K Factor	Inches	1	10	20	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	105	110	115	120	125	130						
FOAMGLASS	.38	3	3.85	39	77	116	135	154	173	193	212	232	250	270	288	308	327															
		4	2.28	23	46	68	80	92	103	114	125	136	148	160	171	184	194		206	217	228		239	250	262		272	285	296			
		5	1.82	18	36	55	64	72	82	91	100	110	118	128	137	144	155		164	173	182		191	200	209		220	228	236			
		6	1.52	15	30	46	53	61	68	76	84	92	99	106	114	122	129		136	144	152		160	168	175		184	190	198			
		7	1.30	13	26	39	46	52	59	65	72	78	85	92	98	104	110		118	124	130		137	144	150		156	163	170			
		8	1.14	11	23	34	40	46	51	57	63	68	74	80	86	92	97		102	106	114		120	126	131		136	143	148			
		9	1.01	10	20	30	35	40	45	50	55	61	65	71	76	81	86		91	96	101		106	111	116		121	126	131			
		10	0.91	9	18	27	32	36	41	46	50	54	59	64	68	72	77		82	86	91		96	100	105		108	114	118			
		11	0.83	8	17	25	29	34	37	42	46	50	54	58	62	68	71		74	79	83		87	92	95		100	104	108			
		12	0.76	7.6	15	23	27	30	34	38	42	46	49	54	57	60	65		68	72	76		80	84	87		91	95	99			
		CORKBOARD	.30	3	2.40	24	48	72	84	96	108	120	132	144	156	168	180	192	204		216	228	240		252	264	276		288	300	312	
				4	1.80	18	36	54	63	72	81	90	99	108	117	126	135	144	153		162	171	180		189	198	207		216	225	234	
5	1.44			14	28	42	50	58	65	72	79	87	94	101	108	115	122		130	137	144		151	159	166		173	180	188			
6	1.20			12	24	36	42	48	54	60	66	72	78	84	90	96	102		108	114	120		126	132	138		144	160	176			
7	1.03			10	20	30	35	41	46	52	57	62	67	72	77	82	88		93	98	103		108	113	118		124	129	134			
8	0.90			9	18	27	32	36	41	45	50	54	59	63	68	72	77		81	86	90		95	99	104		108	113	118			
9	0.80			8	16	24	28	32	36	40	44	48	52	56	60	64	68		72	76	80		84	88	92		96	100	104			
10	0.72			7	14	21	25	29	32	36	40	43	47	50	54	58	61		65	68	72		76	79	83		86	90	94			
11	0.66			6.5	13	19.5	23	26	30	33	36	40	43	46	50	53	56		60	63	66		69	73	76		79	82	86			
12	0.60			6	12	18	21	24	27	30	33	36	39	42	45	48	51		54	57	60		63	66	69		72	75	78			
EXPANDED POLYSTYRENE OR FIBERGLASS	.24			1	5.76	58	115	173	201	230	260	290	320																			
				2	2.88	29	58	86	101	115	130	144	158		173	187	202		216	231	245		260	274	288		303					
		3	1.92	19	38	58	68	77	86	96	106		115	125	135		145	154	163		173	182	192		202	212	221		231	240	251	
		4	1.44	14	29	43	50	58	65	72	79		86	94	101		108	115	123		130	137	144		151	159	166		173	181	188	
		5	1.15	11	23	34	40	46	51	58	63		68	75	80		86	92	98		102	109	115		121	126	132		136	143	150	
		6	0.96	9.6	19	29	34	38	43	48	53		58	62	68		72	77	82		87	91	96		101	106	111		115	120	125	
		7	0.84	8.4	17	25	29	34	38	42	46		50	55	59		63	68	72		76	80	84		88	92	97		101	105	109	
		8	0.72	7.2	14	22	25	29	32	36	39		43	46	50		54	57	61		65	69	72		76	80	83		86	90	93	
		9	0.64	6.4	13	19	22	26	29	32	35		38	42	44		48	52	54		58	61	64		67	70	74		76	80	84	
		10	0.58	5.8	12	17	20	24	26	29	32		34	38	40		44	48	49		52	55	58		61	64	67		69	73	75	
EXTRUDED POLYSTYRENE	.185	1	4.44	44	89	133	155	178	200	222	244		266	289	311		333															
		2	2.22	22	44	67	78	89	100	111	122		133	145	156		167	177	189		200	211	222		233	244	255		266	278	289	
		3	1.48	15	30	44	52	60	67	74	81		89	96	104		111	118	126		133	141	148		155	163	170		178	185	192	
		4	1.11	11	22	34	39	45	50	56	61		67	73	78		84	89	95		100	106	111		117	122	128		133	139	145	
		5	0.89	9	18	27	31	36	40	45	49		54	58	62		67	71	76		80	85	89		93	98	102		107	111	116	
		6	0.74	7.4	15	22	26	30	33	37	40		44	48	52		56	59	63		67	70	74		78	81	85		89	92	96	
		7	0.63	6.3	13	19	22	25	28	32	35		38	41	44		47	50	53		57	60	63		66	69	72		76	79	82	
		8	0.56	5.6	11	17	19	23	25	28	31		34	37	39		42	45	48		50	53	56		59	61	64		67	69	72	
SLAB URETHANE-FOAMED IN-PLACE URETHANE PANELS	.16	1	3.84	38	77	115	134	154	173	192	211		230	250	268		288	307	326													
		2	1.92	19	38	58	67	77	87	96	106		115	124	135		144	154	163		173	183	192		202	212	221		231	240	249	
		3	1.28	13	26	38	45	51	58	64	71		77	83	90		96	102	109		115	122	128		135	141	147		154	160	167	
		4	0.96	9.6	19	29	34	38	43	48	53		58	63	68		72	76	82		87	91	96		101	106	111		115	119	125	
		5	0.75	7.5	15	23	26	30	34	38	41		46	49	52		56	60	64		68	71	75		79	83	86		90	94	98	
		6	0.64	6.4	13	19	22	26	29	32	35		38	42	45		48	51	54		57	61	64		67	70	74		77	80	83	
	.13	3	1.04	10	21	31	36	42	47	52	57		62	68	73		78	83	88		94	99	104		109	114	120		125	130	135	
		4	0.78	7.8	16	23	27	32	35	38	43		46	51	55		59	63	66		70	74	78		82	86	89		94	98	101	
		5	0.62	6.2	12	19	22	24	28	31	34		37	40	43		47	50	53		56	59	62		65	68	71		74	78	8	
BUILDING MATERIALS	Single Glass		27	270	540	810																										
	Double Glass		11	110	220	330			385			440			495			550			600			660			715			770		
	Triple Glass		7	70	140	210			245			280			320			350			390			420			454			490		
	6" Conc. on Grade		4.8	48	96	144																										

# APPENDIX—TABLES

TABLE 1B		HEAT TRANSMISSION COEFFICIENTS FOR OTHER INSULATING AND BUILDING MATERIALS						
	MATERIAL	DENSITY LB/CU FT	MEAN TEMP °F	CONDUCTIVITY K	CONDUCTANCE C	RESISTANCE PER IN	R OVERALL	
BUILDING BOARD	Asbestos-Cement Board	120	75	4.0	—	0.25	—	
	Plaster Board, 1/2"	50	75	—	2.25	—	0.45	
	Plywood	34	75	0.80	—	1.25	—	
	Insulating Board, Sheathing, 1/2"	22	75	—	0.82	—	1.22	
	Sound Deadening Board, 1/2"	15	—	—	—	0.74	—	1.35
	Hardboard, Siding 7/16"	40	75	—	1.49	—	0.67	
	Particleboard, Med. Dens.	50	75	0.94	—	1.06	—	
BUILDING PAPER	Vapor, Permeable Felt	—	75	—	16.70	—	0.06	
	Vapor, Seal, 2 Layers of Mopped 15 lb Felt	—	75	—	8.35	—	0.12	
	Vapor, Seal, Plastic Film	—	75	—	—	—	Negl.	
FLOORING	Carpet & Fiber Pad	—	75	—	0.48	—	2.08	
	Carpet & Rubber Pad	—	75	—	0.81	—	1.23	
	Cork Tile, 1/8"	—	75	—	3.60	—	0.28	
	Terrazzo, 1"	—	75	—	12.50	—	0.08	
	Tile, Asphalt Vinyl or Linoleum	—	75	—	20.00	—	0.05	
	Wood Subfloor, 25/32"	—	—	—	1.05	—	0.95	
	Wood Flooring	—	—	—	1.45	—	0.69	
INSULATION	Blanket, Fiberglass	1.0	75	0.29	—	3.45	—	
	Blanket, Mineral Wool	0.5	75	0.32	—	3.12	—	
	Loose Fill, Perlite, Expanded	5.0-8.0	75	0.37	—	2.70	—	
	Loose Fill, Glass Fiber	2.5	75	0.28	—	3.46	—	
	Loose Fill, Vermiculite, Exp.	7.0-8.2	75	0.47	—	2.12	—	
	Insulating Roof Deck, 2"	—	75	—	0.18	—	5.56	
	Mineral Fiber Board, Accoustical Tile Roof Insulation, 2" (Note 1)	23	75	0.42	—	2.38	—	
MISC.	Sawdust	—	75	0.45	—	2.22	—	
	Snow	—	—	1.2-3.6	—	0.83-0.27	—	
	Soil	—	—	7.2-12.0	—	0.14-0.08	—	
	Water	—	—	4.2	—	0.24	—	
MASONRY	Brick, Common	120	75	5.0	—	0.20	—	
	Brick, Face	130	75	9.0	—	0.11	—	
	Concrete (Sand & Gravel)	140	—	12.0	—	0.08	—	
	Concrete Block (Sand & Gravel — 8")	—	75	—	0.90	—	1.11	
	Concrete Block, Cinder, 8"	—	75	—	0.58	—	1.72	
	Concrete Block, Cinder, 12"	—	75	—	0.53	—	1.89	
	Gypsum Plaster (Sand)	105	75	5.6	—	0.18	—	
	Stone, Lime or Sand	—	75	12.50	—	0.08	—	
	Tile, Hollow 2 Cell, 6"	—	75	—	0.66	—	1.52	
ROOFING	Asphalt Roll Roofing	70	75	—	6.5	—	0.15	
	Roofing, Built-Up, 3/8"	70	75	—	3.0	—	0.33	
	Shingles, Asbestos Cement	120	75	—	4.76	—	0.21	
	Shingles, Asphalt	70	75	—	2.27	—	0.44	
SIDING	Asphalt Insul. Siding, 1/2"	—	75	—	0.69	—	1.46	
	Wood, Bevel, 1/2" x 8" Lapped	—	75	—	1.23	—	0.81	
	Aluminum or Steel (Sheathed)	—	—	—	1.61	—	0.61	
	Insulating-Board Backed, 3/8"	—	—	—	0.55	—	1.82	
WOOD	Hardwoods (Maple, Oak)	45	75	1.10	—	0.91	—	
	Softwoods (Fir, Pine)	32	75	0.80	—	1.25	—	
	Softwoods (Fir, Pine), 3/4"	32	75	—	1.06	—	0.94	

Note 1: Various thicknesses to meet U.S. Department of Commerce Standard.

Extracted From 1972 ASHRAE Handbook of Fundamentals — Reprinted By Permission

# APPENDIX—TABLES

**TABLE 2 SOLAR RADIATION ALLOWANCE**

SURFACE TYPE		°F TO BE ADDED TO NORMAL T.D. (NOTE 1)			
		East Wall	South Wall	West Wall	Flat Roof
DARK	Slate Roofing	8	5	8	20
	Tar Roofing Black Paints				
MEDIUM	Unpainted Wood	6	4	6	15
	Brick				
	Red Tile				
	Dark Cement Red, Grey, or Green Paint				
LIGHT	White Stone	4	2	4	9
	Light Colored Cement				
	White Paint				

Notes: 1. The F degrees noted are to be added to the normal temperature difference to compensate for sun effect in calculating transmission heat gain.  
 2. Not to be used for air conditioning design.  
 3. Add 50% to charted values for buildings adjacent to highly reflective surfaces such as sun, water, or heat-repellent glass.

**TABLE 3 MOTOR EQUIVALENCIES**

HORSE-POWER	BTU PER HORSEPOWER-HOUR		
	Connected Load And Motor In Refrigerated Space (Note 1)	Connected Load Only In Refrigerated Space	Motor Only In Refrigerated Space
1/8 to 1/2	4250	2545	1700
3/4-3	3700	2545	1150
5-20	2950	2545	400

Note 1: Use for forced circulation unit coolers.

**TABLE 4A AVERAGE AIR CHANGES PER 24 HRS FOR MED. TEMPERATURE (ABOVE 32°F) ROOMS DUE TO INFILTRATION AND DOOR OPENINGS**

VOLUME CU FT	AIR CHANGES PER 24 HR	VOLUME CU FT	AIR CHANGES PER 24 HR	VOLUME CU FT	AIR CHANGES PER 24 HR	VOLUME CU FT	AIR CHANGES PER 24 HR
200	44.0	1000	17.5	6000	6.5	30000	2.7
300	34.5	1500	14.0	8000	5.5	40000	2.3
400	29.5	2000	12.0	10000	4.9	50000	2.0
500	26.0	3000	9.5	15000	3.9	75000	1.6
600	23.0	4000	8.2	20000	3.5	100000	1.4
800	20.0	5000	7.2	25000	3.0	200000	0.9

Note: For heavy usage, multiply above values by 2. For long storage, multiply the above values by 0.60. Not valid if ventilating ducts or grilles are used.

**TABLE 4B AVERAGE AIR CHANGES PER 24 HRS FOR LOW TEMPERATURE (BELOW 32°F) ROOMS DUE TO INFILTRATION AND DOOR OPENINGS**

VOLUME CU FT	AIR CHANGES PER 24 HR	VOLUME CU FT	AIR CHANGES PER 24 HR	VOLUME CU FT	AIR CHANGES PER 24 HR	VOLUME CU FT	AIR CHANGES PER 24 HR
250	29.0	1000	13.5	5000	5.6	25000	2.3
300	26.2	1500	11.0	6000	5.0	30000	2.1
400	22.5	2000	9.3	8000	4.3	40000	1.8
500	20.0	2500	8.1	10000	3.8	50000	1.6
600	18.0	3000	7.4	15000	3.0	75000	1.3
800	15.3	4000	6.3	20000	2.6	100000	1.1

Note: For heavy usage, multiply above values by 2. For long storage, multiply the above values by 0.6. Not valid if ventilating ducts or grilles are used.

Tables 2, 3, 4A & 4B from 1972 ASHRAE Handbook of Fundamentals — Reprinted by Permission

# APPENDIX—TABLES

**TABLE 5 HEAT REMOVED IN COOLING AIR TO STORAGE CONDITIONS (BTU PER CU FT)**

STORAGE ROOM TEMP. °F	TEMPERATURE OF OUTSIDE AIR, °F							
	85		90		95		100	
	RELATIVE HUMIDITY, PERCENT							
	50	60	50	60	50	60	50	60
65	0.32	0.52	0.58	0.81	0.85	1.12	1.15	1.46
60	0.58	0.78	0.83	1.06	1.10	1.37	1.39	1.70
55	0.80	1.00	1.05	1.28	1.32	1.59	1.61	1.92
50	1.01	1.21	1.26	1.49	1.53	1.79	1.82	2.13
45	1.20	1.40	1.45	1.68	1.71	1.98	2.00	2.31
40	1.37	1.57	1.62	1.85	1.88	2.15	2.17	2.48
35	1.54	1.74	1.78	2.01	2.04	2.31	2.33	2.64
30	1.78	2.01	2.05	2.31	2.33	2.64	2.65	3.00

STORAGE ROOM TEMP. °F	TEMPERATURE OF OUTSIDE AIR, °F							
	40		50		90		100	
	RELATIVE HUMIDITY, PERCENT							
	70	80	70	80	50	60	50	60
30	0.21	0.26	0.55	0.62	2.05	2.31	2.65	3.00
25	0.37	0.43	0.71	0.78	2.20	2.46	2.79	3.14
20	0.52	0.58	0.86	0.93	2.33	2.60	2.93	3.28
15	0.66	0.72	1.00	1.07	2.46	2.72	3.05	3.40
10	0.80	0.85	1.13	1.20	2.58	2.84	3.17	3.52
5	0.92	0.97	1.25	1.32	2.69	2.95	3.28	3.63
0	1.04	1.09	1.36	1.43	2.80	3.06	3.38	3.74
- 5	1.15	1.20	1.47	1.55	2.90	3.16	3.48	3.84
- 10	1.26	1.31	1.58	1.65	3.00	3.26	3.58	3.93
- 15	1.37	1.42	1.69	1.76	3.10	3.36	3.68	4.03
- 20	1.47	1.52	1.79	1.86	3.19	3.46	3.77	4.12
- 25	1.57	1.62	1.89	1.96	3.29	3.55	3.86	4.21
- 30	1.67	1.72	1.99	2.06	3.38	3.64	3.95	4.30

From 1972 ASHRAE Handbook of Fundamentals — Reprinted by Permission

**TABLE 6 OCCUPANCY HEAT**

ROOM TEMPERATURE °F	HEAT PER PERSON BTU/24 HRS
50	17,300
40	20,200
30	22,800
20	25,200
10	28,800
0	31,200
- 10	33,600

Derived from 1972 ASHRAE Handbook of Fundamentals — Reprinted by Permission

**TABLE 7 ICE CREAM DATA**

PERCENT OF OVERRUN	HARDENING LOAD BTU/GAL ICE CREAM
60	532
70	500
80	470
90	447
100	425
110	405
120	386

Notes:

1. % overrun =  $\frac{(\text{wgt / gal of mix}) - (\text{wgt / gal ice cream})}{\text{wgt / gal of ice cream}}$
2. Values based on entering temp of 25°F (30% frozen).
3. Formula:  $\text{Product Load (Btuh)} = \frac{\text{no of gal} \times \text{Btu/gal}}{\text{hardening time (hrs)}}$
4. 8-10 hr hardening time should be used with forced air circulation; adjust the calculated load for 18-20 hr compressor operation.
5. See Table 42 for prefigured 24 hr hardening loads at 28°F ent. temp. & 18 hr comp. operation (the values charted in Table 42 must be adjusted for the desired hardening time — i.e., 8 or 10 hrs).
6. At 100% overrun, avg. wgt/gal is 4.6 lb with 60% water content.
7. Estimate hardening rooms at a peak daily production rate of 3.3 gal/sq ft and for a storage capacity of 10 gal/sq ft, if sized to stock all flavors.
8. Estimate storage rooms @ 25 gal/sq ft when stacked solid 6 ft high (including aisles).

Extracted from 1971 ASHRAE Guide & Data Book — Reprinted by Permission

**TABLE 8 TIME CYCLE FACTORS**

APPLICATION	RECOMMENDED FACTORS	
	24 HOUR (DIVIDE BY)	HOURLY (MULTIPLY BY)
Coil Temp. Above 32°F — No Frost Accumulation	24	1.0
Light Frost With Positive Defrost Systems	22	1.1
Med. Temp. With Positive Defrost Systems	20	1.2
Low Temp. With Positive Defrost Systems	18	1.3
Off Cycle Defrost, 35°F or Higher Storage Temp., With Evap. Temp. Below 32°F	16	1.5

Note: Factors noted are for average frosting. For heavier frost, or lower than normal evap. temps., use 1-2 hrs less oper. time.



# APPENDIX—TABLES

<b>TABLE 9</b>												
<b>PROPERTIES AND STORAGE DATA FOR PERISHABLE PRODUCTS</b>												
PRODUCT	SP. HEAT BTU/LB/°F <sup>1</sup>		LATENT <sup>2</sup> HEAT OF FUSION BTU/LB	HIGHEST FREEZE POINT °F	WATER CONTENT %	SHORT STORAGE			LONG STORAGE			
	ABOVE FREEZE POINT	BELOW FREEZE POINT				TEMP °F	RH% MIN-MAX	RESPIRATION HEAT BTU/LB/24 HR	TEMP °F	RH% MIN-MAX	RESPIRATION HEAT BTU/LB/24 HR	APPROX. STORAGE LIFE
<b>DAIRY PRODUCTS</b>	(See Tables 24-28 for additional Milk / Cheese Data)											
Butter	.64	.34	15	30.0	15.0	40	75-80	—	-5 to -10	80-85	—	6 Mos
Cheese												
• American	.64	.36	79	17.0	55.0	40 <sup>8</sup>	75-80	—	32 <sup>8</sup>	75-80	—	12 Mos
• Limburger	.70	.40	86	19.0	60.0	40 <sup>8</sup>	80-85	—	32 <sup>8</sup>	80-85	—	2 Mos
• Roquefort	.65	.32	79	3.0	55.0	45 <sup>8</sup>	75-80	—	30 <sup>8</sup>	75-80	—	2 Mos
• Swiss	.64	.36	79	15.0	55.0	40 <sup>8</sup>	75-80	—	32 <sup>8</sup>	75-80	—	2 Mos
Cream	.85	.40	90	28.0	55.0	35	—	—	-5 to -10	—	—	4 Mos
Eggs												
• Crated	.75	.42	96	30.0 <sup>4</sup>	66.0	40 <sup>8</sup>	80-85	—	31 <sup>8</sup>	85-88	—	12 Mos
• Frozen	—	.42	96	30.0 <sup>4</sup>	—	—	—	—	-5 to -10	—	—	18 Mos
• Whole Solid	.22	.21	4	—	3.0	40 <sup>8</sup>	80	—	40 <sup>8</sup>	80	—	12 Mos
Ice Cream	.75	.42	89	28.0	61.0	-15	—	—	-15	—	—	3-4 Mos
Milk												
• Fluid Whole	.92	.48	125	31.0	88.0	35	—	—	—	—	—	5 Days
• Condensed	.42	—	40	—	28.0	40	—	—	40	—	—	3 Mos
• Evaporated	.72	—	106	—	74.0	—	—	—	Rm Temp	—	—	12 Mos
• Dried	.22	—	4	—	3.0	—	—	—	50	80	—	3 Mos
Oleo	.32	.25	22	—	15.5	45	60-70	—	35	60-70	—	8 Mos
<b>FRUIT</b>												
Apples	.87	.45	121	29.3	84.1	35 <sup>6</sup>	85-88 <sup>6</sup>	.72	30 <sup>6</sup>	85-88 <sup>6</sup>	.48	3-8 Mos
Apricots	.88	.46	122	30.1	85.4	35	80-85	.96	31	80-85	.48	2 Wks
Avocados	.81	.45	118	31.5	82.0	50 <sup>6</sup>	85-90 <sup>6</sup>	—	45 <sup>6</sup>	85-90 <sup>6</sup>	—	3 Wks
Bananas												
• Green	.80	.42	108	30.6	74.8	56	90-95	.17	—	—	—	—
• Ripe	.80	.42	108	30.6	74.8	—	—	—	56	85-90	.17	8 Days
Berries (Gen)	.88	.45	120	30.0	84.0	35	80-85	2.90	31	80-85	2.90	8 Days
Cherries	.86	.45	116	28.8	80.4	35	80-85	1.35	31	80-85	.75	2 Wks
Coconuts	.58	.34	67	30.4	46.9	35	80-85	—	32	80-85	—	2 Mos
Cranberries	.90	.46	124	30.4	87.4	40	85-90	.48	36	85-90 <sup>8</sup>	.48	3 Mos
Currants	.88	.45	120	30.2	84.7	36	85-90	—	32	85-90	—	2 Wks
Dates (Cured)	.36	.26	29	3.7	20.0	35 <sup>6</sup>	65-75	—	28 <sup>6</sup>	65-70	—	6 Mos
Dried fruit	.42	.28	39	—	28.0	35	50-60	—	32	50-60	—	12 Mos
Figs (Fresh)	.82	.43	112	27.6	78.0	40	65-75	—	32	65-75	—	12 Days
Grapefruit	.91	.46	126	30.0	88.8	45	85-90	.48	32	85-90 <sup>8</sup>	.24	6 Wks
Grapes (Calif)	.86	.44	116	28.1	81.6	35	80-90	.48	31	85-90 <sup>8</sup>	.24	5 Mos
Lemons	.91	.47	127	29.4	89.3	55 <sup>5</sup>	85-90 <sup>8</sup>	1.44	55	85-90 <sup>8</sup>	.96	3 Mos
Limes	.86	.45	118	29.7	82.9	45	85-90 <sup>8</sup>	1.44	45	85-90 <sup>8</sup>	.96	8 Wks
Melons	.94 <sup>3</sup>	.48 <sup>3</sup>	120 <sup>3</sup>	30.0	87.0 <sup>3</sup>	45	85-90	1.68	40	85-90	.96	3 Wks
Olives (Fresh)	.80	.42	108	29.4	75.2	50	85-90	—	45	85-90	—	5 Wks
Oranges	.90	.46	124	30.6	87.2	40 <sup>6</sup>	85-90	.72	32 <sup>6</sup>	85-90 <sup>8</sup>	.48	3-12 Wks
Peaches	.90	.46	124	30.3	89.1	35	80-85	.96	32	80-85 <sup>8</sup>	.48	2-4 Wks
Pears	.86	.45	118	29.2	82.7	35 <sup>6</sup>	90-95	.72	30 <sup>6</sup>	90-95 <sup>8</sup>	.48	2-7 Mos
Pineapples												
• Green	.88	.45	122	30.2	85.3	50	85-90 <sup>8</sup>	—	—	—	—	4 Wks
• Ripe	.88	.45	122	30.0	85.3	40	85-90 <sup>8</sup>	—	—	—	—	3 Wks
Plums	.88	.45	118	30.5	82.3	40	80-85	1.44	31	80-85 <sup>8</sup>	.72	2-6 Wks
Prunes	.88	.45	118	30.5	82.3	40	80-85	1.44	31	80-85 <sup>8</sup>	.72	2-6 Wks
Quinces	.88	.45	122	28.4	85.3	35	80-85	.72	31	80-85 <sup>8</sup>	.48	2-3 Mos
Raisins (Dried)	.47	.33	45	—	—	45	85-90	—	40	85-90	—	3-6 Mos
Raspberries	.84	.44	122	30.0	80.6	31	85-90	2.40	—	—	—	3 Days
Strawberries	.92	.42	129	30.6	89.9	31	85-90	1.80	—	—	—	5-7 Days
Tangerines	.90	.46	125	30.1	87.3	40	85-90	1.63	32	85-90	1.14	2-4 Wks
<b>MEAT</b>												
Bacon (Cured)	.43	.29	39	—	28.0	55	55-65	—	—	—	—	15 Days
Beef												
• Dried	—	—	—	—	—	—	—	—	55	65-70	—	6 Mos
• Fresh	.77	.42	99	30.0 <sup>3</sup>	70.0	34 <sup>8</sup>	85-90	—	32 <sup>8</sup>	85-90	—	3 Wks
• Brined	—	—	—	—	—	40	80-85 <sup>11</sup>	—	32	80-85 <sup>11</sup>	—	6 Mos
Liver/Tongue	.77	.44	102	—	72.0	34	85-90	—	32	85-90	—	3 Wks
Ham /Shoulder												
• Fresh	.61	.35	80	30.0 <sup>3</sup>	54.0	34 <sup>8</sup>	85-88	—	28 <sup>8</sup>	85-88	—	3 Wks
• Smoked	.56	.33	64	—	—	55	55-65	—	55	55-65	—	6 Mos/ up
Hides	—	—	—	—	—	—	—	—	34	55-70	—	3-5 Yrs

Footnote references above may be found at conclusion of Table on Page 26.

# APPENDIX—TABLES

<b>TABLE 9</b>												
<b>PROPERTIES AND STORAGE DATA FOR PERISHABLE PRODUCTS</b>												
PRODUCT	SP HEAT BTU/LB/°F <sup>1</sup>		LATENT <sup>2</sup> HEAT OF FUSION BTU/LB	HIGHEST FREEZE POINT °F	WATER CONTENT %	SHORT STORAGE			LONG STORAGE			
	ABOVE FREEZE POINT	BELOW FREEZE POINT				TEMP °F	RH% MIN-MAX	RESPIRATION HEAT BTU/LB/24 HR	TEMP °F	RH% MIN-MAX	RESPIRATION HEAT BTU/LB/24 HR	APPROX. STORAGE LIFE
Lamb <sup>a</sup>	.76	.45	100	28.0 <sup>3</sup>	70.0	34	85-90	—	28	85-90	—	2 Wks
Lard	—	—	—	—	0	45	75-80	—	32	75-80	—	6-8 Mos
Pork <sup>a</sup>	.53	.32	60	28.0 <sup>3</sup>	42.0	34	85-90	—	—	—	—	15 Days
Sausage												
• Fresh	.87	.56	92	26.0 <sup>3</sup>	65.0	35	85-90 <sup>b</sup>	—	—	—	—	7 Days
• Smoked	.83	.54	87	29.0 <sup>3</sup>	61.0	40	80-85	—	32	70-75	—	6 Mos
Veal <sup>a</sup>	.75	.40	98	28.0 <sup>3</sup>	65.0	34	85-90	—	28	85-90	—	15 Days
Frozen Meats	—	.42 <sup>3</sup>	—	—	—	—	—	—	-10	90-95	—	9 Mos
<b>POULTRY</b>												
Chicken	.80	.42	106	27.0 <sup>3</sup>	74.0	28	85-90	—	—	—	—	10 Days
Game	.80	.42	114	27.0 <sup>3</sup>	77.0	28	85-90	—	—	—	—	10 Days
Goose	.58	.35	69	28.0	48.0	28	85-90	—	—	—	—	10 Days
Turkey	.66	.38	82	28.0	57.0	28	85-90	—	—	—	—	10 Days
Frozen Fowl	—	.40 <sup>3</sup>	—	27.0 <sup>3</sup>	—	-5	85-90	—	-10	85-90	—	10 Mos
<b>SEA FOOD</b>												
Clams												
• In Shell	.84	.44	115	27.0	80.0	32	—	—	—	—	—	15 Days
• Shucked	.90	.46	125	27.0	87.0	32	70-75	—	—	—	—	10 Days
Crabs (Boiled)	.83	.44	115	—	80.0	25	80-90	—	—	—	—	10 Days
Fish												
• Fresh	.80 <sup>3</sup>	.43 <sup>3</sup>	110 <sup>3</sup>	28.0 <sup>3</sup>	80.0 <sup>3</sup>	30	80-95 <sup>b</sup>	—	—	—	—	15 Days
• Frozen	—	.43 <sup>3</sup>	—	—	—	-5	—	—	-10	—	—	8 Mos
• Smoked	.70	.39	92	—	—	45	50-60	—	40	50-60	—	6 Mos
Lobsters	.83	.44	113	—	79.0	25	80-90	—	—	—	—	10 Days
Oysters												
• In Shell	.84	.44	115	27.0	80.0	32	—	—	—	—	—	15 Days
• Shucked	.90	.46	125	27.0	87.0	32	70-75	—	—	—	—	10 Days
Shrimp/Scallops	.83	.45	119	28.0	75.0	32	70-75	—	—	—	—	7-10 Days
<b>VEGETABLES</b>												
Artichokes	.87	.45	120	29.9	83.7	40	90-95	7.24	31	90-95	5.07	1-2 Wks
Asparagus	.94	.48	134	30.9	93.0	32	85-90	.84	32	85-90 <sup>b</sup>	.84	3-4 Wks
Beans												
• Green	.91	.47	128	30.7	88.9	45	85-90	4.80	45	85-90 <sup>b</sup>	4.80	7-10 Days
• Lima	.73	.40	94	31.0	66.5	40	85-90	7.20	32	85-90 <sup>b</sup>	4.80	1-2 Wks
Beets												
• Bunch	.90	.46	126	31.3	87.6	40	85-90	2.40	32	95 <sup>a</sup>	1.44	10-14 Days
• Topped	.90	.46	126	30.1	87.6	40	85-90	2.40	32	85-90	1.44	3 Mos
Broccoli	.92	.47	130	30.9	89.9	40	90-95	2.40	32	90-95	1.44	9-12 Days
Brussel Sprouts	.88	.46	130	30.9	89.9	40	90-95	2.40	32	90-95 <sup>a</sup>	1.44	3-5 Wks
Cabbage	.94	.47	132	30.4	92.4	35	90-95	2.40	32	90-95 <sup>a</sup>	1.44	3-4 Mos
Carrots												
• Bunch	.86	.46	126	29.5	88.2	40	85-90	1.92	32	85-90 <sup>b</sup>	1.20	10-14 Days
• Topped	.90	.46	126	29.5	88.2	40	85-90	1.92	32	95	1.20	4-5 Mos
Cauliflower	.93	.47	132	30.6	91.7	35	85-90	2.40	32	85-90 <sup>b</sup>	1.44	2-4 Wks
Celery	.95	.48	135	31.1	93.7	35	85-90	2.40	32	90-95 <sup>a</sup>	1.44	3-4 Mos
Collards	.90	—	—	30.6	86.9	35	85-90	2.40	32	90-95 <sup>a</sup>	1.44	2 Wks
Corn (Fresh)	.82	.42	106	30.9	73.9	35	85-90	4.08	32	85-90 <sup>b</sup>	0.96	4-8 Days
Cucumbers	.97	.49	137	31.1	96.1	50	85-95	4.32	45	85-95	2.40	10-14 Days
Egg Plant	.94	.48	132	30.6	92.7	50	85-90	—	45	85-90	—	7 Days
Endive	.94	.48	132	31.9	93.3	35	90-95	4.80	32	90-95 <sup>b</sup>	3.60	2-3 Wks
Garlic (Dry)	.69	.40	89	30.5	61.3	35	85-90	—	32	65-70	—	6 Mos
Greens (Leafy)	.90 <sup>3</sup>	.47	126 <sup>3</sup>	31.1 <sup>3</sup>	86.0 <sup>3</sup>	35	90-95	2.40	32	90-95	1.44	10-14 Days
Kale	.89	.46	124	31.1	86.6	35	90-95	—	32	90-95 <sup>a</sup>	—	10-14 Days
Lettuce	.96	.48	136	31.7	94.8	35	90-95	7.92	32	90-95 <sup>a</sup>	6.00	2-3 Wks
Leeks (Fresh)	.88	.46	126	30.7	85.4	35	90-95	.96	32	90-95 <sup>a</sup>	.48	2-3 Mos
Mushrooms	.93	.47	130	30.4	91.1	32	90	3.05	—	—	—	3-4 Days
Mushroom (Grain Spann)	—	—	—	—	—	40	75-80	—	32	75-80	—	2 Wks
Okra	.92	.46	128	28.7	89.8	50	90-95	9.00	45	90-95	6.50	7-10 Days
Onions	.90	.46	124	30.6	87.5	50	70-75	.96	32	65-70	.48	4-8 Mos
Parsley	.88	.45	122	30.0	85.1	35	90-95	2.40	32	90-95	1.44	1-2 Mos
Parsnips	.84	.44	112	30.4	78.6	35	90-95	1.68	32	90-95	1.20	4-5 Mos
Peas, Green	.79	.42	106	29.2	82.7	35	85-90	6.00	32	85-90 <sup>b</sup>	4.80	1-3 Wks
Peppers	.94	.47	132	30.7	92.4	50	90-95	3.25	45	90-95	2.80	2-3 Wks
Potatoes												
• Irish	.85	.44	116	30.9	81.2	50	85-90	1.44	38	85-90 <sup>b</sup>	.72	—
• Sweet <sup>a</sup>	.83	.42	100	29.7	68.5	55 <sup>a</sup>	85-90	2.40	55 <sup>a</sup>	85-90 <sup>b</sup>	2.40	4-6 Mos
Pumpkins	.92	.47	130	30.5	90.5	55	70-75	—	50	70-75	—	2-3 Mos
Radishes	.95	.48	134	30.7	93.6	35	90-95	—	32	90-95	—	2-4 Mos
Rhubarb	.96	.48	134	30.3	94.9	35	95	—	32	95	—	2-4 Wks
Rutabagas	.91	.47	127	30.1	89.1	35	95	—	32	95	—	2-4 Mos
Sauerkraut (In Kegs)	.92	.52	128	26.0	89.2	45	75-80	—	32	75-80	—	4-5 Mos

Footnote references above may be found at conclusion of Table on Page 26.

# APPENDIX—TABLES

**TABLE 9**      **PROPERTIES AND STORAGE DATA FOR PERISHABLE PRODUCTS**

PRODUCT	SPECIFIC HEAT BTU/LB./°F <sup>1</sup>		LATENT <sup>2</sup> HEAT OF FUSION BTU/LB	HIGHEST FREEZE POINT °F	WATER CONTENT %	SHORT STORAGE			LONG STORAGE			
	ABOVE FREEZE POINT	BELOW FREEZE POINT				TEMP °F	RH% MIN-MAX	RESPIRATION HEAT BTU/LB/24 HR	TEMP °F	RH% MIN-MAX	RESPIRATION HEAT BTU/LB/24 HR	APPROX. STORAGE LIFE
<b>Spinach</b>	.94	.48	132	31.5	92.7	35	90-95 <sup>8</sup>	4.80	32	90-95 <sup>8</sup>	2.88	10-14 Days
<b>Squash</b>												
• Acorn	.92	.47	131	30.5	90.5	50	70-75	—	45	70-75	—	6-8 Wks
• Summer	.95	.48	135	31.1	94.0	50	85-95	—	32	85-95	—	5-14 Days
• Winter	.91	.47	127	30.3	88.6	55	70-75	—	50	70-75	—	4-6 Mos
<b>Tomatoes</b>												
• Green	.95	.48	134	31.0	93.0	55	85-90	3.12	55	85-90	3.12	3-4 Wks
• Ripe	.94	.48	134	31.1	94.1	50	85-90 <sup>8</sup>	.72	—	—	—	5-7 Days
Turnips	.93	.47	130	30.1	91.5	35	90-95	1.20	32	90-95 <sup>8</sup>	.96	4-5 Mos
Vegetable Seed	.29	.23	16	—	12.0 <sup>3</sup>	45	55-65	—	32	50-60	—	—
Vegetables (Mixed)	.92 <sup>3</sup>	.47 <sup>3</sup>	130 <sup>3</sup>	30.0 <sup>3</sup>	92.0 <sup>3</sup>	35	90-95	2.40 <sup>3</sup>	32	90-95	1.60 <sup>3</sup>	—
<b>MISCELLANEOUS</b>												
<b>Beer</b>												
• Metal Keg	.92	—	129	28.0	90.2	40	—	—	35	—	—	3 Mos
• Wood Keg	.92	—	129	28.0	90.2	40	85-90 <sup>11</sup>	—	35	85-90 <sup>11</sup>	—	3 Mos
Bread	.74	.34	53	20.0	34.0 <sup>3</sup>	0	—	—	0	—	—	3 Mos
Candy	.93	—	—	—	—	34	40-50	—	0	40-50	—	6 Mos
Chocolate (Coatings)	.56	.35	40	90.0	—	65	40-50	—	60	40-50	—	6 Mos
<b>Canned Foods</b>												
Cocoa	—	—	—	—	—	60	70	—	32	70	—	1 Yr
Coffee (Green)	.30	.24	20	—	15.0	40	70	—	32	50	—	1 Yr
Dried Foods	—	—	—	—	—	37	80-85	—	35	80-85	—	3 Mos
Flour	—	—	—	—	—	70	40-50	—	32	40-50	—	1 Yr
Flowers	.38	.28	—	—	14.0	82	60-65	—	78	60-65	—	6 Mos
See Table 15 for Data on Cut Flowers, Greens, Bulbs, and Nursery Stock												
<b>Frozen Pack</b>												
Fruits & Vegetables	—	—	—	—	—	0	—	—	-10	—	—	12 Mos
Furs & Fabrics	—	—	—	—	—	40	45-55 <sup>12</sup>	—	34	45-55 <sup>12</sup>	—	Yrs
Honey	.35	.26	26	—	18.0	40	60-70	—	31	60-70	—	1 Yr
Hops	—	—	—	—	—	32	50-60	—	29	50-60	—	3 Mos
<b>Maple Sugar</b>	.24	.21	7	—	5.0	45	65-70	—	31	65-70	—	4 Mos
Maple Syrup	.48	.31	51	—	35.5	45	65-70	—	31	65-70	—	4 Mos
Nursery Stock	See Table 15 For Various Varieties											
<b>Nuts</b>												
• In Shells	.25	.22	8 <sup>3</sup>	—	6.0 <sup>3</sup>	40-45	65-75	—	28-32	65-75	—	10 Mos
• Shelled	.30	.24	10 <sup>3</sup>	—	8.0 <sup>3</sup>	40-45	65-75	—	28-32	65-75	—	8 Mos
<b>Oil (Vegetable)</b>												
Oleo	.32	.25	22	—	15.5	70	—	—	70	—	—	1 Yr
Orange Juice (Chilled)	.91	.47	128	—	89.0	45	75-80	—	35	70-75	—	6 Mos
Popcorn (Unpopped)	.31	.24	19	—	13.5	35	—	—	30	—	—	6 Wks
<b>Precooked</b>												
Frozen Food	—	—	—	—	—	0	—	—	-10	—	—	10 Mos
Seed (Vegetable)	.29	.23	16	—	12.0 <sup>3</sup>	50	55-65	—	32	50-55	—	—
Serums/ Vaccines	—	—	—	—	—	45	70	—	40	70	—	—
Yeast (Compressed Bakers)	.77	.41	102	—	70.9	35	80-85	—	31	75-80	—	—

- Notes: 1. Specific heats for products not listed may be estimated as follows:  
 Specific heat above freezing = 0.20 + (0.008 × % water)  
 Specific heat below freezing = 0.20 + (0.003 × % water)
2. Latent heats of fusion for products not listed may be estimated as follows:  
 Heat of fusion = % water × 143.4 Btu/lb
3. Average value.
4. Eggs with weak albumen freeze just below 30°F.
5. Lemons in terminal markets are customarily stored @ 50-55°F; sometimes, 32°F is used
6. Optimum storage temperature varies widely with variety and/or section where grown. Recommended temperatures for apples, as an example, range from 32°F (Golden Delicious) to 38°F (McIntosh). See USDA handbook #66.
7. Permissible storage period varies widely with variety. See USDA handbook #66.
8. Room design conditions critical.
9. Sweet potatoes must be cured for 10 to 14 days @ 85°F & 85-90% rh for successful storage.
10. Relative humidity is left blank (—) in cases where the product is sealed from the air, or the rh % is otherwise non-critical.
11. High humidity required with wood kegs to prevent drying and resulting leaks.
12. Constant humidity desirable.

Extracted in part from 1971 ASHRAE Applications Guide and Data Book — Reprinted by Permission

# APPENDIX—TABLES

TABLE 10					PRODUCT CHILLING DATA				
PRODUCT	TEMPERATURE <sup>3</sup>		CHILLING DATA		PRODUCT	TEMPERATURE		CHILLING DATA	
	ENT. °F	FINAL °F	TIME, HRS	LOAD FACTOR		ENT. °F	FINAL °F	TIME, HRS	LOAD FACTOR
<b>DAIRY</b>					<b>Lamb</b>	100	35	8	1.35
Eggs (crated)	45	30	10	1.20	<b>Liver</b>	90	35	18	1.44
Eggs (frozen)	40	0	24	1.50	<b>Poultry</b>	85	35	6	1.00
Ice Cream					<b>Sausage</b>	70	35	2	1.00
(5 gal cans)	28	- 10	10	1.38	<b>Smoked</b>	70	35	2	1.00
Milk (cartons)	45	35	10	1.20	(small cuts)				
<b>FRUIT</b>					<b>Tongue</b>	90	35	18	1.44
Apples	80	35	24	1.50	<b>Weiners</b>	70	35	2	1.00
Apricots	80	35	22	1.50	<b>Veal</b>	100	35	7	1.36
Avocados	80	46	22	1.50	<b>VEGETABLES</b>				
Berries	80	35	22	1.50	<b>Asparagus</b>	60	34	24	1.12
Grapes	70	34	20	1.27	<b>Beets<sup>2</sup></b>				
<b>Grapefruit</b>	75	35	22	1.45	(with tops)	70	34	24	1.26
<b>Lemons</b>	75	56	20	1.05	<b>Broccoli</b>	80	34	24	1.26
<b>Limes</b>	75	52	20	1.13	<b>Brussel Sprouts</b>	80	34	24	1.26
<b>Oranges</b>	75	33	22	1.45	<b>Cabbage</b>	70	34	24	1.26
<b>Peaches</b>	85	35	24	1.60	<b>Cantaloupes</b>	80	45	24	1.10
<b>Pears</b>	70	35	24	1.25	<b>Carrots<sup>2</sup></b>				
<b>Pineapples</b>	85	42	3	1.50	(with tops)	70	34	24	1.26
<b>Plums</b>	80	35	20	1.50	<b>Cauliflower</b>	70	34	24	1.26
<b>Prunes</b>	80	35	20	1.20	<b>Corn</b>	70	34	24	1.26
<b>Quinces</b>	80	33	24	1.50	<b>Cucumbers</b>	70	50	24	1.00
<b>MEAT</b>					<b>Onions</b>	70	34	24	1.26
<b>Bacon</b>	105	28	24	1.00	<b>Parsnips</b>	70	34	24	1.26
<b>Beef<sup>1</sup></b>	100	35	18	1.40	<b>Peas</b>	78	34	22	1.45
(carcass)	100	35	24	1.50	<b>String Beans</b>	80	45	22	1.45
<b>Ham</b>	105	38	18	1.00	<b>Tomatoes</b>	80	55	40	1.00
<b>Hogs<sup>1</sup></b>	100	35	18	1.40	<b>Turnips</b>	70	34	24	1.26
(carcass)	100	35	24	1.50					

- Notes: 1. See Tables 11 & 12 for data on typical beef and pork chilling rooms.  
 2. Load factor of beets or carrots withouts tops is 1.  
 3. Design room temperatures at the completion of the chilling process are generally 2°F below the final product temperature.  
 4. The following factors apply to **any blast freezing operation: batch freezing-1.5; continuous process (ie, conveyor fed) freezing-1.0.**  
 5. **Important:** Utilization of load factors results in sufficient refrigeration capacity to accommodate the high initial rates of product heat evolution; room temperature rise is thereby minimized. It is to be noted, however, that the application of load factors necessitates a system design compatible with the diverse pulldown & holding requirements. These factors are **not** to be applied to: (1) small rooms, (2) rooms loaded over an extended period of time, & (3) rooms equipped with single rooftop halocarbon systems. In cases (1), (2) & (3) above, the chill period should be extended, and the room temperature allowed to rise. (See Page 9 for a more detailed discussion of this subject).

# APPENDIX—TABLES

<b>TABLE 11 BEEF CHILLING • • MINIMUM REFRIGERATION REQUIREMENTS IN TONS<sup>1</sup></b>					
TOTAL ROOM CAPACITY — HEAD	FLOOR AREA SQ. FT.	18 HOUR CHILL TIME <sup>2</sup>		24 HOUR CHILL TIME	
		4 HR LOADING	8 HR LOADING	4 HR LOADING	8 HR LOADING
75	650	23.2	18.2	17.9	15.6
100	800	31.0	24.2	23.8	20.8
250	2000	77.5	60.5	59.5	52.1
450	3600	139.5	109.0	107.2	93.8

- Notes: 1. Refrigeration tonnages noted allow for normal room heat gain and defrosting, and are based upon a 65°F temperature pulldown of 550 lb cattle.  
 2. An 18 hour chill time requires additional air circulation and lower than normal room temperatures (32-34°F).

<b>TABLE 12 PORK CHILLING • • MINIMUM REFRIGERATION REQUIREMENTS IN TONS<sup>1</sup></b>					
TOTAL ROOM CAPACITY — HEAD	FLOOR AREA SQ FT	18 HOUR CHILL TIME <sup>2</sup>		24 HOUR CHILL TIME	
		4 HR LOADING	8 HR LOADING	4 HR LOADING	8 HR LOADING
75	200	7.9	6.3	6.2	5.5
100	250	10.5	8.4	8.2	7.3
250	625	26.2	20.9	20.6	18.3
450	1125	47.2	37.8	37.0	33.0

- Notes: 1. Refrigeration tonnages noted allow for normal room heat gain and defrosting, and are based upon a 65°F temperature pulldown of 200 lb hogs.  
 2. An 18 hour chill time requires additional air circulation and lower than normal room temperatures (32-34°F).

<b>TABLE 13 BLAST FREEZING • • PRODUCT LOAD ESTIMATES</b>						
PRODUCT	SUPPLY AIR		PRODUCT TEMP., °F		HEAT REMOVED BTU/LB	ESTIMATED TIME OF HEAT REMOVAL HOURS: MINUTES
	TEMP, °F	VELOCITY, FPM	ENTERING	LEAVING		
4 Oz. Hamburger Patties (unwrapped)	- 17	400	55	25	119	0:22
2 Oz. Hamburger Patties (unwrapped)	- 18	400	40	16	112	0:13
6 Lbs. Ground Beef In Plastic Wrapper (not lean)	- 20	1250	39	0	119	9:00
1 Oz. Fresh Pork Sausage (unwrapped)	- 13	1000	41	15	101	0:20
12 Oz. — 1 ¼" Thick Strip Steak In Plastic Wrapper	- 20	1000	40	0	119	1:03
1 Lb. — 6 Oz. Cooked Chop Suey In Plastic Container	- 21	800	64	0	147	2:13
16 Lb. Fresh Turkey In Plastic Wrapper	- 24	2600	44	0	130	5:24
12 — 1 Lb.-7 Oz. Containers Of Bar-B-Que Beef In Cardboard Box	- 21	1450	78	0	158	10:00


Notes: 1. For a continuous loading operation such as a conveyor or systemized manual feed, the product load in Btu per 24 hrs equals:

$$Q_{\text{Btu/24 hrs}} = \text{Btu/lb} \times \frac{\text{Product per Shift lbs}}{\text{Shift time hrs}} \times 24; \text{ this equation does not apply to "batch loading"}.$$


2. The usual transmission, infiltration, lighting, motor and defrosting loads must be added to the product loads listed.  
 3. In continuous loading operations, the rate of product heat evolution has a negligible effect on the refrigeration load (it does, however, affect room sizing, conveyor size and speed, etc).

# APPENDIX—TABLES

**FIG. F** RELATION BETWEEN FREEZING TIME AND AIR TEMPERATURE



**FIG. G** RELATION BETWEEN FREEZING TIME AND AIR VELOCITY



Notes (Fig. F & G): 1. Freezing time is the time required for product temperature to fall from 32°F to 25°F.  
 2. Fig. F based on 5-8 lb chickens with an initial temperature of 32-35°F, and an air velocity of 450-550 ft./min.  
 3. Fig. G based on 5-8 lb chickens with an initial temperature of 32-35°F, and an air temperature of -20°F

**FIG. H** HOG CHILLING • • TIME-TEMPERATURE CURVES




Fig. F, G & H from ASHRAE 1971 Applications Guide & Data Book — Reprinted by Permission

# APPENDIX—TABLES

**TABLE 14** **PHYSICAL DATA OF PERISHABLE PRODUCT CONTAINERS**

	CONTAINER DATA					LOADING DENSITY <sup>1</sup> LB/ CU FT
	TYPE	OUTSIDE DIMENSIONS <sup>2</sup> H × W × L — INCHES	APPROX. WEIGHTS — LBS			
			PRODUCT	CONTAINER	TOTAL	
<b>DAIRY PRODUCTS</b>						
Cheese	Hoops	13 × 16 × 16	78	6.0	84.0	40.5
Cheese	Wood Box (Export)	14 × 17 × 17	76	11.0	87.0	32.5
Cheese, Swiss	Wheels	7 × 32½ × 32½	171	—	171.0	40.0
Eggs, Shell	Wood Cases	13 × 26 × 12	45	10.0	55.0	19.1
Eggs, Frozen	Cans	12½ × 10 × 10	30	2.0	32.0	41.5
Milk, Condensed	Barrels	35 × 25½ × 25½	600	70.0	670.0	45.6
See Table 23 for Data on Milk Cartons and Bottles						
<b>FROZEN FRUITS, JUICES &amp; VEGETABLES</b>						
Asparagus	24/12 oz Carton	8¾ × 13½ × 11¾	18	3.0	21.0	23.8
Beans (Green)	36/10 oz Carton	8 × 12½ × 11	22.5	3.0	25.5	35.3
Blueberries	24/12 oz Carton	8 × 12 × 11½	18	2.0	20.0	28.2
Broccoli	24/12 oz Carton	8½ × 12½ × 11½	15	3.5	18.5	21.2
Citrus Concentrates	48/6 oz Fiber Carton	7½ × 13 × 8¾	26	1.0	27.0	52.7
Peaches	24/1 lb Carton	7½ × 13½ × 11¾	24	3.0	27.0	36.4
<b>Peas</b>	6/5 lb Carton	9½ × 17 × 11	30	2.0	32.0	28.2
<b>Peas</b>	48/12 oz Carton	12½ × 21½ × 8½	36	2.0	38.0	27.2
<b>Spinach</b>	24/14 oz Carton	8¾ × 12½ × 11	21	3.0	24.0	31.0
<b>Strawberries</b>	30 lb Can	12½ × 10 × 10	30	2.0	32.0	41.5
<b>Strawberries</b>	24/1 lb Carton	8 × 13 × 11	24	4.0	28.0	36.2
<b>Strawberries</b>	450 lb Barrel	35 × 25 × 25	450	—	—	35.5
<b>FRUIT</b>						
Apples						
• Eastern	Lug Box	11¾ × 14½ × 18¾	59	5.0	64.0	31.4
• Western	Wood Box	12¾ × 19½ × 11	42	8.0	50.0	27.8
• General	Fiber Tray Carton	13¾ × 20½ × 12½	43	3.8	46.8	21.9
• General	Fiber Bulk Carton	13 × 19 × 12½	41	3.8	44.8	22.9
• General	Tote Bin	2½ × 4 × 4	1000	150.0	1150.0	25.0
Apricots	Box	5½ × 13 × 17½	22	3.0	25.0	30.4
Avocados	Box	4¾ × 14 × 17½	13	3.0	16.0	19.3
<b>Berries (Gen.)</b>	Crate (24 qt)	11¾ × 11¾ × 24	36	4.0	40.0	18.8
<b>Coconut (Shredded)</b>	Bags	8 × 38 × 18½	100	1.0	101.0	30.7
<b>Cranberries</b>	Fiber Carton	10½ × 15¾ × 11¾	24	2.0	26.0	22.2
<b>Dried Fruit</b>						
• Dates	Fiber Carton	11 × 14 × 14	30	2.0	32.0	24.0
• Raisins, Prunes, Figs	Fiber Carton	7 × 15 × 11	30	2.0	32.0	44.9
<b>Figs (Fresh)</b>	Box	2½ × 11½ × 17½	6	2.0	8.0	20.6
<b>Grapes</b>						
• Eastern	Wood Lug Box	7¾ × 14 × 17½	28	3.5	31.5	27.3
• Western	Wood Lug Box	6½ × 15 × 18	28	3.0	31.0	29.2
<b>Grapefruit</b>	Box	12¾ × 12 × 26	68	7.0	75.0	30.4
<b>Lemons</b>	Box	10¾ × 13½ × 27	72	6.0	78.0	32.9
<b>Oranges</b>						
• California	Box	12¾ × 12 × 26	76	6.0	82.0	34.0
• Florida	Bruce Box	12¾ × 12¾ × 26	82	6.0	88.0	33.5
• California	Fiber Carton	10½ × 16¾ × 10 1/16	37	3.0	40.0	35.2
• Florida	Fiber Carton	8 × 19¾ × 12¾	37	8.0	45.0	33.9
<b>Peaches</b>	Wood Lug Box	5¾ × 18¾ × 11½	23	3.0	26.0	33.1
<b>Pears</b>	Wood Box	8½ × 18 × 11½	48	4.0	52.0	47.1
<b>Plums &amp; Prunes</b>	Crate	5¾ × 16½ × 17¾	20	5.0	25.0	22.4
<b>Quinces</b>	Bushel	See Note 2	48	3.0	51.0	18.3
<b>ICE CREAM<sup>3</sup></b>						
Can, Welded	Standard — 8 qt	6 5/8 Diam. × 14 5/8	9.2	5.5	14.7	24.8
Can, Welded	Standard — 10 qt	8 3/8 Diam. × 10 3/4	11.5	8.0	19.5	24.1
Can, Welded	Standard — 20 qt	8 3/8 Diam. × 20 5/8	23.0	12.0	35.0	25.2
Pressboard, Waxed	Tall — 1 qt	3 7/8 Diam. × 7 1/8	1.2	0.1	1.3	25.9
Pressboard, Waxed	Tall — 2 qt	4 5/8 Diam. × 8 3/4	2.3	0.2	2.5	24.4
<b>Pressboard, Waxed</b>	Squat — 2 qt	7 Diam. × 4	2.3	0.3	2.6	20.3
<b>Pressboard, Waxed</b>	Squat — 4 qt	7 Diam. × 7 1/4	4.6	0.4	5.0	22.4
<b>Pressboard, Waxed</b>	Squat — 10 qt	9 1/4 Diam. × 9 1/2	11.5	0.4	11.9	25.1
<b>Pressboard, Waxed</b>	Squat — 20 qt	9 1/4 Diam. × 19 1/2	23.0	0.5	23.5	24.5
<b>MEAT</b>						
<b>Beef</b>						
• Boneless	Fiber Carton	6 × 28 × 18	140	6.0	146.0	80.0
• Fores	Loose	—	—	—	—	22.2
• Hinds	Loose	—	—	—	—	22.2
<b>Lamb, Boneless</b>	Fiber Box	5 × 20 × 15	53	4.0	57.0	61.0
<b>Pork</b>						
• Bellies	Bundles	7 × 23½ × 10½	57	—	57.0	57.0
• Loins, Regular	Wood Box	10 × 28 × 10	54	6.0	60.0	33.3
• Loins, Boneless	Fiber Box	5 × 20 × 15	52	5.0	57.0	59.9
<b>Veal, Boneless</b>	Fiber Carton	5 × 20 × 15	53	4.0	57.0	61.0

Notes: 1. Loading density for products packaged in bushel baskets, bushel hampers, or barrels is computed on the basis of actual warehouse cubage utilized.

2. Approximate weights and dimensions of bushel baskets and hampers are as follows:
- ½ Bushel Basket — Wgt: 2 lb; 14 ½ in top diam. × 11 ½ in bottom diam. × 10 in high
  - 1 Bushel Basket — Wgt: 3 lb; 18 in top diam. × 14 in bottom diam. × 12 in high
  - 1 Bushel Hamper — Wgt: 3 lb; 16 in top diam. × 10 in bottom diam. × 20 in high
  - 1 ½ Bushel Hamper — Wgt: 5 lb; 17 in top diam. × 12 in bottom diam. × 24 in high

# APPENDIX—TABLES

TABLE 14 PHYSICAL DATA OF PERISHABLE PRODUCT CONTAINERS						
	CONTAINER DATA					LOADING DENSITY <sup>1</sup> LB/CU FT
	TYPE	OUTSIDE DIMENSIONS <sup>2</sup> H × W × L — INCHES	APPROX. WEIGHTS — LBS			
			PRODUCT	CONTAINER	TOTAL	
<b>POULTRY, FRESH</b> Fryers (Whole: 24-30) Fryers (Parts)	Crate	7 × 24 × 10	60	5.0	65.0	25.4
	Crate	12½ × 17¼ × 10	50	4.0	54.0	38.9
<b>POULTRY, FROZEN</b> Ducks, 6 to Pkg. Fowl, 6 to Pkg. Fryers, Cut Up, 12 to Pkg. Roasters, 8 to Pkg.	Fiber Carton	4 × 22 × 16	31	1.5	22.5	38.0
	Fiber Carton	5½ × 20¾ × 18	31	2.5	33.5	26.1
	Fiber Carton	4¼ × 17¼ × 15¾	28	2.5	30.5	41.7
	Fiber Carton	5½ × 20¾ × 18	30	2.5	32.5	25.2
<b>TURKEYS</b> 3-6 lb, 6 to Pkg.	Fiber Carton	6½ × 21 × 17	27	3.0	30	20.1
6-10 lb, 6 to Pkg. 10-13 lb, 4 to Pkg. 13-16 lb, 4 to Pkg. 16-20 lb, 2 to Pkg. 20-24 lb, 2 to Pkg.	Fiber Carton	7 × 26 × 21½	48	4.5	52.5	21.2
	Fiber Carton	7½ × 26½ × 16	46	4.0	50.0	25.0
	Fiber Carton	9 × 29 × 18½	62	5.5	67.5	22.2
	Fiber Carton	9 × 17 × 16	36	3.0	39.0	25.4
	Fiber Carton	9½ × 19 × 16½	44	3.5	47.5	25.5
<b>SEA FOOD — FROZEN</b> Blocks	4/13½ lb Carton	6¾ × 20¾ × 12½	54	2.0	56.0	55.0
	4/16½ lb Carton	11¼ × 19¾ × 10¾	66	2.0	68.0	47.8
	12/16 oz Carton	3¼ × 12¾ × 8¾	12	1.5	13.5	49.6
	10/5 lb Carton	14 × 14½ × 10	50	2.3	52.3	42.7
	5/10 lb Carton	14 × 14½ × 10	50	2.2	52.2	42.7
Fish Sticks	12/8 oz Carton	3¼ × 11 × 8½	6	0.9	6.9	29.3
	24/8 oz Carton	4¼ × 16¾ × 8¾	12	1.8	13.8	32.9
	Panned Fish	None (Glazed)	—	—	—	35.0
	Portions	2, 3, 5 or 6 lb Cartons	—	—	—	29-33
Round Ground Fish	None (Glazed)	Stacked Loose	—	—	—	33-35
Round Halibut	None (Glazed)	Wood Box, Loose	—	—	—	30-35
Round Salmon	None (Glazed)	Stacked Loose	—	—	—	38.0
Shrimp	2½ or 5 lb Cartons	Stacked Loose	—	—	—	33-35
Steaks	1, 5 or 10 lb Packages	Custom Packing	—	—	—	35.0
		Custom Packing	—	—	—	50-60
<b>VEGETABLES</b> Asparagus Beans Beets (Topped) Broccoli Cabbage Carrots (Topped)	Crate	11½ × 9½ (top) × 12½ (bot.) × 17½	32	6.5	38.5	25.0
	Bushel		32	3.0	35.0	14.2
	Bushel		53	3.0	56.0	23.6
	Crate		48	10.0	58.0	13.0
	Hamper (1½ bu)		50	5.0	55.0	17.7
	Bushel		50	3.0	53.0	22.2
Cauliflower Celery Corn (Green) Cucumbers Lettuce (Head) Melons • General	Crate	14½ × 16 × 25½	55	9.0	64.0	16.0
	Crate	9¾ × 20¼ × 16	55	5.0	60.0	30.0
	Bushel	See Note 2	35	3.0	38.0	15.6
	Bushel	See Note 2	46	3.0	49.0	20.4
	Fiber Carton	9½ × 20½ × 13½	35	2.5	37.5	25.2
• Cantaloupe • Honeydew Onions (Dry) Onions Peas (Unshelled) Potatoes	Crate	5⅞ × 14¾ × 23½	27	4.0	31.0	25.7
	Crate	7½ × 16¾ × 23½	42	6.0	48.0	24.4
	Sack	—	50	1.5	51.5	—
	Bushel	See Note 2	50	3.0	56.0	22.2
	Bushel	See Note 2	30	3.0	33.0	13.3
	Bushel	See Note 2	60	3.0	63.0	26.7
Sweet Potatoes	Bushel	See Note 2	55	3.0	58.0	24.4
Tomatoes	Fiber Box Lug Box Crate Lug Box	10¾ × 19 × 10¾	40	3.0	43.0	31.0
• General		7¾ × 17½ × 14	30	4.0	34.0	27.3
• California		11⅞ × 18¾ × 11⅞	60	4.0	64.0	38.7
• Florida		6¾ × 17½ × 14	30	4.0	34.0	31.9
• Texas						
<b>MISCELLANEOUS</b> Beverages <sup>4</sup> Lard (2/28 lb) Nuts • Almonds (In Shell) • Almonds (Shelled) • English Walnuts (In Shell)	Wood Box (Export)	7¾ × 18 × 13¾	56	8.0	64.0	52.5
	Sacks	33 × 24 × 15	90	1.5	91.5	13.1
	Cases	6¾ × 23½ × 11	28	4.0	32.0	27.7
	Sacks	31 × 25 × 11	100	3.0	103.0	20.3
• English Walnuts (Shelled) • Peanuts (Shelled) • Pecans (In Shell) • Pecans (Shelled) • Pecans (In Shell)	Fiber Carton	10 × 14 × 14	25	2.0	27.0	22.0
	Burlap Bag	35 × 10 × 15	125	2.0	127.0	38.6
	Burlap Bag	35 × 22 × 12	125	1.5	126.5	23.4
	Fiber Carton	11 × 13 × 13	30	2.0	32.0	27.9
	Tote Box	60 × 42 × 42	1800	170.0	1970.0	29.4

Notes: 3. Tabulated figures are the true dimensional characteristics of the various containers when empty, and make no allowance for bulging tops or sides when filled.

4. Weights of various products at point of sale holding facilities may vary substantially from the figures noted due to moisture loss during processing or storage.

5. Ice cream assumed at 100% overrun and 4.6 lb/gal.

6. Refer to Table 29 for beer and soda data.



# APPENDIX—TABLES

<b>TABLE 15 STORAGE CONDITIONS FOR CUT FLOWERS AND NURSERY STOCK</b>					
	STORAGE CONDITIONS		APPROXIMATE STORAGE LIFE	METHOD OF HOLDING	HIGHEST FREEZE POINT, °F
	TEMP., °F	REL. HUM., %			
<b>CUT FLOWERS</b>					
Calla lily	40	90-95	1 week	Dry pack	—
Camellia	45	90-95	3-6 days	Dry pack	30.6
Carnation	32-36	90-95	1 month	Dry pack	30.8
Chrysanthemum	32-35	90-95	3-6 weeks	Dry pack	30.5
Daffodil (Narcissus)	32-33	90-95	1-3 weeks	Dry pack	31.8
Dahlia	40	90-95	3-5 days	Dry pack	—
Gardenia	32-33	90-95	2-3 weeks	Dry pack	31.0
Gladiolus	35-40	90-95	1 week	Dry pack	31.4
Iris, tight buds	31-32	90-95	2 weeks	Dry pack	30.6
Lily, Easter	32-35	90-95	2-3 weeks	Dry pack	31.1
Lily-of-the-Valley	31-32	90-95	2-3 weeks	Dry pack	—
Orchid	45-50	90-95	2 weeks	Water	31.4
Peony (tight buds)	32-35	90-95	4-6 weeks	Dry pack	30.1
Rose (tight buds)	32	90-95	1-2 weeks	Dry pack	31.2
Snapdragon	31-32	90-95	3-4 weeks	Dry pack	30.4
Sweet peas	31-32	90-95	2 weeks	Dry pack	30.4
Tulips	31-32	90-95	4-8 weeks	Dry pack	—
<b>GREENS</b>					
Asparagus (plumosus)	32-40	90-95	4-5 months	Polylined cases	26.0
Fern (dagger and wood)	30-32	90-95	4-5 months	Dry pack	28.9
Holly	32	90-95	4-5 weeks	Dry pack	27.0
Huckleberry	32	90-95	1-4 weeks	Dry pack	26.7
Laurel	32	90-95	1-4 weeks	Dry pack	27.6
Magnolia	35-40	90-95	1-4 weeks	Dry pack	27.0
Rhododendron	32	90-95	1-4 weeks	Dry pack	27.6
Salal	32	90-95	1-4 weeks	Dry pack	26.8
<b>BULBS</b>					
Amaryllis	38-45	70-75	5 months	Dry	30.8
Crocus	48-63	—	2-3 months	—	—
Dahlia	40-45	70-75	5 months	Dry	28.7
Gladiolus	38-50	70-75	8 months	Dry	28.2
Hyacinth	55-70	—	2-5 months	—	29.3
Iris, Dutch, Spanish	80-85	70-75	4 months	Dry	—
Lily					
Gloriosa	63	70-75	3-4 months	Poly liner	—
• Candidum	31-33	70-75	1-6 months	Poly liner & peat	—
• Croft	31-33	70-75	1-6 months	Poly liner & peat	—
• Longiflorum	31-33	70-75	1-10 months	Poly liner & peat	28.9
• Speciosum	31-33	70-75	1-6 months	Poly liner & peat	—
Peony	33-35	70-75	5 months	Dry	—
Tuberose	40-45	70-75	4 months	Dry	—
Tulip	31-32	70-75	5-6 months	Dry	27.6
<b>NURSERY STOCK</b>					
Trees and Shrubs	32-36	80-85	4-5 months		—
Rose Bushes	32	85-95	4-5 months	Bare rooted with poly liner	—
Strawberry Plants	30-32	80-85	8-10 months	Bare rooted with poly liner	29.9
Rooted Cuttings	33-40	85-95	—	Poly wrap	—
Herbaceous Perennials	27-28 or 33-35	80-85	—		—
Christmas trees	22-32	80-85	6-7 weeks	—	—

Note: Refer to USDA Handbook No. 66 for additional data relating to flower and nursery stock storage.

# APPENDIX—TABLES

<b>TABLE 16</b>		<b>APPLE STORAGE CAPACITY REQUIREMENTS @ 35°F</b>					
ENTERING FRUIT* TEMPERATURE, °F	MAXIMUM (NOTE 3) RESPIRATION BTU/LB/24 HRS	BTU PER 24 HR PER BOX (NOTES 1, 5 & 8)					
		PERCENTAGE LOADED ON LAST DAY					
		5	10	15	20	25	30
100	9.0	164.6	298.6	432.8	576.9	701.1	835.3
95	7.5	154.0	277.7	401.4	525.1	648.9	772.6
90	6.5	143.5	256.8	370.1	483.4	596.6	709.9
85	5.5	133.1	235.9	338.7	441.6	544.4	647.2
80	4.9	122.6	215.0	307.4	399.8	492.2	584.6
75	4.4	112.2	194.1	276.1	358.0	439.9	445.3
70	3.8	101.7	173.3	244.7	316.2	387.7	459.2
65	3.3	91.4	152.6	213.8	275.0	336.1	397.3
60	2.6	81.0	131.7	182.4	233.2	283.9	334.6
55	2.0	70.5	110.8	151.1	191.4	231.6	271.9
50	1.5	60.1	89.9	119.7	149.6	179.4	209.2
45	1.1	49.6	69.0	88.4	107.8	127.1	146.6
40	0.8	39.2	48.1	57.0	65.0	74.9	83.9

- Notes: 1. The Btu's noted per box represent product load **only**. The usual transmission, infiltration, and miscellaneous loads must be added.
2. One box equals one bushel: gross weight — 50 lbs; net weight — 42 lbs.
3. Respiration heat at 35°F: 0.72 Btu/lb/24 hrs; at 30°F: 0.48 Btu/lb/24 hrs.
4. Sp. heats: apples: 0.88 Btu/lb/°F; boxes: 0.60 Btu/lb/°F; weighted average: 0.835 Btu/lb/°F.
5. Loads will be less under C. A. storage conditions.
6. See Table 10 and Text, Page 9, for applications involving chilling only.
7. Example: 10000 box storage with ent. temp. of 95°F and last day loading of 15 percent: Product Load = 10000 × 401.4 = 4,014,000 Btu/24 hrs.
8. Apply a **0.95** factor to charted loads if containers are 3.75 lb cardboard cartons in lieu of 8 lb wood boxes.
9. Hydrocoolers generally pre-cool the fruit to 40°F or 45°F.

<b>TABLE 17</b>		<b>RECOMMENDED COIL T D BY PRODUCT CLASS</b>			
COIL TYPE	TEMPERATURE DIFFERENTIAL — °F				
	CLASS 1	CLASS 2	CLASS 3	CLASS 4	
<b>FORCED AIR GRAVITY</b>	<b>6 to 9 12 to 16</b>	<b>9 to 12 14 to 18</b>	<b>12-20 16-22</b>	<b>20-25 20-25</b>	

- Class 1** Includes products which require very high relative humidities in order to minimize moisture loss during storage. Examples of this category include unpackaged cheese or butter, eggs, and most vegetables if held for comparatively long periods.
- Class 2** Includes products which require reasonably high relative humidities (but not as high as those included in Class 1). Examples of this category include fruits & cut meats in retail storage<sup>1</sup>.
- Class 3** Includes products which require only moderate relative humidities, and includes such products as mushrooms, carcass meats, hides, smoked fish, and fruits such as melons having tough skins.
- Class 4** Includes products which are either unaffected by humidity, or which require specialized storage conditions in which the maximum relative humidity is limited thru use of a reheat system. Examples of the first group are furs, woolens, milk, beer (steel or aluminum kegs), bottled beverages, canned goods & similar products having a protective coating; nuts and chocolates are good examples of the second group.

Note 1: Some supermarket fixtures for cut meat display are designed to operate with lower TD's.

# APPENDIX—TABLES

TABLE 18		COMMERCIAL ESTIMATING GUIDELINES <sup>1</sup>				
APPLICATION		TEMP, °F	CEILING HEIGHT, FT	COIL TD, °F	SQ FT / TON	COMMENTS
DISTRIBUTION CENTER	Storage Cooler	28-40	16-24	Dry Room 9-15 Wet Room 6-9	150-250	Maximum face velocity for light frosted application is 700 fpm; for wet coil operation, face velocity should not exceed 600 fpm; centrifugal or propeller fans are applicable.
	Storage Freezer	- 10	16-24	10-15	200-300 7000-10000 cu ft/Ton	Maximum fin spacing of 3-4 fpi; propeller fan units with high face velocities and long air throw are normally used.
			24-40			
	Loading Dock	40-55	16-20	10-12	150-175	Low face velocity units (under 650 fpm) are required. Units should blow toward and above the doors to create an air curtain effect. Between-the-rail units are ideal for narrow docks.
MEAT CHILL COOLER	Hogs <sup>2</sup>	28-34	16-20	10-12	25-40 10-16 hd/ton	Coil face velocity should not exceed 750 fpm. Between-the-rail units are specifically designed for this application and should be used whenever possible.
	Beef <sup>3</sup>				30-45 3-5 hd/ton	
Work Rooms Cutting & Grinding Rooms		35-45	10-12	15-25	125-175	Units with low noise level which distribute air with low velocity or in an umbrella pattern optimize worker comfort.

- Notes: 1. Above guidelines are for budgeting purposes only, and should not be used as the sole design criteria.  
 2. Hog chill rooms average 2-2.5 sq ft per head.  
 3. Beef chill rooms average 6-8 sq ft per head.

TABLE 19		BANANA ROOM DESIGN PARAMETERS					
ROOM SIZE	NO OF BOXES	WEIGHT, LBS		EVAPORATOR		REFRIGERATION <sup>4,5</sup> LOAD-BTU/HR	HEATING LOAD-KW
		GROSS	NET	T.D.	CFM		
½ Car	432	20304	18144	15	6000	36,000	4
1 Car	864	40608	36288	15	12000	72,000	8

- Notes: 1. Evaporator fan should have ½" ext. static pressure capability.  
 2. Weights per box: gross-47 lb; net-42 lb.  
 3. Specific heats: bananas-0.8 Btu/lb/°F; cartons-0.4 Btu/lb/°F.  
 4. To calculate load, assume pull-down of 1°F per hour, and peak respiration of 12 Btu/lb/24 hr.  
 5. Tabulated loads represent **total heat removal**.  
 6. Heat is required only to warm a cold load and may not be required.

TABLE 20		U VALUE REVISIONS						
EXISTING SECTION PROPERTIES		REVISED U VALUE AT ADDITIONAL RESISTANCE OF						
U	R	4	6	8	12	16	20	24
1.00	1.00	0.20	0.14	0.11	0.08	0.06	0.05	0.04
0.90	1.11	0.20	0.14	0.11	0.08	0.06	0.05	0.04
0.80	1.25	0.19	0.14	0.11	0.08	0.06	0.05	0.04
0.70	1.43	0.19	0.13	0.11	0.07	0.06	0.05	0.04
0.60	1.67	0.19	0.13	0.10	0.07	0.06	0.05	0.04
0.50	2.00	0.18	0.13	0.10	0.07	0.06	0.05	0.04
0.40	2.50	0.16	0.12	0.10	0.07	0.05	0.05	0.04
0.30	3.33	0.14	0.11	0.09	0.07	0.05	0.04	0.04
0.20	5.00	0.11	0.09	0.08	0.06	0.05	0.04	0.03
0.10	10.00	0.06	0.06	0.06	0.05	0.04	0.04	0.03
0.08	12.50	0.06	0.06	0.05	0.04	0.04	0.03	0.03

Example: Given an existing structure with a U value of 0.50, determine the revised U following the addition of insulation having a resistance of 12: enter Column 1 at 0.50 and move horizontally to the column headed by 12; the revised U value may then be read at 0.07.

From 1972 ASHRAE Handbook of Fundamentals  
 Reprinted by Permission

# APPENDIX—TABLES

PRODUCT CATEGORY		AVERAGE HEAT CONTENT				HIGHEST FREEZING POINT, °F	RECOMMENDED STORAGE CONDITIONS		
		SP HT ABOVE FREEZING	SP HT BELOW FREEZING	LATENT HEAT BTU/LB	TEMPERATURE, °F <sup>1</sup>		RELATIVE HUMIDITY %		
					SHORT TERM			LONG TERM	
DAIRY	Butter	.64	.34	15	30	40	- 5	80-85	
	Cheese, Cream, Eggs, Milk	.85	.40	100	31	35-40	33-35	70-85	
	Bananas (Ripe)	.80	.42	108	30.6	56	56	85-90	
FRUIT	Dried Figs/Raisins	.41	.29	36	- 4	40-50	40	60	
	Avocados	.76	.41	101	30	50-55	45-50	85-90	
	Citrus	.90	.46	123	30	50-55	32	85-90	
	Apples/Apricots/Pears					35	30-38	85-90 <sup>3</sup>	
MEAT	Bacon (Cured)	.43	.29	39	27	55	34-40	55-65	
	Fresh Game	.80	.42	114	27	34	28	85-90	
	Beef, Ham, Lamb, Pork Sausage, Veal	.76	.40	95	29	34	28-32	85-90	
FOWL	Chicken	.79	.42	106	30	34	28	85-90	
	Turkey	.63	.36	78					
SEA FOOD	Boiled Lobsters or Crabs	.84	.44	14	-	25	-	85-90	
	All Other (Fresh)	.84	.44	14	28	32	-	85-95	
VEGETABLES	Beans (Green), Cucumbers, Eggplant, Garlic (Dry), Melons, Okra, Onions (Dry), Peppers, Potatoes, Pumpkins, Squash (Hard Shell), Sweet Potatoes, Tomatoes (Ripe)	.94	.47	136	31	50	50	80	
	Most Other	.94	.47	136	31	35	31-32	90-95	

- Notes: 1. Values are averages by product group, and may be used for estimating rooms in which the exact product loading is unknown.  
 2. Refer to Table 9 for specific properties and storage requirements of individual products.  
 3. Pears require a relative humidity of 92-95%.

INSULATION TYPE AND 'K' VALUE		TEMPERATURE DIFFERENCE (ROOM LESS AMBIENT), °F																
		COOLER					HOLDING FREEZER									SHARP FREEZER		
		50	55	60	65	70	75	80	85	90	95	100	105	110	115	120	125	130
Foamglass	.38	3	4	5	6	6	7	8	8	9	9	9	10	11	11	12	12	12
Corkboard	.30	3	4	4	4	5	5	5	6	6	7	7	8	9	9	10	10	10
Expanded Polystyrene	.24	2	3	3	3	4	4	4	5	5	6	6	6	7	7	8	8	8
Fiberglass	.24	2	3	3	3	4	4	4	5	5	6	6	6	7	7	8	8	8
Extruded Polystyrene	.185	2	3	3	4	4	5	5	5	6	6	6	6	6	7	7	7	7
Slab Urethane	.16	2	3	3	3	3	3	4	4	4	4	5	5	5	6	6	6	6
Foamed-In-Place Urethane	.13	2	2	2	3	3	3	3	3	4 <sup>2</sup>	4 <sup>2</sup>	4 <sup>2</sup>	4 <sup>2</sup>	4 <sup>2</sup>	4	5	5	5

- Notes: 1. Thicknesses shown are for general guidance only. Requirements for a given installation will vary in accordance with operating versus first cost projections.  
 2. 3 inch foamed-in-place urethane is adequate for short term walk-in freezer applications.

# APPENDIX—TABLES

**TABLE 23**
**MILK CONTAINER DATA**

TYPE CONTAINER	CAPACITY		DIMENSIONS, IN.			CONTAINER DATA			BOTTLES OR CARTONS PER CASE	LIQUID WEIGHT LBS	BTU REQ'D TO COOL 1°F WHEN FULL
	OZ	GAL	LENGTH	WIDTH OR MAX. DIAM.	HEIGHT	WEIGHT LBS	SP. HT. B/LB/°F	MATERIAL			
<b>Carton</b>											
<b>Quart</b>	32	—	—	2.81	9.00	0.075	0.50	Paper	—	2.15	2.06
<b>Half Gallon</b>	64	—	—	3.81	9.375	0.142	0.50	Paper	—	4.30	4.11
<b>Gallon</b>	—	1	—	5.56	9.50	0.245	0.50	Paper	—	8.60	8.20
<b>Bottle</b>											
<b>Half Pint</b>	8	—	—	2.375	5.375	0.500	0.20	Glass	—	0.537	0.61
<b>Pint</b>	16	—	—	3.00	7.75	0.810	0.20	Glass	—	1.075	1.18
<b>Quart</b>	32	—	—	4.00	9.75	2.000	0.20	Glass	—	2.15	2.42
<b>Cases<sup>3</sup></b>											
<b>Quart Cartons</b>	—	—	13.0	13.00	11.00	7.0	0.12	Steel	16	34.40	33.80
<b>Half Gal. Cartons</b>	—	—	13.0	13.00	11.00	7.0	0.12	Steel	9	38.70	37.92
<b>Gallon Cartons</b>	—	—	13.0	13.00	11.00	7.0	0.12	Steel	4	34.40	33.80
<b>Half Pint Bottles</b>	—	—	18.5	14.50	6.75	11.0	0.60	Wood	30	16.11	24.90
<b>Pint Bottles</b>	—	—	18.5	14.50	8.50	14.0	0.60	Wood	20	21.50	32.00
<b>Quart Bottles</b>	—	—	18.5	14.50	10.50	16.0	0.60	Wood	12	25.80	38.70
<b>Cans</b>											
<b>5 Gallon</b>	—	5	—	10.50	19.50	15.0	0.12	Steel	—	43.00	42.20
<b>10 Gallon</b>	—	10	—	13.00	25.00	26.0	0.12	Steel	—	86.00	84.00

Notes: 1. Sp. Ht.: 0.94; weight per quart — 2.15 lbs; weight per gallon — 8.60 lbs.

2. Storage areas may be estimated on the basis of 70 lb of milk in glass bottles or 100 lb of milk in paper quart cartons per sq ft, with ½ additional area being allowed for aisles. Cases are usually stacked 5 high.

3. Weights for cases empty (no bottles included).

Extracted in part from ASRE (now ASHRAE) Application Data Section. Some data obtained by actual weighing & measuring.

**TABLE 24 CHEESE MAKE & CURE DATA**

CHEESE	PART OF PROCESS	TEMP. °F	RELATIVE HUMIDITY %	TIME DAYS
<b>Blue</b>	Form Room	68-72	80-90	3-5
	Curing Room	48-50	95	90
	Holding Room	40-45	70	30-180
<b>Cheddar</b>	Curing Room	32-34	70	12-18(mos)
		38-40	70	8-10(mos)
		45-55	85-90	60
		55-70	85-90	indeterminate
<b>Swiss</b>	Salting Room	50-54	In Brine	4-6
	Cool Room	40-45	70	10-14
	Warm Room	68-77	80-85	14
	Curing Room	60	80-85	14-28
	Holding Room	35-40	70	60-180

**TABLE 25 SPECIFIC HEATS OF MILK AND MILK DERIVATIVES**

PRODUCT	TEMPERATURE, °F			
	32	59	104	140
<b>Whey</b>	0.978	0.976	0.974	0.972
<b>Skim Milk</b>	0.940	0.943	0.952	0.963
<b>Whole Milk</b>	0.920	0.938	0.930	0.918
<b>15% Cream</b>	0.750	0.923	0.899	0.900
<b>20% Cream</b>	0.723	0.940	0.880	0.886
<b>30% Cream</b>	0.673	0.983	0.852	0.860
<b>45% Cream</b>	0.606	1.016	0.787	0.793
<b>60% Cream</b>	0.560	1.053	0.721	0.737
<b>Butter</b>	0.512	0.527	0.556	0.580
<b>Milk Fat</b>	0.445	0.467	0.500	0.530

Note 1: Sp. heat in Btu/lb/°F

**TABLE 26 OTHER CHEESE CURE DATA**

CHEESE	CURE TEMP. °F	RELATIVE HUMIDITY %	CURE TIME DAYS
<b>Brick</b>	60-65	90	60
<b>Limburger</b>	60-65	95	42
<b>Camembert</b>	53-59	90	21
<b>Cream Cottage Neufchatel</b>	No Cure		

**TABLE 27 CHEESE FREEZE POINTS**

CHEESE	FREEZE POINT, °F
<b>Brick</b>	16.3
<b>Cheddar</b>	8.8
<b>Cottage</b>	29.8
<b>Limburger</b>	18.7
<b>Process American</b>	16.6
<b>Process Swiss</b>	17.5
<b>Roquefort</b>	3.7
<b>Swiss, Domestic</b>	14.0
<b>Swiss, Imported</b>	14.7

**TABLE 28 CHEESE STORAGE TEMPERATURES**

CHEESE	OPTIMUM STORAGE TEMP., °F	MAXIMUM STORAGE TEMP., °F	CHEESE	OPTIMUM STORAGE TEMP., °F	MAXIMUM STORAGE TEMP., °F
<b>Brick</b>	30-34	50	<b>Process American</b>	40-45	75
<b>Camembert</b>	30-34	50	<b>Process Brick</b>	40-45	75
<b>Cheddar</b>	30-34	60	<b>Process Limburger</b>	40-45	75
<b>Cottage</b>	32-34	45	<b>Process Swiss</b>	40-45	75
<b>Cream</b>	32-34	45	<b>Roquefort</b>	30-34	50
<b>Limburger</b>	30-34	50	<b>Swiss</b>	30-34	60
<b>Neufchatel</b>	32-34	45	<b>Cheese Foods</b>	40-45	55

Tables 24 thru 28 extracted from 1971 ASHRAE Applications Guide and Data Book — Reprinted by Permission

# APPENDIX—TABLES

**TABLE 29**
**BEVERAGE CONTAINER DATA**

TYPE CONTAINER	CAPACITY		DIMENSIONS, IN.			CONTAINER DATA			BOTTLES OR CANS PER CASE	LIQUID WEIGHT LBS	BTU REQ'D <sup>1</sup> TO COOL 1°F WHEN FULL
	FLUID OZ	GAL	LENGTH	WIDTH OR MAX. DIAM.	HEIGHT	WEIGHT LBS	SP. HT. BTU/LB/°F	MATERIAL			
<b>Bottles</b>											
Beer, Tall, Ret.	12	—	—	2.50	9.50	0.75	0.20	Glass	—	0.76	0.91
Beer, Squat, N.R.	12	—	—	2.60	5.75	0.40	0.20	Glass	—	0.76	0.84
Beer, Quart, N.R.	32	—	—	3.63	11.25	1.03	0.20	Glass	—	2.03	2.24
Coca Cola	6	—	—	2.37	7.75	0.85	0.20	Glass	—	0.38	0.55
Soda- 6	6	—	—	2.50	7.75	0.88	0.20	Glass	—	0.38	0.56
Soda- 7	7	—	—	2.37	7.87	0.88	0.20	Glass	—	0.44	0.62
Soda- 8	8	—	—	2.50	7.25	0.88	0.20	Glass	—	0.50	0.68
Soda- 9	9	—	—	2.25	9.13	0.88	0.20	Glass	—	0.56	0.74
Soda-12	12	—	—	2.67	9.75	1.00	0.20	Glass	—	0.75	0.96
Soda-32	32	—	—	3.67	11.50	1.88	0.20	Glass	—	2.03	2.41
<b>Cans</b>											
12 oz. Beer, Steel	12	—	—	2.63	4.59	0.111	0.12	Steel	—	0.76	0.77
12 oz. Beer, Alum.	12	—	—	2.55	4.59	0.047	0.214	Alum.	—	0.76	0.77
Pint Beer, Steel	16	—	—	2.63	6.22	0.134	0.12	Steel	—	1.02	1.03
<b>Cases</b>											
<b>Beer</b>											
Tall, 12 oz, Ret.	—	—	15.87	10.63	10.06	1.81	0.34	Corr. Paper	24	18.26	22.48
Tall, 12 oz, Ret.	—	—	16.19	10.63	9.69	3.19	0.40	Fiber <sup>2</sup>	24	18.26	23.14
Squat, 12 oz, N.R.	—	—	17.31	11.56	6.50	1.38	0.34	Corr. Paper	24	18.26	20.65
Quart, N.R.	—	—	15.94	12.00	10.63	1.81	0.34	Corr. Paper	12	24.34	25.16
Can, 12 oz Tray	—	—	16.00	10.50	4.75	0.27	0.34	Corr. Paper	24	18.26	18.67
Coca Cola	—	—	18.50	12.13	8.25	5.25	0.60	Wood	24	9.12	12.27
<b>Soda</b>											
6 oz	—	—	14.50	11.00	8.25	6.90	0.60	Wood	24	9.12	13.26
8 oz	—	—	14.50	11.00	7.75	6.50	0.60	Wood	24	12.00	15.90
12 oz	—	—	18.00	11.75	10.25	9.25	0.60	Wood	24	18.00	23.55
Quart	—	—	16.67	12.25	12.50	8.00	0.60	Wood	12	24.00	28.80
<b>Kegs — Wood</b>											
1/4	—	4	—	13.5	16.0	22	0.60	Wood	—	33	41
1/2	—	8	—	17.0	21.0	35	0.60	Wood	—	70	80
3/4	—	15	—	20.0	24.0	65	0.60	Wood	—	130	155
Full	—	31	—	24.0	31.0	105	0.60	Wood	—	260	300
<b>Kegs — Insulated Steel</b>											
1/4	—	8	—	16.0	17.25	33	0.12	Steel	—	62	60
1/2	—	16	—	19.0	23.5	60	0.12	Steel	—	124	120
<b>Kegs — Cast Aluminum</b>											
1/4	—	4	—	13.0	15.0	22	0.21	Aluminum	—	31	35
1/2	—	8	—	16.0	17.25	32	0.21	Aluminum	—	62	64
3/4	—	16	—	19.25	23.5	70	0.21	Aluminum	—	124	130

Notes: 1. Specific heats of beer and carbonated beverages estimated at 1 Btu/lb/°F.

2. Storage areas may be estimated on the basis of 24 cans per one half cubic foot, and 24 bottles per 2 cubic feet; one third additional area should be allowed for aisles.

3. Fiber is utilized for returnable bottle cartons in southern climates.

4. Case weights include partitions, but no bottles or cans.

TYPE AND SIZE OF CONTAINER	TEMPERATURE REDUCTION °F (OUTSIDE TEMPERATURE MINUS STORAGE TEMPERATURE)					
	60	55	50	45	40	35
Full keg	3200	2600	2100	1700	1400	1100
Half keg	2600	2100	1700	1400	1100	900
Quarter keg	2200	1900	1600	1300	1000	800
Case 24-12 oz. bottles	2100	1800	1500	1200	900	700

Note 1: Loads are in Btu/24 hr. Multiply the number of kegs delivered per day by the appropriate load per keg, and utilize the resultant number as the total 24 hr infiltration heat gain in Part III B, Form LE-1

**TABLE 31 HEAT LOADS OF KEG AND BOTTLED BEER**

TYPE AND SIZE OF CONTAINER	TEMPERATURE REDUCTION, °F							
	65	50	40	30	20	15	10	5
<b>Keg — Wood</b>								
One Keg	—	—	12000	9000	6000	4500	3000	1500
Half Keg	—	—	5600	4650	3100	2325	1550	775
Quarter Keg	—	—	3200	2400	1600	1200	800	400
Eighth Keg	—	—	1640	1230	820	615	410	205
<b>Keg — Aluminum</b>								
Half Keg	—	—	5200	3900	2600	1950	1300	650
Quarter Keg	—	—	2560	1920	1280	960	640	320
Eighth Keg	—	—	1400	1050	700	525	350	175
<b>Keg — Steel</b>								
Half Keg	—	—	4800	3600	2400	1800	1200	600
Quarter Keg	—	—	2400	1800	1200	900	600	300
<b>Bottles</b>								
6 oz <sup>2</sup>	32	27	22	16	10.8	8.1	5.4	2.7
7 oz <sup>2</sup>	37	31	25	20	12.4	9.3	6.2	3.1
8 oz <sup>2</sup>	42	35	28	21	14.0	10.5	7.0	3.5
9 oz <sup>2</sup>	47	38	30	23	15.2	11.4	7.6	3.8
12 oz <sup>2</sup>	60	50	40	30	20.0	15.0	10.0	5.0
<b>Cases</b>								
12 Oz Tray, Can	1214.2	934.0	746.8	560.4	373.4	280.2	186.7	93.4
Tall, 12 Oz, Ret.	1502.8	1156.0	924.8	693.6	462.4	346.8	231.2	115.6
Squat, 12 Oz, N.R.	1341.6	1032.0	826.0	619.2	413.0	309.6	206.5	103.2

Notes: 1. Specific heat of beer estimated at 1 Btu/lb/°F. 2. Tabulated values may be utilized for carbonated beverages.

**TABLE 32**
**WALK-IN BEER COOLER STORAGE LOADS**

WALK-IN COOLER SIZE	CAPACITY CASES OF 24 — 12 OZ BOTTLES	TOTAL LOAD INCLUDING PRODUCT IN BTU/HR	WALK-IN COOLER SIZE	CAPACITY CASES OF 24 — 12 OZ BOTTLES	TOTAL LOAD INCLUDING PRODUCT IN BTU/HR
6' x 6'	110	5400	10' x 14'	470	13960
6' x 8'	150	6470	10' x 16'	540	15400
6' x 10'	190	7450	10' x 18'	610	16820
6' x 12'	230	8520	10' x 20'	680	18150
8' x 10'	260	9080	12' x 16'	650	17500
8' x 12'	315	10330	12' x 18'	740	19260
8' x 14'	370	11880	12' x 20'	820	20800
8' x 16'	425	13130	12' x 30'	1240	28690

Note: Loads are based on 10' cooler heights, 35°F holding temp., 20°F product temp. reduction and a 75°F environment, and have been adjusted for 18 hr compressor operation. A 20% daily inventory turn was assumed.

Tables 29, 30 & 31 extracted in part from the ASRE (now ASHRAE) Application Data Section; additional data was obtained by actual weighing and measurement.

# APPENDIX—TABLES

**TABLE 33**
**DOMESTIC OUTDOOR DESIGN DATA<sup>1</sup>**

LOCATION	DBWB °F °F	LOCATION	DBWB °F °F	LOCATION	DBWB °F °F	LOCATION	DBWB °F °F
<b>Alabama</b>		<b>Illinois</b>		<b>Montana</b>		<b>South Dakota</b>	
Birmingham	97 79	Champaign	96 79	Billings	94 68	Rapid City	96 72
Mobile	95 80	Chicago	94 78	Helena	90 65	Sioux Falls	95 77
Montgomery	98 80	Springfield	95 79	<b>Nebraska</b>		<b>Tennessee</b>	
Tuscaloosa	98 81	<b>Indiana</b>		Omaha	97 79	Chattanooga	97 78
<b>Alaska</b>		Evansville	96 79	<b>Nevada</b>		Knoxville	97 80
Anchorage	73 63	Fort Wayne	93 77	Las Vegas	108 72	Memphis	98 80
Fairbanks	82 64	Indianapolis	93 78	Reno	94 64	Nashville	97 79
Juneau	75 66	Terre Haute	95 79	<b>New Hampshire</b>		<b>Texas</b>	
<b>Arizona</b>		<b>Iowa</b>		Concord	91 75	Amarillo	98 72
Douglas	100 70	Cedar Rapids	92 78	<b>New Jersey</b>		Corpus Christi	95 81
Phoenix	108 77	Des Moines	95 79	Newark	94 77	Dallas	101 79
Tucson	105 74	<b>Kansas</b>		Trenton	92 78	El Paso	100 70
<b>Arkansas</b>		Dodge City	99 74	<b>New Mexico</b>		Galveston	91 82
Fort Smith	101 79	Topeka	99 79	Albuquerque	96 66	Houston	96 80
Little Rock	99 80	Wichita	102 77	Santa Fe	90 65	San Antonio	99 77
<b>California</b>		<b>Kentucky</b>		<b>New York</b>		<b>Utah</b>	
Bakersfield	103 72	Lexington	94 78	Albany	91 76	Salt Lake City	97 67
Blythe	111 78	Louisville	96 79	Buffalo	88 75	<b>Vermont</b>	
Fresno	101 73	<b>Louisiana</b>		New York	94 77	Burlington	88 74
Los Angeles	94 72	Baton Rouge	96 81	Rochester	91 75	<b>Virginia</b>	
Oakland	85 65	New Orleans	93 81	Syracuse	90 76	Norfolk	94 79
Sacramento	100 72	Shreveport	99 81	<b>North Carolina</b>		Richmond	96 79
San Francisco	80 64	<b>Maine</b>		Asheville	91 75	Roanoke	94 76
<b>Colorado</b>		Portland	88 75	Charlotte	96 78	<b>Washington</b>	
Denver	92 65	<b>Maryland</b>		<b>North Dakota</b>		Seattle	81 67
<b>Connecticut</b>		Baltimore	94 79	Bismarck	95 74	Spokane	93 66
Hartford	90 77	Hagerstown	94 77	Fargo	92 76	Yakima	94 69
New Haven	88 77	<b>Massachusetts</b>		<b>Ohio</b>		<b>West Virginia</b>	
<b>Delaware</b>		Boston	91 76	Cincinnati	94 78	Charleston	92 76
Wilmington	93 79	Springfield	91 76	Cleveland	91 76	Parkersburg	93 77
<b>Dist. Of Columbia</b>		Worcester	89 75	Dayton	92 77	<b>Wisconsin</b>	
Washington	94 78	<b>Michigan</b>		<b>Oklahoma</b>		Green Bay	88 75
<b>Florida</b>		Detroit	92 76	Oklahoma City	100 78	Madison	92 77
Jacksonville	96 80	Grand Rapids	91 76	Lawton	103 78	Milwaukee	90 77
Miami	92 80	Lansing	89 76	Tulsa	102 79	<b>Wyoming</b>	
Orlando	96 80	<b>Minnesota</b>		<b>Oregon</b>		Caspar	92 63
Tallahassee	96 80	Duluth	85 73	Portland	91 69	Cheyenne	89 63
Tampa	92 81	St. Paul	92 77	<b>Pennsylvania</b>		<b>Canada</b>	
<b>Georgia</b>		Minneapolis	92 77	Erie	88 76	Calgary	87 66
Atlanta	95 78	<b>Mississippi</b>		Philadelphia	93 78	Edmonton	86 69
Savannah	96 81	Jackson	98 79	Pittsburg	90 75	Goose Bay	86 69
<b>Hawaii</b>		<b>Missouri</b>		<b>Rhode Island</b>		Halifax	83 69
Honolulu	87 75	Kansas City	100 79	Providence	89 76	Hamilton	91 77
<b>Idaho</b>		St. Louis	96 79	<b>South Carolina</b>		Montreal	88 76
Boise	96 68	Springfield	97 78	Charleston	95 81	Ottawa	90 75
						Toronto	90 77
						Vancouver	80 68
						Winnipeg	90 75

Tables 33 &amp; 34 extracted from 1972 ASHRAE Handbook of Fundamentals — Reprinted by Permission

# APPENDIX—TABLES

TABLE 34		INTERNATIONAL OUTDOOR DESIGN DATA <sup>1</sup>					
LOCATION	DBWB °F °F	LOCATION	DBWB °F °F	LOCATION	DBWB °F °F	LOCATION	DBWB °F °F
<b>Afghanistan</b>		<b>Cuba</b>		<b>Indonesia</b>		<b>Pakistan</b>	
Kabul	98 66	Havana	92 81	Djakarta	90 80	Chittagong	93 82
<b>Algeria</b>		<b>Denmark</b>		Makasser	90 80	Kaachi	100 82
Algiers	95 77	Copenhagen	79 68	<b>Iran</b>		<b>Panama &amp; Canal Zone</b>	
<b>Argentina</b>		<b>Dominican Republic</b>		Abadan	116 82	Panama City	93 81
Buenos Aires	91 77	Santo Domingo	92 81	Meshed	99 68	<b>Paraguay</b>	
Tucuman	102 76	<b>Ecuador</b>		Tehran	102 75	Asuncion	100 81
<b>Australia</b>		Guayaquil	92 80	<b>Iraq</b>		<b>Peru</b>	
Adelaide	98 72	Quito	73 63	Baghdad	113 73	Lima	86 76
Brisbane	91 77	<b>El Salvador</b>		<b>Ireland</b>		<b>Philippines</b>	
Melbourne	95 71	San Salvador	98 77	Shannon	76 65	Manila	94 82
Perth	100 76	<b>Ethiopia</b>		<b>Israel</b>		<b>Puerto Rico</b>	
Sydney	89 74	Addis Ababa	84 66	Tel Aviv	96 74	San Juan	89 81
<b>Austria</b>		<b>Finland</b>		<b>Italy</b>		<b>Saudi Arabia</b>	
Vienna	88 71	Helsinki	77 66	Naples	91 74	Dhahran	111 86
<b>Bahamas</b>		<b>France</b>		Rome	94 74	Riyadh	110 78
Nassau	90 80	Marseilles	90 72	<b>Japan</b>		<b>South Africa</b>	
<b>Belgium</b>		Paris	89 70	Sapporo	86 76	Capetown	93 72
Brussels	83 70	<b>Germany</b>		Tokyo	91 81	Johannesburg	85 70
<b>Bermuda</b>		Berlin	84 68	<b>Jordan</b>		<b>Spain</b>	
Kindley AFB	87 79	Hamburg	80 68	Amman	97 70	Barcelona	88 75
<b>Bolivia</b>		Munich	86 68	<b>Kenya</b>		Madrid	93 71
La Paz	71 58	<b>Ghana</b>		Nairobi	81 66	<b>Sweden</b>	
<b>Brazil</b>		Accra	91 80	<b>Lebanon</b>		Stockholm	78 64
Brasilia	89 76	<b>Greece</b>		Beirut	93 78	<b>Syria</b>	
Porto Alegre	95 76	Athens	96 72	<b>Libya</b>		Damascus	102 72
Rio de Janeiro	94 80	<b>Greenland</b>		Bengasi	97 77	<b>Thailand</b>	
Salvador	88 79	Narssarsuaq	66 56	<b>Malaysia</b>		Bangkok	97 82
Sao Paulo	86 75	<b>Guatemala</b>		Penang	93 82	<b>Tunisia</b>	
<b>British Honduras</b>		Guatemala City	83 69	Singapore	92 82	Tunis	102 77
Belize	90 82	<b>Guyana</b>		<b>Mexico</b>		<b>Turkey</b>	
<b>Burma</b>		Georgetown	89 80	Guadalajara	93 68	Ankara	94 68
Mandalay	104 81	<b>Haiti</b>		Merida	97 80	Istanbul	91 75
<b>Cambodia</b>		Port Au Prince	97 82	Mexico City	83 61	<b>United Arab Republic</b>	
Phnom Penh	98 83	<b>Honduras</b>		Monterrey	98 79	Cairo	102 76
<b>Ceylon</b>		Tegucigalpa	89 73	Vera Cruz	91 83	<b>United Kingdom</b>	
Colombo	90 81	<b>Hong Kong</b>		<b>Netherlands</b>		Belfast	74 65
<b>Chile</b>		Hong Kong	92 81	Amsterdam	79 65	Birmingham	79 66
Santiago	90 71	<b>Iceland</b>		<b>New Zealand</b>		London	82 68
Valparaiso	81 67	Reykjavik	59 54	Auckland	78 67	<b>Uruguay</b>	
<b>Colombia</b>		<b>India</b>		Wellington	76 66	Montevideo	90 73
Bogota	72 60	Bombay	96 82	<b>Nicaragua</b>		<b>Venezuela</b>	
Cali	87 73	Calcutta	98 83	Managua	94 81	Caracas	84 73
Medellin	84 70	New Delhi	110 83	<b>Nigeria</b>		Puerto Ordaz	95 82
<b>Congo</b>				Lagos	92 82	Maracaibo	97 84
Kinasha	92 81					Valencia	95 80
Stanleyville	92 81						

Note 1: Design temperatures shown in Tables 33 & 34 are equalled or exceeded during 1% of summer months.



# APPENDIX—TABLES

**TABLE 35**
**SI METRIC CONVERSION FACTORS**

AREA		LIGHT	
Acre	× 4.047E + 03 = Metre <sup>2</sup> (m <sup>2</sup> )	Footcandle	× 1.076E + 01 = Lux (lx)
ft <sup>2</sup>	× 9.290E - 02 = Metre <sup>2</sup> (m <sup>2</sup> )	Footlambert	× 3.426E + 00 = Candela/Metre <sup>2</sup> (cd/m <sup>2</sup> )
in <sup>2</sup>	× 6.452E - 04 = Metre <sup>2</sup> (m <sup>2</sup> )		
mi <sup>2</sup>	× 2.590E + 06 = Metre <sup>2</sup> (m <sup>2</sup> )	MASS	
yd <sup>2</sup>	× 8.361E - 01 = Metre <sup>2</sup> (m <sup>2</sup> )	Gram	× 1.000E - 03 = Kilogram (kg)
ENERGY		Ounce (Avoir)	× 2.835E - 02 = Kilogram (kg)
Btu	× 1.055E + 03 = Joule (j)	Pound (Avoir)	× 4.536E - 01 = Kilogram (kg)
Calorie	× 4.187E + 00 = Joule (j)	Tonne	× 1.000E + 03 = Kilogram (kg)
Kilocalorie	× 4.187E + 03 = Joule (j)	Ton (long, 2240 lb)	× 1.016E + 03 = Kilogram (kg)
kw-h	× 3.600E + 06 = Joule (j)	Ton (Metric)	× 1.000E + 03 = Kilogram (kg)
w-h	× 3.600E + 03 = Joule (j)	Ton (short, 2000 lb)	× 9.072E + 02 = Kilogram (kg)
ENERGY PER UNIT TIME		MASS PER UNIT TIME	
Btu/(ft <sup>2</sup> •s)	× 1.136E + 04 = Watt Per Metre <sup>2</sup> (w/m <sup>2</sup> )	lb/h	× 1.260E - 04 = Kilogram Per Second (kg/s)
Btu/(ft <sup>2</sup> •min)	× 1.893E + 02 = Watt Per Metre <sup>2</sup> (w/m <sup>2</sup> )	lb/min	× 7.560E - 03 = Kilogram Per Second (kg/s)
Btu/(ft <sup>2</sup> •h)	× 3.155E + 00 = Watt Per Metre <sup>2</sup> (w/m <sup>2</sup> )	lb/sec	× 4.536E - 01 = Kilogram Per Second (kg/s)
Cal/(cm <sup>2</sup> •min)	× 6.978E + 02 = Watt Per Metre <sup>2</sup> (w/m <sup>2</sup> )	lb/(hp•h)	× 1.690E - 07 = Kilogram Per Joule (kg/j)
w/cm <sup>2</sup>	× 1.000E + 04 = Watt Per Metre <sup>2</sup> (w/m <sup>2</sup> )	DENSITY	
w/ft <sup>2</sup>	× 3.281E + 00 = Watt Per Metre <sup>2</sup> (w/m <sup>2</sup> )	g/cm <sup>3</sup>	× 1.000E + 03 = Kilogram Per Metre <sup>3</sup> (kg/m <sup>3</sup> )
w/in <sup>2</sup>	× 1.550E + 03 = Watt Per Metre <sup>2</sup> (w/m <sup>2</sup> )	Oz (Avoir)/Gal	× 7.489E + 00 = Kilogram Per Metre <sup>3</sup> (kg/m <sup>3</sup> )
HEAT		lb/ft <sup>3</sup>	× 1.602E + 01 = Kilogram Per Metre <sup>3</sup> (kg/m <sup>3</sup> )
<b>Heat Density:</b>		lb/in <sup>3</sup>	× 2.768E + 04 = Kilogram Per Metre <sup>3</sup> (kg/m <sup>3</sup> )
Btu/ft <sup>2</sup>	× 1.136E + 04 = Joule Per Metre <sup>2</sup> (j/m <sup>2</sup> )	lb/gal	× 1.198E + 02 = Kilogram Per Metre <sup>3</sup> (kg/m <sup>3</sup> )
Cal/cm <sup>2</sup>	× 4.187E + 04 = Joule Per Metre <sup>2</sup> (j/m <sup>2</sup> )	lb/yd <sup>3</sup>	× 5.933E - 01 = Kilogram Per Metre <sup>3</sup> (kg/m <sup>3</sup> )
<b>Heat Flux Density:</b>		POWER	
Btu/(ft <sup>2</sup> •h)	× 3.155E + 00 = Watt Per Metre <sup>2</sup> (w/m <sup>2</sup> )	Btu/h	× 2.931E - 01 = Watt (w)
Cal/(cm <sup>2</sup> •s)	× 4.187E + 04 = Watt Per Metre <sup>2</sup> (w/m <sup>2</sup> )	Btu/min	× 1.758E + 01 = Watt (w)
<b>Heat Transfer Coefficient (U):</b>		Cal./m	× 6.978E - 02 = Watt (w)
Btu/(h•ft <sup>2</sup> •°F)	× 5.678E + 00 = Watt Per Metre <sup>2</sup> - Kelvin [w/(m <sup>2</sup> •K)]	hp(550ft•lbf/s)	× 7.457E + 02 = Watt (w)
Btu/(s•ft <sup>2</sup> •°F)	× 2.044E + 04 = Watt Per Metre <sup>2</sup> - Kelvin [w/(m <sup>2</sup> •K)]	hp (boiler)	× 9.810E + 03 = Watt (w)
<b>Specific Enthalpy (Latent Heat):</b>		hp (electric)	× 7.460E + 02 = Watt (w)
Btu/lb	× 2.326E + 03 = Joule Per Kilogram (j/kg)	hp (metric)	× 7.355E + 02 = Watt (w)
Cal/g	× 4.187E + 03 = Joule Per Kilogram (j/kg)	ton of refrig.	× 3.517E + 03 = Watt (w)
<b>Specific Heat (C):</b>		PRESSURE	
Btu/(lb•°F)	× 4.187E + 03 = Joule per Kg • Kelvin [j/(kg•K)]	Atmosphere	× 1.013E + 05 = Pascal (pa)
Cal/(g•°C)	× 4.187E + 03 = Joule per Kg • Kelvin [j/(kg•K)]	Cm of Hg	× 1.333E + 03 = Pascal (pa)
<b>Thermal Conductivity (K):</b>		Cm of Water	× 9.806E + 01 = Pascal (pa)
(Btu•F)/(h•ft <sup>2</sup> •°F)	× 1.731E + 00 = Watt Per Metre - Kelvin [w/(m•K)]	Ft of Water	× 2.989E + 03 = Pascal (pa)
(Btu•In)/(S•ft <sup>2</sup> •°F)	× 5.192E + 02 = Watt Per Metre - Kelvin [w/(m•K)]	In of Hg	× 3.386E + 03 = Pascal (pa)
(Btu•In)/(h•ft <sup>2</sup> •°F)	× 1.442E - 02 = Watt Per Metre - Kelvin [w/(m•K)]	In of Water	× 2.490E + 02 = Pascal (pa)
Cal/(cm•s•°C)	× 4.187E + 02 = Watt Per Metre - Kelvin [w/(m•K)]	Mm of Hg	× 1.333E + 02 = Pascal (pa)
<b>Thermal Diffusivity:</b>		Psi <sup>1</sup>	× 6.895E + 03 = Pascal (pa)
ft <sup>2</sup> /h	× 2.581E - 05 = Metre <sup>2</sup> Per Sec (m <sup>2</sup> /s)	TEMPERATURE	
<b>Thermal Resistance (R):</b>		°F	- 32 + 1.8 = °C
(°F•h•ft <sup>2</sup> )/Btu	× 1.761E - 01 = Kelvin - Metre <sup>2</sup> /Watt [(K•m <sup>2</sup> )/w]	°C	× 1.8 + 32 = °F
LENGTH		°F	+ 459.67 + 1.8 = Kelvin
ft	× 3.048E - 01 = Metre (m)	Kelvin	× 1.8 - 459.67 = °F
in	× 2.540E - 02 = Metre (m)	°C	+ 273.15 = Kelvin
micron	× 1.000E - 06 = Metre (m)	Kelvin	- 273.15 = °C
yd	× 9.144E - 01 = Metre (m)	°Rankine	+ 1.8 = Kelvin
mile	× 1.609E + 03 = Metre (m)		

**Notes:**

- No equivalents for the abbreviations "Psia" and "Psig" are utilized in the SI System (if necessary to so designate a given pressure, it would be defined as "an absolute pressure of 50kpa", or "25 kpa (Gage)", etc.
- All factors have been rounded off to 4 significant digits and are, therefore, by SI definition "approximate."
- The "E" notation is utilized for convenience in electronic data processing, and has no other significance.
- SI equivalents are always shown as a number greater than 1 and less than 10. Examples: 1.055E + 03 joule per Btu (rather than 1055); 1.000 E - 03 kg per gram (rather than 0.001), etc.

# APPENDIX—TABLES

<b>TABLE 36</b> WEIGHT EQUIVALENCY OF COMMON MEASURES		
Product	Measure	Weight — Lbs
Apples	Bushel Or Box	50
	Barrel	125
Bananas	Bunch	50
Beef, Dressed	Head (Carcass)	550
Butter	Tub	60
Calves, Dressed	Head (Carcass)	150
Hogs, Dressed	Head (Carcass)	200
Ice	Bushel	50
Lamb, Dressed	Head (Carcass)	45
Peaches/Pears	Bushel	55
Potatoes	Bushel	60

<b>TABLE 37</b> ENGLISH — METRIC CONVERSION FACTORS		
Btu	× 252	= Calories
Cubic Feet	× 28.32	= Liters
Cubic Feet Per Minute	× 472	= Cubic Centimeters per Sec
Cubic Inches	× 16.39	= Cubic Centimeters
Cubic Meters	× 35.31	= Cubic Feet
	× 264.2	= Gallons (U.S. Liq.)
	× 1000	= Liters
Cubic Yards	× 764.6	= Liters
Drams	× 1.772	= Grams
Feet	× 30.48	= Centimeters
Feet Per Second	× 1.097	= Kilometers per Hour
Gallons	× 3.785	= Liters
Grams	× 15.43	= Grains
Grams Per Cubic Centimeter	× 62.4	= Pounds per Cubic Foot
Grams Per Liter	× 1000	= Parts per Million
Grams Per Square Centimeter	× 2.05	= Pounds per Square Foot
Horsepower (English)	× 1.014	= Horsepower (Metric)
Horsepower	× 641.1	= Kilocalories
Inches	× 2.54	= Centimeters
Inches Of Mercury	× 34.53	= Grams per Sq. Centimeter
Kilograms	× 2.205	= Pounds
Kilograms Per Square Centimeter	× 28.96	= Inches of Mercury
	× 14.22	= Pounds per Sq In
Kilocalories	× 3.97	= Btu
Kilometers	× 3281	= Feet
Kilowatts	× 860.5	= Kilocalories per Hour
Liters	× 1.057	= Quarts (U.S. Liq.)
Meters	× 3.281	= Feet
Ounces (Avoir)	× 28.35	= Grams
Ounces (Troy)	× 31.10	= Grams
Pounds	× 453.6	= Grams
Pounds Per Cubic Foot	× 16.02	= Kilograms per Cubic Meter
Quarts	× 946.4	= Cubic Centimeters
Square Feet	× 929	= Square Centimeters
Square Inches	× 6.45	= Square Centimeters
Square Meters	× 10.76	= Square Feet
Tons (Short)	× 907.2	= Kilograms
Tons (Metric)	× 1.102	= Tons (Short)
Watts	× 860.5	= Calories per Hour

<b>TABLE 38</b> ENGLISH CONVERSION FACTORS		
Atmospheres	× 14.696	= Pounds per Sq In
Acres	× 43,560	= Square Feet
Barrels	× 31.5	= Gallons
Bushels	× 1.245	= Cubic Feet
Bushels	× 32	= Quarts (Dry)
Cubic Feet	× 1728	= Cubic Inches
Cubic Feet	× 7.48	= Gallons (U.S. Liq.)
Cubic Yards	× 27	= Cubic Feet
Cubic Yards	× 202	= Gallons (U.S. Liq.)
Gallons	× 231	= Cubic Inches
Grains (Avoir)	× 1.0	= Grains (Troy)
Horsepower	× 2547	= Btu/hr
Horsepower	× 745.7	= Watts
Kilowatts	× 3413	= Btu/hr
Kilowatts	× 1.34	= Horsepower
Kilowatts	× 1000	= Watts
Ounces (Avoir)	× 437.5	= Grains
Ounces (Fluid)	× 1.81	= Cubic Inches
Ounces (Troy)	× 480	= Grains
Ounces (Troy)	× 1.097	= Ounces (Avoir)
Pounds Per Sq In	× 27.686	= Inches of Water
Pounds Per Sq In	× 2.307	= Feet of Water
Pounds	× 7000	= Grains
Pounds	× 16	= Ounces (Avoir)
Pounds	× 14.58	= Ounces (Troy)
Pounds	× 1.22	= Pounds (Troy)
Pounds (Troy)	× 5760	= Grains
Pounds (Troy)	× 13.17	= Ounces (Avoir)
Pounds (Troy)	× 12	= Ounces (Troy)
Pounds Per Sq In	× 2.307	= Feet of Water
Quarts (Liquid)	× 57.75	= Cubic Inches
Square Feet	× 144	= Square Inches
Square Yards	× 1296	= Square Inches
Tons (Short)	× 2000	= Pounds
Tons (Long)	× 1.12	= Tons (Short)
Tons Of Refrigeration	× 12000	= Btu/hr
Watts	× 3.41	= Btu/hr

<b>TABLE 39</b> METRIC CONVERSION FACTORS		
Atmospheres	× 76	= Centimeters of Mercury
Centimeters	× 10	= Millimeters
Cubic Meters	× 1,000,000	= Cubic Centimeters
Cubic Meters	× 1,000	= Liters
Dekagrams	× 10	= Grams
Dekaliters	× 10	= Liters
Dekameters	× 10	= Meters
Grams	× 1,000	= Milligrams
Kilocalories	× 1,000	= Calories
Kilograms	× 1,000	= Grams
Kiloliters	× 1,000	= Liters
Kilometers	× 1,000	= Meters
Kilowatts	× 860.5	= Kilocalories per Hour
Liters	× 1,000	= Cubic Centimeters
Meters	× 100	= Centimeters
Meters	× 1,000	= Millimeters
Milliliters	× 1.0	= Cubic Centimeters
Square Centimeters	× 100	= Square Millimeters
Square Meters	× 10,000	= Square Centimeters
Watts	× 860.5	= Calories per Hour

# APPENDIX—TABLES

TABLE 40		OUTSIDE AREA, ROOM VOLUME AND REFRIGERATION LOADS FOR WALK-IN COOLERS AND FREEZERS AT 95°F AMBIENT <sup>3</sup>											
8 FT HEIGHT <sup>2</sup>							10 FT HEIGHT <sup>2</sup>						
ROOM SIZE OUTSIDE W × L	OUTSIDE AREA SQ FT	ROOM VOLUME CU FT	CAPACITY REQUIREMENTS LESS PRODUCT LOAD-BTU/HR				OUTSIDE AREA SQ FT	ROOM VOLUME CU FT	CAPACITY REQUIREMENTS LESS PRODUCT LOAD-BTU/HR				
			- 20°F	- 10°F	28°F	36°F			- 20°F	- 10°F	28°F	36°F	
6 × 6	228	234	5300	4900	4200	3600	276	294	6000	5600	4700	4100	
6 × 8	272	319	6100	5700	4800	4200	328	402	6900	6500	5400	4700	
6 × 10	316	404	6900	6500	5400	4700	380	509	7800	7300	6100	5200	
6 × 12	360	490	7700	7200	6000	5100	432	616	8700	8100	6700	5800	
8 × 10	368	552	8000	7500	6200	5400	440	694	9000	8400	7000	6000	
8 × 12	416	668	8900	8300	6900	5900	496	840	10000	9300	7700	6600	
8 × 14	464	784	10000	9400	7800	6800	552	987	11300	10500	8700	7500	
8 × 16	512	900	10800	10100	8400	7300	608	1133	12200	11400	9300	8100	
10 × 10	420	699	9000	8400	7000	6000	500	879	10200	9500	7800	6700	
10 × 12	472	846	10300	9700	8000	7000	560	1065	11600	10800	8900	7700	
10 × 14	524	993	11200	10500	8700	7500	620	1250	12600	11800	9700	8400	
10 × 16	576	1141	12100	11300	9300	8100	680	1435	13600	12700	10400	9000	
10 × 18	628	1288	13000	12100	9900	8600	740	1620	14500	13500	11000	9600	
10 × 20	680	1435	13800	12900	10500	9100	800	1806	15400	14400	11700	10100	
12 × 14	584	1203	12400	11600	9500	8200	688	1513	13800	12900	10600	9100	
12 × 16	640	1381	13400	12500	10200	8800	752	1737	14900	13900	11300	9800	
12 × 18	696	1559	14300	13400	10900	9400	816	1962	16000	14900	12100	10500	
12 × 20	752	1737	15200	14200	11500	10000	880	2186	17000	15900	12800	11100	
12 × 30	1032	2629	19600	18200	14500	12600	1200	3307	21900	20400	16100	14000	
14 × 16	704	1621	14500	13500	11000	9600	824	2040	16200	15100	12300	10600	
14 × 20	824	2040	16500	15400	12500	10800	960	2566	18400	17200	13900	12000	
14 × 24	944	2458	18500	17200	13800	12000	1096	3093	20600	19200	15400	13300	
14 × 28	1064	2877	20300	19000	15100	13100	1232	3619	22600	21100	16800	14500	
14 × 32	1184	3295	22200	20700	16400	14200	1368	4146	24600	22900	18100	15700	
16 × 16	768	1861	15700	14600	11800	10300	896	2342	17400	16300	13100	11400	
16 × 20	896	2342	17800	16600	13400	11600	1040	2946	19800	18500	14800	12800	
16 × 24	1024	2822	19900	18600	14800	12800	1184	3551	22200	20700	16500	14300	
16 × 28	1152	3303	22000	20500	16200	14100	1328	4155	24300	22700	18000	15500	
16 × 32	1280	3783	24000	22400	17700	15300	1472	4760	26600	24700	19400	16800	
16 × 36	1408	4264	25800	24000	18900	16400	1616	5364	28600	26600	21000	18100	
20 × 20	1040	2946	20300	18900	15100	13100	1200	3707	22500	21000	16700	14500	
20 × 24	1184	3551	22700	21200	16900	14600	1360	4467	25200	23500	18600	16100	
20 × 28	1328	4155	25000	23300	18400	15900	1520	5228	27700	25800	20400	17600	
20 × 32	1472	4760	27300	25400	19900	17200	1680	5988	30200	28100	22100	19100	
20 × 36	1616	5364	29500	27400	21500	18600	1840	6749	32600	30300	23600	20400	
20 × 40	1760	5969	31700	29400	23000	19900	2000	7509	34900	32500	25300	21900	
30 × 20	1400	4458	26200	24400	19200	16600	1600	5608	29000	27000	21200	18300	
30 × 24	1584	5372	29300	27200	21400	18500	1800	6759	32400	30100	23400	20300	
30 × 30	1860	6744	33800	31500	24300	21100	2100	8484	37000	34400	26700	23200	
40 × 30	2320	9030	41100	38100	29200	25300	2600	11361	44800	41600	32000	27700	
40 × 40	2880	12091	50300	46700	35300	30700	3200	15212	54800	50800	38500	33500	

- Notes: 1. Ratings based on 3" foamed-in-place urethane, average usage, indoor installation & 18 hour compressor operation  
 2. Heights represent internal clearance. Overall heights with floor: 8'6" & 10'6"  
 3. Correction Factors — Other Ambients: 80°F — 0.75; 100°F — 1.10; 115°F — 1.35  
 4. Correction Factors — Other Usage: Light (Long-Term Storage) — 0.80; Heavy — 1.15-1.40  
 5. **IMPORTANT:** Utilization of charted values requires application of properly rated equipment.

# APPENDIX—TABLES

**TABLE 41 AVERAGE PRODUCT LOADS IN BTU/HR FOR WALK-IN COOLERS AND FREEZERS**

ROOM VOLUME CU FT	COOLERS		FREEZERS		ROOM VOLUME CU FT	COOLERS		FREEZERS	
	LBS/DAY	PRODUCT LOAD BTU/HR	LBS/DAY	PRODUCT LOAD BTU/HR		LBS/DAY	PRODUCT LOAD BTU/HR	LBS/DAY	PRODUCT LOAD BTU/HR
250	850	567	300	112	7000	15800	10500	3800	1425
500	1600	1067	600	225	7500	16100	10700	4000	1500
1000	3000	2000	1000	375	8000	16500	11000	4200	1575
1500	4200	2800	1400	525	8500	18000	12000	4400	1650
2000	5100	3400	1700	637	9000	21000	14000	4600	1725
2500	6900	4600	1900	713	9500	22500	15000	4900	1840
3000	8500	5700	2100	787	10000	24000	16000	5100	1910
3500	9800	6500	2250	844	15000	31000	20700	7600	2850
4000	11100	7400	2400	900	20000	40000	26700	9400	3525
4500	12000	8000	2500	938	30000	54000	36000	15000	5625
5000	12900	8600	2900	1090	40000	65000	43200	18000	6750
5500	13700	9100	3200	1200	60000	108000	72000	26000	9750
6000	14600	9700	3400	1275	80000	150000	100000	35000	13100
6500	15200	10100	3600	1350	100000 & up	190000 & up	127000 & up	53000 & up	19500 & up

Notes: 1. Values have been adjusted for 18 hour compressor operation, and apply to holding rooms only with entering product at 15°F above the refrigerator temperature.  
 2. This table is not to be used for unusual product loads, or if product specifics are known.

**TABLE 42 SPECIFIC PRODUCT LOADS IN BTU/HR FOR WALK-IN COOLERS AND FREEZERS<sup>1</sup>**

PRODUCT	DAILY PRODUCT QUANTITY	PRODUCT ENTERING TEMP. °F	FINAL PRODUCT TEMPERATURE - °F							
			60	40	35	32	0	-10	-20	-30
Bakery Goods	100 Lbs	80	82	164	185	197	545	564	583	602
		55	-	34	82	95	443	462	480	500
		36	-	-	4	16	365	384	403	421
Beef	1000 Lbs	100	1667	2500	2708	2833	9194	9422	9649	9877
		55	-	625	833	958	7319	7547	7774	8002
		34	-	-	-	83	6444	6672	6899	7127
Lamb & Veal	1000 Lbs	100	1824	2736	2964	3100	9477	9726	9965	10204
		55	-	684	912	1049	7435	7674	7913	8152
		34	-	-	-	91	6477	6716	6955	7194
Pork	1000 Lbs	100	1178	1766	1914	2002	6106	6283	6461	6639
		55	-	441	589	677	4781	4958	5136	5314
		34	-	-	-	59	4104	4281	4459	4637
Beer & Soda	100 Cases	80	3555	7110	8000	8530	-	-	-	-
		60	-	3555	4440	4980	-	-	-	-
		50	-	1775	2670	3200	-	-	-	-
Frozen Food	1000 Lbs	10	-	-	-	-	278	556	833	1111
		0	-	-	-	-	-	278	556	835
Ice Cream <sup>3</sup>	100 Gal • Soft Mix • Pre-Hardened	28	-	-	-	-	2667	2962	3284	3631
		10	-	-	-	-	364	606	793	1163
Milk	100 Gal	45	-	228	456	547	-	-	-	-
Poultry & Fresh Game	1000 Lbs	55	-	658	879	1009	7747	7980	8214	8447
		50	-	439	658	790	7528	7761	7995	8228
		35	-	-	-	132	6870	7103	7337	7570
Pizza Meat Pies & TV Dinners	100 14 Oz Units	80	73	146	164	175	611	630	649	669
		60	-	73	91	102	537	557	576	596
		35	-	-	-	11	446	466	485	505
Sea Food	100 Lbs	70	47	141	165	179	933	957	982	1006
		50	-	47	71	85	838	862	887	911
		35	-	-	-	14	768	792	817	841
Vegetables	1000 Lbs	90	1500	2500	2750	2900	10409	10666	10922	11178
		75	750	1750	2000	2150	9659	9916	10172	10428
		55	-	750	1000	1150	8659	8916	9172	9428
		35	-	-	-	150	7659	7916	8172	8428

Notes: 1. Values are for 24 hour pulldown and have been adjusted for 18 hour compressor operation.  
 2. For shorter pulldown periods, or for continuous blast freezing operations, utilize the following formula:

$$\text{Product Load Btu/hr} = \frac{\text{Charted Value} \times 24}{\text{Pulldown or Shift Time}_{\text{hrs}}}$$

3. Ice cream loads must be modified for the preferred hardening period (usually 8-10 hrs) to prevent crystallization.

NO. OF DOORS <sup>1</sup>	COOLER@35°F		FREEZER		
	75°F AMBIENT	90°F AMBIENT	80°F TD <sup>4</sup>	90°F TD <sup>4</sup>	110°F TD <sup>4</sup>
2 to 4	960	1200	1800	2100	2600
5 to 7	890	1100	1550	1600	2100
8 to 12	820	1000	1440	1500	2000
13 to 16	630	800	1330	1400	1800
16 to 20	550	700	1240	1300	1600

Notes: 1. Values are per door, and are based on standard 30" x 66" double glazed cooler, and triple glazed freezer, doors. Factors for other standard door sizes: 30" x 72": 1.11; 30" x 80": 1.26.  
 2. Values do not apply to reach-in refrigerators.  
 3. Unit coolers should be placed opposite and above the doors (blowing toward the doors) to create an air curtain effect.  
 4. T D represents the difference between box and room temperatures.

# APPENDIX—TABLES

**TABLE 44**
**PROPERTIES OF SOLIDS**

MATERIAL DESCRIPTION	SPECIFIC HEAT BTU/LB/°F	DENSITY LB/CU FT	THERMAL CONDUCTIVITY BTU • FT/HR/SQ FT/°F	EMISSIVITY	
				RATIO	SURFACE CONDITION
Aluminum (alloy 1100)	0.214	171	128.00	0.09 0.20	Commercial sheet heavily oxidized
Aluminum Bronze (76% Cu, 22% Zn, 2% Al)	0.09	517	58.00		
Alundum (aluminum oxide)	0.186				"Paper"
Asbestos:				0.93	
• fiber	0.25	150	0.097		
• insulation	0.20	36	0.092		
Ashes, wood	0.20	40	0.041 [122]		
Asphalt	0.22	132	0.43		
Bakelite	0.35	81	9.70		
Bell metal	0.086 [122]			0.93	
Bismuth tin	0.040		37.60		
Brick, building	0.2	123	0.40		
Brass:					
• red (85% Cu, 15% Zn)	0.09	548	87.0		
• yellow (65% Cu, 35% Zn)	0.09	519	69.0		
Bronze	0.104	530	17 [32]		0.02 0.81
Cadmium	0.055	540	53.70		
Carbon (gas retort)	0.17		0.20 [2]		
Cardboard	0.34		0.04		
Cellulose	0.32	3.4	0.033		
Cement (Portland clinker)	0.16	120	0.017		
Chalk	0.215	143	0.48	0.34	About 250 F
Charcoal (wood)	0.20	15	0.03 [392]		
Chrome Brick	0.17	200	0.67		
Clay	0.22	63			
Coal	0.3	90	0.098 [32]		
Coal Tars	0.35 [104]	75	0.07		
Coke (petroleum powdered)	0.36 [752]	62	0.55 [752]		0.072
Concrete (stone)	0.156 [392]	144	0.54		
Copper (electrolytic)	0.092	556	227.00		
Cork (granulated)	0.485	5.4	0.028 [23]		
Cotton (fiber)	0.319	95	0.024		
Cryolite (AlF <sub>3</sub> • 3NaF)	0.253	181			
Diamond	0.147	151	27.00		0.41
Earth (dry and packed)		95	0.037		
Felt		20.6	0.03		
Fireclay brick	0.198 [212]	112	0.58 [392]		
Flourspar (CaF <sub>2</sub> )	0.21	199	0.63		
German Silver (nickel silver)	0.09	545	19.00		
Glass:				0.94	Smooth
• crown (soda-lime)	0.18	154	0.59 [200]		
• flint (lead)	0.117	267			
• pyrex	0.20	139	0.59 [200]		
• "wool"	0.157	3.25	0.022	0.02	Highly polished
Gold	0.0312	1208	172.00		
Graphite:				0.75 0.903	On a smooth plate
• powder	0.165		0.106		
• "Karbate" (impervious)	0.16	117	75.00		
Gypsum	0.259	78	0.25		
Hemp (fiber)	0.323	93			
Ice:					
• [32 F]	0.487	57.5	1.30		
• [-4 F]	0.465		1.41		
Iron:				0.435 0.94	Freshly turned Dull, oxidized Gray, oxidized
• cast	0.12 [212]	450	27.60 [129]		
• wrought		485	34.90		
Lead	0.0309	707	20.10		
Leather (sole)		62.4	0.092		
Limestone	0.217	103	0.54		
				0.36 to 0.90	
Linen			0.05		Oxidized
Litharge (lead monoxide)	0.055	490			
Magnesia:					
• powdered	0.234 [212]	49.7	0.35 [117]		
• light carbonate		13	0.034		
Magnesite brick	0.222 [212]	158	2.20 [400]		
Magnesium	0.241	108	91.00		
				0.55	

Note : Values are for room temperature unless otherwise noted in brackets.

From 1972 ASHRAE Handbook of Fundamentals — Reprinted By Permission

# APPENDIX—TABLES

TABLE 44						PROPERTIES OF SOLIDS				
MATERIAL DESCRIPTION	SPECIFIC HEAT BTU/LB/°F	DENSITY LB/CU FT	THERMAL CONDUCTIVITY BTU • FT/HR/SQ FT/°F	EMISSIVITY						
				RATIO	SURFACE CONDITION					
<b>Marble</b> <b>Nickel</b> <b>Paints:</b> <ul style="list-style-type: none"> <li>• White lacquer</li> <li>• White enamel</li> <li>• Black lacquer</li> <li>• Black shellac</li> <li>• Flat black lacquer</li> <li>• Aluminum lacquer</li> </ul>	0.210	162	1.50	0.931	Light gray, polished					
	0.105	555	34.40			0.045	Electroplated, polished			
	<ul style="list-style-type: none"> <li>• On rough plate</li> <li>• "Matte" finish</li> <li>• On rough plate</li> </ul>	0.800	63	0.15	0.910					
		0.910			0.800					
		0.910			0.960					
		0.390			0.960					
<b>Paper</b> <b>Paraffin</b> <b>Plaster</b> <b>Platinum</b> <b>Porcelain</b> <b>Pyrites (Copper)</b>	0.320	58	0.075	0.920	Pasted on tinned plate					
	0.690	56	0.14 [32]							
	<ul style="list-style-type: none"> <li>• Rough</li> <li>• Polished</li> <li>• Glazed</li> </ul>	0.032	132	0.43 [167]	0.910					
		0.180	1340	39.90	0.054					
		0.131	162	1.30	0.920					
		0.131	262							
<b>Pyrites (Iron)</b> <b>Rock Salt</b> <b>Rubber:</b> <ul style="list-style-type: none"> <li>• Vulcanized (soft)</li> <li>• Vulcanized (hard)</li> </ul> <b>Sand</b> <b>Sawdust</b> <b>Silica</b>	0.136 [156]	310		0.860	Rough					
	0.219	136				0.08	0.950	Glossy		
	0.480	68.6				74.3	0.092			
		94.6				12	0.19			
	0.191	12				0.03				
	0.316	140				0.83 [200]				
<b>Silver</b> <b>Snow</b> <ul style="list-style-type: none"> <li>• Freshly fallen</li> <li>• At 32°F</li> </ul> <b>Steel (mild)</b> <b>Stone (quarried)</b> <b>Tar:</b> <ul style="list-style-type: none"> <li>• pitch</li> <li>• bituminous</li> </ul>	0.0560	654	245.00	0.020	Polished and at 440 F					
	0.120	7	0.34	0.120	Cleaned					
		0.200	31			1.30				
	0.59	489	26.20	0.51						
		0.59	95			0.41				
	<b>Tin</b> <b>Tungsten</b> <b>Wood:</b> <ul style="list-style-type: none"> <li>• Hardwoods: (Most woods vary between)</li> <li>• Ash, white</li> <li>• Elm, American</li> <li>• Hickory</li> <li>• Mahogany</li> <li>• Maple, sugar</li> <li>• Oak, white</li> <li>• Walnut, black</li> </ul> <ul style="list-style-type: none"> <li>• Softwoods:</li> <li>• Fir, white</li> <li>• Pine, white</li> <li>• Spruce</li> </ul> <b>Wool:</b> <ul style="list-style-type: none"> <li>• Fiber</li> <li>• Fabric</li> </ul>	0.0556	455	37.50	0.060	Bright and at 122 F				
0.032		1210	116.00	0.032	Filament at 80 F					
0.450/0.650		23/70	0.065/0.148	0.900	Planed					
		43	0.0992							
		36	0.0884							
		50								
<ul style="list-style-type: none"> <li>• Fiber</li> <li>• Fabric</li> </ul>	0.650	22/46	0.061/0.093	0.230	Fairly bright					
	0.670	27	0.068							
	0.325	27	0.063							
		26	0.065							
	0.092	82	0.021/0.037							
		0.094				6.9/20.6				
<ul style="list-style-type: none"> <li>• Cast</li> <li>• Hot-rolled</li> <li>• Galvanizing</li> </ul>	445	65.00	0.050	Polished						
	445	62.00								

Note: Values are for room temperatures unless otherwise noted in brackets.

TABLE 45		PROPERTIES OF WATER <sup>1</sup>	
Specific Heat of Water	=	1 Btu/lb/°F	1 Cal/Gram/°C
Specific Heat of Ice	=	0.5 Btu/lb/°F	0.5 Cal/Gram/°C
Latent Heat of Vaporization	=	970 Btu/lb @ 212°F & 1 ATM	540 Cal/Gram @ 100°C & 1 ATM
Latent Heat of Fusion	=	144 Btu/lb	80 Cal/Gram
One Cubic Foot	=	62.4 Pounds	7.48 Gallons
One Gallon	=	8.33 Pounds	3.77 Kilograms

Note: Water @ 39.2°F

TABLE 46		PROPERTIES OF AIR <sup>1</sup>	
One Pound of Air	=	13.33 Cubic Feet	0.075 Pounds
One Cubic Foot of Air	=	0.075 Pounds	
One Cubic Foot Per Minute (Cfm)	=	4.5 Pounds per Hour	

Note: Standard Dry Air @ 69.8°F<sup>o</sup> and 1 Atmosphere Pressure.

# APPENDIX—TABLES

**TABLE 47**

## PROPERTIES OF LIQUIDS

NAME OR DESCRIPTION	NORMAL BOILING POINT °F AT 1 ATM	ENTHALPY OF VAPORIZATION BTU/LB	SPECIFIC HEAT, $C_p$		VISCOSITY		ENTHALPY OF FUSION BTU/LB	SPECIFIC GRAVITY OR DENSITY (P)		THERMAL CONDUCTIVITY		FREEZING POINT °F	
			BTU/LB/°F	TEMP °F	LB/(HR) (FT)	TEMP °F		LB/CU FT P	TEMP °F	K	TEMP °F		
Acetaldehyde	69.44	245.1			0.558	68			48.9	64.4			-192.3
Acetic Acid	245.3	174.1	0.522	79-203	2.956	68	84.0	65.49	68	0.099	68		61.9
Acetone	133.2	228.9	0.514	37-73	0.801	68	42.1	49.4	68	0.102	86		-139.6
Alcohol													
• Allyl	206.6	294.1	0.655	70-205	3.298	68		53.31	68	0.104	77-86		-200.2
• Amyl	280.6	216.3			9.686	73.4	48.0	51.06	59	0.094	86		-110.2
• Ethyl	173.3	367.5	0.680	32-208	2.889	68	46.4	50.0	68	0.082	68		-162.4
• Isobutyl	226.4	249	0.116	68	9.450	68		49.27	68	0.105	68		-179.1
• Methyl	148.9	473.0	0.601	59-68	1.434	68	42.7	49.40	68	0.124	68		-144.0
Ammonia	-28	583.2	1.099	32	0.643	-28.3	142.9	43.50	-50	0.290	5-86		-107.9
Aniline	363.8	186.6	0.512	46-180	10.806	68	48.8	63.77	68	0.100	32-68		20.84
Benzene	176.2	169.4	0.412	68	1.580	68	54.2	54.9	68	0.085	68		42.0
Bromine	137.8	79.4	0.107	68	2.390	68	28.5	194.7	68				19.0
Brine, CaCl <sub>2</sub> (20% by wt)			0.744	68	4.800	68		73.8	68	0.332	68		2.0
Carbon Disulfide	115.3	148.8	0.240	68	0.880	68	24.8	78.9	68	0.093	86		-168.0
Carbon Tetrachloride	170.2	83.7	0.201	68	2.340	68	12.8	99.5	68	0.062	68		-9.0
Chloroform	142.3	106.0	0.234	68	1.360	68		92.96	68	0.075	68		-81.8
Ethyl Ether	94.06	151.0	0.541	68	0.560	68	42.4	44.61	68	0.081	68		-177.3
Ethyl Acetate	170.8	183.8	0.468	68	1.090	68	51.2	52.3	68	0.101	68		-116.3
Ethyl Chloride	54.2	165.9	0.368	32			29.68	56.05	68	0.179	33.6		-213.5
Ethylene Bromide	268.8	99.2	0.174	68	0.0694	68	24.82	136.05	68				49.2
Ethylene Chloride	182.3	153.4	0.301	68	0.0338	68	38.02	77.10	68				-31.64
Ethylene Glycol	388.4	344.0					77.86	69.22	68	0.100	68		12.7
Formic Acid	213.3	215.8	0.526	68	0.0719	68	118.89	76.16	68	0.104	33		47.1
Glycerine (glycerol)	359												
(20 mm)								78.72	68	0.113	68		68.0
Heptane	209.2	138.0	0.532	68	0.990	68	60.4	42.7	68	0.0741	68		-132.0
Hexane	154	145.0	0.538	68	0.775	68	65.0	41.1	68	0.0720	68		-139.0
Hydrogen Chloride	-120.8	191.0					23.6	74.6	b.p.				-174.6
Kerosene	400-560		0.500	68	6.000	68		51.2	68	0.086	68		
Linseed Oil					104.000	68		58.0	68				-11.0'
Methyl Acetate	134.6	177.0	0.468	68		68		60.6	68	0.093	68		-144.6
Methyl Iodide	108.5	82.6			1.210	68		142.0	68				-87.7
Naphthalene	411.4	136.0	0.402	m.p.	2.180	m.p.	64.9	60.9	m.p.				176.4
Nitric Acid	186.8	270.0	0.420	68	2.200	68	71.5	94.45	68	0.160	68		-42.9
Nitrobenzene	411.6	142.0	0.348	68	5.200	68	40.28	75.2	68	0.960	68		42.3
Octane	258.3	131.7	0.510	68	1.360	68	77.70	43.9	68	0.084	68		-69.7
Petroleum		98-165	0.4-0.6	68	19-2900	68		40-66	68				
n-Pentane	96.8	153.6	0.558	68	0.546	68	50.1	39.1	68	0.066	68		-201.5
Sodium Chloride Brine													
• 20% by wt.	220.8		0.745	68	3.800	68		71.8	68	0.337	68		2.6
• 10% by wt.	215.5		0.865	68	2.850	68		66.9	68	0.343	68		20.6
Sulfuric Acid and Water													
• 100% by wt.	550.0		0.335	68	53.000	68		114.4	68				50.9
• 90% by wt.	500.0		0.390	68	60.000	68		113.4	68	0.220	68		15.0
Toluene (C <sub>6</sub> H <sub>5</sub> CH <sub>3</sub> )	231.0	156.0	0.404	68	1.420	68	30.9	54.1	68	0.090	68		-139.0
Turpentine	303.0	123.0	0.420	68	1.320	68		53.9	68	0.073	68		
Water	212.0	970.3	0.999	68	2.390	68	143.5	62.32	68	0.348	68		32.018
Xylene													
C <sub>6</sub> H <sub>4</sub> (CH <sub>3</sub> ) <sub>2</sub>													
• Ortho	291.0	149.0	0.411	68	2.010	68	55.1	55.0	68	0.900	68		-13.0
• Meta	283.0	147.0	0.400	68	1.520	68	46.9	54.1	68	0.900	68		-53.0
• Para	281.0	146.0	0.393	68	1.620	68	69.3	53.8	68				+56.0

Notes:

1. Approximate solidification temperature.
2. Thermal conductivity units are Btu/(hr)(sq ft)(°F per ft)

From 1972 ASHRAE Handbook of Fundamentals — Reprinted by Permission

# APPENDIX—TABLES

**TABLE 48**

## HEAT TRANSFER AND ELECTRICAL FORMULAS

HEAT TRANSFER FORMULAS		KEY TO SYMBOLS
<b>HEAT TRANSMISSION</b>	$Q_{Tot} = U \times A \times \Delta t$	<p><b>Q<sub>Tot</sub></b> — Total Heat in Btu/hr</p> <p><b>U</b> — Heat Transfer Coefficient in Btu/hr/sq ft/°F</p> <p><b>A</b> — Surface Area thru which Heat is Conducted</p> <p><b>Δt</b> — Temperature Difference Between Initial &amp; Final Product Temp., Storage and Outside Temp., or Entering &amp; Leaving Air Temperature</p> <p><b>Q<sub>1</sub></b> — Sensible Product Heat Removal Above Freezing in Btu/hr</p> <p><b>Q<sub>2</sub></b> — Sensible Product Heat Removal Below Freezing in Btu/hr</p> <p><b>Q<sub>Sens</sub></b> — Sensible Heat in Btu/hr</p> <p><b>Q<sub>Lat</sub></b> — Latent Heat in Btu/hr</p> <p><b>Q<sub>Res</sub></b> — Respiration Heat in Btu/hr</p> <p><b>C<sub>1</sub></b> — Specific Heat Above Freezing in Btu/lb/°F</p> <p><b>C<sub>2</sub></b> — Specific Heat Below Freezing in Btu/lb/°F</p> <p><b>HL</b> — Latent Heat Of Fusion in Btu/lb</p> <p><b>HR</b> — Heat Of Respiration in Btu/hr/lb</p> <p><b>Cfm</b> — Cubic Feet per Minute</p> <p><b>ΔH</b> — Enthalpy Difference Between Entering &amp; Leaving Wet Bulb in Btu/lb</p> <p><b>ΔSH</b> — Specific Humidity Difference (Grains of Water Removed per lb of Air).</p> <p><b>Gpm</b> — Gallons per Minute</p> <p><b>TEW</b> — Entering Water Temp. in °F</p> <p><b>TLW</b> — Leaving Water Temp. in °F</p> <p><b>W</b> — Product Weight in Pounds</p>
<b>PRODUCT LOADS</b>	$Q_{Tot} = Q_1 + Q_{Lat} + Q_2 + Q_{Res}$	
	$Q_{Sens} = W \times C_{1 \text{ or } 2} \times \Delta t$	
	$Q_{Lat} = W \times hL$	
	$Q_{Res} = W \times hr$	
<b>COOLING COILS</b>	$Q_{Tot} = 4.5 \times Cfm \times \Delta h$	
	$Q_{Sens} = 1.08 \times Cfm \times \Delta t$	
	$Q_{Lat} = 0.68 \times Cfm \times \Delta SH$	
	$lbs/hr = \frac{4.5 \times Cfm \times \Delta SH}{7000 \text{ gr/lb}}$	
<b>HEATING COILS</b>	$Q_{Sens} = 1.08 \times Cfm \times \Delta t$	
<b>HEAT RECLAIM AND CONDENSER COILS</b>	$Q_{Sens} = 1.08 \times Cfm \times \Delta t$	
<b>WATER HEATING</b>	$Q_{Tot} = 500 \times Gpm \times (TLW - TEW)$	
<b>WATER COOLING</b>	$Q_{Tot} = 500 \times Gpm \times (TEW - TLW)$	
ELECTRICAL FORMULAS		CONVERSION FACTORS
Full Load Current = (Single Phase)	$I = \frac{P}{E}$	<p><b>4.5</b> — Converts Cfm to lbs/hr</p> <p><math>4.5 = \frac{60 \text{ Minutes}}{13.35 \text{ ft}^3 \text{ per lb (Spec. Vol.)}}</math></p> <p><b>1.08</b> — Combines 4.5 With Specific Heat</p> <p><math>1.08 = 4.5 \times 0.24 \text{ Btu/lb/}^\circ\text{F}</math></p> <p><b>0.68</b> — Combines 4.5 With Heat of Vaporization &amp; Grains per lb</p> <p><math>0.68 = \frac{4.5 \times 1054.3 \text{ Btu/lb}}{7000 \text{ gr/lb}}</math></p> <p><b>500</b> — Converts Gpm Water to lb/hr</p> <p><math>500 = \frac{60 \text{ Minutes} \times 62.4 \text{ lb/cu ft}}{7.48 \text{ gal/cu ft}}</math></p>
Full Load Current = (Three Phase)	$I = \frac{P}{1.732 \times E}$	
Volts = Amperage × Resistance	$E = I \times R$	
Watts = Amperage × Voltage	$P = I \times E$	
	$P_2 = P_1 \left(\frac{E_2}{E_1}\right)^2$	
Watts (@ Voltage E <sub>2</sub> ) = Watts (@ Voltage E <sub>1</sub> ) × (Volts <sub>2</sub> /Volts <sub>1</sub> ) <sup>2</sup>		

Note: Heat Transfer Formulas are valid for standard air @ 69.8°F & 14.7 Psig; Conversion Factors must be utilized for other conditions.



# APPENDIX—TABLES

**TABLE 49**
**FAHRENHEIT-CELSIUS TEMPERATURE CONVERSION CHART**

TEMPERATURE			TEMPERATURE			TEMPERATURE			TEMPERATURE		
CELS.	C OR F	FAHR.	CELS	C OR F	FAHR.	CELS	C OR F	FAHR.	CELS	C OR F	FAHR.
-40.0	-40	-40.0	-6.7	<b>+20</b>	<b>+68.0</b>	<b>+26.7</b>	<b>+80</b>	<b>+176.0</b>	<b>+60.0</b>	<b>+140</b>	<b>+284.0</b>
-39.4	-39	-38.2	-6.1	<b>+21</b>	<b>+69.8</b>	<b>+27.2</b>	<b>+81</b>	<b>+177.8</b>	<b>+60.6</b>	<b>+141</b>	<b>+285.8</b>
-38.9	-38	-36.4	-5.5	<b>+22</b>	<b>+71.6</b>	<b>+27.8</b>	<b>+82</b>	<b>+179.6</b>	<b>+61.1</b>	<b>+142</b>	<b>+287.6</b>
-38.3	-37	-34.6	-5.0	<b>+23</b>	<b>+73.4</b>	<b>+28.3</b>	<b>+83</b>	<b>+181.4</b>	<b>+61.7</b>	<b>+143</b>	<b>+289.4</b>
-37.8	-36	-32.8	-4.4	<b>+24</b>	<b>+75.2</b>	<b>+28.9</b>	<b>+84</b>	<b>+183.2</b>	<b>+62.2</b>	<b>+144</b>	<b>+291.2</b>
-37.2	-35	-31.0	-3.9	<b>+25</b>	<b>+77.0</b>	<b>+29.4</b>	<b>+85</b>	<b>+185.0</b>	<b>+62.8</b>	<b>+145</b>	<b>+293.0</b>
-36.7	-34	-29.2	-3.3	<b>+26</b>	<b>+78.8</b>	<b>+30.0</b>	<b>+86</b>	<b>+186.8</b>	<b>+63.3</b>	<b>+146</b>	<b>+294.8</b>
-36.1	-33	-27.4	-2.8	<b>+27</b>	<b>+80.6</b>	<b>+30.6</b>	<b>+87</b>	<b>+188.6</b>	<b>+63.9</b>	<b>+147</b>	<b>+296.6</b>
-35.6	-32	-25.6	-2.2	<b>+28</b>	<b>+82.4</b>	<b>+31.1</b>	<b>+88</b>	<b>+190.4</b>	<b>+64.4</b>	<b>+148</b>	<b>+298.4</b>
-35.0	-31	-23.8	-1.7	<b>+29</b>	<b>+84.2</b>	<b>+31.7</b>	<b>+89</b>	<b>+192.2</b>	<b>+65.0</b>	<b>+149</b>	<b>+300.2</b>
-34.4	-30	-22.0	-1.1	<b>+30</b>	<b>+86.0</b>	<b>+32.2</b>	<b>+90</b>	<b>+194.0</b>	<b>+65.6</b>	<b>+150</b>	<b>+302.0</b>
-33.9	-29	-20.2	-0.6	<b>+31</b>	<b>+87.8</b>	<b>+32.8</b>	<b>+91</b>	<b>+195.8</b>	<b>+66.1</b>	<b>+151</b>	<b>+303.8</b>
-33.3	-28	-18.4	.0	<b>+32</b>	<b>+89.6</b>	<b>+33.3</b>	<b>+92</b>	<b>+197.6</b>	<b>+66.7</b>	<b>+152</b>	<b>+305.6</b>
-32.8	-27	-16.6	+0.6	<b>+33</b>	<b>+91.4</b>	<b>+33.9</b>	<b>+93</b>	<b>+199.4</b>	<b>+67.2</b>	<b>+153</b>	<b>+307.4</b>
-32.2	-26	-14.8	+1.1	<b>+34</b>	<b>+93.2</b>	<b>+34.4</b>	<b>+94</b>	<b>+201.2</b>	<b>+67.8</b>	<b>+154</b>	<b>+309.2</b>
-31.7	-25	-13.0	+1.7	<b>+35</b>	<b>+95.0</b>	<b>+35.0</b>	<b>+95</b>	<b>+203.0</b>	<b>+68.3</b>	<b>+155</b>	<b>+311.0</b>
-31.1	-24	-11.2	+2.2	<b>+36</b>	<b>+96.8</b>	<b>+35.6</b>	<b>+96</b>	<b>+204.8</b>	<b>+68.9</b>	<b>+156</b>	<b>+312.8</b>
-30.6	-23	-9.4	+2.8	<b>+37</b>	<b>+98.6</b>	<b>+36.1</b>	<b>+97</b>	<b>+206.6</b>	<b>+69.4</b>	<b>+157</b>	<b>+314.6</b>
-30.0	-22	-7.6	+3.3	<b>+38</b>	<b>+100.4</b>	<b>+36.7</b>	<b>+98</b>	<b>+208.4</b>	<b>+70.0</b>	<b>+158</b>	<b>+316.4</b>
-29.4	-21	-5.8	+3.9	<b>+39</b>	<b>+102.2</b>	<b>+37.2</b>	<b>+99</b>	<b>+210.2</b>	<b>+70.6</b>	<b>+159</b>	<b>+318.2</b>
-28.9	-20	-4.0	+4.4	<b>+40</b>	<b>+104.0</b>	<b>+37.8</b>	<b>+100</b>	<b>+212.0</b>	<b>+71.1</b>	<b>+160</b>	<b>+320.0</b>
-28.3	-19	-2.2	+5.0	<b>+41</b>	<b>+105.8</b>	<b>+38.3</b>	<b>+101</b>	<b>+213.8</b>	<b>+71.7</b>	<b>+161</b>	<b>+321.8</b>
-27.8	-18	-0.4	+5.5	<b>+42</b>	<b>+107.6</b>	<b>+38.9</b>	<b>+102</b>	<b>+215.6</b>	<b>+72.2</b>	<b>+162</b>	<b>+323.6</b>
-27.2	-17	+1.4	+6.1	<b>+43</b>	<b>+109.4</b>	<b>+39.4</b>	<b>+103</b>	<b>+217.4</b>	<b>+72.8</b>	<b>+163</b>	<b>+325.4</b>
-26.7	-16	+3.2	+6.7	<b>+44</b>	<b>+111.2</b>	<b>+40.0</b>	<b>+104</b>	<b>+219.2</b>	<b>+73.3</b>	<b>+164</b>	<b>+327.2</b>
-26.1	-15	+5.0	+7.2	<b>+45</b>	<b>+113.0</b>	<b>+40.6</b>	<b>+105</b>	<b>+221.0</b>	<b>+73.9</b>	<b>+165</b>	<b>+329.0</b>
-25.6	-14	+6.8	+7.8	<b>+46</b>	<b>+114.8</b>	<b>+41.1</b>	<b>+106</b>	<b>+222.8</b>	<b>+74.4</b>	<b>+166</b>	<b>+330.8</b>
-25.0	-13	+8.6	+8.3	<b>+47</b>	<b>+116.6</b>	<b>+41.7</b>	<b>+107</b>	<b>+224.6</b>	<b>+75.0</b>	<b>+167</b>	<b>+332.6</b>
-24.4	-12	+10.4	+8.9	<b>+48</b>	<b>+118.4</b>	<b>+42.2</b>	<b>+108</b>	<b>+226.4</b>	<b>+75.6</b>	<b>+168</b>	<b>+334.4</b>
-23.9	-11	+12.2	+9.4	<b>+49</b>	<b>+120.2</b>	<b>+42.8</b>	<b>+109</b>	<b>+228.2</b>	<b>+76.1</b>	<b>+169</b>	<b>+336.2</b>
-23.3	-10	+14.0	+10.0	<b>+50</b>	<b>+122.0</b>	<b>+43.3</b>	<b>+110</b>	<b>+230.0</b>	<b>+76.7</b>	<b>+170</b>	<b>+338.0</b>
-22.8	-9	+15.8	+10.6	<b>+51</b>	<b>+123.8</b>	<b>+43.9</b>	<b>+111</b>	<b>+231.8</b>	<b>+77.2</b>	<b>+171</b>	<b>+339.8</b>
-22.2	-8	+17.6	+11.1	<b>+52</b>	<b>+125.6</b>	<b>+44.4</b>	<b>+112</b>	<b>+233.6</b>	<b>+77.8</b>	<b>+172</b>	<b>+341.6</b>
-21.7	-7	+19.4	+11.7	<b>+53</b>	<b>+127.4</b>	<b>+45.0</b>	<b>+113</b>	<b>+235.4</b>	<b>+78.3</b>	<b>+173</b>	<b>+343.4</b>
-21.1	-6	+21.2	+12.2	<b>+54</b>	<b>+129.2</b>	<b>+45.6</b>	<b>+114</b>	<b>+237.2</b>	<b>+78.9</b>	<b>+174</b>	<b>+345.2</b>
-20.6	-5	+23.0	+12.8	<b>+55</b>	<b>+131.0</b>	<b>+46.1</b>	<b>+115</b>	<b>+239.0</b>	<b>+79.4</b>	<b>+175</b>	<b>+347.0</b>
-20.0	-4	+24.8	+13.3	<b>+56</b>	<b>+132.8</b>	<b>+46.7</b>	<b>+116</b>	<b>+240.8</b>	<b>+80.0</b>	<b>+176</b>	<b>+348.8</b>
-19.4	-3	+26.6	+13.9	<b>+57</b>	<b>+134.6</b>	<b>+47.2</b>	<b>+117</b>	<b>+242.6</b>	<b>+80.6</b>	<b>+177</b>	<b>+350.6</b>
-18.9	-2	+28.4	+14.4	<b>+58</b>	<b>+136.4</b>	<b>+47.8</b>	<b>+118</b>	<b>+244.4</b>	<b>+81.1</b>	<b>+178</b>	<b>+352.4</b>
-18.3	-1	+30.2	+15.0	<b>+59</b>	<b>+138.2</b>	<b>+48.3</b>	<b>+119</b>	<b>+246.2</b>	<b>+81.7</b>	<b>+179</b>	<b>+354.2</b>
-17.8	0	+32.0	+15.6	<b>+60</b>	<b>+140.0</b>	<b>+48.9</b>	<b>+120</b>	<b>+248.0</b>	<b>+82.2</b>	<b>+180</b>	<b>+356.0</b>
-17.2	+1	+33.8	+16.1	<b>+61</b>	<b>+141.8</b>	<b>+49.4</b>	<b>+121</b>	<b>+249.8</b>	<b>+82.8</b>	<b>+181</b>	<b>+357.8</b>
-16.7	+2	+35.6	+16.7	<b>+62</b>	<b>+143.6</b>	<b>+50.0</b>	<b>+122</b>	<b>+251.6</b>	<b>+83.3</b>	<b>+182</b>	<b>+359.6</b>
-16.1	+3	+37.4	+17.2	<b>+63</b>	<b>+145.4</b>	<b>+50.6</b>	<b>+123</b>	<b>+253.4</b>	<b>+83.9</b>	<b>+183</b>	<b>+361.4</b>
-15.6	+4	+39.2	+17.8	<b>+64</b>	<b>+147.2</b>	<b>+51.1</b>	<b>+124</b>	<b>+255.2</b>	<b>+84.4</b>	<b>+184</b>	<b>+363.2</b>
-15.0	+5	+41.0	+18.3	<b>+65</b>	<b>+149.0</b>	<b>+51.7</b>	<b>+125</b>	<b>+257.0</b>	<b>+85.0</b>	<b>+185</b>	<b>+365.0</b>
-14.4	+6	+42.8	+18.9	<b>+66</b>	<b>+150.8</b>	<b>+52.2</b>	<b>+126</b>	<b>+258.8</b>	<b>+85.6</b>	<b>+186</b>	<b>+366.8</b>
-13.9	+7	+44.6	+19.4	<b>+67</b>	<b>+152.6</b>	<b>+52.8</b>	<b>+127</b>	<b>+260.6</b>	<b>+86.1</b>	<b>+187</b>	<b>+368.6</b>
-13.3	+8	+46.4	+20.0	<b>+68</b>	<b>+154.4</b>	<b>+53.3</b>	<b>+128</b>	<b>+262.4</b>	<b>+86.7</b>	<b>+188</b>	<b>+370.4</b>
-12.8	+9	+48.2	+20.6	<b>+69</b>	<b>+156.2</b>	<b>+53.9</b>	<b>+129</b>	<b>+264.2</b>	<b>+87.2</b>	<b>+189</b>	<b>+372.2</b>
-12.2	+10	+50.0	+21.1	<b>+70</b>	<b>+158.0</b>	<b>+54.4</b>	<b>+130</b>	<b>+266.0</b>	<b>+87.8</b>	<b>+190</b>	<b>+374.0</b>
-11.7	+11	+51.8	+21.7	<b>+71</b>	<b>+159.8</b>	<b>+55.0</b>	<b>+131</b>	<b>+267.8</b>	<b>+88.3</b>	<b>+191</b>	<b>+375.8</b>
-11.1	+12	+53.6	+22.2	<b>+72</b>	<b>+161.6</b>	<b>+55.6</b>	<b>+132</b>	<b>+269.6</b>	<b>+88.9</b>	<b>+192</b>	<b>+377.6</b>
-10.6	+13	+55.4	+22.8	<b>+73</b>	<b>+163.4</b>	<b>+56.1</b>	<b>+133</b>	<b>+271.4</b>	<b>+89.4</b>	<b>+193</b>	<b>+379.4</b>
-10.0	+14	+57.2	+23.3	<b>+74</b>	<b>+165.2</b>	<b>+56.7</b>	<b>+134</b>	<b>+273.2</b>	<b>+90.0</b>	<b>+194</b>	<b>+381.2</b>
-9.4	+15	+59.0	+23.9	<b>+75</b>	<b>+167.0</b>	<b>+57.2</b>	<b>+135</b>	<b>+275.0</b>	<b>+90.6</b>	<b>+195</b>	<b>+383.0</b>
-8.9	+16	+60.8	+24.4	<b>+76</b>	<b>+168.8</b>	<b>+57.8</b>	<b>+136</b>	<b>+276.8</b>	<b>+91.1</b>	<b>+196</b>	<b>+384.8</b>
-8.3	+17	+62.6	+25.0	<b>+77</b>	<b>+170.6</b>	<b>+58.3</b>	<b>+137</b>	<b>+278.6</b>	<b>+91.7</b>	<b>+197</b>	<b>+386.6</b>
-7.8	+18	+64.4	+25.6	<b>+78</b>	<b>+172.4</b>	<b>+58.9</b>	<b>+138</b>	<b>+280.4</b>	<b>+92.2</b>	<b>+198</b>	<b>+388.4</b>
-7.2	+19	+66.2	+26.1	<b>+79</b>	<b>+174.2</b>	<b>+59.4</b>	<b>+139</b>	<b>+282.2</b>	<b>+92.8</b>	<b>+199</b>	<b>+390.2</b>

Notes: 1. The numbers in bold-face type in the center column refer to the temperature, either in Celsius or Fahrenheit, which is to be converted to the other scale. If converting Fahrenheit to Celsius, the equivalent temperature will be found in the left column. If converting Celsius to Fahrenheit, the equivalent temperature will be found in the column on the right.

2. 1 Degree Celsius = 1 Kelvin

3. Formula: Temp °F = 9/5 Temp. °C + 32; Temp. °C = 5/9 (Temp. °F - 32)

From 1972 ASHRAE Handbook of Fundamental—Reprinted by Permission

# APPENDIX—CHARTS

## CHART 1

### ESTIMATING UNIT COOLER CAPACITIES

#### GENERAL:

It is often necessary in the expansion or re-application of a cold storage room to estimate the capacity of existing equipment. Additionally, it is sometimes necessary to physically check evaporators to determine whether they are actually working. Chart 1 may be used for this purpose.

#### STEPS TO FOLLOW:

(1) Measure entering air temperature ( $t_1$ ) and Leaving air temperature ( $t_0$ ).


(2) Calculate  $\Delta t$ :  $\Delta t = t_{10F} - t_{20F}$

(3) Measure face velocity and face area.

(4) Calculate Cfm:  $Cfm = Vel_{fpm} \times Area_{ft^2}$

(5) Enter chart on the x-axis at the calculated Cfm and move vertically to the  $\Delta t$  calculated above. Read indicated capacity on the y-axis.


(6) Apply the appropriate correction factor from the chart below to the indicated capacity for entering air temperatures other than +20°F.



# APPENDIX—CHARTS

## CHART 2


NORMAL TEMPERATURE PSYCHROMETRIC CHART (32 TO 130°F)  
STANDARD ATMOSPHERIC PRESSURE OF 29.921 IN HG



# APPENDIX—CHARTS

## CHART 3

LOW TEMPERATURE PSYCHROMETRIC CHART ( - 40 TO 50°F)  
STANDARD ATMOSPHERIC PRESSURE OF 29.92 IN HG



ATMOSPHERIC PRESSURES AT OTHER ALTITUDES	
ALTITUDE FT	PRESSURE IN HG
- 1000	31.02
- 500	30.47
0	29.92
500	29.38
1000	28.86
2000	27.82
3000	26.82
4000	25.84
5000	24.90
6000	23.98
7000	23.09
8000	22.22
9000	21.39
10000	20.58
15000	16.89

Courtesy ASHRAE — Reproduced By Permission

# INDEX OF APPENDIX

TABLE NO.	DESCRIPTION
1A	Heat Gain Factors for Common Insulating & Building Materials
1B	Heat Transmission Coefficients for Other Insulating & Building Materials
2	Solar Radiation Allowance
3	Motor Equivalencies
4A	Average Air Changes Above 32°F Due to Infiltration & Door Openings
4B	Average Air Changes Below 32°F Due to Infiltration & Door Openings
5	Heat Removed in Cooling Air to Storage Conditions
6	Occupancy Heat
7	Ice Cream Data
8	Time Cycle Factors
9	Properties and Storage Data for Perishable Products
10	Product Chilling Data
11	Beef Chilling — Minimum Refrigeration Requirements in Tons
12	Pork Chilling — Minimum Refrigeration Requirements in Tons
13	Blast Freezing Product Load Estimates
14	Physical Data of Perishable Product Containers
15	Storage Conditions for Cut Flowers and Nursery Stock
16	Apple Storage Capacity Requirements
17	Recommended Coil TD by Product Class
18	Commercial Estimating Guidelines
19	Banana Room Design Parameters
20	U Value Revisions
21	Food Storage Estimating Guidelines
22	Recommended Insulation Thickness
23	Milk Container Data
24	Cheese Make and Cure Data

TABLE NO.	DESCRIPTION
25	Specific Heats of Milk and Milk Derivatives
26	Other Cheese Cure Data
27	Cheese Freeze Points
28	Cheese Storage Temperatures
29	Beverage Container Data
30	Infiltration Loads When Storing Beer Containers
31	Heat Loads of Keg & Bottled Beer
32	Walk-In Beer Cooler Storage Loads
33	Domestic Outdoor Design Data
34	International Outdoor Design Data
35	SI Metric Conversion Factors
36	Weight Equivalency of Common Measures
37	English-Metric Conversion Factors
38	English Conversion Factors
39	Metric Conversion Factors
40	Outside Area, Room Volume and Refrigeration Load for Walk-In Coolers
41	Average Product Loads for Walk-In Coolers & Freezers
42	Specific Product Loads for Walk-In Coolers & Freezers
43	Glass Display Door Loads for Walk-In Coolers & Freezers
44	Properties of Solids
45	Properties of Water
46	Properties of Air
47	Properties of Liquids
48	Heat Transfer & Electrical Formulas
49	Fahrenheit-Celsius Temperature Conversion Chart
<b>Chart I</b> — Estimating Unit Cooler Capacities	
<b>Chart II</b> — Normal Temp. Psychrometric Chart	
<b>Chart III</b> — Low Temp. Psychrometric Chart	



**Krack Corporation**

1300 North Arlington Heights Rd., Suite 130  
Itasca, IL 60143  
Ph: 630.629.7500

[krack.com](http://krack.com)