



SEISMIC

Qualification Certificate

Delivered on: Monday, February 12nd 2018

References:

- **VIRLAB** test procedure number **141128E3**, issue 1, dated 02/12/2014: *STANDARD TEST PROCEDURE FOR THE SEISMIC QUALIFICATION OF “TWO DISTRIBUTION SWITCHBOARDS SYSTEM PRO AND POWER” ACCORDING TO IEEE Standard 693-2005 and EUROPEAN STANDARDS EN60068-3-3:1993 AND EN60068-2-57:2000*
- North American standard **IEEE-693/2005**: “*IEEE Recommended Practice for Seismic Design of Substations*”.
- European standard **EN 60068-3-3/1993**: *Environmental testing – Part 3: Guidance. Seismic tests methods for equipments.*
- European standard **EN 60068-2-6/2008**: *Environmental testing – Part 2: Tests – Fc: Vibration (sinusoidal).*
- European standard **EN 60068-2-47/2005**: “*Environmental testing - Part 2-47: Tests. Mounting of specimens for vibration, impact and similar dynamic tests*”.
- European standard **EN60068-2-57/2000**: “*Environmental testing - Part 2-57: Test Ff: Vibration - Time-history method*”.
- **TURKISH SEISMIC CODE**, edition 2007.
- **REQUIRED RESPONSE SPECTRA** applicable to “YATAY” and “DIKEY” sites (**TURKEY**).

Laboratory Name: **VIRLAB, S.A.** (accredited by ENAC, Spanish National Accreditation Entity).
ENAC certificate number 54/LE131.

Laboratory Address: Polígono Industrial de Asteasu, Zona B - 44
Apartado 247
20159 ASTEAU (SPAIN)

Equipment tested: A **DISTRIBUTION SWITCHBOARD**, manufactured by **ABB SACE ADB (Italy)**, according to drawing number 862553, revision 0, dated 06/11/2013, with the characteristics described here below:

- **Name of the Switchboard:** Conf.4 3200 A
- **Family:** system pro E_Power
- **Protection degree IP:** 65
- **Icw máx (KA):** 100





VIRLAB, S.A.
Division of URBAR INGENIEROS, S.A.
Vibration Test Laboratory

- **Segregation form:** 4B
- **Ue (V):** 436
- **Overall size HxLxP (mm):** 2214x2008x816

Picture included here below shows the **Switchboard** on the test platform EDB250x250 (2500x2500 mm), before starting the tests.




VIRLAB, S.A. certifies that the referred **Switchboard** has been seismically tested in January, between the 20th and the 21th 2014, according to test procedure number **141128E3**, Issue 1, of VIRLAB, elaborated in agreement with **IEEE Standard 693-2005** and **European Standards EN 60068-2-57:2000, EN 60068-3-3:1993, EN 60068-2-6:2008** and **EN 60068-2-47:2005**.

This equipment has been initially submitted to seismic tests with the envelope of the “**High Required Response Spectrum, 0.5 g**” of the American Standard **IEEE-693:2005**, the **EN60068-2-57: 2000 (Category 1, ZPA=0.5 g)** and the **YATAY** required spectra, that considers a Zero Period Acceleration, ZPA, of **0.5 g in horizontal direction and 0.4 g in vertical direction** for the **IEEE-693:2005** and the **EN60068-2-57: 2000** standards; and of **0.69 g in horizontal and vertical direction** for the **YATAY** site.


So, the envelope of the three referred spectra presents a ZPA (*Zero Period acceleration*) of **0.69 g in both horizontal and vertical direction**, corresponding to the **YATAY** site.

Here below are included the referred levels, defined as spectra of level S2 according to standard **UNE EN 60068-3-3**, drawn for the 5% of damping.





S2 HORIZONTAL (5% Damping)



S2 VERTICAL (5% Damping)

The horizontal ZPA (Zero Period acceleration), **0.69 g**, is higher than the corresponding to the AG5 “Ground Acceleration Reference” defined in Table 3 of point 8.2.4 of European standard *EN 60068-3-3*, value calculated, as it is described in point 8.2.7 of the referred standard, as follows:

$$\text{➤ } a_f = a_g \times K \times D = 0.5 \times 1 \times 1 = \underline{0.5 \text{ g}}, \text{ being}$$

a_f (floor acceleration);

a_g (ground acceleration) = 0.5 g (Table 3 of EN 60068-3-3: 1993);

K (amplification factor) = 1 (Table 4 of EN 60068-3-3: 1993);

D (direction factor) = 1 (Table 5 of EN 60068-3-3: 1993).

The vertical ZPA, **0.69 g**, is also higher than the corresponding to the AG5, **0.25 g**, value calculated as follows:

$$\text{➤ } a_f = a_g \times K \times D = 0.5 \times 1 \times 0.5 = \underline{0.25 \text{ g}}, \text{ being}$$

a_f (floor acceleration);

a_g (ground acceleration) = 0.5 g (Table 3 of EN 60068-3-3: 1993);

K (amplification factor) = 1 (Table 4 of EN 60068-3-3: 1993);

D (direction factor) = 0.5 (Table 5 of EN 60068-3-3: 1993).





The **Switchboard** has been submitted to the tests described here below:

- Resonance search tests between 1 and 35 Hz, before and after performing the seismic tests. These tests have been carried out in horizontal direction, *front-to-back* and *side-to-side* and in vertical direction to the **Switchboard**.
- Seismic tests, longer than 20 seconds, performing five (5) S1 (50% S2) level tests followed by one (1) S2 level test. These tests have been carried out in the two main horizontal directions, *front-to-back* and *side-to-side* with regard to the **Switchboard**, simultaneously with the vertical direction.

The tested **Equipment** complies with the CRITERIA 0, according to point 4.3 of European standard **EN 60068-3-3: 1993**, which states that “*equipment tested has experienced no malfunction either during or after the test*”.


No deviations in the resonances longer than the 20%, allowed by standard **IEEE693/2005**, have been detected.

After having performed the seismic tests with the envelope of the “**High Required Response Spectrum, 0.5 g**” of the American Standard **IEEE-693:2005**, the **EN60068-2-57: 2000 (Category 1, ZPA=0.5 g)** and the **YATAY** required spectra, one more S2 level test has been performed in OY/OZ and OX/OZ Direction with the envelope of the levels described here below:


- The level according to the “**High Required Response Spectrum, 0.5 g**” of the **IEEE-693 of 2005**, **incremented in a 50%**, so, considering a Zero Period Acceleration of **0.75 g in horizontal direction** and **0.6 g in vertical direction** (80% of the horizontal component), reaching maximum spectral accelerations of 1.875 g in horizontal direction, for 5% damping.
- The level according to **EN60068-2-57: 2000 (Category 1, ZPA=0.5 g)**, **incremented in a 50%**, so, considering a Zero Period Acceleration of also **0.75 g in horizontal direction** and **0.6 g in vertical direction** (80% of the horizontal component), reaching maximum spectral accelerations of 2.25 g in horizontal direction, for 5% damping.

The envelope of referred **S2** level Required Response Spectra, for both the horizontal and the vertical direction, drawn for the 5% damping are included here below.





S2 HORIZONTAL (0.75 g ZPA; 5% Damping)



S2 VERTICAL (0.6 g ZPA; 5% Damping)

On the other hand, during tests performed with the level of acceleration of **0.75 g**, the following incidences have been detected in the *Switchboard*:

- Several screws of the front panels of the *Switchboard* fall.
- Several small locking pieces of the *Switchboard* internal doors are broken.
- A lateral panel of the *Switchboard* is released.

In test report number **152146** of **VIRLAB, S.A.**, will be included all the information obtained, with tables, photographs and so on.

VIRLAB representative



Mr. ALBERTO CORRAL
Engineer of Laboratory

