

# *UltraTech Cement Limited*

## *(Unit: Kotputli Cement Works-Power Plant)*



**Welcome to CII**

**19<sup>th</sup> National Award for Excellence in  
Energy Management 2018**

### *Participants*

- *Pintoo Dodiya (Assistant Manager)*
- *R.N.Tripathi (Assistant Manager)*
- *Harish Mittal (Assistant Engineer)*

- **Company profile and Flow diagram**
  - **Specific energy consumption data in last 3 years**
    - **Information on competitor and Bench marking**
      - **Energy saving projects implemented in consecutive 3 years**
        - **Major innovative projects implemented in FY'17-18**
          - **Utilization of renewable energy**
            - **GHG Inventorisation**
              - **Team work employee involvement & monitoring**
                - **Implementation of ISO 50001**
                  - **Awards & Accolades**


# Profile



## • UltraTech Cement.....


- Kotputli Cement Work
- An Aditya Birla Group Company.
- 2X23 MW Captive Power Plant
- 3.3 MTPA capacity Green field Cement plant.
- Certified with ISO 9001, 14001, OHSAS 18001 , ISO 27001, ISO 50001 & ISO 17025.
- UltraTech-Kotputli TPP won First prize in “National Energy Conservation Award- 2017” by Ministry of Power Awarded by honourable President of India.
- The continual Energy improvements by KCW TPP have been recognized by awarding “CII – Excellence Energy Efficient Unit award” for last consecutive four years at CII –Hyderabad
- Adopted World Class Manufacturing Excellence Model

# Process flow diagram




# Specific Energy consumption


### OVERALL PLANT APC (%)




### PLANT HEAT RATE (KCAL/KWH)



### ACC-1 AUXILIARY POWER CONS. (%)



### BOP APC (%)



# National Benchmarking





## 3.15 CAPTIVE POWER PLANT

| Parameter            | Unit       | Plant 1 | Plant 2 | Plant 3 | Plant 4 | Plant 5 | Plant 6                       | Plant 7 | Plant 8 | Plant 9 | Plant 10 | KCW  |
|----------------------|------------|---------|---------|---------|---------|---------|-------------------------------|---------|---------|---------|----------|------|
| Installed capacity   | MW         | 15      | 30      | 9       | 15      | 17.5    | 12.5                          | 25 x 2  | 15      | 17.5    | 17.5     | 2X23 |
| Type                 |            | AFBC    | AFBC    | AFBC    | AFBC    | AFBC    | AFBC                          | CFBC    | AFBC    | AFBC    | AFBC     | CFBC |
| PLF                  | %          | 82.3    | 68.5    | 88.5    | 65      | 84      | 88                            | 97.4    | 64      | 77.8    | 85       | 80.8 |
| Heat rate            | Kcal / kWh | 3250.36 | 3327    | 3040    | 3048    | 3028    | 3490                          | 2932    | 3495    | 3035    | 3074     | 3030 |
| Coal CV              | Kcal / kg  | 5268.83 | 5503    | 3204    | 4062    | 3213    | Petcoke + Lignite (NCV): 4940 | 6475    | 4981    | 3175    | 3205     | 7562 |
| LOI - Bed ash        | %          | 20.1    | 19.42   | <1      | 5.12    | <1      | 0.4-0.5                       | 3.73    | 14.21   | <1      | <1       | 2.5  |
| Int. header pressure | Bar        | 5.5     | 5.5     | 6       | 5.2     | 6       | 6                             | 6.4     | 5.5     | 6       | 6        | 5.5  |
| Fly ash tpt pressure | Bar        | 4.5     | 4       | 5       | 3.5     | 5       | 4.5                           | 5.2     | 4       | 5       | 5        | 4.5  |
| APC                  | %          | 7.97    | 8.53    | 8.96    | 9.1     | 9.3     | 9.5                           | 9.51    | 9.56    | 9.56    | 9.69     | 8.38 |

Ref- For International Benchmark BEE presentation during interactive workshop on normalization factor in Ahmedabad

Ref. For National Benchmark Data Best Thermal energy efficiency award by NCCBM for FY2014-15.

# Benchmarking With UTCL Units 2017-18



# Road map for Benchmarking



- *Plant Digitalization and installation of Optimax software for boiler efficiency improvement (saving in HR 26 kcal/kwh ).*
- **Overhauling of TG-1 for Heat Rate improvement ( saving in HR 67 kcal/Kwh)**
- **Improvement of PLF by power wheeling to other sister units in group.**
- **Existing ETP Pump replacement with Grundfos make energy efficient pump.**
- **Installation of Energy efficient 3 phase rectifiers for ESP.**
- **Installation of VAM in place of existing package AC.**
- **ACC-1 all fan replacement with Energy efficient fan blade (Encon.)**



# Energy Savings Projects with No Investment (2015-16)



| SN | Energy Saving Projects   | Saving Achieved         |                           |               |
|----|--|-------------------------|---------------------------|---------------|
|    |  | Electrical Energy (MWH) | Thermal Energy (Ton/Year) | (Rs. Million) |
| 1  | Improved heat rate of TG-2 by operating with higher vacuum   | -                       | 313                       | 1.65          |
| 2  | Intermittently stopped service air compressor to avoid idle running during pet coke usage & DP level in ESP hoppers. | 340.5                   | -                         | 1.25          |
| 3  | Developed a logic (Auto set point calculation) for BFP discharge pressure w.r.t. steam drum pressure.                | 320.2                   | -                         | 1.19          |
| 4  | Developed a logic (Auto set point calculation) for CEP discharge pressure w.r.t. deaerator pressure.                 | 268.6                   | -                         | 0.96          |
| 5  | Reduction of both boiler ESP field power by changing charging ratio with respect to fuel types.                      | 278                     | -                         | 0.93          |
| 6  | Adiabatic cooling system for inlet air of ACC Fans in unit-1   | 216                     | -                         | 0.73          |

# Energy Savings Projects with No Investment (2015-16)



| SN | Energy Saving Projects  | Saving Achieved         |                           |               |
|----|---|-------------------------|---------------------------|---------------|
|    |   | Electrical Energy (MWH) | Thermal Energy (Ton/Year) | (Rs. Million) |
| 7  | Through put increased & run hours reduction of CHP by using Belt power feedback display on DCS.                           | 164.3                   | -                         | 0.55          |
| 8  | Indigenous development of auto import -export logic during power export.  | 150.7                   | -                         | 0.50          |
| 9  | Reduced Instrument air pressure set point from 6.5 kg/cm <sup>2</sup> to 5.8 kg/cm <sup>2</sup> (gradually in two phase). | 72.6                    | -                         | 0.26          |
| 10 | WTP running hours reduction by commissioning & utilising dump steam system.(Savings of 06 Months)                         | 48.4                    | -                         | 0.16          |
| 11 | Reduction in BAC fan air flow from 22 to 19 TPH   | 46.2                    | -                         | 0.15          |
| 12 | Reduction in idling hours by implementing remote operation of Fly ash compressors.  | 18.2                    | -                         | 0.06          |

# Energy Savings Projects with Investment (2015-16)



| SN | Energy Saving Projects  | Saving Achieved         |                           |             | Investment (Rs. Million) | Pay back Month |
|----|---|-------------------------|---------------------------|-------------|--------------------------|----------------|
|    |   | Electrical Energy (MWH) | Thermal Energy (Ton/Year) | Rs. Million |                          |                |
| 1  | Up keepment of steam turbine-2 to improve heat rate   | -                       | 1342                      | 7.07        | 2.61                     | 4              |
| 2  | Reduction in power consumption of air conditioners by using Nano technology & installing water cooled condensers                            | 203.6                   | -                         | 0.69        | 0.20                     | 4              |
| 3  | Installation of separate energy efficient side stream filter pump (Grundfos Make) for cooling tower to reduce power from existing ACW pump. | 17.3                    | -                         | 0.06        | 0.05                     | 10             |
| 4  | Usage of renewable (solar)energy for lighting at HSD area .   | 5.6                     | -                         | 0.02        | 0.14                     | 88             |

# Energy Savings Projects with No Investment (2016-17)



| SN | Energy Saving Projects  | Saving Achieved         |                           |               |
|----|---|-------------------------|---------------------------|---------------|
|    |   | Electrical Energy (MWH) | Thermal Energy (Ton/Year) | (Rs. Million) |
| 1  | Reduction of BFP power by developing discharge pressure biasing.                      | 330                     |                           | 1.09          |
| 2  | Reduction in Boiler PA Fan KW by optimizing the PA Air flow according the boiler load | 264                     |                           | 0.87          |
| 3  | Condensate interconnection to reduce heat loss (From Aug-16 to Mar-17)                |                         | 4.12                      | 0.03          |
| 4  | Reduction in SAC running hours through ESP hopper level by Draft transmitter.         | 165                     |                           | 0.54          |
| 5  | Utilising lower CFM & KW compressor for Fly ash conveying                             | 66                      |                           | 0.22          |
| 6  | Usage of 90% Pet coke in fuel mix & Reduction in CHP power by increasing through put  | 66                      |                           | 0.22          |

# Energy Savings Projects with No Investment (2016-17)



| SN | Energy Saving Projects   | Saving Achieved         |                           |               |
|----|--|-------------------------|---------------------------|---------------|
|    |  | Electrical Energy (MWH) | Thermal Energy (Ton/Year) | (Rs. Million) |
| 7  | Reduction in AC & lighting power   | 33                      |                           | 0.11          |
| 8  | Reduction in ID fan power consumption due low bed ash cooler running hour                  | 33                      |                           | 0.11          |
| 9  | Reduction in BLR SA fan KW by optimizing the SA air pressure.                              | 31.68                   |                           | 0.10          |
| 10 | Reduction in instrument air compressor power by optimizing the air flow in BLR MDC sealing | 31.68                   |                           | 0.10          |
| 11 | Silo bag filter purging air pressure reduction   | 26.4                    |                           | 0.09          |
| 12 | CEP power cons. reduction by inter connecting condensate line during unequal loads on TG.  | 8.25                    |                           | 0.03          |

# Energy Savings Projects with No Investment (2016-17)



| SN | Energy Saving Projects  | Saving Achieved         |                           |               |
|----|---|-------------------------|---------------------------|---------------|
|    |   | Electrical Energy (MWH) | Thermal Energy (Ton/Year) | (Rs. Million) |
| 13 | Reduction of RO Degasser transfer pump power consumption by utilising old CT sump as storage  | 3.56                    |                           | 0.01          |
| 14 | Reduction of raw water pump running hours by continuous make up of cooling tower  | 1.81                    |                           | 0.01          |
| 15 | ACW pump power reduction by optimizing the CW flow of equipment's according the ambient temp.   | 39.6                    |                           | 0.13          |
| 16 | Use of Raw Mill dust to reduce sensible heat loss due to bed drain & Usage of High GCV fuel in the boiler to achieved higher boiler efficiency. |                         | 81.22                     | 0.52          |
| 17 | Reduction in import of Grid power ( Diff. @ Rs 2.8 in Power generation cost against Grid Power)   | 896                     |                           | 2.50          |
| 18 | Power Sale to other group units ( Difference @ Rs 1.86 in Power generation cost against Grid Power)   | 5257                    |                           | 9.78          |

# Energy Savings Projects with Investment (2016-17)



| SN | Energy Saving Projects  | Saving Achieved         |                           |             | Investment (Rs. Million) | Pay back Month |
|----|---|-------------------------|---------------------------|-------------|--------------------------|----------------|
|    |   | Electrical Energy (MWH) | Thermal Energy (Ton/Year) | Rs. Million |                          |                |
| 1  | TG 1 ACC fan 2 VFD installation   | 115.5                   |                           | 0.38        | 0.42                     | 13             |
| 2  | Replacement of TG 1 MOP with high efficiency pump   | 79.2                    |                           | 0.26        | 0.16                     | 7              |
| 3  | Bed ash cooler fan outlet duct inter connection   | 69.3                    |                           | 0.23        | 0.1                      | 5              |
| 4  | Boiler-1 BAC fan VFD installed  | 69.3                    |                           | 0.23        | 0.42                     | 22             |
| 5  | Cooling tower fan VFD installed   | 33.99                   |                           | 0.11        | 0.15                     | 16             |
| 6  | Power reduction by Installation of submersible pump in main effluent pit for transfer to mines. | 11.88                   |                           | 0.04        | 0.038                    | 12             |

# Energy Savings Projects with Investment (2016-17)



| SN | Energy Saving Projects  | Saving Achieved               |                                 |                | Investment<br>(Rs. Million) | Pay<br>back<br>Month |
|----|---|-------------------------------|---------------------------------|----------------|-----------------------------|----------------------|
|    |   | Electrical<br>Energy<br>(MWH) | Thermal<br>Energy<br>(Ton/Year) | Rs.<br>Million |                             |                      |
| 7  | Utilisation of TG-2 1st extraction steam in PRDS for ejector (From Nov-16 to Mar-17)                  | 4.8                           | 50.05                           | 0.33           | 0.45                        | 16                   |
| 8  | Lighting power optimisation.  | 6.6                           |                                 | 0.02           | 0.02                        | 11                   |
| 9  | LOI reduction in fly ash by U beam straightening to improve ash circulation rate & by MDC replacement |                               | 307.31                          | 1.96           | 0.63                        | 4                    |



# Energy Savings Projects with No Investment (2017-18)



| SN | Energy Saving Projects  | Saving Achieved         |                           |               |
|----|---|-------------------------|---------------------------|---------------|
|    |   | Electrical Energy (MWH) | Thermal Energy (Ton/Year) | (Rs. Million) |
| 1  | Cooling tower fan temperature control PID set point increased from 30 to 30.5 deg C for power saving. | 10.35                   |                           | .05           |
| 2  | Boiler feed pumps pressure biasing set point reduction from 7 kg/cm2 to 6.3 for power reduction.      | 99.36                   |                           | .45           |
| 3  | Stopped root blower for fluidizing in fly ash silo & used its service air for silo fluidization.      | 12.42                   |                           | .06           |
| 4  | CHP bag filter damper throttling for power reduction.   | 27.60                   |                           | .12           |
| 5  | CEP discharge Condensate line interconnection to reduce heat loss due to make-up water.               |                         | 16                        | .15           |
| 6  | Installation of low pressure compressor for feeding Raw meal powder in to bunker.                     | 20.7                    |                           | .09           |

# Energy Savings Projects with Investment (2017-18)



| SN | Energy Saving Projects   | Saving Achieved         |                           |             | Investment (Rs. Million) | Pay back Month |
|----|--|-------------------------|---------------------------|-------------|--------------------------|----------------|
|    |  | Electrical Energy (MWH) | Thermal Energy (Ton/Year) | Rs. Million |                          |                |
| 1  | Replacement of ACC-1 HDG tube bundles with SRC tube bundles & Improved heat rate of both TG by operating with higher vacuum. (Commissioned in the month of Dec-17) | 296.78                  | 256                       | 3.64        | 42                       | 32             |
| 2  | Installation of VFD in Bed ash cooler fan of Unit-2  | 113.85                  | -                         | 0.51        | .42                      | 10             |
| 3  | 02 Nos Fan blade change in ACC-2 with energy efficient fan blade(Encon.)   | 183.9                   | -                         | 0.83        | .95                      | 14             |
| 4  | Interconnection of Instrument Air with service air & utilizing instrument air compressor with VFD  | 345.0                   | -                         | 1.56        | 0.02                     | 1              |
| 5  | Fly ash recycle to bunker line erection of ESP -1 filed in both boilers.   |                         | 184                       | 1.68        | 0.5                      | 4              |
| 6  | Energy efficient lube oil pump   | 33.12                   |                           | 0.15        | 0.16                     | 13             |


# Project -1# ACC HDG Tube bundle replacement with SRC bundle

## Approach:

- Brainstorming within team & explored opportunity for low cost & efficient alternative technology within & outside India.

## Technology Adoption:

- Approached new technology supplier having ACC-Single Row Condenser (SRC) technology at low cost & high heat transfer efficiency resulting lesser heat & power consumption.
- Heat transfer co efficient:
- MRC-HDG- 26.79 Kcal/M2 Hr deg
- SRC ALE- 36.18 Kcal/M2 Hr deg



# Project -1# ACC HDG Tube bundle replacement with SRC bundle



## ☐ Result Achieved:


### Tangible Benefits-

- Savings of Rs. 24.25 Lacs due to savings in Fuel(for 3 month Jan-March).
- Savings of Rs. 5.26 Lacs due to savings in Aux. Power.

### Intangible Benefits-

- Able to run TG on full load at Peak ambient temperature.
- Capable to fulfil the power requirement of Customer.
- Wheeled Power to Sister Unit.
- Higher Vacuum operation of Turbine.

## Results



- Power requirement for Steam condensing reduced **by 1.06 Kwh/MT.**
- Steam condensation increased **by 0.29 MT/Kwh.**

## Project-2 # Instrument and service air Inter connection for Utilization of maximum VFD drive compressor.

❑ Theme: Capacity Utilization of VFD drive compressor instead of DOL operated service air compressor .


### ❑ Approach:

Brainstorming within team & explored opportunity for:

- Change DOL drive compressor with VFD drive.
- How can get maximum out put of VFD operated and partial loaded instrument compressor.

### ❑ Technology Adoption:

Inter connected both air supply line with control valve and further air pressure obtained for both by individual smart flow controller as according to required process.



# Project-2 # Instrument and service air Inter connection for Utilization of maximum VFD drive compressor.


## □ Result Achieved:

### Tangible Benefits-

- Savings of Rs. 15.6 Lacs due to savings in auxiliary power.

### Intangible Benefits-

- Able to minimize surrounding area noise by running single compressor instead of two.



## Project-3 #ACC fan blade replacement with energy efficient fan blade

Theme: ACC fan replacement with energy efficient fan.

Approach: by Optimizing Fan dia. & no. of Blades

Efficiency  $\eta = Q \times TP$

Q = Airflow (M3 / Second)

TP = Total pressure (Pascal)


Technology Adoption:

1-Selection of High-Grade FRP

2- UV Degradation (Epoxy Resin) Composites

3-Higher dampening property

4-Uniform air flow causing less turbulence and avoid flickering forces on the structure



### Old Design:

- Dimensions of Fan blades at shoulder (590mm), Tip (590mm)
- The blade Tip angle (31 Deg), shoulder (45 Deg)

### New Design:

- Dimensions of Fan blades at shoulder (820 mm) and Tip (290 mm)
- The blade Tip angle (20 Deg), shoulder (40 Deg)

## *Project-3 #ACC fan blade replacement with energy efficient fan blade*



### **Action Taken:**

- Replaced Existing ACC Fan blades with new energy efficient fan blade in Fan - 1 and 4 of Unit-1.

### **Benefit Achieved:**

- Conducted Pre and post flow measurement of ACC Fan in which blades replaced.
- Achieved power consumption reduction by 25% and improvement in flow by 10 % at full speed.
- Resulting saving of Rs. 1.68 Lacs per annum per ACC fan.


.




# Utilization of renewable energy sources

## Usage of renewable energy for lighting at TPP HSD Area:


- *Installed Solar Power Generation at HSD area : 1000Watts*
- *Solar energy : 0.04 % of total power share*



# GHG Inventorisation



# Green Belt Development (Plant, Colony & Mines)



Developed 34% area at Plant/Colony and 61% area at Mines  
as Green Belt against the statutory requirement of 33%.  
Cumulative Survival rate = 91%

# Green Belt Development & environment initiatives



Sapling Distribution to Villagers



Green Belt Development



Ground water recharging through injection well



Recognition of student by UH on occasion of Environment day

# Daily monitoring system

| KCW TPP Daily Report       |                              |          |          |           |        |          |        |         |         |          |          |          |           |
|----------------------------|------------------------------|----------|----------|-----------|--------|----------|--------|---------|---------|----------|----------|----------|-----------|
|                            |                              | Date     |          | 15-Aug-18 |        | 4/1/2018 |        |         |         |          |          |          |           |
|                            |                              | Budget   |          | Today     |        |          |        |         |         | YTD      |          |          |           |
| Parameters                 | Units                        | Unit-1   | Unit-2   | Unit-1    | Unit-2 | Total    | Unit-1 | Unit-2  | Total   | Unit-1   | Unit-2   | Total    |           |
| <b>A Plant Performance</b> |                              |          |          |           |        |          |        |         |         |          |          |          |           |
| 1                          | Availability Factor          | %        | 75.6     | 100.0     | 100.0  | 100.0    | 100.0  | 100.0   | 100.0   | 84.7     | 95.0     | 89.9     |           |
| 2                          | STG Running Hours            | Hrs      | 744      | 744       | 24.00  | 24.0     | 48.0   | 360.00  | 360.00  | 2786.0   | 3009.8   | 5795.8   |           |
| 3                          | Plant Load Factor            | %        | 81.0     | 78.0      | 83.97  | 79.18    | 81.57  | 90.17   | 79.29   | 84.73    | 79.46    | 77.41    | 78.44     |
| 4                          | Gross Generation             | KWh      | 13868966 | 13347360  | 463488 | 437064   | 900552 | 7465921 | 6564872 | 14030793 | 50919425 | 53587663 | 104507088 |
| 5                          | Aux Consumption              | KWh      | 1241272  | 1161220   | 35408  | 32928    | 68336  | 548361  | 516762  | 1065123  | 4284396  | 4637403  | 8921799   |
|                            |                              | %        | 9.0      | 8.7       | 7.65   | 7.55     | 7.60   | 7.34    | 7.87    | 7.591    | 8.38     | 8.62     | 8.502     |
| 6                          | Shut Down Power              | Kwh      |          |           | 0      | 0        | 0      | 0       | 0       | 129726   | 75680    | 205406   |           |
| 7                          | Aux. Power from Cement Plant | Kwh      |          |           | 65     | 65       | 130    | -28     | -28     | -56      | -18183   | -18183   | -36366    |
| 8                          | Aux. power including SD      |          |          |           | 7.65   | 7.55     | 7.60   | 7.34    | 7.87    | 7.591    | 8.63     | 8.76     | 8.699     |
| 9                          | Net Generation               | MWh      | 12627694 | 12186140  | 428015 | 404071   | 832086 | 6917588 | 6048138 | 12965726 | 46523486 | 48892763 | 95416249  |
| 10                         | Average Load                 | MW       | 18.64    | 17.94     | 19.31  | 18.21    | 37.52  | 20.74   | 18.24   | 38.97    | 18.28    | 17.80    | 36.08     |
| 11                         | TG1/L Steam                  | MT       | 60191    | 56326     | 1960   | 1853     | 3813   | 31626   | 27941   | 59567    | 219289   | 226812   | 446101    |
| a                          | Steam from Boiler-1          | MT       |          |           | 1960   | 0        | 1960   | 31626   | 0       | 31626    | 219289   | 13987    | 233276    |
| b                          | Steam from Boiler-2          | MT       |          |           | 0      | 1853     | 1853   | 0       | 27941   | 27941    | 0        | 212825   | 212825    |
| 12                         | Sp. Steam Cons               | Kg/kwh   | 4.34     | 4.22      | 4.23   | 4.24     | 4.23   | 4.24    | 4.26    | 4.25     | 4.31     | 4.23     | 4.27      |
| 13                         | Turbine Heat Rate            | Kcal/KWH | 2643     | 2612      | 2632   | 2647     | 2639   | 2622    | 2653    | 2636     | 2674     | 2631     | 2652      |
| 14                         | Station Heat Rate            | Kcal/KWH | 3015     | 2980      | 3001   | 3017     | 3009   | 2990    | 3024    | 3005.68  | 3053     | 3000     | 3026      |
| 15                         | SFC                          | Kg/kwh   | 0.41     | 0.41      | 0.41   | 0.41     | 0.41   | 0.41    | 0.41    | 0.41     | 0.43     | 0.42     | 0.43      |
| 16                         | Vacuum                       | Kg/Cm2   | -0.8     | -0.81     | -0.82  | -0.81    | -0.82  | -0.80   | -0.60   | -0.71    | -0.78    | -0.77    | -0.78     |

Energy calculation sheet

4\_BOILER

ADITYA BIRLA

UltraTech

KCW-I 23 MW,UTCL

PLANT PERFORMANCE CALCULATIONS

BOILER

ABB

INDEX

MAN I/P

BOILER

HEATRATE


TURBINE

HEATERS

SANKEY

DRIVES

KCW-II



LOAD **15.79 MW**

TURBINE HEAT RATE **2674.19 kcal/kwh**

PLANT GROSS HEAT RATE **3058.68 kcal/kwh**

UNIT EFFICIENCY **28.12 %**

**BOILER PERFORMANCE**

LOSSES DUE TO

|                             |        |
|-----------------------------|--------|
| UNBURNT CARBON              | 0.68 % |
| DRY FLUE GAS                | 4.28 % |
| MOISTURE IN FUEL            | 0.55 % |
| HYDROGEN IN FUEL            | 4.23 % |
| MOISTURE IN AIR             | 0.15 % |
| RADIATION                   | 0.75 % |
| SENSIBLE HEAT OF BOTTOM ASH | 0.25 % |
| SENSIBLE HEAT OF FLY ASH    | 0.08 % |
| CO IN FLUE GAS              | 0.3 %  |
| LIMESTONE LOSSES            | 0.3 %  |

TOTAL LOSSES **12.57 %**

**BOILER EFFICIENCY 87.43 %**

107.72 bar (a)

74.77 t/hr

195.2 deg c


199.56 kcal/kg

On line boilers losses calculation

# Daily monitoring system




On line Efficiency monitor




On line drive efficiency calculation

# Review meeting chaired by

- Well Established energy management cell headed by FH-TPP.
- Daily monitoring of Heat rate and Aux. power deviation report.
- Analysis of equipment performance for deviation.
- Identification of energy conservation scope.
- Theme base suggestions/Kaizens scheme under “Energy Saving”.
- Feasibility study of suggestions & submit proposal for sanction.
- Preparation of detail action plan.
- Benefits analysis after project implementation.



# *Methodology for identification of improvement projects*





# Project implementation through Kaizen



Suggestion and kaizen steps



Manthan program for idea sharing



Kaizen Award



Kaizen Submission

# Project Implemented through workers and supervisor



| SN | Idea   | Status    |
|----|--|-----------|
| 1  | Reduction of boiler bottom ash loss by provided extra air pressure to spreading air for uniform fuel spreading in to furnace.  | Completed |
| 2  | MDC RAV shaft sealing cold air provided by PA fan out let in place utilization of compressed. So power saving of compressor.   | Completed |
| 3  | Coal circuit stand by stream suction damper isolation during running of main circuit. Power saving of bag filter.              | Completed |
| 4  | Pushing air provided to Fly ash conveying system for avoiding line jamming and avoiding continuous utilisation of service air. | Completed |
| 5  | Utilization of ESP fist field Ash to coal bunker for recycle and reduction of LOI  | Completed |

# Implementation of ISO 50001



ISO  
50001

2015

Energy Management



## DNV BUSINESS ASSURANCE MANAGEMENT SYSTEM CERTIFICATE

Certificate No. 172280-2015-AE-IND-RvA

*This is to certify that*

### **UltraTech Cement Limited (Unit : Kotputli Cement Works)**

Village: Mohanpura, Tehsil: Kotputli,  
Dist. Jaipur, 302002, Rajasthan, India

*has been found to conform to the Energy Management System Standard:*

**ISO 50001:2011**

*This Certificate is valid for the following Scope:*

**Manufacture of cement and clinker.**

*Initial Certification date:*  
9 March 2015

*This Certificate is valid until:*  
9 March 2018

*The audit has been performed under the supervision of:*  
**Hitesh Dhandhusaria**  
Lead Auditor



*Place and date:*  
Barendrecht, 9 March 2015

*For the issuing office:*  
DET NORSKE VERITAS CERTIFICATION B.V.,  
Zwolsseweg 1, 2994 LB Barendrecht, The Netherlands

**B. Poldermans**  
Management Representative

Lack of fulfilment of conditions as set out in the Certification Agreement may render this Certificate invalid.  
Accredited Unit: Det Norske Veritas Certification B.V. Zwolsseweg 1, 2994 LB Barendrecht, The Netherlands, TEL: +31 10 2922 688 - www.dnvba.com

# Energy Management System Policy



## ULTRATECH CEMENT LIMITED UNIT: KOTPUTLI CEMENT WORKS ENERGY MANAGEMENT POLICY

*We are committed to demonstrate excellence in Energy performance in all our activities of manufacturing of cement and clinker on a continual basis so as to make our operations environmentally sustainable for future.*

*We shall achieve this by :*

- *Monitoring and control of energy consumption through effective energy management system and periodic energy audit.*
- *Continuous up-gradation of process with energy efficient and ecofriendly technology, support the purchase of energy efficient product, services and design, for continual improvement of Energy performance.*
- *To ensure the availability and providing information & resources to promote and propagate energy awareness among all employees to achieve objective and targets.*
- *Recognizing efforts of our employees in energy conservation initiatives.*
- *Benchmarking our performance with best and striving to beat the best.*
- *Meeting all statutory & legal requirements and other requirements.*

*Revision No.: 02*



*Unit Head*  
*Date: 10/11/2014*

# Awards & Accolades



# Awards & Accolades



**"National Energy conservation Award" In "Excellent Energy Efficient Unit" In "Excellent Energy Efficient Unit" year 2017.**



**"Noteworthy water efficient unit" In year 2017. "Excellent Energy Efficient Unit" in year 2015. "Noteworthy water efficient unit" In year 2016.**

# Awards & Accolades



**“Rajasthan Energy Conservation” in year 2014.**



**“Energy Efficient Unit ” In year 2013.**



**“Water Efficient Unit” in year 2012.**



**“Excellent Energy Efficient Unit ” In year 2014.**



**Commendation Certificate by the Ministry of Power, Government of India in recognition of efforts made to conserve the energy for year 2012-13**



*The less you burn, the more you earn.*



Sincere Thanks..  
**UltraTech Cement Ltd**  
**Kotputli Cement Works**  
**Power Plant**

