

## User Guidance Notes Submission of HP data

#### 1 Introduction

These Guidance Notes have been prepared to explain how to submit data to the Energy Networks Association (ENA) for inclusion in the ENA Heat Pump (HP) and Electric Vehicle Charge Point (EVCP) Databases.

These Guidance Notes should be read in conjunction with the Low Carbon Technologies (LCT) Application Form and associated Process Flow Chart.

#### 2 Scope

It is assumed that the equipment is intended for connection to a Low Voltage (LV) electricity distribution system; values quoted in amperes (A) assume this.

#### **3** Purpose of Databases

The purpose of the ENA Heat Pump (HP) and Electric Vehicle Charge Point (EVCP) Databases are to simplify the application process for the connection of LCT to Distribution Network Operator (DNO) or Independent Distribution Network Operator (IDNO) electricity distribution networks.

HPs and EVCPs are viewed as equipment that have the potential to disturb the quality of voltage provided to DNO/IDNO customers. The intention is to hold the technical information in a database that is necessary for DNOs/IDNOs to design connection to their networks. This allows for customers to use a simplified application form that refers to the make and model proposed, reducing the technical information that has to be submitted on the Application Form with each connection application.

#### 4 Data submission

Data shall be submitted electronically by email using a copy of the relevant Microsoft Excel spreadsheet (for example, 'ENA Heat Pump Database Draft revXXX'), with accompanying supporting information attached to the email (see Table 1).

Contact	Energy Networks Association	
Email	innovation@energynetworks.org	
Telephone	+44 (0) 20 7706 5100	

#### Table 1 – Contact Information



### **5** Common principles of EMC testing

#### 5.1 General

The EMC Directive<sup>1</sup> applies to most manufactured products that contain electrical and electronic components. The EMC Directive covers exclusively the electromagnetic compatibility of equipment. It does not apply to 'inherently benign equipment'.

Inherently benign equipment is defined as equipment that does not generate or contribute to the electromagnetic emissions. Some examples of equipment which are inherently benign include, but not limited to,

- Cables
- Equipment containing only resistive loads that are not automatically controlled e.g. not controlled by a thermostat
- Batteries

1

• Electromagnetic relays without active electronic parts

It is the manufacturer's responsibility to apply the appropriate method for EMC assessment and the manufacturer shall prove compliance to the relevant EMC assessment standards.

All intended operating conditions shall be assessed in line with the EMC standards. It is the manufacturer's responsibility to declare all possible operating configurations are representative of normal use and meet the essential requirements.

The manufacturer is responsible for identifying the "worst case" configuration and shall be declared in the relevant documentation.

All HPs and EVCPs are considered to include components which require assessment against the EMC assessment standards. The EMC assessment standards that apply to any equipment that is capable of producing harmonics and that causes flicker are,

- 1. BS EN 61000-3-2 Electromagnetic compatibility (EMC). Limits. Limits for harmonic current emissions (equipment input current ≤16 A per phase).
- BS EN 61000-3-3 Electromagnetic compatibility (EMC). Limits. Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection.
- BS EN 61000-3-11 Electromagnetic compatibility (EMC). Limits. Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems. Equipment with rated current ≤ 75 A and subject to conditional connection.
- BS EN 61000-3-12 Electromagnetic compatibility (EMC). Limits. Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current > 16 A and ≤ 75 A per phase.

Energy Networks Association 1<sup>st</sup> Floor, 4 More London Riverside, LONDON SE1 2AU

T +44 (0)20 7706 5100 E info@energynetworks.org W www.energynetworks.com Follow us on Twitter @EnergyNetworks Energy Networks Association Ltd is a company registered in England & Wales. No. 04832301



For equipment > 75 A per phase the following is relevant,

- For harmonics, data shall be determined in accordance with the requirements of BS EN 61000-3-12 or BS EN 6100-3-4 (BS EN 61851-21-2 is relevant for EVCPs). The data shall be used for an assessment is accordance with against ENA EREC G5/5.
- For flicker and voltage fluctuation, data shall be determined in accordance with the requirements of BS EN 61000-3-11. The data shall be used for an assessment in accordance with ENA EREC P28.

#### 5.2 Harmonic Assessment

Harmonics are caused by non-linear loads that affect the power quality of the network. Harmonics cause a distortion in the current and voltage waveforms. This leads to:

- Network voltage wave shape distortion
- Failures in compensation systems
- Overheating in electrical engines and transformers
- Failures in sensitive electronic devices, such as semi-conductors and power electronics
- Difficulties and abrasions in insulation levels of equipment
- Increased losses in the system
- Maloperation of the protection and control systems of electrical networks
- Increase in acoustic noise and induced noise (telephone buzzing).

Therefore, it is vital to understand the harmonic current emissions produced by the equipment to ensure minimal disruption to the network and put in place reinforcements where required.

To carry out harmonic assessments in accordance with the relevant EMC assessment standards, the basic components required are:

- 230V/400V ac power source with a low impedance (Z<sub>s</sub>)
- Harmonic analyser
- The equipment under test (EUT)


The test circuit is shown in Figure 1 below, where:

S - power supply source consisting of,

- G open-loop voltage of the supply source
- Z<sub>s</sub> internal impedance of the supply source
- M measurement equipment (harmonic analyser) consisting of,
  - Z<sub>M</sub> input impedance of measurement equipment



- EUT Equipment Under Test
- $I_{h}$  harmonic component of order h of the line current
- U test voltage



#### Figure 1 - Harmonic measurement circuit for single-phase equipment

BS EN 61000-3-2 requires the source voltage U to be stable to within ±2% of the rated voltage of the EUT and the frequency to remain stable within 0.5% of nominal. The impedance  $Z_M$  should create a voltage drop of less than 0.15V and the total impedance  $Z_S$  and  $Z_M$  should cause negligible variation in the load current.

BS EN 61000-3-2 only allows direct measurement of harmonic currents using the equipment stated above. However, BS EN 61000-3-12 provides two methods that can be used to measure harmonic currents.

- 1. Direct measurement
- 2. Calculation by valid simulation

#### 5.2.1 Direct measurement

Typically, the direct measurement is predominantly used to measure harmonic currents.

Prior to measuring the harmonic currents, the following test conditions need to be adhered to:

- Harmonic current emission tests shall be conducted with the operation controls or automatic programs set to produce the maximum total harmonic current (THC) under normal operating conditions.
- The ambient temperature shall be at a level resulting in greater than 90% of the maximum THC under normal operating conditions.
- Or a special test mode shall be used which results in a load condition exceeding 90% of the maximum THC. This special test mode may bypass the normal control settings and allow the testing authority to operate at or near maximum rated current.
- If the above is not achievable or practical the manufacturer shall specify a test temperature that results in a THC of greater than 70% of the maximum THC.



- The temperature control shall be set to the lowest temperature in the cooling mode and to the highest temperature in the heating mode.
- The most onerous configuration shall be sought and the results declared in the test report.

In order to comply with the harmonic limits specified in BS EN 61000-3-12, the manufacturer shall choose a trial value of  $R_{sce}$  ( $R_{sce min}$ ), based on the knowledge of the product design. The  $R_{sce}$  is defined as the short circuit ratio of a piece of equipment. If compliance is not achieved with the trial value  $R_{sce min}$ , a higher value of  $R_{sce min}$  shall be chosen and the test repeated, until a value of  $R_{sce min}$  is found that achieves compliance.

For equipment  $\leq$  75 A per phase, harmonic current components should be measured from the 2<sup>nd</sup> and up to the 40<sup>th</sup> harmonic order in accordance with the Note in Clause 7.3 of BS EN 61000-3-12. The manufacturer shall also declare the results for the most onerous condition.

Test conditions are described in BS EN 61000-3-12.

For equipment > 75 A per phase, harmonic currents should be measured up to the  $50^{\text{th}}$  harmonic order to satisfy the assessments required by ENA EREC G5/5. This also requires the device to be tested at 10% intervals of its rating to enable the discovery of the most onerous power output.

#### 5.2.2 Calculation by valid simulation

An appropriate software modelling tool is required to simulate the harmonic emission from a device. This requires close attention to the representation of the device within the model and setting of supply characteristic parameters – this is beyond the scope of this guidance document.

#### 5.2.3 BS EN 61000-3-2 and BS EN 61000-3-12 relationship

The harmonic limits for Class A BS EN 61000-3-2 are more onerous than BS EN 61000-3-12 and devices rated > 16 A and  $\leq$  75 A per phase are not expected to be compliant with BS EN 61000-3-2, BUT some may be because their harmonic emissions are low. Indeed, a proposed amendment (19/30400445) to BS EN 61000-3-12 indicates that the manufacturer can comply with the absolute limits given in BS EN 61000-3-2, Table 1, instead of the proportional limits given in BS EN 61000-3-12. Class A includes equipment such as balanced three-phase equipment, household appliances and audio equipment. The harmonic limits are a ratio of the actual harmonic current and reference current  $I_{ref}$ .

Identifying equipment as meeting the limits in BS EN 61000-3-2 has the advantage of confirming emissions are low and no detailed network study is needed for harmonics. In addition, equipment complying with BS EN 61000-3-2 are subject to an unconditional connection, and can follow the notification process i.e. connect and notify.

Equipment which is compliant with BS EN 61000-3-12 is subject to conditional connection meaning a particular impedance is required on the electricity network. The value of the impedance is dependent on the short-circuit ratio  $R_{sce}$ . BS EN 610000-3-12 allows different values of  $R_{sce}$  to be applied during assessment. For equipment complying with BS EN 61000-3-12, it is inferred that  $R_{sce}$  = 33.

For equipment not complying with the harmonic current emission limits corresponding to  $R_{sce}$  = 33, the manufacturer shall:

Energy Networks Association 1<sup>st</sup> Floor, 4 More London Riverside, LONDON SE1 2AU

T +44 (0)20 7706 5100 E info@energynetworks.org W www.energynetworks.com Follow us on Twitter @EnergyNetworks Energy Networks Association Ltd is a company registered in England & Wales. No. 04832301



- determine the minimum value of R<sub>sce</sub> for which the limits given are not exceeded, and;
- declare the value of the short-circuit power  $S_{sc}$  corresponding to this minimum value of  $R_{sce}$  and instruct the installer to ensure that the equipment is connected only to a supply of that  $S_{sc}$  value or more.

Note: It is the DNO's responsibility to ensure the impedance value is achievable at the PCC.

#### 5.3 Flicker and Fluctuation Testing

The current drawn from an electrical equipment can cause its voltage to change, fluctuate or flicker due to the impedance of the network. Flicker is the term used for rapid voltage fluctuations. Flicker can cause lights to change in luminance but also have an adverse effect on people's health, causing fatigue, lack of concentration, migraines and in some cases, epileptic shock. Besides the health-related issues, flicker can cause nuisance tripping of equipment because of the maloperation of control and protection circuits.

BS EN 61000-3-3 applies to equipment up to 16A per phase that is not subject to conditional connection. Compliance with the EMC Directive is a requirement for all electrical equipment that will be connected to the low voltage network.

Equipment which complies with the requirements of BS EN 61000-3-3, even if it consumes between 16A and 75A per phase, is deemed to comply with both BS EN 61000-3-3 and EN 61000-3-11 and is not subject to conditional connection.

Equipment that does not comply with the limits in BS EN 61000-3-3 must be declared compliant with BS EN 61000-3-11 and be subject to conditional connection.

BS EN 61000-3-3 declares the reference impedance to be used when measuring the voltage fluctuations at the supply terminals of the equipment under test.

Single Phase	$Z_{ref} = 0.4 + j0.25 \Omega$
Split Phase	$Z_{ref} = 0.48 + j0.3 \ \Omega$
Three Phase	Z <sub>ref</sub> = 0.24 + j0.15 Ω

The voltage fluctuations are then analysed for comparison to the limits. The limits are placed on three factors:

- The relative voltage change (maximum d<sub>max</sub> and steady-state d<sub>c</sub>)
- The short-term flicker value Pst
- The long-term flicker value P<sub>lt</sub>

#### Table 2 – Limits of voltage fluctuations and flicker

	Pst	Pit	d(t)	dc	d <sub>max</sub>
Limit	1	0.65	3.3% for more than 500ms	3.3%	4% without additional conditions

Energy Networks Association 1<sup>st</sup> Floor, 4 More London Riverside, LONDON SE1 2AU

T +44 (0)20 7706 5100 E info@energynetworks.org W www.energynetworks.com Follow us on Twitter @EnergyNetworks Energy Networks Association Ltd is a company registered in England & Wales. No. 04832301



	6% for equipment switched manually or switched automatically more than twice a day	
--	--	--

Note:  $P_{st}$  and  $P_{lt}$  do not apply to manual switching or voltage fluctuations occurring less frequently than once per hour. However, the  $d_{max}$  and  $d_c$  does apply for such occasional events and this places a limit on the allowable switch-on inrush current for any equipment.

The manufacturer has two options for specifying conditional connection,

- Determine and declare the maximum permissible system impedance Z<sub>max</sub> at the supply terminals of the user's supply i.e. at the 'cut-out'. This is done by calculating the a.c. supply system impedance that would be required for the equipment's current fluctuations to cause voltage fluctuations that met the limits. This is based on knowing the values of various tested parameters when tested with one system impedance and using that information to calculate the impedance that would be required to actually meet the limits.
- 2. Test the equipment as is done for BS EN 61000-3-3 but with a lower a.c. supply system impedance and declare that the equipment is intended for use only in premises having a service current capacity of ≥ 100A per phase, which equates to:

Single Phase  $Z_{max} = 0.25 + j0.25 \Omega = 0.354 \Omega$ Three Phase  $Z_{max} = 0.15 + j0.15 \Omega = 0.212 \Omega$ 

Fluctuation and flicker can be measured directly or calculated.

#### 5.3.1 Direct measurement

To carry out fluctuation and flicker tests in accordance with the relevant EMC standards, the basic instrumentation is essentially the same as the harmonic analyser used for testing to BS EN 61000-3-2 and therefore the harmonics and flicker analysers are often packaged together.




Figure 2 - Voltage fluctuations and flicker measurement circuit



#### 5.3.2 Calculating flicker and fluctuation

To calculate flicker and fluctuation, the maximum voltage change  $d_{max}$  needs to be determined (difference between the maximum and minimum r.m.s voltage change). To calculate  $d_{max}$ , knowledge of the system power rating, starting current, form factor and starting sequence are required. For each start/step, the maximum voltage change is determined. The highest value of  $d_{max}$  from the sequence is then chosen. This  $d_{max}$  value is used to calculate short-term flicker  $P_{st}$ . The long-term flicker  $P_{lt}$  is calculated using successive values of  $P_{st}$ .

If the values of either  $d_{max}$ ,  $P_{st}$  and  $P_{lt}$  are above the limits stated in Table 2 then the manufacturer should re-test using a lower test impedance  $Z_{test}$ .

For a single-phase equipment,

 $Z_{\text{test}} = 0.25 + j0.25 \Omega = 0.354 \Omega$ 

For three phase equipment,

$$Z_{\text{test}} = 0.15 + j0.15 \Omega = 0.212 \Omega$$

If the values of  $d_{max}$ ,  $P_{st}$  and  $P_{lt}$  are within the limits using the lower impedance, the manufacturer shall declare compliance to BS EN 61000-3-11 but state the service capacity required has to be greater than or equal to 100A per phase.

If the values of  $d_{max}$ ,  $P_{st}$  and  $P_{lt}$  are above the limits using the lower impedance, the manufacturer shall then determine and declare the maximum permissible system impedance  $Z_{max}$  at the supply terminals of the user's supply.

#### 5.3.3 BS EN 61000-3-3 and BS EN 61000-3-11 relationship

BS EN 61000-3-11 is a companion standard to BS EN 61000-3-3 and uses the same tested parameters and flickermeter. However, BS EN 61000-3-11 applies to equipment that require a conditional connection.

#### 6 Heat Pump Systems

#### 6.1 Overview of typical systems

A heat pump can operate in many different configurations. The table below summarises typical heat pump systems that are installed.

Configuration	Schematic	Description
Heat pump only		A simple heat pump unit with no additional heating elements.



Heat pump + 'onboard' associated DERH	A heat pump with an onboard DERH that can provide additional heating when required. Both the heat pump and DERH are tested together as a whole system.
Heating pump + 'external' associated DERH	A heat pump that makes use of an external DERH. The external DERH may be tested with the heat pump or tested individually.
Outdoor heat pump and indoor heat pump	Two heat pumps that are connected together but make use of two different refrigerants.

#### 6.2 Terms and Definitions

#### 6.2.1

#### direct electric resistance heater (DERH)

#### 6.2.1.1

#### associated DERH

module which is configured as part of the heat pump system design or system installation and may be located either internally or externally to the heat pump module.

#### 6.2.1.2

#### replacement heater

DERH that is capable of replacing all or some of the heat output from the heat pump in the event of the heat pump not being operational. This type of heater will only operate in the event of heat pump failure.

#### 6.2.1.3

#### water heater or 'immersion heater'

DERH located in the domestic hot water cylinder and used to top-up heat from the heat pump

#### 6.2.2

#### heat pump system

heat pump technology, including all associated DERH where applicable, that is installed and operated under a single controller



#### 6.2.3

#### Rated power (S<sub>equ</sub>)

input power of the piece of equipment as declared by the manufacturer and marked as such on the rating plate of the piece of equipment or stated in the product documents

#### 6.3 Heat Pump spreadsheet for data submissions

The spreadsheet for data submissions comprises the following Worksheets:

- A1 Summary Data worksheet
- A2 Data ≤16A worksheet
- A3 Data ≤75A harmonics worksheet
- A4 Data ≤75A (d, e, f) harmonics worksheet<sup>2</sup>
- A5 Data >75A harmonics worksheet
- A6 Data ≤75A fluctuations worksheet
- A7 Data >75A fluctuations worksheet
- A8 Data >16A harmonics worksheet3

Data descriptions for each data field are provided in Tables A1-A8 of Annex A.

The flowchart in Figure 3 illustrates which worksheets to complete based on equipment rating.

The data for heat pump systems provided by manufacturers may relate to the whole system or one or more parts/modules of the system. Worksheet A1 has a drop-down list in column O to enable summary data to be entered for each module in a separate row. Worksheets A2 to A8 are for provision of supporting data; it may be necessary to replicate one or more of these worksheets so that the supporting data for each module can be provided.


<sup>&</sup>lt;sup>2</sup> This sheet is provided for equipment types meeting Table 5 specified conditions (d), (e) and (f) in BS EN 61000-3-12.

<sup>&</sup>lt;sup>3</sup> This sheet is provided for use in conjunction with sheet A3 and A4 to provide data in support of the claim for connection design purposes of compliance with the Class A emission limits of BS EN 61000-3-2 despite the equipment being out of scope of that standard.

Energy Networks Association 1<sup>st</sup> Floor, 4 More London Riverside, LONDON SE1 2AU

T +44 (0)20 7706 5100 E info@energynetworks.org W www.energynetworks.com Follow us on Twitter @EnergyNetworks Energy Networks Association Ltd is a company registered in England & Wales. No. 04832301





NOTE: IEC 61000-3-2/12 are the same as BS EN 61000-3-2/12. Likewise, IEC 61000-3-3/11 are the same as BS EN 61000-3/11.

#### Figure 3 - Heat Pump data submission process

#### 6.4 Different Modes of Operation (Heating only, Heating and Cooling)

#### 6.4.1 General

Heat pumps can be installed to operate in either heating mode, or heating and cooling modes. A heat pump system that could be installed as "heating only" and "heat and cooling" will require separate submissions by the heat pump manufacturer.

NOTE: The test report shall include all harmonic and fluctuation/flicker data for all modes being considered to enable the most onerous emissions to be declared on the submission.

Energy Networks Association 1<sup>st</sup> Floor, 4 More London Riverside, LONDON SE1 2AU

T +44 (0)20 7706 5100 E info@energynetworks.org W www.energynetworks.com Follow us on Twitter @EnergyNetworks Energy Networks Association Ltd is a company registered in England & Wales. No. 04832301



When compiling the data for such submissions there are a number of pertinent considerations which are described below.

#### 6.4.2 Current ratings and emissions

In the Summary Sheet A1, the rated current for each load shall be entered. The value entered shall be as declared by the manufacturer and marked as such on the rating plate of the piece of equipment, or as stated in the product documents. The maximum current demand may differ from the rated current demand, as it may reflect current demand of the system under extreme conditions. Where the maximum current demand differs from the rated current it should be stated. Figure 4 shows a typical display of rating information for a heat pump.


The linear and non-linear load should be separately identified so the host DNO can determine the connection requirement appropriately i.e. the connection requirement can be determined for the non-linear load only.

NOTE 1: Depending on the design of the heat pump system, the total rated current for the system is typically the sum of all the modules rated currents. Where a module is interlocked with another, the current rating is not the sum of the modules, rather the rating of the module with the highest current draw.

Туре	Type Designation:	
Power supply 1	Rated Voltage	230V~ 1ф 50Hz
(Heat Pump)	Current / Power	29.0A / 6.27kW

#### Figure 4 – Example of rated current as declared in an EMC test report

#### Figure 5 – Example of rated current entered in the Summary Sheet A1



For devices rated above 16 A and below 75 A, harmonic emission data shall be entered in Sheet A3 (Sheet A4 required in special cases). In Sheet A3, two particular values of current required are defined in BS EN 61000-3-12 as follows:

 I<sub>equ</sub> "Input current of the piece of equipment as declared by the manufacturer and marked as such on the rating plate of the piece of equipment or stated in the product documents"

This value  $(I_{equ})$  is typically the rated current for the module as entered in Sheet A1. However,  $I_{equ}$  may differ (be lower) from the rated current due to the particular operating mode for the device.

T +44 (0)20 7706 5100 E info@energynetworks.org W www.energynetworks.com Follow us on Twitter @EnergyNetworks Energy Networks Association Ltd is a company registered in England & Wales. No. 04832301



• I<sub>ref</sub> "value of the r.m.s. input current of the equipment determined according to 4.1 and used to establish emission limits"

The reference current  $I_{ref}$  shall be determined during the test and stated in the EMC report.

Considering an example, the value of  $I_{equ}$  is declared in the EMC test report and is dependent on the mode of operation i.e. a heat pump for different modes of operation may have different  $I_{equ}$  values. The EMC report will provide harmonic emission data for all modes of operation being considered. The data to be captured in the submission shall be the most onerous emission data associated with relevant modes of operation.

Where the value of  $I_{equ}$  and  $I_{ref}$  differ, the manufacturer should include a note to explain the difference. For example, the most onerous condition may not be at the rated current  $I_{equ}$  or the  $I_{ref}$  used may be due to the limit of the testing device.

Figures 6 and 7 show the  $I_{equ}$  values for a heat pump with a cooling mode and heating mode which are 17.24 A and 17.45 A respectively.

NOTE 2: The most onerous mode of operation for harmonics is not necessarily the mode with the highest current draw, but rather the mode with the highest current values for each harmonic order. The percentage harmonic current is affected by  $I_{ref}$  (a smaller  $I_{ref}$  increases the percentage vales).

<u>ltem</u>	<u>Rsce</u>	<u>Remarks</u>	Calculation:			
<b>I</b> 3	113.2957		THD(%)	=	30,686	
15	69.1941		I <sub>equ</sub> = I <sub>1</sub> X (1+THD <sup>2</sup> ) <sup>1/2</sup>	=	17.24	A
17	-183.4553		Up (rated voltage)	=	230.00	V
<b>l</b> 9	99.1635		S <sub>equ</sub> = U <sub>p</sub> X I <sub>equ</sub>	=	3964.60	W
I <sub>11</sub>	-103.7263					
I <sub>13</sub>	67.2817		S <sub>sc</sub> = R <sub>sce</sub> X (3 X S <sub>equ</sub> )	=	1536031.21	W
THD	129.1455	Max selected	(Additional 10% + rounded		1700	kW
PWHD	-150.1186		To nearest 50kW)			

Figure 6 – Example of I<sub>equ</sub> for Cooling

Figure 7 – Example of Iequ for Heating

<u>ltem</u>	<u>Rsce</u>	<u>Remarks</u>	Calculation:			
l <sub>3</sub>	110.3326		THD(%)	=	30.435	
l <sub>5</sub>	65.3072		I <sub>equ</sub> = I <sub>1</sub> X (1+THD <sup>2</sup> ) <sup>½</sup>	=	17.45	A
17	-183.5631		Up (rated voltage)	=	230.00	V
19	95.1321		S <sub>equ</sub> = U <sub>p</sub> X I <sub>equ</sub>	=	4014.47	W
l11	-105.0434					
I <sub>13</sub>	65.0560		S <sub>sc</sub> = R <sub>sce</sub> X (3 X S <sub>equ</sub> )	=	1515065.27	W
THD	125.8002	Max selected	(Additional 10% + rounded		1650	kW
PWHD	-151.4482		To nearest 50kW)			

Therefore, having determined the most onerous emissions for each mode, the value in cell D38 of Sheet A3 ( $I_{equ}$ ) for the heating & cooling mode shall be equal to 17.24 A, and for the heating only mode shall be equal to 17.45 A.

#### Figure 8 – Capturing $I_{equ}$ from Figure 6 and Figure 7

Energy Networks Association 1<sup>st</sup> Floor, 4 More London Riverside, LONDON SE1 2AU

T +44 (0)20 7706 5100 E info@energynetworks.org W www.energynetworks.com Follow us on Twitter @EnergyNetworks Energy Networks Association Ltd is a company registered in England & Wales. No. 04832301



Phase	L1	F	Phase	L1
	Current (A)	· .		Current (A)
	current (A)			Current (A)
l <sub>equ</sub>	17.24	1	equ	17

Similarly, for the reference current, the heating & cooling mode shall be equal to 16.479 A, and 16.698 A for the heating only mode, as described in the EMC test report. This shall be entered into cell D39 Sheet A3 ( $I_{ref}$ ) for the two separate submissions.

Reference of	current, I <sub>ref</sub>	:	16.698A (I	Heating),16.47	'9A (Cooling)
I <sub>ref</sub>	16.479	_	I <sub>ref</sub>	16.698	

The third and last value of current required in Sheet A3 (cell D42) is the 'RMS' current, which is defined in BS EN 61000-3-12 as:

 $I_{RMS}$  "The manufacturer may specify any value of r.m.s. current which is within ± 10 % of the actual measured value and use it as the reference current for the original manufacturer's conformity assessment test."

The RMS current value is normally ascertained by reviewing the EMC test report: it is typically stated within the harmonic current values table as the fundamental (order 1) harmonic value.

#### Figure 9 - Example of RMS Current for different modes

Average harmonic current results				Harmo	nic current res	ults - DS: 1716
	Hn	leff [A]	leff [%]	Hn	leff [A]	leff [%]
	1	15.689	95.206	1	15.826	94.777

	Current (A)	I <sub>h</sub> /I <sub>ref</sub> (%)		Current (A)	I <sub>h</sub> /I <sub>ref</sub> (%)
RMS	15.689	95.21	RMS	15.826	94.78

Having captured  $I_{equ}$ ,  $I_{ref}$  and  $I_{RMS}$  current values, the last requirement is to provide individual harmonic values. The individual harmonic values shall be from the 2<sup>nd</sup> up to and including the 40<sup>th</sup> harmonic, or up to and including the 50<sup>th</sup> harmonic, if possible, for each of the operating modes. At this point, the data submission requirements will have been met.

#### 6.5 Heat Pumps with associated DERH

The system may consist of a heat pump and associated direct electric resistance heater (DERH), which may or may not be powered separately, together forming the heating circuit and operated by one control system.

T +44 (0)20 7706 5100 E info@energynetworks.org W www.energynetworks.com Follow us on Twitter @EnergyNetworks Energy Networks Association Ltd is a company registered in England & Wales. No. 04832301



The manufacturer shall declare, in the documentation, the switching stages of the heating elements i.e. switched ON in stages or in one 'lump' or if the load is spread across multiple phases.

A controlled DERH module (switched on/off automatically) would generally fall under the requirements of the EMC Directive. Hence, the manufacturer would be required to provide reference to the technical documentation demonstrating evidence of compliance.

A typical example of a DERH module is a heater which replaces all or some of the heat output from the heat pump in the event of the heat pump not being operational.

Where modules (heat pump and DERH) are designed to normally operate simultaneously and there is a possibility of the disturbances from each module being additive, these modules should be treated as a whole and tested/assessed as such. Attention is drawn to the wording of Schedule 1 to the EMC Regulations 2016 (SI 2016 no.1091):

3. The electromagnetic compatibility assessment must take into account all normal intended operating conditions. Where the apparatus is capable of taking different configurations, the electromagnetic compatibility assessment must confirm whether the apparatus meets the essential requirements set out in paragraph 1 of Schedule 1 in all the possible configurations identified by the manufacturer as representative of its intended use.

Where it is demonstrated that modules do not operate simultaneously with no additive disturbances, there may be separate testing/assessment i.e. one EMC report for the heat pump and one EMC report for the DERH.

The test/assessment data for modules considered separately shall be entered in the appropriate template i.e. separate lines used for each module. In Summary Sheet A1, the rating details for the total system and for each module are captured as shown in the example in Figure 10. Each module will have its own rated current (determined as described in Section 6.4.2) and the total maximum system demand should be entered as the sum of the individual modules, unless modules are interlocked (refer to NOTE in Section 6.4.1).

Total Heat Pump System Maximum	Total Heat Pump System Maximum		•	Module Input Rated Power
Demand (A)	Demand (kVA)	Module	(A)	(kVA)
38.40	8.83	Heat pump	14.90	3.43
58.40		Back-up heater	23.50	5.40

The declaration of conformity can either be declared for both modules in one document or declared individually.

Based on the module rated current, the appropriate harmonic and voltage fluctuation/flicker standards shall be referenced in the submission data and the relevant data provided.



Therefore:

- a) For modules < 16A, Sheet A2 shall be completed
- b) For modules rated > 16A, Sheets A3 (<75A Harmonics) and A6 (<75A Fluctuations) shall be completed.
- c) For modules rated > 16A but satisfying BS EN 61000-3-2 Class A limits, Sheets A3 (<75A Harmonics), A6 (<75 Fluctuations) and Sheet A8 shall be completed (see Section 6.6).</li>

It is normally expected that there are very little harmonics associated with a DERH module – this would be confirmed during the submission of data. Therefore, harmonic data is not applicable and the module may be listed as satisfying the requirements of BS EN 61000-3-2 – see Figure 11. However, some DERH modules may be controlled by power electronics in which case there may be relevant harmonic data.

Figure 11 - Compliance with EN 61000-3-2 with rated current > 16A

			Standards Cited on CE Declaration of Conformity	
	Module Input Rated Current	indica i onci		Voltage Fluctuation/
Module	(A)	(kVA)	Standards	Flicker Standards
Heat pump	14.90	3.43	EN 61000-3-2	EN 61000-3-3
Back-up heater	23.50	5.4	EN 61000-3-2	EN 61000-3-11

A typical submission for a system consisting of a heat pump > 16A and a DERH > 16A, would be; Sheets A1, A3 (for the heat pump) and A6 (one for the heat pump and one for the DERH).

# 6.6 Heat Pump Systems > 16 A, but compliant with BS EN 61000-3-2 and BS EN 61000-3-3

#### 6.6.1 General

In general, heat pumps >16A fall outside of the scope of the BS EN 61000-3-2 standard. However, some larger heat pump systems (> 16A) may satisfy the Class A limits in BS EN 61000-3-2. If the heat pump system has a total system (input) current (rated and/or maximum) less then 32A and compliance to both BS EN 61000-3-2 Class A limits and BS EN 61000-3-3 requirements are satisfied, the heat pump can be listed as 'Connect & Notify' on the database.

#### 6.6.2 Demonstrating Class A limits in BS EN 61000-3-2 are satisfied

To validate if the heat pump complies with BS EN 61000-3-2 Class A limits, the average and maximum harmonic currents up to and including the 40<sup>th</sup> harmonic are required. The current values shall be included in Sheet A8.

NOTE: In accordance with Clause 6.3.3.4 of BS EN 61000-3-2, it is acceptable for some current harmonic values to exceed the limits as defined in Table 1 of the standard.

A typical example is shown in Figure 12.



#### Figure 12 - Example of a Heat Pump > 16A which complies with BS EN 61000-3-2 Class A limits

		Heating Ave.	Max. Ave.	Compliant	Heating Max	Compliant
h	Class A Limit	Emission (A)	Emission (A)	100% Limit?	Emission (A)	150% Limit?
2	1.08	0.2245	0.2245		0.2268	YES
3	2.3	0.2764	0.2764	YES	0.2834	YES
4	0.43	0.0957	0.0957	YES	0.097	YES
5	1.14	0.2248	0.2248	YES	0.2278	YES
6	0.3	0.0503	0.0503	YES	0.0513	YES
7	0.77	0.1242	0.1242	YES	0.1264	YES
8	0.23	0.0349	0.0349	YES	0.0359	YES
9	0.4	0.1029	0.1029	YES	0.1043	YES
10	0.184	0.0234	0.0234	YES	0.0246	YES
11	0.33	0.0743	0.0743	YES	0.0767	YES
12	0.153333333	0.0189	0.0189	YES	0.0202	YES
13	0.21	0.0164	0.0164	YES	0.02	YES
14	0.131428571	0.0146	0.0146	YES	0.016	YES
15	0.15	0.0258	0.0258	YES	0.0279	YES
16	0.115	0.0119	0.0119	YES	0.0136	YES
17	0.132352941	0.0286	0.0286	YES	0.0307	YES
18	0.102222222	0.0098	0.0098	YES	0.0118	YES
19	0.118421053	0.016	0.016	YES	0.0181	YES
20	0.092	0.0092	0.0092	YES	0.0107	YES
21	0.107142857	0.0327	0.0327	YES	0.0349	YES
22	0.083636364	0.0097	0.0097	YES	0.0107	YES
23	0.097826087	0.0419	0.0419	YES	0.0436	YES
24	0.076666667	0.01	0.01	YES	0.0115	YES
25	0.09	0.0365	0.0365	YES	0.0392	YES
26	0.070769231	0.013	0.013	YES	0.0156	YES
27	0.083333333	0.0592	0.0592	YES	0.0616	YES
28	0.065714286	0.015	0.015	YES	0.017	YES
29	0.077586207	0.0628	0.0628	YES	0.0659	YES
30	0.061333333	0.0131	0.0131	YES	0.0156	YES
31	0.072580645	0.0661	0.0661	YES	0.069	YES
32	0.0575	0.0121	0.0121	YES	0.0133	YES
33	0.068181818	0.0662	0.0662	YES	0.0687	YES
34	0.054117647	0.0119	0.0119	YES	0.0135	YES
35	0.064285714	0.0519	0.0519	YES	0.0541	YES
36	0.051111111	0.0119	0.0119	YES	0.014	YES
37	0.060810811	0.0522	0.0522	YES	0.0544	YES
38	0.048421053	0.0109	0.0109	YES	0.0122	YES
39	0.057692308	0.0432	0.0432	YES	0.0452	YES
40	0.046	0.0087	0.0087	YES	0.0104	YES

#### 6.6.3 Demonstrating that the requirements of BS EN 61000-3-3 are satisfied.

When declaring conformance to the requirements of BS EN 61000-3-3, the important requirement is to have tested the device with the appropriate impedance. This test impedance shall be declared in the manufacturer's documentation to assist with compliance checks.

In accordance with BS EN 61000-3-3, the reference impedance for:

- a single-phase system shall be  $Z_{ref} = 0.4 + j0.25 \Omega$ ;
- a split-phase system shall be  $Z_{ref} = 0.48 + j0.3 \Omega$ ;
- a three-phase system shall be  $Z_{ref} = 0.24 + j0.15 \Omega$ .

If the reference impedance used during the type test is less than that stated in BS EN 61000-3-3, the maximum impedance applicable shall be declared in accordance with BS EN 61000-3-11.

#### 6.7 Heat pump submissions where EMC flicker test data is incomplete

In cases where heat pump voltage fluctuation data for validating conformance to BS EN 61000-3-3/11 is either incomplete or not substantive, an ENA EREC P28 Stage 2



assessment may be undertaken by the host DNO and the Heat Pump placed on the ENA database.

It is important that a DNO is engaged to undertake the ENA EREC P28 Stage 2 assessment i.e. the heat pump manufacturer shall liaise with the most relevant DNO for the connection(s) being considered.

In doing an ENA EREC P28 Stage 2 assessment, the DNO will undertake a network study using relevant tools e.g. WinDebut. The flicker limits prescribed in EREC P28 for a Stage 2 shall be applied.

The following minimum information is required from the manufacturer:

- Equipment manufacturer and model
- Number of connected phases e.g. 1,2,3,
- Whole system rating in kW (input) i.e. compressor plus any back-up and/or boost heating elements
- Compressor motor rating in kW (input) e.g. 5 kW
- Starting method e.g. direct-on-line (DOL) or Soft Start (Inverter driven)

Unless the manufacturer provides sufficient details of the starting current (motor start curve), the DNO shall assume that:

- ➢ for soft start the starting current is 2.5 times the rated current
- > for DOL the starting current is 7.5 times the rated current
- Maximum number of starts per hour
- Rating of back-up heating element(s) e.g. 3kW or 3kW (an option to disable may be used)
- Number of switches to energise the back-up heating element(s) e.g. 1 or 2
- If there are multiple heating elements, do they start sequentially?
  - NOTE: if there are multiple heating elements that start sequentially, it is worth providing kW (input) rating for each element (if different from one another) for example, 2 heating elements; one rated at 3kW and the other 6kW. 1 x 3kW (On or Off)

The host DNO shall determine the maximum impedance of the connection (between the point of common coupling and the cut-out) to ensure that the limits prescribed by EREC P28 for a Stage 2 assessment are satisfied.

Where multiple motors are used, the number of starts per hour should be assumed to be the summation of the number of starts of both motors e.g. 2 motors starting 6 times each. In this case the DNO should model one motor for flicker but the number of starts is set at 12 to provide the correct maximum voltage change associated with the  $P_{st}$  = 0.5 curve.

The DNO should make the following assumptions with regards to harmonic emissions:

- a) Where the motor has a DOL starting method, it may be assumed that the device complies with BS EN 61000-3-2 Class A emission limits.
- b) Where the device has a soft starting motor or a variable speed drive, it may be assumed that the motor complies with the emissions limits in BS EN 61000-3-12 for an R<sub>sce</sub> of 33.



### 7 EV Charge Points

Guidance on the data required for EV Charger Points is currently in development.



#### ANNEX A DATA DESCRIPTIONS

#### Table A1 – Summary Data Worksheet

	Attribute Name	Description	Values present
	Heat Pump Type Register	First 2 numbers denote the make,	Alphanumeric
	Number	second 2 numbers denote the	
		model, both in ascending order	
	Make	Manufacturer of heat pump	Alphanumeric
ντα		equipment	-
SUMMARY DATA	Model	Manufacturer's model reference for	Alphanumeric
ſRΥ		the equipment	
MA	Model Reference	Manufacturers reference code used	Alphanumeric
Σ		to describe specific variants of a	
SI		Model	
	Function	Heating/Cooling function of system;	Heating only/Heating
		enables different declaration for	& Cooling
		heating only arrangement versus	
		heating and cooling arrangement for	
		connection design purposes	
	Heat Pump Type	Type of heat pump in terms of the	Air Source/
		source of heat energy	Ground Source/
			Water Source
	Phases	AC port phase inputs: single-phase,	1/Split/3
		split phase or three-phase.	
	Voltage (V)	AC input rated voltage (Volts)	230/400
	Total Heat Pump System	AC input rating of the entire heat	0-500
	(Input) Rated Current (A)	pump system (Amps)	
	Total Heat Pump System	AC input rating of the entire heat	0-346
	(Input) Rated Power (kVA)	pump system (kVA)	
	Total Heat Pump System	Maximum AC input current of entire	0-500
	Maximum Demand (A)	heat pump system (Amps) (e.g.	
		under extreme operating conditions)	
	Total Heat Pump System	Maximum AC input apparent power	0-346
	Maximum Demand (kVA)	of entire heat pump system (kVA)	
		(e.g. under extreme operating	
		conditions)	
	Module Reference	Manufacturer's reference code used to describe Module	Alphanumeric
	Module	Description of whole/part of heat	Whole system/
		pump system to allow individual	Heat pump/
		declarations/statements if system is	Back-up heater – on-
		modular or, alternatively,	board/Back-up
		declarations for whole system	heater – external/
		,	Supplementary
			(boost) heater – on-
			board/Supplementary
			(boost) – external/



		Water (immersion) heater – on- board/Water (immersion) heater - external
Module Input Rated Current (A)	AC input rating of the Module as declared by the manufacturer (Amps)	0-500
Module Input Rated Power (kVA)	AC input rating of the Module as declared by the manufacturer (kVA)	0-346
CE Declaration of Conformity: Filename	Name of electronic file for the EU/CE Declaration of Conformity document	filename.*
CE Declaration of Conformity: Document/Certificate Number	Document or certificate number of the EU/CE Declaration of Conformity document	Alphanumeric
Standards cited on CE Declaration of Conformity: Harmonic Standards	EN standard covering harmonic emissions stated on the EU/CE Declaration of Conformity document	EN 61000-3-12/ EN 61000-3-2/ EN 61000-6-3/ EN 61000-6-4
Standards cited on CE Declaration of Conformity: Voltage Fluctuations/Flicker Standards	EN standard covering voltage fluctuations/flicker emissions stated on the EU/CE Declaration of Conformity document	EN 61000-3-11/ EN 61000-3-3/ EN 61000-6-3/ EN 61000-6-4
Manufacturer's EMC Test Report: Filename	Name of electronic file for the manufacturer's test report which underpins the standards compliance statement on the EU/CE Declaration of Conformity document	filename.*
Manufacturer's EMC Test Report: Document Number	Document number of the manufacurer's test report which underpins the standards compliance statement on the EU/CE Declaration of Conformity document	Alphanumeric
For Connection Design purposes, Compliant with: Class A Limits of IEC 61000- 3-2	Declaration of compliance with the Class A current limits in IEC 61000-3- 2 (despite being out of scope of that standard) to enable a Distribution Network Operator to treat the equipment as if it met that standard for connection electricity network design purposes	Yes/No/Unknown
For Connection Design purposes, Compliant with: Technical Requirements of IEC 61000-3-3	Declaration of compliance in accordance with 'Comparison of calculated and measured emission values with clause 5 limits to enable	Yes/No/Unknown



	a declaration of compliance with IEC 61000-3-3' section of EN 61000-3-11	
For Connection Design purposes, Compliant with: Both Standards?	Logical statement of compliance of Module with both 'Class A Limits of IEC 61000-3-2' and 'Technical Requirements of IEC 61000-3-3'.	Yes/No
For Connection Design purposes, Compliant with: Both Standards for All Parts of System?	Logical statement of compliance of all Modules of heat pump system with both 'Class A Limits of IEC 61000-3-2' and 'Technical Requirements of IEC 61000-3-3'	Yes/No
Total Heat Pump System Maximum Demand ≤32A?	Logical statement of compliance with 32A limit for Total System Maximum Demand (A)	Yes/No
Connect & Notify?	Logical statement that heat pump system is suitable for the 'Connect and Notify' ENA process based upon compliance of all Modules of heat pump system with both 'Class A Limits of IEC 61000-3-2' and 'Technical Requirements of IEC 61000-3-3' and compliance with 32A limit for Total Heat Pump System Maximum Demand (A)	Yes/No
Apply to Connect?	Logical statement is not suitable for the 'Connect and Notify' ENA process and is subject to the 'Apply to Connect' ENA process	Yes/No
Manufacturer's Documentation	Manufacturer's literature including statements in accordance with EN 61000-3-12 and/or EN 61000-3-11	Alphanumeric
Manufacturer's Documentation Declaration: In accordance with EN 61000-3-12	Statement in accordance with 'Product Documentation' section of EN 61000-3-12	Equipment complying with IEC 61000-3-12/ Equipment complying with IEC 61000-3-12 subject to minimum short-circuit power/ Not applicable
S <sub>SC min</sub> 3-phase (kVA)	Minimum permissible 3-phase short- circuit level at the supply terminals determined in accordance with EN 61000-3-12	120-20000
S <sub>SC min</sub> single-phase (kVA)	Minimum permissible single-phase short-circuit level at the supply terminals determined in accordance with EN 61000-3-12	40-6667
Manufacturer's	Statement in accordance with	Equipment complying



In accordance with EN 61000-3-11	measurement and evaluation procedures' sections of EN 61000-3- 11	technical requirements/ Requires Z <sub>source</sub> ≤Z <sub>ma</sub> Requires Service Current Capacity ≥100A per phase/ Not applicable
Z <sub>max</sub> (Ω)	Maximum permissible system impedance at the supply terminals determined in accordance with EN 61000-3-11	0.001-5.000
External Back-up Heater: Facility to control via heat pump?	Declaration of whether heat pump system controller has facility to control external back-up heater	Yes/No
External Back-up Heater: Capable of limiting maximum current?	Declaration of whether heat pump system controller has capability to limit maximum current of external back-up heater	Yes/No
External Back-up Heater: Maximum current limit (A)	Declaration of maximum current limit where heat pump system controller has capability to limit maximum current of external back- up heater	0-500
External Supplementary (boost) Heater: Facility to control via heat pump?	Declaration of whether heat pump system controller has facility to control external supplementary (boost) heater	Yes/No
External Supplementary (boost) Heater: Capable of limiting maximum current?	Declaration of whether heat pump system controller has capability to limit maximum current of external supplementary (boost) heater	Yes/No
External Supplementary (boost) Heater: Maximum current limit (A)	Declaration of maximum current limit where heat pump system controller has capability to limit maximum current of external supplementary (boost) heater	0-500
External Water (immersion) Heater: Facility to control via heat pump?	Declaration of whether heat pump system controller has facility to control external water (immersion) heater	Yes/No
External Water (immersion) Heater: Capable of limiting maximum current?	Declaration of whether heat pump system controller has capability to limit maximum current of external water (immersion) heater	Yes/No
External Water (immersion) Heater: Maximum current limit (A)	Declaration of maximum current limit where heat pump system controller has capability to limit	0-500



maximum current of external water	
(immersion) heater	



#### Table A2 – Data Entry Sheet - ≤16A Worksheet

	Attribute Name	Description	Values present
-	Make	Manufacturer of heat pump	Alphanumeric
16/	indice	equipment	, apriananiene
VI I	Model	Manufacturer's model reference for	Alphanumeric
		the equipment	
SH	Model Reference	Manufacturers reference code used	Alphanumeric
RY		to describe specific variants of a	
L Z		Model	
DATA ENTRY SHEET - ≤16A	Heat Pump Type	Type of heat pump in terms of the	Air Source/
		source of heat energy	Ground Source/
			Water Source
	Phases	AC port phase inputs: single-phase,	1/Split/3
		split phase or three-phase.	
	Voltage (V)	AC input rated voltage (Volts)	230/400
	Total Heat Pump System	AC input rating of the entire heat	0-500
	(Input) Rated Current (A)	pump system (Amps)	
	Total Heat Pump System	AC input rating of the entire heat	0-346
	(Input) Rated Power (kVA)	pump system (kVA)	
	Total Heat Pump System	Maximum AC input current of entire	0-500
	Maximum Demand (A)	heat pump system (Amps) (e.g.	
	Total Lloat Dump System	under extreme operating conditions)	0-346
	Total Heat Pump System Maximum Demand (kVA)	Maximum AC input apparent power of entire heat pump system (kVA)	0-340
		(e.g. under extreme operating	
		conditions)	
	Module Reference	Manufacturer's reference code used	Alphanumeric
		to describe Module	
	Module	Description of whole/part of heat	Whole system/
		pump system to allow individual	Heat pump/
		declarations/statements if system is	Back-up heater – on-
		modular or, alternatively,	board/Back-up
		declarations for whole system	heater – external/
			Supplementary
			(boost) heater – on-
			board/Supplementary
			(boost) – external/
			Water (immersion)
			heater – on-
			board/Water
			(immersion) heater – external
	Module Input Pated Current	AC input rating of the Medule as	0-500
	Module Input Rated Current (A)	AC input rating of the Module as declared by the manufacturer	0-300
		(Amps)	
	Module Input Rated Power	AC input rating of the Module as	0-346
	(kVA)	declared by the manufacturer (kVA)	
L			l



CE Declaration of	Name of electropic file for the EU/CE	filename.*
	Name of electronic file for the EU/CE	mename.*
Conformity:	Declaration of Conformity document	
Filename		
CE Declaration of	Document or certificate number of	Alphanumeric
Conformity	the EU/CE Declaration of Conformity	
Document/Certificate	document	
Number		
Standards cited on CE	EN standard covering harmonic	EN 61000-3-12/
Declaration of Conformity:	emissions stated on the EU/CE	EN 61000-3-2/
Harmonic Standards	Declaration of Conformity document	EN 61000-6-3/
		EN 61000-6-4
Standards cited on CE	EN standard covering voltage	EN 61000-3-11/
Declaration of Conformity:	fluctuations/flicker emissions stated	EN 61000-3-3/
Voltage Fluctuations/Flicker	on the EU/CE Declaration of	EN 61000-6-3/
Standards	Conformity document	EN 61000-6-4
Manufacturer's EMC Test	Name of electronic file for the	filename.*
Report:	manufacturer's test report which	
Filename	underpins the standards compliance	
	statement on the EU/CE Declaration	
	of Conformity document	
Manufacturer's EMC Test	Document number of the	Alphanumeric
Report Document Number	manufacturer's test report which	
	underpins the standards compliance	
	statement on the EU/CE Declaration	
	of Conformity document	



	Attribute Name	Description	Values present
DATA ENTRY SHEET - ≤75A [Harmonics]	Make	Manufacturer of heat pump equipment	Alphanumeric
	Model	Manufacturer's model reference for the equipment	Alphanumeric
	Model Reference	Manufacturers reference code used to describe specific variants of a Model	Alphanumeric
	Heat Pump Type	Type of heat pump in terms of the source of heat energy	Air Source/ Ground Source/ Water Source
A ENTI	Phases	AC port phase inputs: single-phase, split phase or three-phase.	1/Split/3
AT/	Voltage (V)	AC input rated voltage (Volts)	230/400
Ğ	Total Heat Pump System (Input) Rated Current (A)	AC input rating of the entire heat pump system (Amps)	0-500
	Total Heat Pump System (Input) Rated Power (kVA)	AC input rating of the entire heat pump system (kVA)	0-346
	Module	Description of whole/part of heat pump system to allow individual declarations/statements if system is modular or, alternatively, declarations for whole system	Whole system/ Heat pump/ Back-up heater – on- board/Back-up heater – external/ Supplementary (boost) heater – on- board/Supplementary (boost) – external/ Water (immersion) heater – on- board/Water (immersion) heater – external
	Module Input Rated Current (A)	AC input rating of the Module as declared by the manufacturer (Amps)	0-500
	Module Input Rated Power (kVA)	AC input rating of the Module as declared by the manufacturer (kVA)	0-346
	l <sub>equ</sub>	Equipment rated current (A) in accordance with EN 61000-3-12	0-500
	I <sub>ref</sub>	Reference current (A) in accordance with EN 61000-3-12	0-500
	l <sub>h</sub>	Harmonic current (A) for order h	0-500
	ТНС	Total Harmonic Current in accordance with EN 61000-3-12	Numeric



PWHC	Partial Weighted Harmonic Current in accordance with EN 61000-3-12	Numeric
Manufacturer's EMC Test Report: Filename	Name of electronic file for the manufacturer's test report which underpins the standards compliance statement on the EU/CE Declaration of Conformity document	filename.*
Manufacturer's EMC Test Report Document Number	Document number of the manufacturer's test report which underpins the standards compliance statement on the EU/CE Declaration of Conformity document	Alphanumeric
Manufacturer's Documentation Declaration: In accordance with EN 61000-3-12	Statement in accordance with 'Product Documentation' section of EN 61000-3-12	Equipment complyin with IEC 61000-3-12, Equipment complyin with IEC 61000-3-12 subject to minimum short-circuit power/ Not applicable
Minimum short-circuit level, S <sub>SC min</sub> (kVA)	Minimum permissible short-circuit level at the supply terminals determined in accordance with EN 61000-3-12	120-20000
Declaration of Conformity - CE Declaration of Conformity: Filename	Name of electronic file for the EU/CE Declaration of Conformity document	filename.*
Declaration of Conformity - CE Declaration of Conformity Document/Certificate Number	Document or certificate number of the EU/CE Declaration of Conformity document	Alphanumeric
Standards cited on CE Declaration of Conformity: Harmonic Standards	EN standard covering harmonic emissions stated on the EU/CE Declaration of Conformity document	EN 61000-3-12/ EN 61000-3-2/ EN 61000-6-3/ EN 61000-6-4
Standards cited on CE Declaration of Conformity: Voltage Fluctuations/Flicker Standards	EN standard covering voltage fluctuations/flicker emissions stated on the EU/CE Declaration of Conformity document	EN 61000-3-11/ EN 61000-3-3/ EN 61000-6-3/ EN 61000-6-4
Manufacturer's Declaration for Connection Design Purposes	Declaration of compliance with the Class A current limits in IEC 61000-3- 2 (despite being out of scope of that standard) to enable a Distribution Network Operator to treat the	Emissions do not exceed Class A limits in IEC 61000-3-2



equipment as if it met that standard for connection electricity network	
design purposes	



	Attribute Name	Description	Values present
nics]	Make	Manufacturer of heat pump equipment	Alphanumeric
larmoi	Model	Manufacturer's model reference for the equipment	Alphanumeric
(d/e/f) [H	Model Reference	Manufacturers reference code used to describe specific variants of a Model	Alphanumeric
DATA ENTRY SHEET - ≤75A (d/e/f) [Harmonics]	Heat Pump Type	Type of heat pump in terms of the source of heat energy	Air Source/ Ground Source/ Water Source
' SHEE	Phases	AC port phase inputs: single-phase, split phase or three-phase.	1/Split/3
L R	Voltage (V)	AC input rated voltage (Volts)	230/400
la en	Total Heat Pump System (Input) Rated Current (A)	AC input rating of the entire heat pump system (Amps)	0-500
DAT	Total Heat Pump System (Input) Rated Power (kVA)	AC input rating of the entire heat pump system (kVA)	0-346
	Module	Description of whole/part of heat pump system to allow individual declarations/statements if system is modular or, alternatively, declarations for whole system	Whole system/ Heat pump/ Back-up heater – on- board/Back-up heater – external/ Supplementary (boost) heater – on- board/Supplementary (boost) – external/ Water (immersion) heater – on- board/Water (immersion) heater – external
	Module Input Rated Current (A)	AC input rating of the Module as declared by the manufacturer (Amps)	0-500
	Module Input Rated Power (kVA)	AC input rating of the Module as declared by the manufacturer (kVA)	0-346
	l <sub>equ</sub>	Equipment rated current (A) in accordance with EN 61000-3-12	0-500
	I <sub>ref</sub>	Reference current (A) in accordance with EN 61000-3-12	0-500
	Ih	Harmonic current (A) for order h	0-500
	ТНС	Total Harmonic Current in accordance with EN 61000-3-12	Numeric

#### Table A4 – Data Entry Sheet - ≤75A (d/e/f) [Harmonics] Worksheet



PWHC	Partial Weighted Harmonic Current in accordance with EN 61000-3-12	Numeric
Manufacturer's EMC Test Report: Filename	Name of electronic file for the manufacturer's test report which underpins the standards compliance statement on the EU/CE Declaration of Conformity document	filename.*
Manufacturer's EMC Test Report Document	Document number of the manufacturer's test report which underpins the standards compliance statement on the EU/CE Declaration of Conformity document	Alphanumeric
Manufacturer's Documentation Declaration: In accordance with EN 61000-3-12	Statement in accordance with 'Product Documentation' section of EN 61000-3-12	Equipment complyin with IEC 61000-3-12/ Equipment complyin with IEC 61000-3-12 subject to minimum short-circuit power/ Not applicable
Minimum short-circuit level, S <sub>SC min</sub> (kVA)	Minimum permissible short-circuit level at the supply terminals determined in accordance with EN 61000-3-12	120-20000
Declaration of Conformity - CE Declaration of Conformity: Filename	Name of electronic file for the EU/CE Declaration of Conformity document	filename.*
Declaration of Conformity - CE Declaration of Conformity Document/Certificate Number	Document or certificate number of the EU/CE Declaration of Conformity document	Alphanumeric
Standards cited on CE Declaration of Conformity: Harmonic Standards	EN standard covering harmonic emissions stated on the EU/CE Declaration of Conformity document	EN 61000-3-12/ EN 61000-3-2/ EN 61000-6-3/ EN 61000-6-4
Standards cited on CE Declaration of Conformity: Voltage Fluctuations/Flicker Standards	EN standard covering voltage fluctuations/flicker emissions stated on the EU/CE Declaration of Conformity document	EN 61000-3-11/ EN 61000-3-3/ EN 61000-6-3/ EN 61000-6-4
Manufacturer's Declaration for Connection Design Purposes	Declaration of compliance with the Class A current limits in IEC 61000-3- 2 (despite being out of scope of that standard) to enable a Distribution Network Operator to treat the	Emissions do not exceed Class A limits in IEC 61000-3-2



equipment as if it met that standard for connection electricity network	
design purposes	

#### Table A5 – Data Entry Sheet - >75A [Harmonics] Worksheet

	Attribute Name	Description	Values present
DATA ENTRY SHEET - >75A [Harmonics]	Make	Manufacturer of heat pump equipment	Alphanumeric
	Model	Manufacturer's model reference for the equipment	Alphanumeric
	Model Reference	Manufacturers reference code used to describe specific variants of a Model	Alphanumeric
	Heat Pump Type	Type of heat pump in terms of the source of heat energy	Air Source/ Ground Source/ Water Source
A ENTF	Phases	AC port phase inputs: single-phase, split phase or three-phase.	1/Split/3
AT/	Voltage (V)	AC input rated voltage (Volts)	230/400
	Total Heat Pump System (Input) Rated Current (A)	AC input rating of the entire heat pump system (Amps)	0-500
	Total Heat Pump System (Input) Rated Power (kVA)	AC input rating of the entire heat pump system (kVA)	0-346
	Module	Description of whole/part of heat pump system to allow individual declarations/statements if system is modular or, alternatively, declarations for whole system	Whole system/ Heat pump/ Back-up heater – on- board/ Back-up heater – external/ Supplementary (boost) heater – on- board/Supplementary (boost) heater – external/ Water (immersion) heater – on- board/Water (immersion) heater – external
	Module Input Rated Current (A)	AC input rating of the Module as declared by the manufacturer (Amps)	0-500



Module Input Rated Power	AC input rating of the Module as	0-346
(kVA)	declared by the manufacturer (kVA)	
I <sub>rated</sub>	Equipment rated input current (A) as	0-500
	declared by the manufacturer and	
	marked as such on the rating plate or	
	in product documentation	
l <sub>h</sub>	Harmonic current (A) for order h	0-500
Manufacturer's EMC Test	Name of electronic file for the	filename.*
Report:	manufacturer's test report which	
Filename	underpins the standards compliance	
	statement on the EU/CE Declaration	
	of Conformity document	
Manufacturer's EMC Test	Document number of the	Alphanumeric
Report Document Number	manufacturer's test report which	
	underpins the standards compliance	
	statement on the EU/CE Declaration	
	of Conformity document	



#### Table A6 – Data Entry Sheet - ≤75A [Fluctuations] Worksheet

	Attribute Name	Description	Values present
DATA ENTRY SHHET - ≤75A [Fluctuations]	Make	Manufacturer of heat pump equipment	Alphanumeric
	Model	Manufacturer's model reference for the equipment	Alphanumeric
	Model Reference	Manufacturers reference code used to describe specific variants of a Model	Alphanumeric
	Heat Pump Type	Type of heat pump in terms of the source of heat energy	Air Source/ Ground Source/ Water Source
ENTRY	Phases	AC port phase inputs: single-phase, split phase or three-phase.	1/Split/3
Μ	Voltage (V)	AC input rated voltage (Volts)	230/400
	Total Heat Pump System	AC input rating of the entire heat	0-500
_	(Input) Rated Current (A)	pump system (Amps)	
	Total Heat Pump System	AC input rating of the entire heat	0-346
	(Input) Rated Power (kVA)	pump system (kVA)	
	Module	Description of whole/part of heat pump system to allow individual declarations/statements if system is modular or, alternatively, declarations for whole system	Whole system/ Heat pump/ Back-up heater – on- board/ Back-up heater – external/ Supplementary (boost) heater – on- board/Supplementary (boost) – external/ Water (immersion) heater – on- board/Water (immersion) heater – external
	Module Input Rated Current (A)	AC input rating of the Module as declared by the manufacturer (Amps)	0-500
	Module Input Rated Power (kVA)	AC input rating of the Module as declared by the manufacturer (kVA)	0-346
	Manufacturer's Documentation Declaration: In accordance with EN 61000-3-11	Statement in accordance with 'Requirements' and 'Test, measurement and evaluation procedures' sections of EN 61000-3- 11	Equipment complying with IEC 61000-3-3 technical requirements/ Requires Z <sub>source</sub> ≤Z <sub>max</sub> / Requires Service Current Capacity ≥100A per phase/



		Not applicable
Z <sub>max</sub> (Ω)	Maximum permissible system	0.001-5.000
	impedance at the supply terminals	
	determined in accordance with EN	
	61000-3-11	
Manufacturer's EMC Test	Name of electronic file for the	filename.*
Report:	manufacturer's test report which	
Filename	underpins the standards compliance	
	statement on the EU/CE Declaration	
	of Conformity document	
Manufacturer's EMC Test	Document number of the	Alphanumeric
Report Document Number	manufacturer's test report which	
	underpins the standards compliance	
	statement on the EU/CE Declaration	
	of Conformity document	



#### Table A7 – Data Entry Sheet - >75A [Fluctuations] Worksheet

	Attribute Name	Description	Values present
DATA ENTRY SHHET - >75A [Fluctuations]	Make	Manufacturer of heat pump equipment	Alphanumeric
	Model	Manufacturer's model reference for the equipment	Alphanumeric
	Model Reference	Manufacturers reference code used to describe specific variants of a Model	Alphanumeric
	Heat Pump Type	Type of heat pump in terms of the source of heat energy	Air Source/ Ground Source/ Water Source
	Phases	AC port phase inputs: single-phase, split phase or three-phase.	1/Split/3
Z	Voltage (V)	AC input rated voltage (Volts)	230/400
DA.	Total Heat Pump System	AC input rating of the entire heat	0-500
	(Input) Rated Current (A)	pump system (Amps)	
	Total Heat Pump System	AC input rating of the entire heat	0-346
	(Input) Rated Power (kVA)	pump system (kVA)	
	Module	Description of whole/part of heat pump system to allow individual declarations/statements if system is modular or, alternatively, declarations for whole system	Whole system/ Heat pump/ Back-up heater – on- board/ Back-up heater – external/ Supplementary (boost) heater – on- board/Supplementary (boost) – external/ Water (immersion) heater – on- board/Water (immersion) heater – external
	Module Input Rated Current (A)	AC input rating of the Module as declared by the manufacturer (Amps)	0-500
	Module Input Rated Power (kVA)	AC input rating of the Module as declared by the manufacturer (kVA)	0-346
	Maximum source impedance to comply with IEC 61000-3-11 Section 5 limits (Ω)	Maximum permissible system impedance at the supply terminals to satisfy the limits in Section 5 of IEC 61000-3-11	0.001-5.000
	Manufacturer's EMC Test Report: Filename	Name of electronic file for the manufacturer's test report which underpins the standards compliance statement on the EU/CE Declaration of Conformity document	filename.*



Manufacturer's EMC Test	Document number of the	Alphanumeric
Report Document Number	manufacturer's test report which	
	underpins the standards compliance	
	statement on the EU/CE Declaration	
	of Conformity document	



L	Attribute Name	Description	Values present
DATA ENTRY SHEET - >16A [Harmonics]	Make	Manufacturer of heat pump equipment	Alphanumeric
	Model	Manufacturer's model reference for the equipment	Alphanumeric
	Model Reference	Manufacturers reference code used to describe specific variants of a Model	Alphanumeric
	Heat Pump Type	Type of heat pump in terms of the source of heat energy	Air Source/ Ground Source/ Water Source
	Phases	AC port phase inputs: single-phase, split phase or three-phase.	1/Split/3
AT	Voltage (V)	AC input rated voltage (Volts)	230/400
Ď	Total Heat Pump System	AC input rating of the entire heat	0-500
	(Input) Rated Current (A)	pump system (Amps)	
	Total Heat Pump System	AC input rating of the entire heat	0-346
	(Input) Rated Power (kVA)	pump system (kVA)	
	Module	Description of whole/part of heat pump system to allow individual declarations/statements if system is modular or, alternatively, declarations for whole system	Whole system/ Heat pump/ Back-up heater – on- board/ Back-up heater – external/ Supplementary (boost) heater – on- board/Supplementary (boost) – external/ Water (immersion) heater – on- board/Water (immersion) heater – external
	Module Input Rated Current (A)	AC input rating of the Module as declared by the manufacturer (Amps)	0-500
	Module Input Rated Power (kVA)	AC input rating of the Module as declared by the manufacturer (kVA)	0-346
	Irated	Equipment rated current (A)	0-500
	I <sub>RMS</sub>	RMS current (A) associated with harmonic emission data	0-500
	I <sub>h max</sub>	Maximum harmonic current (A) for order h	0-500



I <sub>h ave</sub>	Average harmonic current (A) for order h	0-500
Manufacturer's EMC Test Report: Filename	Name of electronic file for the manufacturer's test report which underpins the standards compliance statement on the EU/CE Declaration of Conformity document	filename.*
Manufacturer's EMC Test Report Document Number	Document number of the manufacturer's test report which underpins the standards compliance statement on the EU/CE Declaration of Conformity document	Alphanumeric



#### ANNEX B REFERENCES

EN Standard	IEC Standard	Title
EN 61000-3-2	IEC 61000-3-2	Limits for harmonic current emissions (equipment input
		current ≤16A per phase)
EN 61000-3-3	IEC 61000-3-3	Limitation of voltage changes, voltage fluctuations and
		flicker in public low-voltage supply systems, for equipment
		with rated current $\leq$ 16 A per phase and not subject to conditional connection
EN 61000-3-11	IEC 61000-3-11	Limitation of voltage changes, voltage fluctuations and
		flicker in public low-voltage supply systems – Equipment
		with rated current $\leq$ 75A and subject to conditional
		connection
EN 61000-3-12	IEC 61000-3-12	Limits for harmonic currents produced by equipment
		connected to public low-voltage systems with input current
		>16A and ≤75A per phase
EN 61000-6-3		Generic standards — Emission standard for residential,
		commercial and light-industrial environments
EN 61000-6-4		Generic standards — Emission standard for industrial
		environments